

MAINTENANCE WORK ORDER

WO-79534 | Priority: MEDIUM | Status: OPEN

Location: Store #4421 -- Maple Grove, MN

Date Opened: August 08, 2026

Date Closed: OPEN

Category: Refrigeration

Equipment: Compressor Rack #1

Assigned To: CoolTech Services -- Tech: Dave K.

Problem Description

Condenser fan motor failure. Unit running but not cooling.

Resolution

PENDING -- Vendor site visit scheduled. Interim mitigation in place.

Cost

TBD