

MAINTENANCE WORK ORDER

WO-79605 | Priority: LOW | Status: CLOSED

Location: Store #7345 -- Apple Valley, MN

Date Opened: August 25, 2026

Date Closed: August 25, 2026

Category: Refrigeration

Equipment: Walk-in Cooler #2 (Husmann IRL-0608)

Assigned To: Refrigeration Solutions Inc. -- Tech: Alex R.

Problem Description

Condenser fan motor failure. Unit running but not cooling.

Resolution

Diagnosed and repaired on-site. Verified operational.

Cost

\$3939.00