

MAINTENANCE WORK ORDER

WO-78432 | Priority: EMERGENCY | Status: CLOSED

Location: Store #4421 -- Maple Grove, MN
Date Opened: July 15, 2026
Date Closed: July 15, 2026
Category: Refrigeration
Equipment: Walk-in Cooler #2 (Husmann IRL-0608, Serial: HRL2019-44218)
Reported By: Sarah Chen (Food Safety Inspector -- triggered by inspection finding)
Assigned To: Refrigeration Solutions Inc. -- Tech: Dave Kowalski

Problem Description

Walk-in cooler #2 operating at 44F, exceeding 41F food safety threshold. Deli meat product measured at 43F internal. Immediate service required per food safety protocol.

Resolution

Diagnosed failed evaporator fan motor (part #EFM-2247). Replaced on-site from service truck inventory. Verified unit cooling to 36F within 90 minutes. All product above 41F discarded per food safety SOP. Estimated product loss: \$847.

Cost

\$1,247.00 (labor: \$400, parts: \$289, product loss: \$847)