

MAINTENANCE WORK ORDER

WO-78623 | Priority: MEDIUM | Status: OPEN

Location: Store #3287 -- Bloomington, MN
Date Opened: July 28, 2026
Date Closed: OPEN
Category: Plumbing
Equipment: Bakery prep sink (Advance Tabco FC-3-1620, install date 2019)
Reported By: Health Dept Inspection finding -- hot water below minimum
Assigned To: Roto-Rooter Commercial -- awaiting scheduling

Problem Description

Hot water at bakery prep sink measured 87F. Minimum required 110F for handwash / equipment sanitation. Point-of-use water heater suspected. Flagged during health department inspection 8/5.

Resolution

PENDING -- Vendor site visit scheduled for 8/8. Interim mitigation: portable hot water dispenser placed at station.

Cost

TBD