


TX  
COORDINATE #  
314400245076,M7387  
LOADING DISTRICT  
WINTER  
TX SIZE - 167/100/25  
KVA 1Ø - 25.4  
KVA 3Ø - 218.2  
% L.F. - N/A


LEGEND	
INSTALL	DESCRIPTION
SV	1 RUN OF 28'-1/0 TPX UG SVC IN APPLICANT INSTALLED 14' 1-3" CONDUIT
[3]	24"x36" S/B BY PG&E
[17x30]	17"x30" S/B W/ CCSF LID INST'D BY CUST
[TTC]	CITY'S TRAFFIC CONTROL
[X]	CCSF ST. LIGHT 108W

- NOTES:
1. APPLICANT TO STUB INTO EXISTING #2 S/BOX AND GET PG&E INSPECTION.
  2. PG&E TO REPLACE EXISTING #2 S/BOX WITH NEW #3 S/BOX
  3. PG&E TO INSTALL 28' OF 1/OAL TPX IN CUSTOMER INSTALLED 14' OF 3" DUCT FROM EXISTING PG&E S/BOX TO CUSTOMER INSTALLED 17"x30" CCSF BOX. PG&E TO STANDBY DURING CONDUIT INSTALLATION INTO S/BOX.

- GENERAL NOTES:
1. APPLICANT TO TRENCH & INSTALL ALL CONDUITS AND SUBSTRUCTURES AS SHOWN.
  2. CUSTOMER SHALL CONFORM TO SPEC'S AS OUTLINED IN PG&E GREENBOOK STANDARDS ([HTTP://WWW.PGE.COM/GREENBOOK](http://www.pge.com/greenbook))
  3. ALL CONDUITS & SUBSTRUCTURES SHALL BE INSPECTED BEFORE BACKFILLING. CALL (415)695-7519 FOR INSPECTION AT LEAST 2 WORKING DAYS IN ADVANCE.



NOTE:  
ST LIGHT BADGE NUMBERS  
PROVIDED BY CCSF AT LATER DATE



PRIMARY VOLTAGE: 12 KV		VOLTAGE AREA: 3	EST: ALEX GILLEN		628-260-2564
LATITUDE: 37.72227		LONGITUDE: -122.437174	ADE: JOSE HERRERA		415-695-3367
SOURCE SIDE DEVICE: 2369			SUPV: WILFRED ALBOVIAS		415-827-1661
SUB & CIRCUIT: SF H 1105			REP: PRISCILLA MORGAN		707-328-1789
DSGN SAG: N/A		RAPTOR ZONE: No	PLNR:		
LOADING AREA: Light		ARRESTER DIST: 3	NOTIF: 119140821		JPA#:
CORROSION AREA: Non		INSULATION DIST: AA	SCALE: 1:50		DATE: 8/18/2020
EXEMPT EQUIP. INST.: NO		FIRE AREA: LRA-TIER 1	PM: 35183555		SHEET: 1 OF 1 REV.

CONSTRUCTION SKETCH

WDT - 4750 MISSION ST

SAN FRANCISCO, CA

811

Know what's below.  
Call before you dig.

NO ENVIRONMENTAL ISSUES

GAS CONFLICT: IN PROXIMITY

NEAR LOC: 1