



- NOTE:
- ALL WORK SHOWN ON THIS PLAN, EXCEPT AS OTHERWISE INDICATED IN THE DETAILS, IS TYPE A WORK.
 - CONTRACTOR SHALL POTHOLE TO VERIFY THE SIZE AND DEPTH OF UTILITIES. MAINTAIN 5' CLEARANCE TO THE EXISTING 24-INCH DIAMETER STEEL PIPE.
 - REFER TO SPECIFICATION SECTION 01 69 50 - SYSTEM OUTAGE REQUEST.
 - CONTRACTOR SHALL PROTECT TREES, RESTORE CURB, CUTTER, SIDEWALK, MEDIAN, DRIVEWAY, PAVEMENT AND WALL TO THEIR ORIGINAL CONDITIONS.
 - ALL CONSTRUCTION WORK WITHIN STERN GROVE SHALL ONLY BE PERFORMED FROM JANUARY 1, 2021 TO JANUARY 31, 2021, AND/OR JANUARY 1, 2022 TO JANUARY 31, 2022. CONSTRUCTION WORK SHALL INCLUDE, BUT NOT BE LIMITED TO, MOBILIZATION AND DEMOBILIZATION, INSTALLATION OF 54" X 36" TEE, 36" WS MAIN, 36" GATE VALVE, 8" BLOW OFF ASSEMBLY, 5' DIAMETER MANHOLE WITHIN THE SIDEWALK AREA ON SLOAT BOULEVARD, REPAIR AND/OR RECONSTRUCTION WORK TO RESTORE SIDEWALK AND ROADWAY, AS SHOWN ON THE CONTRACT PLANS.
 - CONTRACTOR SHALL POTHOLE TO VERIFY THE SIZE AND DEPTH OF UTILITIES BEFORE PREPARING SHOP DRAWINGS.




PLAN APPROVAL DATE		CONTRACT No.	PROJECT ID	DISTRICT	COUNTY	ROUTE	POST MILES TOTAL PROJECT
		04-0G3501	0400000325	04	SF	1	R0.94/4.05

REFERENCES
GATE BOOK PAGES, PLANS,
SURVEY NOTES, ETC., USED

65 & 90

CCSF 2013
NAVD88



NO.	DATE	DESCRIPTION	BY	APPR'D
1	10/01/21	TUNNELING PCO & RFI 54 - ADD VPI	MM	JA
2	03/10/21	PCO #3 - CHANGE 36" PIPELINE MATERIAL TO STEEL	MM	JA

WATER CONTRACT NO. WD-2775
CONTRACT NO. 2652J

CITY AND COUNTY OF SAN FRANCISCO
PUBLIC UTILITIES COMMISSION
INFRASTRUCTURE DIVISION
ENGINEERING MANAGEMENT BUREAU

INSTALLATION OF 16-INCH AND 36-INCH, AND RELOCATION OF 8-INCH DUCTILE IRON WATER MAINS AT VARIOUS LOCATIONS ON 19TH AVENUE FROM HOLLOWAY AVENUE TO LINCOLN WAY
PLAN & PROFILE 36-INCH, 16-INCH DI MAIN
(STA 10+00 TO STA 12+00)

CHECKED / APPROVED	DRAWN	AS SHOWN
SECTION MANAGER AA	DESIGNED	OCT 2018
APPROVED	APPROVED	
MANAGER, ENGINEERING MANAGEMENT BUREAU	MANAGER, CITY DISTRIBUTION DIVISION	
SHEET	PLAN NO.	DRAWING NO.
1 OF 1	WD-2775-2	E-31365

REVISIONS