




SAVE Monday, December 10, 2018 3:20:48 PM



-16"/20" DI PIPES ON 19TH AVENUE AT ULLOA STREET: 5'-6"± TO 6'-6"±

ITEM	QUAN	DESCRIPTION
30	1	CAST-IN-PLACE CONCRETE EQUIPMENT PAD FOR DIRECT BURIED GATE VALVE, AND FABRICATED VALVE BOX AND RISER - SEE DWG MA-D05 FOR DETAILS
31	1	10" SQUARE DI "HPFS" ACCESS COVER, FRAME, DUST PAN AND 6"Ø DI "HPFS" ACCESS COVER, FRAME, DUST PAN - SEE DWG MA-D05 FOR DETAILS
32	1	8" DI CLASS 300 FLG PIPE SPOOL, CTS - SEE NOTE 6
33	1	8" DI BLIND FLG WITH A 1" NPT 300 LB BRONZE ANGLE VALVE - SEE NOTE 6
34	1	27" SQAURE DI "HPFS" FRAME, COVER, AND DUST PAN - SEE NOTE 6
35	A/R	STAINLESS STEEL TIE RODS, NUTS, WASHERS
36	10	CONCRETE THRUST BLOCK

12/1

9	APPROVED <i>[Signature]</i> ENGINEERING MANAGER		APPROVED <i>[Signature]</i> MANAGER, CITY DISTRIBUTION DIVISION		SCALE 1"=2'
D	SHEET 240 OF 350	PLAN NO. MA 152	FILE NO. 111 547	DATE 01/	

PLAN APPROVAL DATE	CONTRACT No.	PROJECT ID	DISTRICT	COUNTY	ROUTE	POST MILES TOTAL PROJECT
	04-0G3501	0400000325	04	SF	1	R0.94/4.05

FOR REDUCED PLANS ORIGINAL SCALE IS IN INCHES