


TYPE 2 PIECE BEND (0° TO 22 1/2°)

N.T.S.



TYPE 3 PIECE BEND (MORE THAN 22 1/2° TO 45°)

N.T.S.

DETAILS


N.T.S.

1

NOT USED

N.T.S.


4



SECTION

N.T.S.


A



DETAIL

N.T.S.


B



TYPICAL STEEL PIPE SECTION

N.T.S.


C



2" TEMPORARY OUTLET DETAIL

N.T.S.

2




NOTES:

1. T EQUAL TO T1 OR T2 WHICHEVER IS GREATER.

TYPICAL BUTT STRAP DETAIL

N.T.S.


5



TEST BULKHEAD DETAIL

N.T.S.

3



FIELD BUTT JOINT NOTES:

- 1) CONTRACTOR'S OPTION TO PLACE THE BACKING RING ON THE INSIDE OR OUTSIDE OF PIPE.
- 2) THE LINING TIE-IN SHALL BE PER PLAN COATING TRANSITION DETAILS.
- 3) PLATES MAY BE DIFFERENT THICKNESSES. MATCH ID OF PIPE, MIN THICKNESS OF WELD SHALL MATCH THE THINest OF THE JOINED PIPES, WELDS SHALL BE MADE IN ACCORDANCE W/AWS STANDARDS.

TYPICAL FIELD BUTT JOINT DETAIL

N.T.S.

6

NOTES:

1. SEE DRAWINGS AND/OR SPECIFICATIONS FOR PLATE THICKNESS OF PIPES.
2. TYPICAL BUTT STRAPS SHALL COME IN TWO-SEMICIRCULAR PIECES FITTED TO PIPE.
3. PROVIDE 3/8" x 2" BACKING PLATE AT BUTT STRAP ENDS.
4. AIR TEST TO 100psi MINIMUM.
5. "T" THICK BUTT STRAPS SHALL BE FABRICATED IN HALVES COMPLETE WITH 8 DRILLED AND TAPPED HOLES FOR STANDARD 1/4" THREADED PIPE. "T" SHALL EQUAL T1 OR T2 WHICHEVER IS THICKER.
6. SEE PLAN NO. WD-2775-18.1 FOR ADDITIONAL DETAILS FOR COATING AND LINING.
7. SEE SPEC FOR FILLER WRAP MATERIAL REQUIREMENTS.


PLOT: EXTEND
SCALE: 1:1
BORDER:
22,34
COLOR: No.
RED 0.70MM
YELLOW 0.20MM
GREEN 0.25MM
CYAN 0.40MM
BLUE 0.50MM
MAGENTA 0.20MM
WHITE 0.35MM
GRAY 0.15MM
9 0.15MM
10 1.00MM
100 0.70MM
210 0.60MM

PLAN APPROVAL DATE	CONTRACT No.	PROJECT ID	DISTRICT	COUNTY	ROUTE	POST MILES TOTAL PROJECT
	04-0G3501	0400000325	04	SF	1	R0.94/4.05

FOR THE SOLE USE OF THE DOCUMENT RECIPIENT
- DO NOT CITE, COPY, OR CIRCULATE WITHOUT
THE EXPRESSED PERMISSION OF THE SFPUC.

REFERENCES
GATE BOOK PAGES, PLANS,
SURVEY NOTES, ETC., USED

CCSF 2013
NAVD88



NO.	DATE	DESCRIPTION	IC	JA
1	03/10/21	PCO #3 - REVISE SECTION DETAILS		
REVISIONS				

WATER CONTRACT NO. WD-2775
CONTRACT NO. 2652J

CITY AND COUNTY OF SAN FRANCISCO
PUBLIC UTILITIES COMMISSION
INFRASTRUCTURE DIVISION
ENGINEERING MANAGEMENT BUREAU

INSTALLATION OF 16-INCH AND 36-INCH, AND RELOCATION OF
8-INCH DUCTILE IRON WATER MAINS AT VARIOUS LOCATIONS
ON 19TH AVENUE FROM HOLLOWAY AVENUE TO LINCOLN WAY

TYPICAL STEEL PIPE DETAILS

CHECKED / APPROVED	BY / EC	DRAWN	AS SHOWN
SECTION MANAGER	T. LEE	DESIGNED	OCT 2018
APPROVED	William P. Teahan	APPROVED	
MANAGER, ENGINEERING MANAGEMENT BUREAU	MANAGER, CITY DISTRIBUTION DIVISION	REVISION NO.	
SHEET	PLAN NO.	DRAWING NO.	
1	WD-2775-7	E-31375	