



SHEET NOTES:

- CONTRACTOR SHALL VERIFY ALL STATIONS, ELEVATION, PIPE BEND, ETC. WITH PIPELINE DRAWINGS PRIOR TO START OF CONSTRUCTION.
- PIPE PROFILE SHOWN ARE APPROXIMATE. REFER TO PIPELINE DRAWINGS FOR DETAILS.
- COMPACT SUBGRADE TO A MINIMUM OF 95% RELATIVE COMPACTION.
- ALL REBARS SHALL HAVE 3IN CLEAR COVER TO THE STEEL PIPE AND EDGE OF TRUST BLOCK.

PLOT: EXTEND
SCALE: 1:1
BORDER:
22,34
COLOR: No.
RED 0.70MM
YELLOW 0.20MM
GREEN 0.25MM
CYAN 0.40MM
BLUE 0.50MM
MAGENTA 0.20MM
WHITE 0.35MM
GRAY 0.15MM
9 0.15MM
10 1.00MM
100 0.70MM
210 0.60MM

PLAN APPROVAL DATE	CONTRACT No.	PROJECT ID	DISTRICT	COUNTY	ROUTE	POST MILES TOTAL PROJECT
	04-0G3501	0400000325	04	SF	1	R0.94/4.05

FOR THE SOLE USE OF THE DOCUMENT RECIPIENT
- DO NOT CITE, COPY, OR CIRCULATE WITHOUT
THE EXPRESSED PERMISSION OF THE SFPUC.

REFERENCES
GATE BOOK PAGES, PLANS,
SURVEY NOTES, ETC., USED

65 & 90

CCSF 2013
NAVD88



NO.	DATE	DESCRIPTION	BY	APPR'D
1	03/10/21	POCAWELDED STEEL PIPE CONCRETE THRUST BLOCK NEW DWG	AC	WY

WATER CONTRACT NO. WD-2775 CONTRACT NO. 2652J		
CITY AND COUNTY OF SAN FRANCISCO PUBLIC UTILITIES COMMISSION INFRASTRUCTURE DIVISION ENGINEERING MANAGEMENT BUREAU		
INSTALLATION OF 16-INCH AND 36-INCH, AND RELOCATION OF 8-INCH DUCTILE IRON WATER MAINS AT VARIOUS LOCATIONS ON 19TH AVENUE FROM HOLLOWAY AVENUE TO LINCOLN WAY		
CONCRETE THRUST BLOCK-PLAN DETAILS II		
CHECKED / APPROVED	AL	DRAWN
SECTION MANAGER	YC	APC
DESIGNED	WY	AS SHOWN
APPROVED	William P. Tahan	
MANAGER, ENGINEERING MANAGEMENT BUREAU	MANAGER, CITY DISTRIBUTION DIVISION	
SHEET	PLAN NO.	REVISION NO.
1 OF 1	WD-2775-8.3	E-31376.2