



KETERANGAN :

- Pompa Waterplays.01 (Patung Air) – PW.01
Ebhara 4JA55.5–100x80; H=15M;Q=1100 L/Mnt
- Pompa Waterplays.02 (Dry Pool) – PW.02
Ebhara 4JA55.5–100x80; H=15M;Q=1100 L/Mnt
- Pompa Filtrasi 1 (PF.01)
Ebhara 4JA53.7–80x65; H=15M;Q=600 L/Mnt
- Pompa Filtrasi 2 (PF.02)
Ebhara 4JA53.7–80x65; H=15M;Q=600 L/Mnt
- Pompa Kolan Arus 1
SHOWFU 7.5 KW In & Out Ø10"
- Pompa Kolan Arus 2
SHOWFU 7.5 KW In & Out Ø10"
- Pipa Waterplays
- Pipa Filtrasi
- Pipa Overflow Kolan (OV)
- Pipa MainDrain Kolan (MD)
- BTV Butterfly Valve
- BV Ball Valve
- CV Check Valve
- FJ Flexible Joint
- RD Reducer
- HC Hair Catcher
- FL = Flange
- WI = Wall Inlet
- MD = Main Drain
- BC = Backwash Filter
- HD = Header Fiberglass

PROYEK: PENAMBAHAN WAHANA KOLAM ARUS
WATERPARK CITRA INDAH JONGGOL
JONGGOL - INDONESIA

OWNER:

KONSULTAN PERENCANA: PT."Panca Wira Dharma"
Konsultan Teknik
Telp. (031) 3523974 - 3521009

KONSULTAN PENGAWAS:

KONTRAKTOR: PT."Panca Wira Dharma"
Konsultan Teknik
Telp. (031) 3523974 - 3521009

No.	Tanggal Revisi	Keterangan

Judul Gambar	Skala
DENAH INSTALASI PIPA PATUNG AIR (WATER CURTAIN) AREA KOLAM ARUS WATERPARK CITRA INDAH JONGGOL	1 : 200

PENANGGUNG JAWAB GAMBAR	DI SETUJUI

DI PERIKSA	DI GAMBAR

Kode Gambar: SD - PL - KAR.04