

(TYPICAL SECTION FOR FOOTING)

ALLOWABLE BEARING CAPACITY FOR ISOLATED/ STRIP FOOTINGS

Width of Footing	Allowable Bearing Pressure	Modulus of sub-grade
Up to 2.00m	140 kN/m2	16,800 kN/m3
Up to 3.00m	130 kN/m2	15,600 kN/m3
Up to 4.00m	120 kN/m2	14,400 kN/m3

- Excavate and level the existing soil at the Level of -2.25m below the D.LVL (19.15) level established on the site .
- Compact using heavy rollers, the soil at the bottom of the excavation at level of -(2.25m) from the D.LVL (19.15) level established on the site to at least 95% of its maximum dry density at its optimum moisture content obtained from Modified Proctor Compaction Test.
- Place Two (2) layers of selected granular backfill materials (Road Base) 25cm thick each to reach the required foundation level. Each layer shall be compacted by heavy vibratory roller to a degree of compaction not less than 95% of the maximum dry density as obtained by modified proctor compaction test (BS 1377:1990; PART 4).
- A 100 mm thick layer of blinding concrete (PCC) should be placed to protect the final compacted surface.
- Shallow foundation can be placed on engineered fill. (i.e., Approximately -1.65m D.LVL established on the site.)

DETAILS FONDATION

Govemment Of Ras Al Khaimah
R.A.K. Municipality
Buildings Administration

حكومة رأس الخيمة
دائرة البلدية
إدارة المباني

Approved On — اعتمد في

31 October 2024

Building Permit #: PRMT-24-0004844

Appoved By:

STRUCTURAL NOTES

ACI 318-11
F'C/FCU = 28/35 N/mm2
FY = 460N/mm2
FYt = 420N/mm2

CONCRETE COVERS :

Foundations cover = 75mm
Columns cover = 40mm
Walls cover = 30mm
Beams cover = 40mm
Slabs & Stairs cover = 25mm

Rooms	Space	Number
Residential		
Commercial		
Industrial		
Goverment		
Resident.-Comm.		
Total		

Savana
Engineering Consultancy & Interior design

Client	KHALED ALI SAEED BEN SHUOOM AL SHEHHI		
Project	DOUBLE STORY VILAA		
Drg.Title	DETAILS FOUNDATION		
Area	ARIFAA	Floortype	
Case ID.	2673358	Draw. Type.	STRC
Sec No.	1	Com. No.	
Block No.		Plot No.	406131922
Bldg. No.	BLD-24-04245	Floor No.	
Date	OCT-2024	Sht. No.	S13
Scale	1/100	Job No.	

G.Manager	Architect	Designed By
ENG AYMEN	ENG IMEN	ENG.IBRAHIM