



TYPICAL SECTION FOR SUNK SLAB



DETAIL B

DETAIL C-C



NOTE :- ACC BLOCKS WILL BE USED UBOVE KITCHEN BLOCK SLAB

SCHEDULE OF FIRST BEAMS

TYPE	BEAM SIZE	BOTTOM REINFORCEMENT		TOP REINFINFORCEMENT			SIDE BARS (F)	STIRRUPS					
	MM XMM	STRAIGHT (A)	EXTRA @ MID SPAN(B)	STRAIGHT (C)	EXTRA @ CONT. SUPPORT (D)	EXTRA @ DISCONT. SUPPORT (E)	EACH SIDE	AT SUPPORT OUTER (G1)	AT SUPPORT INNER (G2)	AT MIDSPAN OUTER (H1)	AT MIDSPAN INNER (H2)	NO OF LEGS	REMARKS
B	200X700	3T16	2T14	2T16	1T14	1T14	2T12	T10-200	------	T10-200	------	2	
B1	200X900	3T16	2T16	3T16	2T16	2T16	3T12	T10-150	------	T10-200	------	2	
B2	200X1000	3T16	3T16	3T16	2T16	2T16	3T12	T10-150	------	T10-200	------	2	
B3	200X970	3T16	3T16 + 2T16	3T16	3T16	3T16	4T12	T10-150	------	T10-200	------	2	
B4	250X1300	2T20+2T20	2T20	3T16	3T16	3T16	4T12	T10-150	------	T10-200	------	2	
CB	200X900	3T16	------	3T16+3T16			3T12	T10-150	------	T10-200	------	2	

USE LIGHT WEIGHT BLOCKS

Govemment Of Ras Al Khaimah
R.A.K. Municipality
Buildings Administration

حكومة رأس الخيمة
دائرة البلدية
إدارة المباني

Approved On — اعتمد في

10 November 2025

Building Permit #: PRMT-24-0005227

Approved By:

LEGEND:

- COLUMN / WALL TO BE CONTINUED
- COLUMN / WALL TO BE TERMINATED

STRUCTURAL NOTES	CONCRETE COVERS :
ACI 318-11	Foundations cover = 75mm
F'C/FCU = 28/35 N/mm2	Columns cover = 40mm
FY = 460N/mm2	Walls cover = 30mm
FYt = 420N/mm2	Beams cover = 40mm
	Slabs & Stairs cover = 25mm

Savana
Engineering Consultancy & Interior design

Client	SAEED AHMED MOHAMMED HASAN ALMANSOORI		
Project	DOUBLE STORY VILAA		
Drg.Title	GROUND FLOOR SLAB-BEAMS		
Area	ARIFAA	Floortype	
Case ID.	3060961	Draw. Type.	STRC
Sec No.	1	Com. No.	
Block No.		Plot No.	607011962
Bldg. No.	BLD-24-03157	Floor No.	
Date	NOV-2025	Sht. No.	S05
Scale	1/100	Job No.	

G.Manager	Architect	Designed By
ENG AYMEN	ENG IMEN	ENG.IBRAHIM

GROUND FLOOR SLAB-BEAMS