

Zone Sizing Summary for HP-101-FITNESS

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-101-FITNESS**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1279.5** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-101-FITNESS	1215	1215	0.95	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-101-FITNESS	21.2	June 19:00	5.6	1279.5

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-101-FITNESS						
141-FITNESS	17.3	June 19:00	992	5.1	1117.5	0.89
142-GUEST LAUNDRY	3.9	July 18:00	223	0.5	162.0	1.38

Zone Sizing Summary for HP-102-OFFICES

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-102-OFFICES**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **774.0** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-102-OFFICES	333	333	0.43	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-102-OFFICES	5.3	June 20:00	2.6	774.0

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-102-OFFICES						
119-SALES OFFICE	0.8	July 19:00	44	0.1	109.9	0.40
119-WORK AREA	2.5	July 19:00	142	0.3	407.7	0.35
122-GM OFFICE	1.0	July 18:00	58	0.7	120.3	0.48
123-CLOSET	0.1	July 20:00	5	0.0	25.2	0.20
124-RETAIL STORAGE	1.0	June 21:00	84	1.5	110.9	0.75

Zone Sizing Summary for HP-103-BOH EMPLOYEE

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-103-BOH EMPLOYEE**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **593.7** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-103-BOH EMPLOYEE	584	584	0.98	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-103-BOH EMPLOYEE	10.2	October 14:00	3.9	593.7

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-103-BOH EMPLOYEE						
125-BOH CORRIDOR	0.3	July 19:00	18	0.1	140.3	0.13
132-BREAK ROOM	9.7	October 14:00	556	3.7	389.1	1.43
133-STAFF RR	0.2	September 17:00	10	0.0	64.3	0.15

Zone Sizing Summary for HP-104-BOH LAUNDRY

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-104-BOH LAUNDRY**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1317.5** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-104-BOH LAUNDRY	1293	1293	0.98	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-104-BOH LAUNDRY	21.9	August 14:00	6.0	1317.5

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-104-BOH LAUNDRY						
126-BOH LAUNDRY	14.5	August 13:00	831	2.7	871.6	0.95
127 - DRYER ENCLOSURE	5.6	September 16:00	318	1.1	117.8	2.70
128-LINEN STORAGE	1.8	August 13:00	119	2.1	171.4	0.69
129-STORAGE	0.2	July 20:00	9	0.1	48.6	0.18
130-LINEN CLOSET	0.3	July 20:00	17	0.1	108.1	0.15

Zone Sizing Summary for HP-105-LOBBY/MARKET

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-105-LOBBY/MARKET**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1301.9** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-105-LOBBY/MARKET	918	918	0.70	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-105-LOBBY/MARKET	16.0	July 18:00	8.0	1301.9

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-105-LOBBY/MARKET						
101/102-MARKET/RECEPTION	10.1	June 18:00	579	5.2	651.0	0.89
103-LOBBY (entry)	5.9	July 17:00	339	2.8	650.9	0.52

Zone Sizing Summary for HP-106-DINING LARGE

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-106-DINING LARGE**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1092.2** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-106-DINING LARGE	833	833	0.76	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-106-DINING LARGE	14.5	July 16:00	7.9	1092.2

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-106-DINING LARGE						
105A DINING	14.5	July 16:00	833	7.9	1092.2	0.76

Zone Sizing Summary for HP-107-BUFFET/SERVING

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-107-BUFFET/SERVING**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **747.0** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-107-BUFFET/SERVING	780	780	1.04	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-107-BUFFET/SERVING	13.6	July 18:00	3.5	747.0

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-107-BUFFET/SERVING						
106-BREAKFAST/BUFFETT	13.6	July 18:00	780	3.5	747.0	1.04

Zone Sizing Summary for HP-108-FOOD PREP

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-108-FOOD PREP**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **695.6** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-108-FOOD PREP	1080	1080	1.55	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-108-FOOD PREP	18.9	July 20:00	3.1	695.6

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-108-FOOD PREP						
107-FOOD PREP	18.9	July 20:00	1080	3.1	695.6	1.55

Zone Sizing Summary for HP-109-DINING FLEX

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-109-DINING FLEX**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **362.7** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-109-DINING FLEX	361	361	1.00	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-109-DINING FLEX	6.3	September 13:00	2.5	362.7

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-109-DINING FLEX						
109-DINING/FLEX	6.3	September 13:00	361	2.5	362.7	1.00

Zone Sizing Summary for HP-110-DINING SMALL

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-110-DINING SMALL**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **713.0** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-110-DINING SMALL	703	703	0.99	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-110-DINING SMALL	12.3	October 13:00	5.1	713.0

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-110-DINING SMALL						
105B - DINING	12.3	October 13:00	703	5.1	713.0	0.99

Zone Sizing Summary for HP-111-MEETING

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-111-MEETING**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **808.8** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-111-MEETING	1281	1281	1.58	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-111-MEETING	22.1	November 13:00	7.1	808.8

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-111-MEETING						
111-MEETING ROOM	20.0	November 13:00	1143	5.4	658.9	1.73
111-MEETING STORAGE	2.4	September 16:00	138	1.6	149.9	0.92

Zone Sizing Summary for HP-112-ENGINEERING

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-112-ENGINEERING**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **232.6** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-112-ENGINEERING	77	77	0.33	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-112-ENGINEERING	1.4	July 19:00	0.4	232.6

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-112-ENGINEERING						
134-ENGINEERING	1.4	July 19:00	77	0.4	232.6	0.33

Zone Sizing Summary for HP-STAIRS1

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-STAIRS1** Number of zones **1**
Equipment Class **SPLT AHU** Floor Area **992.6** sqft
Air System Type **SZCAV** Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec** Zone CFM Sizing **Sum of space airflow rates**
Sizing Data **Calculated** Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-STAIRS1	512	512	0.52	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-STAIRS1	8.3	July 12:00	7.3	992.6

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-STAIRS1						
109-STAIRS 1	1.9	July 12:00	139	2.4	196.0	0.71
200-STAIRS 1	1.6	July 12:00	90	1.1	196.0	0.46
300-STAIRS 1	1.6	July 12:00	90	1.1	201.7	0.44
400-STAIRS 1	1.6	July 12:00	90	1.1	203.1	0.44
500-STAIRS 1	1.8	July 13:00	102	1.5	196.0	0.52

Zone Sizing Summary for HP-STAIRS2

(In Alternative: Default Alternative)

Project: HAP_HamptonInn(Hilton)
Prepared by: Shakespeare Engineering

05/29/2026
1:23 PM

Air System Information

Air System Name **HP-STAIRS2**
Equipment Class **SPLT AHU**
Air System Type **SZCAV**

Number of zones **1**
Floor Area **1000.7** sqft
Location **St George Municipal, UT, USA**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/sqft	Reheat Coil Capacity (MBH)	Reheat Coil Water gpm @ 20.0 F	Zone Htg Unit Coil Capacity (MBH)	Zone Htg Unit Water gpm @ 20.0 F	Mixing Box Fan Airflow (CFM)
HP-STAIRS2	607	607	0.61	0.0	-	0.0	-	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (sqft)
HP-STAIRS2	10.6	August 18:00	7.4	1000.7

Space Loads and Airflows

Zone Name / Space Name	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (sqft)	Space CFM/sqft
HP-STAIRS2						
143-STAIRS 2	2.5	August 18:00	141	2.5	201.3	0.70
210-STAIRS 2	2.0	August 19:00	112	1.1	202.7	0.55
310-STAIRS 2	2.0	August 19:00	112	1.1	198.6	0.56
410-STAIRS 2	1.9	August 19:00	110	1.1	199.1	0.55
510 STAIRS 2	2.3	August 18:00	132	1.5	199.1	0.66