

Ref.: N-III/Mech-CPP/(Cont-643)/

**Job List**

**Name of work : various miscellaneous rectification jobs of CPP.**

**Job No 1:** Rectification of expansion joint leakage of waste heat boiler-I

1. Covering the damaged area with insulation blanket
2. Cutting of CS plate.
3. Tag Welding of the plate as necessary to cover the blanket.

**Job No 2:** Replacement of existing coupling oil filter console with new one of GTG-I

1. Shifting of new console from store to site.
2. Taking proper measurement of existing pipeworks for F2F replacement.
3. Removal of existing filter console.
4. Cutting & welding (TIG) as required.
5. Boxing up of inlet & outlet line union with proper tightening.

**Job No 3:** Replacement of damage portion of pipeworks of CBD line of WHB-I.

1. Removal of insulation.
2. Identification of damaged pipeworks of CBD line.
3. Cutting of damaged portion of CBD line.
4. Fabrication of new pipelines of suitable length.
- a. Any scaffolding required will have to be arranged by the executing agency and Iso their assembling and dismantling.

**Job No 4:** Rectification of welding leakage of one no drum vent valve of WHB-I.

**Job No 5:** Replacement of one drain line valve near discharge valve of BCW Pump-A.

**Job No-6:** Repairing of refractory works in WHB-I.

1. Repairing of Refractory wall of WHB-I Economiser zone.
2. Repairing of Refractory wall of WHB-I burner zone.

**Job No-7:** Replacement of two nos defective valves (3/4 inch) in service boiler

1. Economiser Outlet header drain valve
2. Service boiler outlet header drain valve

**General conditions:**

1. The scope of work shall include but not limited to the above for completion of entire job.
2. All tools and tackles, cutting and welding appliances and accessories shall be adequately supplied by the executing agency.
3. Any scaffolding required will have to be arranged by the executing agency and also their assembling and dismantling.
4. All best engineering practices and procedures and safety gadgets to be strictly followed to carryout the job.
5. Returning the unused supplied material to the Engineer-in-charge and cleaning of site debris / wastes and dumping them in the dumping yard.
6. Jobs should be executed as instructed by the Engineer-in-charge

(M.Hoque)  
PE (M), CPP & UTY-III

Ref: N-III/Mech-CPP/(Cont-643)/

**SCHEDULE OF WORK & QUANTITY:**

**Job Name:** various miscellaneous rectification jobs of CPP

SL. NO.	Item	QNTY	RATE (₹)	AMOUNT (₹)
	Various miscellaneous rectification jobs of CPP. (As per annexure-I)	01 (One Lot)		
	Service Tax @ 15% on.....			
	VAT @6% on .....			
	Sub Total			

**NOTE:**

- i) Party not to add Service Tax (ST) if they are exempted and to write “**NOT APPLICABLE**”, but to attach proof copy issued from the competent/ statutory authority.
- ii) Party to fill the tender form with clear handwriting as instructed and avoid overwriting.

In words: (Rupees .....)

..... Only

Signature of the tenderer with Date:

Party's name:

Address:

SEAL:

PAN No. ....

.....