Ref. No: N-III/MECH-5/Cont-959

(A) JOB LIST

Reconditioning & overhauling of safety valve in Ammonia-III plant:

SI. No.	Description	Quantity
1	Safety relief valve of SGC lube oil pump no. 1 Size: : 4"/6" Ø	01 No
	Re-set pressure: 13.5 Kg /cm ² Set pressure: 15.0 Kg/cm ²	
2	Safety relief valve of C2 column Size: : 6"/8" Ø Re-set pressure: 28.0 Kg /cm ²	01 No
	Set pressure: 31.0 Kg/cm ²	

(B) SCOPE OF WORK

The scope of work shall include but not limited to the following for completion of entire job:-

- 1. Dismantling, cleaning of pressure parts, proper lapping, blue matching, replacement of gaskets & gland packing, mounting on line and pressure testing.
- 2. Reconditioned valve shall be subjected to pressure testing at the required test pressure. The tenderer shall make hydraulic and or pneumatic pressure testing arrangements available.
- 3. All good engineering practices and safety system shall be followed till completion of the job.
- 4. The entire job shall be carried out round the clock basis and is to complete within time.
- 5. Any other activities, not included above but required for successful completion of the jobs, shall be in the party's scope.
- 6. Carrying / cleaning of site debris/waste to dumping yard after finishing of job.
- 7. All necessary gaskets, nuts & bolts, gland packing material, etc shall be supplied by BVFCL at
- 8. Returning of unused supplied material(s) to the Engineer-in-charge.
- 9. Job shall be executed as instructed by Engineer-in-charge.

2.00 Terms & conditions:-

- 2.01 The tenderer may visit the site to asses quantum & nature of job.
- 2.02 Required man Power for execution of job shall be arranged by the party.
- 2.03 All required tools & tackles shall be arranged by the party.
- 2.04 Scaffolding if required will be in the scope of the party.
- 2.05 All necessary safety precautions are to be taken by the party.

3.00 SPECIAL TERMS & CONDITIONS

- 3.01 The contractors have to abide by the terms and conditions mentioned in G.D.C.C. in respect of carrying out the job, payments, settlement of disputes etc.
- 3.02 II works are to be done under the strict supervision of the contractor to the entire satisfaction of the Engineer-in-charge / site in charge.
- 3.03 All Safety measure and gears required for the job shall have to be arranged by the contractor and to be followed strictly.
- 3.04 After completion of job, the site shall be cleaned and removed all debris properly.

4.0 BVFCL Scope

- 4.01 Provision of new gaskets
- 4.02 Provision of Nuts & bolts if required
- 4.03 Provision of water & electricity at want point if required

5.0 Payment Terms

- 5.01 All necessary safety precautions are to be taken by the party.
- 5.02 90% value of the completed work shall be released after successful completion of work, submission of bill in triplicate and as certified by Engineer in Charge after deductions, if any. Payment can be released against successful completion of each cooler for one time also.
- 5.03 Balance 10% shall be retained as security deposit which shall be released after Successful completion of workmanship guarantee period of six months.
- 5.04 Service tax/ VAT at the applicable rate shall be reimbursed / deducted on production of documentary evidence.
- 6.00 Party shall quote & submit their rates in the given performa in Annexure-II by going thoroughly in the scope of work Annexure-I (scope of work).
- 7.00 The contractors shall abide by all the statutory obligation under various statutory Acts and rules made there under, and as amended from time to time in respect of their establishment and / or workmen engaged by them. Under any circumstances, BVFCL shall not be liable or held responsible in any manner whatsoever, for default or omission on the part of the contractor(s) for non-compliance of the aforesaid Acts and rules, and any other laws applicable to contractors and / or their establishment and the workmen engaged by them.
- 8.00 BVFCL is committed to a corruption free environment." All the works contract, services and commitments of BVFCL will be honored without the citizen having to pay any bribe". In case any person demands any bribe, it is the duty of responsible citizen to inform the matter to Vigilance Office, BVFCL, Namrup, Assam.

(KK Dihider) CE (M), A-III & CPP

Schedule of work, quantity & rates: -

Job: Reconditioning of Safety relief valve of following in Ammonia-III plant.

- i) Reconditioning of Relief valve of SGC lube oil pump no. 1
- ii) Reconditioning of Safety relief valve of C-2 column.

SI.	Description	Quantity	Rate(`)	Amount
No.				(`)
1	Safety relief valve of SGC lube oil pump no-1	01 No		
2	Safety relief valve of C2 Column	01 No		
	Sub Total			
			Service Tax @ 15%	
			Total Amount	

NIO	TF	
INO	1 L	•

- i) Party not to add Service Tax (ST) if they are exempted and to write "NOT APPLICABLE", but to attach proof copy issued from the competent/ statutory authority.
- ii) Party to write "EXTRA", if the Service Tax is applicable.
- iii) Party to fill the tender form with clear handwriting and avoid overwriting.

In words: Rupees		
) only.	
Signature of the tenderer:	Date	
Party's name :		
Address:		
SFAI ·	PAN No	