BRAHMAPUTRA VALLEY FERTILIZER CORPORATION LIMITED, N A M R U P

(A Govt. of India Undertaking)
P.O: Parbatpur-786623, Dist: Dibrugarh (Assam)
Corporate Identity Number of BVFCL is U24123AS2002GOI006786

CORRIGENDUM No-1

AMMONIA-III (Mechanical Deptt.)

Ref NIT No: N-III/MECH-5/Cont-1083/3614 Dated: 15-02-2019

No: N-III/MECH-5/Cont-1083/Corr-1/3631 Date: 20/02/2019

The total thickness of insulation and thickness of aluminium sheet is revised and may be read as follows:

Supply of material and erection of insulation as per list given below:

Item No	Quantity	Designation	Temperature	Aluminium	Total	Surface
			(°C)	sheet	Insulation	area
				Thickness	thickness	(sq.m)
				(mm)	(mm)	
01	Top of the boiler					
1-1	1	Тор	326	1.0	200	62.5
1-2	2	Walls	326	1.0	200	56.2
1-3	1	Wall	326	1.0	200	10.6
1-4	1	Door	326	1.0	200	1.0
02	Boiler Drum					
2-1	1	Wall	326	1.0	200	8.4
2-2	1	Drum body	326	1.0	200	17.9
2-3	2	Drum heads	326	1.0	200	4.3
2-4	2	Drum body	326	1.0	200	6.3
2-5	2	Manholes	326	1.0	200	1.0
03	Body of the boiler					
3-1	2	Side Walls	326	1.0	200	309.8
3-2	1	Front wall	326	1.0	200	68.5
3-3	1	Back wall	326	1.0	200	33.2
3-4	1	Back wall	498	1.0	200	42.8
3-5	1	Cooler1	415	1.0	200	9.6
3-6	1	Cooler2	476	1.0	200	10.7
04	Bottom of the boiler					
4-1	1	Bottom	326	1.0	200	64.7
4-2	2	Shell	326	1.0	200	30.4
4-3	15	Pipe DN125	326	1.0	200	16.4
					TOTAL	754.30
						SAY
						754.00

NOTE:

The insulation mattresses are to be erected in double/triple layer construction as per OEM standards following standard engineering practice to achieve total thickness of insulation of 200 mm.

Material requirement: (Revised)

- 1. Aluminium corrugated sheet of standard size having thickness of 1mm.
- 2. Lightly resin bonded mattresses of standard size as per IS 8183 with one side GI wire netting used for industrial high-temperature boilers.
- 3. Density of insulation material: 100 Kg/m³, Service Temperature: Upto 520° C.
- 4. Rivets with flat heads.
- 5. Self tapping screws(Approx dim: 4.8 mm x 25 mm length)
- 6. G I binding wires, aluminium strips required for the job.
- 7. Tapes/Sealing compounds.

CE (M), AG, CPP&CMW

