



NOTICE INVITING TENDER

PUR 7

ब्रह्मपुत्र वैली फर्टिलाइजर कारपोरेशन लिमिटेड
BRAHMAPUTRA VALLEY FERTILIZER CORPORATION LIMITED
(A GOVT. OF INDIA UNDERTAKING)
NAMRUP

Please reply to:

उप महाप्रबंधक / Dy. General Manager (MM)
बी.वी.एफ.सी.एल., नामरूप / BVFCL, Namrup
P.O. Parbatpur - 786 623
डिब्रूगढ़ / Dist. Dibrugarh
असम / (Assam), India.

REGISTERED/ U. C. OF POSTING

Phone: +91 (0)374 250 7059 FAX: +91 (0)374 250 0204 / 250 0317, e-mail: vktamboli@bvfc.co.in,
Website: www.bvfcl.com, CIN No: U24123AS2002GOI006786 GST No: 18AABCB9399R1ZK

For Reply Please Quote:

Ref. No: AN/2021/90-02/126/MOU/ENQ-0305

Date: 26/07/2021

To: M/s. As per list

Please submit your quotation in ~~SINGLE STAGE~~ ^{Two} ~~TWO STAGE~~ in DUPLICATE in SEALED COVER on or before 25/08/21 2:30 PM (IST) and shall be opened thereafter at 3:00 PM (IST) on the same date. The quotation as well as the envelope shall be addressed to Materials Manager with our reference no. cited above and date of opening DULY SUPERSCRIBED on the cover for the under-noted stores subject to the TERMS AND CONDITIONS printed overleaf.

Please quote prices FOR Station of Despatch/ FOR Destination.

Delivery of the materials would be required by : Minimum Delivery Period may be quoted

Earnest Money Deposit (EMD) : NIL

SL. NO.	DESCRIPTION	QUANTITY
1.	Online UPS, capacity 1000 VA/800W with features Details are as per annexure I	1 Nos.

#Note:

- In order to comply with newly introduced rule under Section 206AB provision w.e.f. 01.07.2021, In order to assess the Income-tax return filing status and to ensure that TDS is deducted at appropriate rate, the successful bidders have to submit us a declaration in the prescribed formate along with the tax Invoice at the time of supply only.
- Tenderers not registered with BVFCL are requested to furnish self-certified documentary evidence in support of qualifying requirements of their tenders as stipulated below:
 - Experience & Past Performance of similar contract for last 2 years.
 - Capability with respect to Personnel, equipment and manufacturing facilities.
 - Financial standing through Annual Report (Balance sheet and profit & loss account) of last 3 years.
 - Statutory requirement such as GST, PAN, ESI, Labour Licence no. EPF registration no. etc wherever applicable.

Note. 1. Goods bearing ISI mark will be given preferences.
2. BVFCL is committed to a corruption free work environment. "All the above purchases, services and commitments of BVFCL will be honoured without the citizen having to pay any bribe". In case any person demands any bribe, it is the duty of the responsible to inform the matter to vigilance office, BVFCL, Namrup, P. O. Parbatpur, Dist. Dibrugarh, Assam PIN: 786623. (Tel no: 0374-2507092 / 0374-2507167).

for and on behalf of
Brahmaputra Valley Fertilizer Corporation Ltd.,

VK
(V.K. Tamboli)
Dy. Materials Manager

Specifications for Online UPS, Capacity 1000 VA/ 800 W

- Quantity required: 1 No.
- (1) UPS make: Emerson Liebert/ APC/ Microtek/ BPE
 - (2) UPS Type: Online UPS (Without Battery)
 - (3) Rated Capacity: 1000 VA/ 800 Watt
 - (4) Digital display: Yes, LCD / LED, I/P & O/P Voltage, Frequency, Battery Voltage,
 - (5) Capacity, Charging, Low, Fault, UPS Online, Bypass etc.
 - (6) Normal Input voltage: 220 ~ 240 V AC
 - (7) Automatic Voltage : 170 V AC ~ 270 V AC
 - (8) Regulation
 - (9) Input Frequency: 40 Hz ~ 70 Hz
 - (10) Phase: Single Phase with Ground
 - (11) Power Factor: ≥ 0.99 @ full load
 - (12) Output Voltage: 230 V AC
 - (13) Output voltage : $\pm 1\%$ (Batt. Mode)
 - (14) Regulation
 - (15) Output Frequency: 47 Hz ~ 53 Hz (Synchronized Range)
 - (16) Overload: 50 Hz ± 0.25 Hz Batt. Mode
 - (17) Current Crest Ratio: 3 : 1
 - (18) Output waveform: Pure sinewave
 - (19) Transfer Time: Zero (AC Mode to Batt. Mode)
 - (20) Efficiency: 88 %
 - (21) Battery to be: 36 Volts (3 nos 12 V Battery in series)
 - (22) Connected Battery Type: SMF-VRLA
 - (23) Battery Rating: 12 V / 42 Ah x 3 Nos.
 - (24) Battery Charging Voltage: 41.0 VDC $\pm 1\%$
 - (25) Battery Charging Current: 6.0 A
 - (26) Other Features: (a) Overload, Short Circuit and discharge / overcharge protections
(b) Over Temperature Protection, (c) Auto Restart while AC is recovering, (d) Automatic Battery Charging in UPS Off-Mode
 - (27) Output Socket: Indian x 3 nos.
 - (28) Accessories: (i) Power supply connecting cable, (ii) Battery connection Cable to be supplied.
 - (29) Warranty: The supplier must ensure 2 years warranty of each UPS from the date of supply.

Note: Party should supply printed technical literature of their product along with their quotation.