

BRAHMAPUTRA VALLEY FERTILIZER CORPORATION LIMITED

(A GOVT. OF INDIA UNDERTAKING)

NAMRUP



Please reply to:

Dy. General Manager(MM)

BVFCL, Namrup

P.O. Parbatpur – 786 623

Dist. Dibrugarh (Assam), India.

CIN No: U24123AS2002GOI006786

GST No: 18AABCB9399R1ZK

Phone: +91 [374] 2507216; FAX: +91 [374] 2500204 / 2500317; e-mail: matmgt@bvfc.co.in, website: www.bvfc.com

To,

M/s. _____

NOTICE INVITING TENDER

- | | |
|--------------------------|---------------------------------|
| 1. NIT NO | : AN/2019/81-01/065/RC/Enq- 075 |
| 2. DATE OF ISSUE | : 28/02/2019 |
| 3. TYPE OF BID | : Two Stage |
| 4. BID OPENING | : 29/03/2019 |
| 5. EARNEST MONEY DEPOSIT | : NIL |

BRAHMAPUTRA VALLEY FERTILIZER CORPORATION LIMITED, NAMRUP INVITES SEALED BID IN TWO STAGE FOR SUPPLY OF THE FOLLOWING ITEMS AS PER ANNEXURE- A.

Sl. No.	DESCRIPTION	QUANTITY
1.	Totally enclosed fan cooled squirrel cage 3-Phase Induction Motor with enclosure confirming to protection IP 55 Horizontal Foot Cum Flange Mounted (IMB35), Construction code- J, Details: Annexure A	01 No.

SPECIAL TERMS & CONDITIONS.

1. The bid will include / indicate the following.
 - a) The complete scope of supply conforming to the specifications stipulated above and at Annexure A and Annexure – I & II.
 - b) Basic Price, Packing & Forwarding charges, if any. The applicable GST and any other applicable charges.
 - c) The mode of transportation and charges thereon for delivery of the materials at Namrup, Assam.
 - d) Acceptance of terms of payment within 30 days after receipt and acceptance of the materials at site as per Clause No.7 of Annexure – I of the NIT.
 - e) Confirmation that the firm prices have been quoted.
 - f) Confirmation of the bid validity for 90 days from the bid opening date.
 - g) Please confirm that the material shall be guaranteed for a period of 18 months from the date of supply or 12 months from the date of commissioning, whichever is earlier and a certificate to this effect shall accompany along with the supply.
 - h) Please clearly indicate PAN/ GST No. in your quotation.
 - i) Acceptance of all other terms & conditions of Annexure – I & II
2. Bidder must submit quotations along with manufacturer's detail technical specifications, Characteristic Curve and GI Drawing of the motor.
3. Bidder must submit Test Report and Guarantee Certificate at the time of delivery of the motor.
4. The parties who are not registered as pre-qualified vendor of BVFCL will submit the documents pertaining to the eligibility criteria at point no. 19 of Annexure – I.
5.
 - a. MSEs shall be given the benefits of issue of tender documents free of cost, exemption from submission of Earnest money deposit, price preference, etc. as per Govt. Guidelines.
 - b. SC/ST owned enterprises shall submit relevant SC/ST certificates and registration should remain valid at the time of bidding.
 - c. Condition of prior turnover & prior experience with respect to start-up and micro & small enterprises will be relaxed as per Govt. Policy circular No. 1(2) (1)/2016-MA Dtd. 10/03/2016 & F.20/2/2014-PPD (Pt) Dtd. 20/09/16 subject to meeting of Quality & technical specifications
6. Goods bearing ISI mark will be given preference.
7. Materials shall be packed properly to avoid any damage during transit.
8. BVFCL is committed to a corruption free work environment. "All the above purchases, services and commitments of BVFCL will be honoured without the citizen having to pay any bribe". In case any person demands any bribe, it is the duty of the responsible to inform the matter to vigilance office, BVFCL, Namrup, P. O. Parbatpur, Dist. Dibrugarh, Assam PIN: 786623. (Tel no: 0374-2507092 / 0374-2507167).

Enclosures: 1. Annexure-A
2. Annexure I, II

Yours faithfully,
For and on behalf of
Brahmaputra Valley Fertilizer Corporation Ltd


For Asst. Materials Manager

Sl no	Code/ Folio no	Description of the item	Unit	Qty reqd
1	2	3	4	5
01	6081620104	<p>(A) 3-Phase Squirrel Cage Induction Motor, horizontal foot cum flange mounted, T.E.F.C, Champion series ISE0..N -IE2 energy efficient conforming to IS 12615: 2011 / IEC 60034- 30- or latest amended.</p> <p>Power- 0.75KW/1HP</p> <p>Frame size-90S</p> <p>Voltage-415V AC (Star connection)</p> <p>Amps- 2.05 A,</p> <p>Frequency-50HZ,</p> <p>Synchronous speed-1000 RPM,</p> <p>Number of poles-6</p> <p>Insulation class-F with temperature rise limited to class-'B',</p> <p>Duty-S1</p> <p>Efficiency values are confirming to IS 12615:2011 IEC 60034-30-2008</p> <p>Type of construction-IMB35(Foot cum Flange mounted)</p> <p>Construction Code- J</p> <p>Direction-Bidirectional</p> <p>(B) Environmental condition & spare required along with the motor :</p> <ol style="list-style-type: none"> 1. Ambient temperature- 50 degree centigrade (Maximum) 2. Relative humidity- 100%. 3. Location-outdoor. 4. Atmospheric pollution- Ammonia & Urea dust. 5. Motor terminal box should be preferably available on right hand side, if viewed from NDE side of motor & should be larger in size. 6. Test certificate & Characteristic graph should be provided along with the motor. 7. Guarantee certificate to accompany the supply. 	51	01