BRAHMAPUTRA VALLEY FERTILIZER CORPORATION LIMITED

(A GOVT. OF INDIA UNDERTAKING) **NAMRUP**



Please reply to:

Dy.General Manager(MM) BVFCL, Namrup P.O. Parbatpur – 786 623 Dist. Dibrugarh (Assam),India. CIN No: **U24123AS2002GOI006786** GST No: **18AABCB9399R1ZK**

Phone: +91 [374] 2507216; FAX: +91 [374] 2500204 / 2500317; e-mail: matmgt@bvfcl.co.in, website: www.bvfcl.com

| Filone. | +91 [374] 2507216, | FAX. +91 [3/4] 250020 | 14 / 25003 i / , e-iiiaii . <u>I</u> | natingt@bvici.co.in, | website. | www.bvici.com |
|---------|--------------------|-----------------------|---|----------------------|----------|---------------|
| To, | | | | | | |
| | M/s | | _ | | | |
| | | | | | | |

NOTICE INVITING TENDER

1. NIT NO : AN/2019/81-07/455/RC/Eng-0553

 2. DATE OF ISSUE
 : 27.12.2019

 3. TYPE OF BID
 : Two Stage

 4. BID OPENING
 : 27.01.2020

 5. EARNEST MONEY DEPOSIT
 : NIL

BRAHMAPUTRA VALLEY FERTILIZER CORPORATION LIMITED, NAMRUP INVITES SEALED BID IN TWO STAGE FOR SUPPLY OF THE FOLLOWING ITEMS AS PER ANNEXURE- A, B.

| SI. No. | DESCRIPTION | QUANTITY |
|---------|--|----------|
| | 3-Phase Totally enclosed fan cooled squirrel cage Induction Motor with both ends extended | |
| 1. | shaft horizontal foot mounted for Urea-II Prilling Tower (PT) Lift | 01 No. |
| | (As per Motor Rotor Shaft Drg. No. – N-II-ELECT/778 attached) | |
| | Details: Annexure A , Drawing – Annexure B | |
| | *Bidder must submit technical details and price bid in two separate- sealed envelopes else bid | |
| | will be rejected | |

SPECIAL TERMS & CONDITIONS.

- 1. The bid will include / indicate the following.
 - a. The complete scope of supply conforming to the specifications stipulated above and at Annexure A, B and Annexure I & II.
 - b. Basic Price, Packing & Forwarding charges, if any. The applicable GST and any other applicable charges.
 - c. The mode of transportation and charges thereon for delivery of the materials at Namrup, Assam.
 - d. Acceptance of terms of payment within 30 days after receipt and acceptance of the materials at site as per Clause No.7 of Annexure – I of the NIT.
 - e. Confirmation that the firm prices have been quoted.
 - f. Confirmation of the bid validity for 90 days from the bid opening date.
 - g. Please confirm that the material shall be guaranteed for a period of 18 months from the date of supply or 12 months from the date of commissioning, whichever is earlier and a certificate to this effect shall accompany along with the supply.
 - h. Please clearly indicate PAN/ GST No. in your quotation.
 - i. Acceptance of all other terms & conditions of Annexure I &II
- 2. The items should be of IS Standards with latest amendment.
- 3. Bidder must submit quotations along with motor data sheet/detail technical specifications, Characteristic Curve, GA Drawing and Guarantee period of the motor.
- 4. Bidder must submit Test Report and Guarantee Certificate at the time of delivery of the motor.
- 5. Bidder must submit techno-commercial bid and price bid in two separate- sealed envelopes as per Clause No. 1.3 of Annexure- I.

- The parties who are not registered as pre-qualified vendor of BVFCL will submit the documents pertaining to the eligibility criteria:
 - New tenderers are requested to furnish self-certified documentary evidence in support of qualifying requirements of their tenders as stipulated below:
 - i. Experience & Past Performance of similar contract for last 2 years.
 - ii. Capability with respect to Personnel, equipment and manufacturing facilities.
 - iii. Financial standing through Annual Report (Balance sheet and profit & loss account) of last 3 years.
 - Statutory requirement such as GST, Central Excise, Sales Tax, PAN, TAN, TIN, ESI.

7.

- MSEs shall be given the benefits of issue of tender documents free of cost, exemption from submission of Earnest money deposit, price preference, etc. as per Govt. Guidelines.
- SC/ST owned enterprises shall submit relevant SC/ST certificates and registration should remain valid at the time of bidding.
- c. Condition of prior turnover & prior experience with respect to start-up and micro & small enterprises will be relaxed as per Govt. Policy circular No. 1(2) (1)/2016-MA Dtd. 10/03/2016 & F.20/2/2014-PPD (Pt) Dtd. 20/09/16 subject to meeting of Quality & technical specifications
- 8. Goods bearing ISI mark will be given preference:
- 9. Materials shall be packed properly to avoid any damage during transit.
- 10. BVFCL is committed to a corruption free work environment. "All the above purchases, services and commitments of BVFCL will be honoured without the citizen having to pay any bribe. In case any person demands any bribe, it is the duty of the responsible to inform the matter to vigilance office, BVFCL, Namrup, P. O. Parbatpur, Dist. Dibrugarh, Assam PIN; 786623. (Tel no: 0374-2507092 / 0374-2507167).

Enclosures: 1. Annexure-A, B 2. Annexure I, II

Yours faithfully, For and on behalf of Brahmaputra Valley Fertilizer Corporation Ltd

AMO

Xalwaylo

| SI no | Code/ Folio no | Description of the item | Unit | Qui |
|----------|-------------------|---|------|-----|
| 1 | 2 | 3 | 4 | 5 |
| 01 | To be codified. | PT Lift Motor with both ends extended rotor shaft (Prilling Tower Hight- 49 mtrs.) (As per Motor Rotor Shaft Drg. NoN-II-ELECT/778 attached) 1) 3-Phase Induction Motor(Horizontal Foot mounted-B3) ii) Power - 5.5 kW/7.5 HP iii) Voltage - 415V, iv) Frequency- 50 Hz, v) RPM - 1500, vi) Number of poles- 4 vii) Insulation class-F, with temperature rise limited to class- 'B', viii) Frame size - 132S, ix) IP 55, x) Duty-B \$3-100% CDF xi) P.F-0.80, xii) Efficiency values are confirming to IS 12615:2011 / IEC 60034-30-2014 xiii) Shape-IMB3(Foot mounted) with both side extended shaft as per our drawing xiv) Direction-Bidirectional | 51 | 01 |
| | | (B) Environmental condition & spare required along with the motor: 1) Ambient temperature- 50 degree centigrade (Maximum). ii) Relative humidity- 100%. iii) Location- Indoor. iv) Atmospheric pollution- Ammonia & Urea dust. | | |

