

Name of Department: **Electrical (CPP)**

| <b>Details of Nomination Basis Tender</b>                    |  |   |  |  |
|--|--|---|--|--|
| <b>Work Order No. &amp; Date</b>                             | <b>Name of Party</b>   | <b>Name of Work</b>   | <b>Work Order Value</b>  | <b>Reason for Nomination</b>   |
| Nam/Elect/<br>CPP/2021/<br>W.O.-<br>04/732<br><br>21.05.2021 | M/s Universal Industrial Products, 27-27A & 151, Block B, Ghatkopar Industrial Estate Ghatkopar (W), Mumbai-400086 | Repairing, modification and commissioning of Battery Charger of M/s SEIRA ELETTRONICA INDUSRIALE, Italy make, 24V DC, 100 Amps thyristor controlled system in CPP | Rs.4, 28,340.00 (Rupees Four Lakh Twenty Eight Thousand Three Hundred Forty) only including transportation charges and GST | <p>The 24 V DC charger is imported and of M/s SEIRA ELETTRONICA INDUSRIALE, Italy make and more than 35 years old and of out dated spare parts. Repairing of the charger is essential to feed permanent basis reliable and sustain 24 V DC control supply to instrument panel for running of WHB-II and other auxiliaries in CPP.</p> <p>M/s Universal Industrial Products, Mumbai is an expert and reputed party in the field (manufacturing and servicing/repairing) of charger. Earlier the party has already repaired the identical 24 V DC charger of WHB-I in CPP against W.O.no Nam/Elect/ CPP/W.O.-10/363 Date: 05.03.2019 and charger is operating satisfactorily without any interruption. M/s Universal Industrial Products , Mumbai had also supplied two nos. thyristor controlled battery chargers in the year 2003 in A-II and has modified and rectified the same two nos. charger in 2017 and taken in line for supplying 110V DC in 66 KV and A-II substation. Since then the chargers are providing sustain 110V DC control supply to A-II Sub-station and 66KV sub-station and running satisfactory.</p> |

PE (E), CPP & Utility-III