



Karnataka Fire and Emergency Services Department

Office of the Chief fire officer,
Bangalore west zone, High-ground fire station premises,
Sheshadri road, Bangalore - 560 009.
080 - 22971523 / 500 / 600. Fax : 080 - 22971523.



No.303/FSR/CFO/BWZ/2021

25 -03-2021

To,

The Principal,
Sri Taralabalu Central School (CBSE),
Anubhava Mantapa, Ajjihalli Village,
Channagiri Taluk
Davanagere District.

Sir,

Sub : Issue of 'Fire safety Recommendation' to Sri Taralabalu Central School (CBSE) at Sy. No. 91 and Assessment No. 668, Ajjihalli Village, Channagiri Taluk & Davanagere District.

Ref: Your letter Dated 17-03-2021.

*** **

With reference to the subject above cited, the premises of Sri Taralabalu Central School (CBSE) situated at Sy. No. 91 and Assessment No. 668, Ajjihalli Village, Channagiri Taluk & Davanagere District was inspected by District Fire Officer, Davanagere Fire Station on 18-03-2021 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under;

ANNEXURE-B

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the building / premises :-

01.	Name and Address of the Applicant.	:	The Principal, Sri Taralabalu Central School (CBSE), Anubhava Mantapa, Ajjihalli Village, Channagiri Taluk Davanagere District.
02.	Name and Address of the premises.	:	of Sri Taralabalu Central School (CBSE) Sy. No. 91 and Assessment No. 668, Ajjihalli Village, Channagiri Taluk & Davanagere District



ಕಾರ್ಯದರ್ಶಿ

ಪ್ರಧಾನ ಪರಿಶೀಲಕರು

ಅಧಿಕಾರಿ ಮುಖ್ಯ ಮಂತ್ರಿ ಮಂತ್ರಿ ಕಛೇರಿ


PRINCIPAL

Sri Taralabalu Central School
Anubhava Mantapa, Ajjihalli Post-577213
Channagiri Tq. Davanagere Dist.



03.	Name & address of the building owner	:	The President, Sri Dr. Shivamurthy Shivacharya Mahaswamji, Sri Taralabalu Jagadgurubhranmath, Sirigere Village, Chitradurga Taluk & District.
04.	Number of buildings	:	One building.
05.	Number of floors	:	Ground and 2 upper floors
06.	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	Principal room, office room, 12 class rooms, 02 labs, girls waiting room, boys waiting room, store room & toilets
	1 st floor	:	02 staff rooms, 12 class rooms, girls waiting room, boys waiting room, store room & toilets
	2 nd floor	:	02 staff rooms, 11 class rooms, library, girls waiting room, boys waiting room, store room & toilets.
07.	Height of the building	:	11.10 Mtrs.
08.	Site area	:	20655.82 Sq. Mtrs
09.	<u>Built-up area of each floor:-</u>		
	Ground to 2 nd floor	:	(1532.50 Sq. mtrs on each floor X 3 floors) 4597.50 Sq. Mtrs.
10.	Total built-up area	:	4597.50 Sq. Mtrs.
11.	<u>Surrounding properties:-</u>		
	East	:	Private property / agriculture land
	West	:	Private property thereafter 12.00 mtrs wide Channagiri to Ajjihalli road.
	North	:	Agriculture land
	South	:	Agriculture land
12.	<u>Open space all around the building:-</u>		
	East	:	Min 05.00 mtrs
	West	:	Min 10.00 mtrs
	North	:	Min 04.50 mtrs
	South	:	Min 15.00 mtrs
Allowed setbacks (open space) should be maintained free from further obstruction / construction for easy movement of emergency vehicles.			

CMR
ಕಾರ್ಯದರ್ಶಿ

ಶಿಕ್ಷಣ ಸಹಾಯಕ ಮುಖ್ಯ

ನಿರ್ದೇಶಕರು, ಶಿಕ್ಷಣ ಮತ್ತು ಪ್ರಮಾಣೀಕರಣ, ಬೆಂಗಳೂರು

Principal
25-3-2021
PRINCIPAL

Sri Taralabalu Central School
Anubhava Mantapa, Ajjihalli Post-577213
Channagiri Tq. Davanagere Dist.

B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the Premises	The premises is accessible from 12.00 mtrs wide Channagiri to Ajjihalli road located on western side.		Adequate
02.	Number of entrances	One entry cum exit of 06.00 mtrs width has been provided		Complied
03.	Diesel generator	Not provided		One adequate capacity of diesel generator should be provided & it should be connected fire fighting systems.
04.	Number of staircase	Nos. of staircases	: 03 nos	Complied
		Width of staircases	: One of 02.80 mtrs and remaining 2 each of 01.70 mtrs	
		Width of treads	: 30 Cms	
		Height of risers	: 15 Cms	
		Nos. of riser per flight	: 09 nos	
		Height of handrails	: 01.00 mtrs	
		Head room clearance	: 03.40 Mtrs	
05.	Portable extinguishers	02 DCP type fire extinguishers, each of 6 kgs capacity has been provided.		In-additional to the existing fire extinguishers A. One water mist & CAFS type fire extinguisher of 9 ltrs capacity should kept near each staircase landing.

Signature
ಅಭಿಮಾನಿ

ಶಾಲೆಯ ಸಹಾಯಕ ಪ್ರಿನ್ಸಿಪಲ್

ಅನುಭವ ಮಂಟಪ, ಅಜಿಹಳ್ಳಿ ಪುರ, ದಾವಣಗೆರೆ ಜಿಲ್ಲೆ 577213

Signature
25-3-2021
PRINCIPAL

Sri Taralabalu Central School
Anubhava Mantapa, Ajjihalli Post-577213
Channagiri Tq. Davanagere Dist.


			<p>B. One mechanical foam extinguisher of 9 ltrs capacity & One ABC type extinguisher of 6 kgs capacity should be provided near diesel generator.</p> <p>C. One CO2 type fire extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board & electrical room.</p>
06.	Hose reel hose system	Not provided	<p>02 Hose Reel Hose systems should be near the staircase. The hose reel hose of min 19mm size and of adequate length to reach the farthest point of each floor should be provided shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing.</p>
07.	Terrace tank over respective tower terrace.	Not provided	<p>Each system should be connected to an over head tank of 15,000 ltrs capacity</p>
08.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Not provided	<p>The system should be connected to an booster pump of 900 LPM.</p> <p>Further the system should be connected to an alternative source of power supply.</p>


ಕಾರ್ಯದರ್ಶಿ

ಶೃಂಗೇರಿ ಶಾಲಾ ಮುಖ್ಯ

ಕರಾವಳಿ ನಗರ ಮತ್ತು ನೈ.ಮರ. ಜಿಲ್ಲೆ


PRINCIPAL
Sri Taralabalu Central School
Anubhava Mantapa, Ajihalli Post-577213
Channagiri Tq. Davanagere Dist.




09.	Escape routes	Not marked	Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.
10.	Fire order (Fire safety plans)	Not displayed	A notice board Have been indicated the action should be taken by the employees in case of any emergency with the telephone number of Channagiri fire station i.e 08189 - 229007 & 101, 550, 500 & 600 and the telephone number of nearest ambulance service & Police station.
11.	No smoking board	Not displayed	COTPA Sec-4 directin No Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry / exit of the each floor.
12.	Fire fighting training	Not imparted	At-least 40% of the staff should be got trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore

(Signature)
ಕಾರ್ಯದರ್ಶಿ

ಶಾಲೆಯ ಕಲಾಕಾರಿ

ನೇತೃತ್ವದ ಶಾಲೆಯಲ್ಲಿ ನಡೆಸಿದ ಸಭೆಯ ದಾಖಲೆ



PRINCIPAL


Sri Taralabalu Central School
Anubhava Mantapa, Ajmalali Post-577213
Channagiri To. Davanagere Dist.

13. **Fire precautionary measures :-**


- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should not be stored in the building.
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to out side.
- G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing '**Fire Safety Recommendation**' to of **Sri Taralabalu Central School (CBSE)** situated at Sy. No. 91 and Assessment No. 668, Ajjihalli Village, Channagiri Taluk & Davanagere District subject to condition and compliance of the above recommendations in column -3 of serial - B within 3 months and compliance to the undersigned.

This **Fire Safety Recommendation** is issued for the period of only one year from the date of issue and it is renewable.

 All requirements recommended above are as per National Building Code- 2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully


Chief Fire Officer
Bangalore West, Bangalore South,
Highground Fire Station, Bangalore
Bangalore - 560 009.


ಕಾರ್ಯದರ್ಶಿ

ಪ್ರಕೃತ ಸಂಸ್ಥೆ

ಪರಮಪುರುಷ ಮಠ, ಮೈಸೂರು, ಕೆ.ಆರ್.ನಗರ, ಚನ್ನಗಿರಿ


PRINCIPAL
Sri Taralabalu Central School
Anubhava Mantapa, Ajjihalli Post-577213
Channagiri Td. Davanagere Dist.