



District Level Water Testing Laboratory (Uttar Pradesh Jal Nigam, Pilibhit)

Address: Office of Executive Engineer, Construction Division,
U.P. Jal Nigam in front of district veterinary Hospital, Tanakpur road, Pilibhit. Pin- 262001
(NABL Certified Laboratory)



TC-13341

WATER ANALYSIS REPORT

Rept. No	3999	Date:	18.07.2025
Customer Details			
Office Name and Address	Rajendra Mohan Chandrika Prasad Academy, Bilsanda, Pilibhit.		
Ref Letter No & Date	Application by customer Date 17-07-2025		
Sample Description			
District	Pilibhit	Block	Bilsanda
Gram Panchayat/Nagar Panchayat	Ghanshyampur	Village/Ward No.	Ghanshyampur
Habitation	Ghanshyampur	Location	Rajendra Mohan Chandrika Prasad Academy
Water Source	Handpump	Sample Code	PIL/25/07/3999
Date & Time of Sample Collection	17.07.2025 09:20AM	Sample Collector Name	Narendra Mohan Saxena
Receiving Date & Time	17.07.2025 11:30AM	Sample Receiver	Sanjeev Kumar
Water Sample Type	Drinking Water	Quantity of Sample	1000 ml

Environmental Condition


Temperature	25°C ±2°C	Humidity	50% ±20%
Analysis Date	18.07.2025		


Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Chloride	8.99	mg/l	250	1000	IS 3025 (Part 32) : 2019
2	Fluoride	0.103	mg/l	1	1.5	APHA 24th Edition 4500-F Method C (Electrode Method) : 2023
3	Iron	0.082	mg/l	1	No relaxation	IS 3025 (Part 53) : 2019
4	Nitrate	1.13	mg/l	45	No relaxation	APHA 24th Edition 4500-NO ₃ Method B (UV Screening Method):2023
5	pH	7.98	NA	6.5-8.5	No relaxation	IS 3025 (Part 11) : 2022
6	Sulphate	2.11	mg/l	200	400	APHA 24th Edition 4500-SO ₄ ⁻² Method E (Turbidimetric Method) : 2023
7	TDS	207	mg/l	500	2000	IS 3025 (Part 16) : 2023
8	Total Alkalinity	165	mg/l	200	600	IS 3025 (Part 23) : 2023
9	Total Hardness	118	mg/l	200	600	IS 3025 (Part 21) : 2019
10	Turbidity	0.78	NTU	1	5	IS 3025 (Part 10) : 2023

Note 1. This Certificate refers only to the particular sample(s) submitted for testing.

- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- Sample will be stored up to 2-3 days (in case of non perishable items only) from the date of issue of tests reports unless.


Analysis by
Sanjeev Kumar
(Lab Assistant)


Authorized Signatory
Sanjeev Kumar
(Lab. Chemist)
U.P. Jal Nigam
PILIBHIT

End of the Report



District Level Water Testing Laboratory (Uttar Pradesh Jal Nigam, Pilibhit)

Address: Office of Executive Engineer, Construction Division,
U.P. Jal Nigam in front of district veterinary Hospital, Tanakpur road, Pilibhit. Pin- 262001

WATER ANALYSIS REPORT

Rept. No	3999	Date:	18.08.2025			
Customer Details						
Office Name and Address	Rajendra Mohan Chandrika Prasad Academy, Bilsanda, Pilibhit.					
Ref Letter No & Date	Application by customer Date 17-07-2025					
Sample Description						
District	Pilibhit	Block	Bilsanda			
Gram Panchayat/Nagar Panchayat	Ghanshyampur	Village/Ward No.	Ghanshyampur			
Habitation	Ghanshyampur	Location	Rajendra Mohan Chandrika Prasad Academy			
Water Source	Handpump	Sample Code	PIL/25/07/3999			
Date & Time of Sample Collection	17.07.2025 09:20AM	Sample Collector Name	Narendra Mohan Saxena			
Receiving Date & Time	17.07.2025 11:30AM	Sample Receiver	Sanjeev Kumar			
Water Sample Type	Drinking Water	Quantity of Sample	1000 ml			
Environmental Condition						
Temperature	25°C $\pm$ 2°C	Humidity	50% $\pm$ 20%			
Analysis Date	18.07.2025					
Technical Data of Analysis						
Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Total Coliform	00	CFU	00	No relaxation	APHA 23 rd Edition :2017 (IS 10500)
2	E .Coli	00	CFU	00	No relaxation	APHA 23 rd Edition :2017 (IS 10500)
Note 1. This Certificate refers only to the particular sample(s) submitted for testing. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has. 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample will be stored up to 48 hrs (in case of non perishable items only) from the date of issue of tests reports unless.						
Microbiologist U.P. JAL NIGAM (BLR) Disst. Water Microbiology Laboratory Pilibhit						

End of the Report

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 3999

Dated:

It is certified that an inspection team headed by **Anuj Kumar Lab Chemist** (Name of Officers with designation) from **Uttar Pradesh Jal Nigam (Rural)**, **Pilibhit PHED** inspected the **Rajendra Mohan Chandrika Prasad Academy, Ghanshyampur, Bilsanda, Pilibhit, Uttar Pradesh** (Name & Address of the school) on **17/07/2025** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **PIL/25/07/3999** dated **18.07.2025** Of **Uttar Pradesh Jal Nigam (Rural)**, **Pilibhit (PHED Lab)** certified that the **Rajendra Mohan Chandrika Prasad Academy, Ghanshyampur, Bilsanda, Pilibhit, Uttar Pradesh** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17/01/2026

Signature with Seal: [Signature]
Name : Manish Gangwar
Designation : Executive Engineer
Name & Address of the Office / Department :

To

MANAGER

Rajendra Mohan Chandrika Prasad
Academy, Ghanshyampur,
Bilsanda, Pilibhit, Uttar Pradesh

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies