

General Notes

- 1.) The most recent revision of the Maine Subsurface Wastewater Disposal Rules (“Rules”) dated 9/23/2023 is hereby made a part of this HHE-200 Form and shall be consulted by the disposal system installer pertaining to the installation of this proposed disposal system.
- 2.) This HHE-200 is intended to represent facts pertinent to the “Rules” only. The owner and applicant must check both local and state ordinances, and regulations regarding other building regulations (i.e. zoning, wetlands, building codes, minimum lot size, etc.) before considering this an approved or buildable site. I can provide you with other local, state and federal regulatory investigation of pertinent land use regulations, affecting the suitability or buildability of the site, at an additional cost, per your request.
- 3.) All information shown on this form relating to the property lines and subsurface structures (such as but not limited to: water lines, septic tanks, cess pools, cellar drains, utility lines, etc.) are notes, plotted or left off as not affecting the system based on information provided by the owner or his agent. It is the responsibility of the owner or his agent to confirm, **BEFORE CONSTRUCTION BEGINS**, the above and/or any other features, which may affect (or be adversely affected by) the installation of the system.
- 4.) When a gravity system is proposed, **BEFORE CONSTRUCTION BEGINS**, the disposal system installer and building contractor shall review and verify the relative elevation of all points given on this HHE-200 Form and the elevation of the existing or proposed building drain and septic tank openings for compatibility to the minimum code pitch requirements. Any questions that arise should be directed to the local plumbing inspector or myself. When a pump system is installed, provisions shall be made to keep the tank and lift station outlets above the high water table. An alarm device warning of pump failure is required. Venting of a pumped system is required.
- 5.) If the use of a laundry machine becomes excessive, a separate laundry bed should be designed and installed. A lint-catching device should be installed for the washing machine (if it doesn’t have one) and cleaned frequently. A distribution box has been shown in the design and is intended to offer an inspection port whereby the owner can check for excessive lint or grease buildup before damage to the system is done. Inspection should be frequent. This system has not been designed or sized to accommodate a garbage disposal. If one is to be used, you must first notify me so that I can increase the size of the septic tank capacity by 30% minimum.
- 6.) The actual water flow or number of bedrooms shall not extend the design criteria indicated on the HHE-200 form without a re-evaluation of the system.
- 7.) All Construction shall conform to Section 12 of the “Rules” in general: (A) the vegetation in the proposed disposal area and fill extensions shall be removed and the ground surface scarified (rotor tilled) to minimize glazing of original soils. (B) The bottom of the disposal area and distribution line shall be level and with maximum grade tolerance of 2 inches per 100 feet. (C) Backfill shall be clean, gravely, coarse sand, and free of foreign material placed in eight inch lifts and lightly compacted as placed. (D) The finish grade of the backfill over the disposal area shall extend 3 to 5 feet beyond the edge of the disposal area. At that point, the fill shall be sloped at a uniform grade of no greater than 25% (4:1) to the original ground. (E) The land adjacent to the disposal area shall be graded to prevent both the accumulation of surface water on the disposal area and the flow of surface water across the disposal area. (F) The finished disposal area and fill extensions shall be seeded to prevent erosion: (a) Grass, clover, trefoil vetch, perennial wildflowers or other herbaceous perennials may be utilized for disposal area surfaces. **Woody shrubs are unacceptable**. (b) Woody shrubs in conjunction with a hardy perennial ground clover may be used on fill extensions only.
- 8.) The setback distance between a well and a disposal area serving a single-family residence is 100 feet; the setback distance from a well to a septic tank is 50 feet. The location of a well (new or existing) that is less than these distances from a proposed system may void this design. For additional setback requirements, see Table 8B and Table 9A of the “Rules”.
- 9.) All construction shall be inspected by, the local plumbing inspector (LPI) according to Section 3(J) of the “Rules” prior to backfilling. Backfill material shall comply with Section 12(E) of the “Rules”.
- 10.) If the owner or installer has any questions, please do not hesitate to call 240-5567 (cell).