






DEPARTMENT OF SCIENCE AND TECHNOLOGY
Regional Office No. X

REQUEST FOR MAINTENANCE

Work Requested: Parts and labor services for the repair of Window Type Air-conditioning Unit located at RSTL Hallway		Received by: RAPangan		Date: 3 September 2020	
Brief Description The ACU window is not working properly.	Check-up finding > Defective starting capacitor > defective shaping & bearing	Job Order: > Attached is the service report.	Corrective Maintenance Performed: > Attached is the service report.	Inspection & Acceptance: ACU is in good condition & operational.	
Requested by Name & Signature:  Date: 3 SEPT. 2020	Check-up done by: Name & Signature:  Date: 16 OCT. 2020	Work accepted by: Name & Signature:  Date: 16 OCT. 2020	Corrective maintenance by: Name & Signature:  Date: 16 OCT. 2020	End-user Receipt Name & Signature:  Date: 19 OCT. 2020	


VVP REF'S & AIRCONS SERVICES

Carinugan, Balulang CDO
Cell # 0926-255-3134

CUSTOMER : DOST - X
ADDRESS : CARMEN, CDOC
DATE : October 16, 2020

SERVICE REPORT

- 1 UNIT WINDOW TYPE AIRCONDITIONING
 Location: Micro Laboratory
 - Installation of Window Type A/C
- 1 UNIT WINDOW TYPE AIRCONDITIONING
 Location: Hallway
 - Replacement of starting capacitor
 - Replacement of shafting & bearing
- 1 UNIT SPLIT TYPE AIRCON
 Location: Sterile Laboratory
 - Replacement of shafting
 - Replacement of Fan motor
 - Re-alignment of Fan blade and blower

PREPARED BY:

VAN VICTOR B. PIL