



# DEPARTMENT OF SCIENCE AND TECHNOLOGY

Regional Office No. X

## REQUEST FOR MAINTENANCE

Work Requested: Check-up of Samsung Air-Conditioning Unit in TSD		Received by: 	Date: 22 JUNE 2022
Brief Description - There is water leaking from the Samsung Aircon unit.	Check-up finding - Water leaking @ Samsung ACU located @ TSD - ACU is subject for corrective maintenance	Corrective Maintenance Performed: - Corrective Maintenance done by the provider on 25 JUNE 2022 - ACU cleaning + cleaning of PVC pipe	Inspection & Acceptance: - Samsung ACU is now in good working condition
- Request for clearing of the back yard of DOST-X Building	- Backyard of DOST-X building are weedy. - Subject for cleaning of backyard this coming Saturday, 25 JUNE 2022	- Cleaning of backyard clo Maintenance Team	- Maintenace Team/clean backyard. DOST-X backyard.
Requested by Name & Signature:  ENGR. ROMELA N. PANTUA Date: JUNE 22, 2022	Check-up done by: Name & Signature:  Date: 22 JUNE 2022	Work accepted by: Name & Signature:  Date: 22 JUNE 2022	Corrective maintenance by: Name & Signature:  Date: 25 JUNE 2022
End-user Receipt Name & Signature:  Date: 25 JUNE 2022			