

## A critical review of PV systems' faults with the relevant detection methods

Khaled Osmani<sup>a</sup>, Ahmad Haddad<sup>b,c</sup>, Thierry Lemenand<sup>a</sup>, Bruno Castanier<sup>a</sup>, Mohammad Alkhedher<sup>d</sup>, Mohamad Ramadan<sup>a,b,c,\*</sup>

<sup>a</sup> LARIS EA 7315, Polytech Angers, UNIV Angers, France

<sup>b</sup> School of Engineering, International University of Beirut BIU, Beirut, Lebanon

<sup>c</sup> School of Engineering, Lebanese International University LIU, Beirut, Lebanon

<sup>d</sup> Mechanical Engineering Department, Abu Dhabi University, United Arab Emirates

### ARTICLE INFO

**Keywords:**

PV faults  
Fault detection  
Detection methods  
Fault type  
PV troubleshooting

### ABSTRACT

PhotoVoltaic (PV) systems are often subjected to operational faults which negatively affect their performance. Corresponding to different types and natures, such faults prevent the PV systems from achieving their nominal power output and attaining the required level of energy production. Regarding the operational optimization of PV systems, this paper aims primarily at surveying and categorizing different types of PV faults, classified as electrical, internal, and external, where each is thoroughly investigated: internal faults occur at the PV cellular level, and can either be short circuit, open circuit, bridging, or bypass diode faults. External faults on the other side are mainly classified as temporary (i.e., clouds shading, snowstorms, etc.) or permanent (e.g., glass breakage, frame defects, etc.) mismatch faults. Lastly, electrical faults involve common circuitry problems, such as short circuits (e.g., line to ground, line to line, etc.), power processing units' faults (e.g., inverter faults), and arc faults. As for the detection methods, six major fault detection methods are investigated for the AC side of the PV system with twenty-nine total AC based fault detection methods. On the other hand, eleven major fault detection methods are surveyed for the DC side of PV systems with seventy-three total DC based fault detection methods. The investigated methods are critically analyzed, and compared relevantly to each other, within the mutual sub-sets. The resulting tabulated comparative data assessments for PV faults (i.e., cause-effect relationships, impact on the PV system performance), as well as for faults detection methods (i.e., priority for application, etc.) compose a rich background for related PV systems' performance security fields, where a nexus future work is also suggested.

### Introduction

Population growth and modern life commitments have led to an excessive consumption of fossil fuels. This in turn caused higher emissions of greenhouse gases, leaving future generations in danger [1]. The need for alternative power resources peaked as a result, due to the increase in electricity demand on one hand, and to the underproductive performances of existing generating units (diesel and gas-based engines) on the other hand [2]. Consequently, a worldwide increase in renewable energy studies, usages, and optimization has emerged [3].

Among different types of renewable energy supplies (wind, hydro, etc.) PhotoVoltaic (PV) systems are considered the cleanest and safest technology [4]. This is due to the fact that such systems do not involve any mechanically moving parts (i.e., actuators, shafts, etc.) and work silently. Thus, such systems in particular have achieved a global interest

and a massive popularity as a promising solution for offsetting the underproductive problem of existing power resources and are considered to have a potential contribution to the future electricity mix [5].

Unfortunately, many obstacles exist and impede PV systems from functioning properly. Environmental factors, such as dust, temperature, snowfall, and humidity reduce the PV systems' capability in power production and cause various failure modes in the PV panels [6]. For instance, the dust accumulated over the PV modules' surfaces during the span of eight weeks under the desertic environment in Saharan environment, decreases the PV maximum power output by 8.41 % as compared to the same PV system without dust accumulation [7]. In other words, the stated environmental leftovers, aside than possibly damaging the PV panels, could create consequent problems for PV systems, preventing their power production sustainability: as another example, a power drop of 9.99 % and an average power reduction of 2.93 % is witnessed for an uncleaned PV system (from dust and dirt) in a

\* Corresponding author at: School of Engineering, International University of Beirut BIU, Beirut, Lebanon.

E-mail address: [mohamad.ramadan@liu.edu.lb](mailto:mohamad.ramadan@liu.edu.lb) (M. Ramadan).

<b>Nomenclature</b>	
ABCO	Artificial bee colony optimization
AC	Alternating current
AFCI	Arc fault circuit interrupter
AITs	Artificial intelligence techniques
ANFIS	Adaptive neuro-fuzzy inference system
ANFIS-SM	Adaptive neuro-fuzzy inference system-sugeno model
ANN	Artificial neural network
ANOVA	ANalysis of variance
APRE	Absolute performance ratio error
AR	Auto regressive
BPNN	Back propagation neural network
CART	Classification and regression tree
CBs	Circuit breakers
CCC	Current carrying conductor
CDIT	Climatic data independent technique
CM	Common mode
CMM	Comparison between measured and modeled
CR	Capacitive region
DC	Direct current
DC-DCF	DC-DC converters fault identification
DE	Deviation error
DFI	Degradation fault identification
DLL	Dourly lower limit
D-S	Dampster-Shefer
DSP	Digital signal processor
DT	Decision tree
DUL	Dourly upper limit
ECM	Earth capacitance measurement
EGC	Earth ground conductors
EI	Electroluminescence imaging
ELM	Extreme learning machine
EM	Electrical measurement
EMI	Electro magnetic interference
EMR	Electro magnetic resonance
ERV	Estimating randomness in the voltage signal
EWMA	Experimentally weighted moving average
FBI/RBI	Forward bias imaging/reverse bias imaging
FDC	Fault detection and classification
FDD	Fault detection and diagnosis
FDTI	Fault detection techniques for three-phase inverters
FF	Fill factor
FFT	Fast Fourier transform
FIRBPS	Finite impulse response band pass filter
FPGA	Field programmable gate array
FRSA	Frequency spectrum analysis
FSA	Frequency spectrum analysis
FTD	Flash test driver
GCPVS	Grid connected photovoltaic system
GFDI	Ground fault detection and interruption fuse
GISTEL	GIsement solaire par teledetection
GUI	Graphical user interface
HET	Heat exchange and temperature
HF	High frequency
HIGF	High impedance ground fault
HMI	Human machine interface
HV/LV	High/low voltage
ICCD	Intensified charge coupled device
ICR	Inductance capacitance resistance
IDTs	Islanding detection techniques
IGBT	Insulated gate bipolar transistor
IMR	Insulation monitoring relay
In/ThI	Infrared/thermal imaging
IR	Infra-red
I-V	Current-voltage
KELM	Kernel extreme learning machine
kNN	k-nearest neighbors
LAPART-FD	Laterally primed adaptive resonance theory - fault detection
LCD	Liquid crystal display
LF	Low frequency
L-G	Line-to-ground
LIT	Lock in thermography
L-L	Line-to-line
LOF	Local outlier factor
MBDM	Model based difference measurement
MEWMA	Modified exponentially weighted moving average
ML	Machine learning
MPPT	Maximum power point tracker
MRAS	Model reference adaptive system
MSDP	Multistate data processing
MWPT	Modified wavelet packet transform
NDZ	Non detection zones
NOCT	Normal operating cell temperature
OC/SC	Open/short-circuited
OCPD	Over current protection device
Onm/offm	Online/offline model
OPC	Object linking and embedding for process control
PCC	Points of common coupling
PIC	Peripheral Interface controller
PLA	Power loss analysis
PNN	Probabilistic neural network
PPs	Peak points
PPU	Power processing unit
PS/CS	Partial/complete shading
PSMFD	Partially shaded modules fault detector
PV	Photovoltaic
P-V	Power-voltage
PVA	Photovoltaic array
PVLOF	LOF based on PV string current
Q-f	Reactive power-frequency
RCDs	Residual current devices
RCM	Reliability centered maintenance
RDM	Real-time difference measurement
RF	Random forest
RPS	Residential photovoltaic system
SCADA	Supervisory control and data acquisition
SFA	Subsection fluctuation analysis
SFS	Sandia frequency shift
SHLFNNs	Single hidden layer feedforward neural networks
SM	Sugeno model
SMS	Slip mode frequency shift
SPM	Signal processing methods
SR	Shunt resistance
SSTDR	Spread spectrum time domain reflectometry
STCs	Standard test conditions
STFT	Short time Fourier transform
TDR	Time domain reflectrometry
THD	Total harmonic distortion
TSKFR	Takagie-Sugeno Kahn fuzzy rule
TSKFRBS	Takagie-Sugeno kahn fuzzy rule based system
UIM	Ultrasonic inspection method
WOEWMA	Wavelet optimized exponentially weighted moving average
WPT	Wavelet packet transform
WT	Wavelet transforms

Mediterranean climate based region of installation, when compared to the same cleaned PV system [8].

Other than environmental implications, PV systems are seen to encounter inner faults for example, ranging from basic electrical faults (open-short/circuit) to Power Processing Units (PPU) faults such as Maximum Power Point Tracker (MPPT), and inverter malfunction [9, 10]. Consequently, such faults disturb the produced power waveforms and could eventually cause drastic interruptions on the users' end.

Regardless of the fault's types, their recurrence on PV systems, leaves bad impacts such as harmonics distortion, voltage unbalancing, current leakages, deviated waveforms, smaller consumable power quantities than expected and service interruption by partial/total blackouts. For a healthy state of PV systems, with an extended lifecycle and an acceptable performance, abundant research is taking place to mitigate fault residues on such systems: for example, in order to reduce the partial shading conditions consequences' (i.e., caused by the movements of clouds), which partially shade the sunrays for up to 75 % of the total PV array space, different PV array reconfiguration techniques can be adapted [11]. From a thermal optimization point of view, the decreased PV cell efficiency by 0.45 % for each temperature rise of 1 °C (due to high temperature environmental conditions) can be compensated by the application of phase change material, that are used to cool down the PV panels' operating temperature [12]. Adjusting the PV tilt angle from another side is recorded elevating the PV produced power by up to 50.36 % for different regions of PV systems installations, thus compensating the lost solar irradiance due to positioning and self-shading [13].

As intended to optimize the performance and extend the longevity of PV systems with minimum fault occurrences, it is imperative to know first the difference types of possible PV faults, then accordingly acknowledge the corresponding PV fault detection methods (that are to be applied in real PV applications). For this purpose, ample research took place in order to quantify different PV faults, with the relevant detection techniques: for instance, the work in the reference [290] has categorized all possible PV faults into five main categories, as mismatch, ground, line-to-line, arc, and other types of faults. As for the fault detection methods in the same study, the presented survey classified all fault detection techniques as either visual/thermal or electrical based methods, without considering the model-based measurements methods, for example. From another side, the similarly related work in [291], takes into consideration only the failure modes in the PV inverter's power modules. Moreover, the authors in [292] have only reviewed the PV fault detection methods through the application of artificial neural networks, such that the review in [293] has grouped the PV faults either as optical degradation, electrical mismatch, or other electrical and hardware faults, having only imaging technologies based resultant fault detection methods. From a different approach, the work in [294] focused mainly on the outer physical degradation of the PV encapsulant, while the most reviewed fault detection methods emphasized on the visual inspection. Accordingly, and for the purpose of a broader PV faults classification with better expanded faults detection methods, throughout this paper, different faults will be first categorized as either internal, external, or electrical. The consequences of each will be clearly presented in tabulated data, in order to record the affected parts of a PV system. Moreover, two major fault detection techniques classifications will take place, as either detection at the AC side of the PV system or at the DC side. For each part, there exist various sets of methods, and sometimes sub-methods. Each technique will be uniquely identified, investigated, and compared to others within the same set. A critical comparison between detection schemes and targeted faults will be presented. The rest of this paper consists as follows: Section 2 presents a general overview for a PV system with a fault detection scheme, Section 3 classifies and investigate all possible PV faults, where in Section 4 the fault detection methods are expanded and analyzed. Section 5 presents a discussion based on the results of the different reviewed faults and fault detection methods with a future work recommendation, where finally in

Section 6 conclusions are derived.

## Overview of a typical PV system with a fault detection structure

As an additive to a typical off/on-grid PV system, a fault detector is an extra equipment, with the ability to guide the PV system's operators about the existence of a fault, its type and location within the PV system. Consisting of different sensors, processing units, actuators, transducers, and different protective relays and circuit breakers, such a system can be installed at any node indicated by the dashed polylines in Fig. 1. On its output level, the fault detector contains a set of alarms, buzzers, and different forms of Graphical User Interface (GUI) to acknowledge the workers in the field about any fault incident. The full process of fault detection takes place within two distinct steps: monitoring and diagnosis.

### Monitoring

To evaluate the PV system's performance, the monitoring system collects and analyzes a set of different parameters (voltage, current, power, etc.) [14]. This process is crucially important, as a prior step before detecting the fault, with a continuous tracking on the electrical power generation. For data acquisition of various attributes, sensors are the first input to the monitoring system. The data are then transferred through signal processing units, where at final stage, they would be stored for further investigations [14,15]. Fig. 2 reveals the cascaded monitoring process for a PV system, embedded within a fault detection scheme.

### Diagnosis

The results of the monitoring system (in form of acquainted information) are injected to the fault diagnosis scheme as primal data. When compared with reference values, the inputted data can either declare a fault or not [16,17]. Its source of acquisition (whether from the DC or the AC side of the PV system) guides the fault detector about how to investigate upon it. Fig. 3 reveals the different steps of PV fault diagnosis in a cascaded form, beginning by information analysis to alarm launching.

## Different PV system's faults


Due to their outdoor nature, PV systems encounter diverse faults, causing a massive decrease in the PV energy outcome, potential reduction, and most importantly the inability to satisfy various load demands. The fault classification can be mainly classified into three categories as follows:

- Internal
- External
- Electrical


The internal PV faults take place inside a PV module (underneath the protective glass), on the level of PV cells, and strings. External faults localize outside the PV module protective glass and are perceived as either temporary mismatch or permanent mismatch faults. Electrical faults on the other hand, refer to the perturbations of physical entities (i.e., voltage, current, power, etc.) in terms of quantities and waveforms. Fig. 4 entitles the triggers for each set of PV faults.

### Internal PV faults


Internal PV faults take place inside the PV module itself. Their initial cause is the manufacturer's defects, poor quality of fabrication, damages due to inconvenient packaging, and improper methods of wiring. Regardless of their root cause, internal faults are classified according to



**Fig. 1.** Fault detector allocation in an off-grid PV system.



**Fig. 2.** Block diagram of PV monitoring system.



**Fig. 3.** Block diagram of PV fault diagnosis scheme.

the effects they impose on a PV system, as either open/short-circuit, bridging and bypass diode faults. [Table 1](#) groups the causes to consequences of different internal faults.

#### Short circuit fault

Improper connections (low impedance and sometimes bolted pathways) between the solar cells, or defects from initial manufacturing circuitry [[18,19](#)], lead to a short circuit on the module or on the bypass diode [[20](#)].

#### Bridging fault

Improper connection (high impedance and sometimes complete open circuit) between PV modules [[21](#)], causes such types of faults where the output tends to become null.

#### Inverted bypass diode fault/bypass diode fault

Faulty wiring made by the operator [[22,23](#)], resulting in bypass diode fault, reflects as abnormal voltage conditions on the output level.

#### Open circuit with/without bypass diode fault

An open circuit fault, reflected as maximum cell's output voltage, with no ability of current to flow (hence no power output) is often caused by broken cells, damaged connections between them, loose connections, and defected power cables due to aging. The excessive plugging/unplugging routines, yield to faulty open-circuited terminals mainly at junction boxes [[23](#)].

#### External PV faults

Due to the fact that PV systems need to be installed outdoors to receive direct solar radiation, they often interact with undesired environmental conditions. The weather for instance can fluctuate, ranging from hot (elevated ambient temperature) to cold (rain/snow accumulation). Accordingly, PV modules would rarely operate under the Standard Test Conditions (STCs), thus their nameplate power is never attained.

Moreover, natural disasters like intense lightning can burn PV panels. On the other hand, dust/leave accumulation results in partial shading/impedance mismatch. From another part, PV panels fall from height as well as abuse by stones throwing inflicts a permanent damage (glass/frames breakage). [Table 2](#) encapsulates the causes-to-consequences relation for different external faults.

#### Temporary mismatch fault

When the irradiation varies, the PV system performance (i.e., in terms of power production) changes accordingly (e.g., low irradiation reflects lower power production, and vice-versa). Some regions of the PV system (i.e., zones of PV arrays) produce larger power quantities than others [[24](#)]. Even though, faulty PV regions due to temporary mismatch do not produce power as rated values or even close. This can be referred to a non-homogeneous PV output due to non-homogeneous shading [[25–27](#)].

This heterogeneity in power production which is caused by physical light barriers, such as trees, buildings, and overhead power lines, results in detrimental effects over the PV panels [[28](#)]. Depending on the climate conditions and geographical locations, snow can cover some panels of the PV system as well. From another part, biological conditions such as bird's droppings, and leaves accumulation on the surfaces of the PV modules can also lead to partial shading conditions [[29,30](#)]. Dust and dirt from another side, can cover the PV arrays' surfaces, and sometimes sudden natural disasters as lightning and storms can also leave a PV




Fig. 4. Summarizing block diagram representation of PV fault types and characterization.

**Table 1**  
Cause-effect relationship of different PV internal faults.

Internal faults			
Types	Causes	Results	Consequences
Short circuit	Manufacturer's defects	Low impedance/bolted path between internal power rails	Inability to deliver power to DC load or to the power conditioning unit
Bridging	Manufacturer's defects/improper wiring	Creation of impedance faulted linking path	Null power output
Bypass diode	Manufacturer's defects/improper wiring	Bypass diode cannot be forward biased	Inability to mitigate hotspots events
Open circuit	Manufacturer's defects	Absence of link between power paths	Inability to deliver power to DC load or to the power conditioning unit

**Table 2**  
Cause-effect relationship of different PV external faults.

External faults			
Types	Causes	Results	Consequences
Temporary mismatch fault	<ul style="list-style-type: none"> <li>Occasional shading</li> <li>Environmental conditions</li> <li>Natural disasters</li> </ul>	Non homogeneous power production across PV surfaces and creation of hotspots	Low power production compared to standard values and risk of burning
Permanent mismatch fault	Equipment permanent damage	Null power production	Complete blackout

system with a non-uniform irradiance distribution [31,32].

#### Permanent mismatch fault


Unlike partial mismatch fault conditions, a permanent mismatch cannot be reversed. It can be a result of bad soldering, degradation of modules, glass breakage, delamination, discoloration, defects in frame, cell breakage and micro-cracks.

These triggers have a wide range of causes, of which some are manifested by bad operations such as manual soldering of the cell at a breaking temperature, or poor packaging during transportation. Permanent mismatch faults can also be triggered during manufacturing processes, like inconvenient wafer slicing, cell production stringing and other embedded operations that eventually lead to cell cracks.

Such causes are referred to manufacturing defects. Environmental conditions can lead also to permanent mismatch faults. For instance, heavy snow loads in cold regions can break PV modules. Also, frequent temperature changes can wear out the cell interconnections [33,34]. Fig. 5 reveals the physical delamination (indicated by red arrows) of the front encapsulation of a PV module, caused by external faults.

#### Electrical PV faults

Aside than the physical PV faults occurrence, driven by physical barriers (dust/snow/leaves accumulation) and internal manufacturing defects, PV systems also encounter intrinsic electrical faults. According to the PV system's electrical network distribution, electrical faults can occur as ground, line to line, line to ground, arc, and power conditioning units' faults. Table 3 summarizes the causes-to-consequences relation for different electrical faults.



**Fig. 5.** Delamination of the PV module's front encapsulation [51].

#### Ground faults

The PV system includes parts that aren't designed nor supposed to be exposed to any current, like the metallic part of a PV array, the enclosures and other equipment [35,36]. These non-current carrying labels are protected using Earth Ground Conductors (EGC) in order to eliminate any possibility for an electric shock which the operators might examine when working in field, such that the sudden electric current find its way to the ground instead of being trapped inside the equipment [37,38]. When the ground contains active currents, the analysis turns to the case of a fault [39,40]. This type can be decomposed into two sub-parts:

- Upper ground fault: an unintentional low impedance or bolted path between the Current Carrying Conductors (CCC) of the last two modules in a PV string and the ground [41].
- Lower ground fault: an unintentional low impedance or bolted path between the CCC of the second and third modules in a PV string and the ground with large feedback current [41].

#### Line to line faults

The cascading of PV modules creates PV strings, which in turn are wired in parallel to create an array, in order to deliver higher power outputs. The Line to Line (L-L) faults denote erroneous connection between different strings/arrays potentials. By taking an example of a PV string, a L-L cross string fault exists between one string and another. Such faults are very hard to detect and cause severe losses in the overall output before being distinguished [42]. It can be summarized by unintentional connections between two or more nodes of the PV strings/arrays [43,44] and is considered as a top reason for inducing open-circuit faults (due to electrical switchgear tripping mechanisms).

**Table 3**

Cause-effect relationship of different electrical faults.

Electrical faults			
Types	Causes	Results	Consequences
Ground fault	Improper wiring of ground/earth connections	Existence of a large feedback current in the ground	Risk of operator electrocution and voltage instability
Line to line fault	Existence of a faulty connection link between different power rails	Power loss on the output level (three-phase system)	Risk of equipment burning and wire damage
Line to ground fault	Short circuit between current carrying conductor and the ground	Power loss on the output level (single-phase system)	Risk of equipment burning and wire damage
Arc fault	Loose connections/loss of conductivity	Creation of arc current/sparks	Risk of burning/fire
Power conditioning units fault	Malfunctioning of PPUs due to internal fault	Inability to efficiently charge the battery bank and existence of disturbances on the output AC waveform	Lowering the PV system efficiency and decreasing its standby time

#### Line to ground faults

When there is a physical connection between the current carrying conductor and the ground, whether directly or through a low impedance path, a Line to Ground (L-G) fault takes place [45]. A L-G fault is extremely hazardous, as it causes a massive electron flow, in a timely manner, across a faulty small path when compared to the total system's wiring, what would generally result in fire hazards.

#### Arc faults

The conductors used in electrical circuits, often confront corrosion and lack of conductivity due to their chemical reaction with the surrounding environments, and damages resulting of excessive usage. This phenomenon creates an arc current high enough to ignite the surrounding material [46,47]. Such faults are chaotic, random, and might be active for a dangerous amount of time before being detected or resolved. When there is an insulation breakdown, parallel arc faults are ignited. Series arc faults on the other hand, take place when the connections get loose, the connection cables are damaged, or in the event of hotspots [47]. The resultant spontaneous faulty current is often too small to be detected by safety equipment such as Residual Current Devices (RCDs) [48,49].

#### Power processing units' faults

The Power Processing Units (PPUs) are equipment that work on shaping the resultant signals waveforms or modifying their quantities. For PV systems, two main PPUs exist:

- Inverter: used to transform the original DC power to consumable AC power (since most industrial/residential loads operate on AC).
- Maximum Power Point Tracker (MPPT): included in charge controllers, to extract the maximum available power under partial shading conditions.

These elements in turn, can interact with faulty scenarios, prohibiting them from achieving their destined functions. The PPUs faults are

**Table 4**

Cause-effect relationship of different PPUs faults.

Power conditioning units faults			
Types	Causes	Results	Consequences
Inverter failure	<ul style="list-style-type: none"> <li>• High temperature for prolonged amount of operating time</li> <li>• Excessive operations</li> </ul>	Failure in switching mechanisms	<ul style="list-style-type: none"> <li>• Disturbance in the resulting AC waveform</li> <li>• Load malfunctioning</li> </ul>
MPPT failure	<ul style="list-style-type: none"> <li>• Sensors malfunctioning</li> <li>• Algorithm bugs</li> </ul>	<ul style="list-style-type: none"> <li>• Delayed time for battery bank charging</li> <li>• Battery bank over-charging</li> </ul>	<ul style="list-style-type: none"> <li>• Shortening the life cycle of the batteries</li> <li>• Batteries permanent damage</li> <li>• Lowering the standby time under low irradiance conditions</li> </ul>

summarized in [Table 4](#).

**Inverter failure.** Inverters can have their efficiency reduced, with faulty operational behavior, when exposed for example to continuous high temperatures for a prolonged amount of time, and when experiencing an excessive mechanical stress on their power switches. For instance, when Insulated Gate Bipolar Transistor (IGBT) fails as a solid-state switch in conduction for example, the algorithm conducting other IGBTs resets and the entire power electronics switching circuit fails, hence the inverter fault [50].

**MPPT fault.** The MPPT works in collaboration with sensors and charge controllers, to be able to identify the Peak Points (PPs) in the characteristic Current–Voltage (I–V) curve of the PV module and calibrate the charging process of the batteries [52]. When sensors get disconnected/defected, and the MPPT's algorithm experiences an erroneous workflow, the MPPT zone within the PV system gets faulty [53].

When the MPPT fails, it often leads to a damage on the level of the battery bank: the charge controller abnormally selects reference voltage levels. This yields to over-charging where the bank is exposed to higher than standards voltage inputs, for prolonged amounts of time. Under-charging from another part also takes place when the MPPT fails: consequently, the electrodes are damaged inside the batteries due to low input voltage feeding [54]. Since each type of the faults affects the performance of the PV system in a specific severity, [Table 5](#) in accordance provides a comparative assessment between the different reviewed PV faults.

### Fault detection methods

The approaches to detect faults in PV systems are classified to work in either the DC or the AC regions of the PV system [246]. The entirety of techniques can be summed up as in [Fig. 6](#), where six major techniques are listed on the AC side and eleven techniques on the DC side of the PV system.

#### Detection at AC side

This set of fault detection techniques covers up the zone in PV systems where all AC quantities exist. The red dashed area in [Fig. 7](#) enfolds the referred region for detection. The output of the inverter is fed and distributed into the AC grid, by means of Main Distribution Boards (MDBs). Any power failure in the red dashed zone, needs AC relevant protective equipment, such as Circuit Breakers (CBs), Residual Current Devices (RCDs), and others protective switchgear. To be able to send tripping/switching commands to the AC safety switchgear, specific algorithms are required, which rely under Artificial Intelligence Techniques (AITs), Real-time Difference Measurement models (RDM), Fault Detection Techniques for three-phase Inverters (FDTI) and Islanding Detection Techniques (IDTs).

#### Artificial intelligence techniques (AIT)

Artificial intelligence used in PV systems' fault detection aims to transfer a certain knowledge into computers and make decisions accordingly. Based on computational algorithms, this set of techniques allows computers to learn using human-inspired reasoning. When applied, their implementation results in a faster and more accurate decision making [278]. The following methods represent some examples about AIT for PV fault detection:

- PIC based extension matter.
- SCADA for Ground Connected Photo Voltaic Systems GCPVS/NUI algorithm based on SCADA inputs.
- Automated diagnostic signal software tool based on comparison of APRE.

**Table 5**  
Comparison of different types of PV fault consequences.

Type	Reason	Reason						Possibility of occurrence	Fault severity			
		Environmental			Physical				Complete blackout	Partial blackout	Non homogeneous power production	Impurities in output signals
Leaves	Dust	Soil	Weather	Storms	Lightning	Stones	Bird dropping	Shading	L-G	L-L	MPP-T	
Internal PV faults									✓	✓	✓	✓
External PV faults	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Electrical PV faults											✓	✓




Fig. 6. Complete PV fault detection methods at AC/DC sides of the PV system.




Fig. 7. AC detection zone.

- d) SA-RBF Kernel Extreme Learning Machine KELM.
- e) Predictive Maintenance and Anomaly detection.
- f) ANN model detecting operational and environmental faults.

**PIC based extension matter.** A Peripheral Interface Controller (PIC) is implemented for fault diagnosis. By combination of PIC microcontroller, coded in assembly, with a ZigBee wireless sensor, a remote access is granted on monitoring the occurring faults in the AC parts of PV systems. The power generation of a PV system is firstly analyzed under normal/defected operations. Then by relying on extension theory, a matter-element model (problem solving tactic based on human thinking) is constructed from the initial data collections. This PV fault

diagnosis only requires small amounts of data to construct the matter-element model, while providing a high fault detection accuracy [55]. Recent evolution in computerized and embedded systems has led to more powerful micro-controllers than the one used in [55], where in terms of computational speed, a programmable logic controller is better used to detect the PV faults. *SCADA for Ground Connected Photo Voltaic Systems GCPVS/NUI algorithm based on SCADA inputs*

This algorithm based model feeds input signals to a Supervisory Control And Data Acquisition (SCADA) system to categorize and identify different electrical faults such as string fault, short circuit fault and line to line fault for Grid Connected PhotoVoltaic System (GCPVS). The needed attributes are ambient temperature, irradiation (measured via a pyranometer), and power ratio [56]. The synoptic scheme for this model is shown in Fig. 8.

The fault detection model has achieved a high detection accuracy of 99.80 %, but this value may fluctuate due to the major system's dependability on meteorological/electrical sensors, which might give false readings due to false/inaccurate calibration [56]. Similarly, a fault detector for PV plants using a web server relying on Non-Uniformity Index (NUI) can also act as a remote server based on SCADA inputs. The NUI algorithm which allows remote supervision and fault detection has been examined and with such model, the faulty PV zones within a PV farm can be identified according to their produced energy levels either as acceptable or not. With the usage of special temperature/irradiance models, this system seems to have diminished the required number of sensors for PV fault identification [164].

*Automated diagnostic signal software tool based on comparison of APRE.* Using certain electrical quantities (i.e., voltage, current) as reference values, an automated diagnostic signal tool to detect non-recoverable faults at AC sides of a PV system can be established [57]. The failure identification process takes place with the two indicators  $R_C$  (DC current) and  $R_V$  (DC voltage) as shown in Eq. (1) and Eq. (2) respectively.




Fig. 8. Synoptic scheme for GCPVS [56].

$$R_C = \frac{I_{pv\_sim}}{I_{pv\_meas}} \quad (1) \quad DLL = 3\sigma_d \quad (4)$$

$$R_V = \frac{V_{pv\_sim}}{V_{pv\_meas}} \quad (2) \quad DUL = 5\sigma_d \quad (5)$$

with  $I_{pv\_sim}$ ,  $I_{pv\_meas}$  denoting the simulated and measured array's DC current respectively and  $V_{pv\_sim}$ ,  $V_{pv\_meas}$  the simulated and measured array's DC voltage respectively. A set of comparison takes place for the two equations where each translates into a specific fault situation. The entire procedure is based on Absolute Performance Ratio Error ((APRE) which represents a performance metric for machine learning), where the fault is located inside a GCPV plant by monitoring the DC and AC power ratio. The model has resulted in a good detection accuracy with a great potential for future adaptation as a widespread tool for GCPV [57].

**SA-RBF kernel extreme learning machine (KELM).** This intelligent fault diagnostic tool uses simulated annealing algorithm based on radial function Kernel Extreme Learning Machine (KELM). The method begins by establishing the fault model and optimizes it using the Simulated Annealing (SA) algorithm [62]. The adopted KELM function  $\Omega_{ELM}$  is shown in the following equation.

$$\Omega_{ELM} = \exp\left(-\frac{|x - x_i|^2}{2\sigma^2}\right) \quad (3)$$

where  $\sigma$  is the radial width parameter and  $x, x_i$  composers of target value vector. The SA algorithm optimizes the parameters for radial basis function KELM, where the resultant algorithm can quickly and effectively identify short circuit, aging and PV faults related to partial shading [62].

**Predictive maintenance and anomaly detection.** Working upon historical data, specifically using the actual two-year measurements of irradiance, temperature, and other climatic conditions as historical data to be fed into a predictive algorithm database, a learning-approach-based model can detect any reduced output fault by comparing both measured and predicted values of AC power [63]. Two normal operation limits were classified as Daily Lower Limit (DLL) and Daily Upper Limit (DUL), are expressed in Eq. (4) and Eq. (5) respectively.

where  $\sigma_d$  denotes a daily-equivalent standard deviation index. Samples which are numerically compared to the thresholds  $DLL$  and  $DUL$  represent normal/faulty operations of the PV system [63].

**ANN model detecting operational and environmental faults.** A two-layer Artificial Neural Network (ANN) based model that works as a Supervisory Control and Data Acquisition (SCADA) system, operates as a monitoring tool on PV assets as well as on their environmental conditions. This methodology can perform also economic evaluations about the current PV system's states, also on upgrading the previously designed PV systems to supply larger loads. It consists of a two-layer ANN model that states any lack of insulation, or solar tracker blockage using a private logic decision making [66]. Fig. 9 reveals the connections between the input/output layers of the algorithm, where  $b$  represents the bias,  $n$  the neuron,  $W_{j,i}$  the weight of the input ( $j, i$ ), and  $W_{y,dj}$  the output weight of the ANN.


Different attributes, such as internal and ambient temperatures, radiation and time of performance are mutually linked to different nodes within the hidden layer. The probabilities of occurrence of an attribute within a specific node, are all taken into consideration. This would finally result in an estimated accumulated active energy level, to deduce the fault impact on the overall power production.

#### Real-time difference measurement (RDM)

Real-time difference measurement systems acquire instantaneous physical samples (voltage, current, etc.), resulting from experimental/analytical measurements to dynamically provide data concerning the process of PV functioning (fault detection). This set of methods contains the following sub-methods:

- a) Using AC output data
- b) Using capacitance change criteria

**Using AC output data.** Using AC output data in PV system, a preliminary method consisting of three sub-methods used entirely to detect faults. The first sub-method relies on comparing both measured output values



**Fig. 9.** Multi-layer ANN back propagation [66].

and estimated values. The second deals with present and past performance ratios and finally the last relies on comparing present and past output differences. By combining these three sub-methods, the resultant model overcomes the erroneous fault identification of other AC based PV fault methods for specific PV circuitry [68].

**Using capacitance change criteria.** Using AC parameter characterization, hot spots in PV systems can be detected by noticing the capacitance change within a single cell (that is comprised of series/parallel resistances and parallel capacitance). The measuring the AC impedance value in the range of 10–70 kHz the capacitance change is detected by monitoring first a High Frequency (HF) in the Capacitive Region (CR) and Low Frequency (LF) in DC impedance region. Such a fault detection system does not only help in identifying the formation of hotspots but can also help in the optimization of MPPT algorithms [155].

#### Fault detection techniques for three-phase inverters (FDTI)

Embodying the raw source of AC power in a PV system, good monitoring and control techniques are required for inverters for a safe switch off, and an optimum overall performance of the system. Locating the fault of the inverter enables the usage of standby equipment (to get rid of blackouts) and modifications in the functional strategy [80–88]. There are two general ways to detect faults in inverters:

#### I Signal-based methods

- 1 By measurements of inverter's output voltages
- 2 By measurements of load currents

#### II Models-based methods

#### Signal-based methods

These methods require the measurements of inverter output voltages [110–116], or load currents [117–120, 173–181].

#### Measurements of inverter's output voltages

**Mass center of the voltage pattern.** To identify an open switch fault inside the inverter, an analysis of the pattern mass center derives an algorithm for that aim. First the algorithm starts by acquiring the AC voltages of the inverter and results of histograms created according to Eq. (6) [89].

$$\begin{cases} PR \ oj_{V_a}(V_a) = n_k \\ PR \ oj_{V_b}(V_b) = n_k \\ PR \ oj_{V_c}(V_c) = n_k \end{cases} \quad (6)$$

where  $PR$  represents the reference for the inverter's histogram voltage representations,  $V_a$ ,  $V_b$  and  $V_c$  are the voltage magnitudes for each phase and  $n_k$  is the sample's number during one period of the signal. Successively, the left and right mass centers are calculated. From the mass center of each zone, the normalized diagnostic variables are calculated where any transistor open fault is identified by means of a Schmitt-trigger circuit. This method is characterized by its low computational requirements [89].

**Open circuit fault identification rule for the inverter.** Depending on the voltage variation of PV arrays, residual voltage errors are calculated. Basing on the amount of such errors, an open circuit fault identification rule is identified for the inverter as shown in the following equation.

$$R_i = [\text{sign } (r_i) + 1] \cdot (p_{\min} - p_{\text{poi}}) \quad (7)$$

where  $R_i$  represents the improved judgment criterion,  $\text{sign}$  refers to the

signum function,  $r_i$  is the voltage residual error,  $p_{min}$  the minimum output power of PV and  $p_{poi}$  the  $i$ th PV panel power. Designed for grid-connected PV systems, this method has shown reliability and flexibility, with a robustness in detecting PV faults under maximum power points variations [94].

#### Measurements of load currents

**Current comparator method.** By comparing the current between any two identical branches inside the AC distribution network, the inverter fault can be detected based on the fact that these two currents must be equal [90]. By setting a small constraint  $\epsilon$  which corresponds to a maximum tolerance level, the difference between two nodes' currents  $\Delta I_{Nm}$  must obey the inequality of the following equation.

$$\Delta I_{Nm} < \epsilon \quad (8)$$

with  $N$ ,  $m$  representing the currents' nodes. Therefore, when the difference between the two nodes' currents  $\Delta I_{Nm}$  equals or surpasses  $\epsilon$  an inverter fault is detected [90,99].

**State observer method.** To detect an open-circuit fault for an inverter in a grid-tied PV, a mathematical model is first built for the converter. Then, a state observer is constructed with the aim to generate any occurring current residuals. The fault is detected by means of a comparison between the residual error with the setting threshold. For PV inverters open-circuit faults, this method is validated with a good feasibility [92].

**Knowledge-based models.** Based on a knowledge-model, an inverter's fault detection technique is established by using two approaches, the current vector trajectory, and the instantaneous frequency. Hence, an open transistor fault in the inverter is detected [96]. For three phase inverters, fault diagnosis is based on the most probable defect, as a way to overcome the lack of Fourier analysis in proceeding explicit determination of the fault [97].

**Similarity measurements based methods.** When inverters interfere with failures, the semiconductor devices' based topologies become non-symmetrical. Therefore, the resultant three phase current become nonsymmetrical in turn. Based on the residuals of current ordered-sequence Mannhardt distance, the measuring algorithm can detect and locate the open-circuit faults [98].

**Based on information fusion.** For inverters' open-circuit fault detection, an improvement of Dempster-Shafer (D-S) evidence theory is achieved by the mixture of Back-Propagation Neural Network (BPNN) with Classification And Regression Tree (CART) algorithms. The load current signals are processed using Wavelet Transforms (WT). In other words, WT is used to extract fault characteristics (such as transistor faults in inverters). At a second order, BPNN and CART are used to diagnose the open-circuit faults. The improvement to the decision level concerning fault detection is held by means of the improved D-S [100–103].

**Park's vector method.** The open-circuit fault as well as other defects in the power switches (IGBT, MOSFET, etc.) are detected by calculating the position of the current trajectory's midpoint. The Park's vector transformation allows the obtainment of both magnitude and phase angle of the pre-calculated three-phase average currents. An open fault exists if the magnitude of the space vector is nonzero and greater than a threshold [104–107].

**Model-based methods.** These methods require the accurate system model's design to achieve an optimum algorithm and consist of four distinct sub-methods.

**Observer-based diagnosis scheme.** As a way for detecting faults related to power switches inside an inverter, a directional residual evaluation in the frame is employed [108]. The fault detection process is held by residual vector evaluation shown in windowed norm as in the following equation.

$$\|r_{dq}\|_{2,t,T} = \sqrt{\int_{t-T}^t \|r_{dq}\|^2 dt} \quad (9)$$

where  $r_{dq}$  is the current residual vector and  $t, T$  are time constants. The algorithm for the inverter's fault detection used in this model is independent of the load torque, where simultaneous faults can be isolated, in a quantitative way with no need of extra measurements for voltage/current required for implementation [108,91].

**MRAS-based diagnosis.** The open-switch inverter faults are detected by the employment of a permanent magnet synchronous motor. The model relies on reference adaptive system techniques, corresponding to normal voltage balancing/sequencing in each phase. In other words, in order to detect open circuit faults, this method takes into account the input voltages to the inverter and observes any voltage distortion at the output level. This proposed method can be well combined with the corrective maintenance schemes, such as the reconfiguration of inverter, while demanding less extra circuitry (e.g., voltage/current sensors), and low computing facility [109].

**Multistate data processing and subsection fluctuation analysis for photovoltaic inverter.** Composed of three distinct blocks: Multistate Data Processing (MSDP), Subsection Fluctuation Analysis (SFA) and Artificial Neural Network (ANN), the MSDP retains the main fault features and abducts the influence of load's change (to distinguish between this scenario and a fault). Secondly, the SFA classifies the different states of the inverter's switches. Finally, ANN combines MSDP and SFA to adapt an intelligent classification of faults [93].

**Combination of a model-based and data processing perspective.** Different fault scenarios (under model-based topology) are estimated by means of an additive model, which employs in turn sliding-mode proportional-integral observers. Then by performing a directional residual evaluation within a fixed reference frame, through data processor, faults can be detected in the inverter [95].

#### Islanding detection technique (IDT)

An over-current fault is noticed inside the AC region of the PV system, by means of Circuit Breakers (CBs). The CBs tripping, provided by an internal electro-mechanical mechanism, is executed to reduce any wires/equipment damaging. Islanding consists of switching off a faulty zone in the AC distribution panel, similarly to the operation of CBs. To detect islanding means to figure out where the fault has taken place, hence allowing its quick removal, therefore restoring power back to the faulty zone. The islanding detection technique possesses two different sub-techniques:

- a) Central remote techniques
  - 1 System state monitoring
  - 2 Switch rate monitoring
  - 3 Inter-tripping
- b) Local islanding techniques
  - 1 Passive techniques
  - 2 Active techniques
  - 3 Hybrid techniques

#### Central remote techniques

**System state monitoring.** Unintentional islanding here can be detected using parameter distribution quantity measurements such as voltage, frequency and transients in these two labels [185]. This method plays a complementary role to the SCADA and needs fewer number of state measurements [121–123]. Machine language can be as well added to the monitoring process of the system's state by means of Decision Tree (DT) algorithms [182–184].

**Switch rate monitoring.** A tripped CB is a clear indicator about an over-current fault, yielding in islanding some zones of the PV system.

Hence, a transfer trip detection technique scheme can be used to monitor all CBs that might cause the islanding of the PV inverter. The integration of a SCADA with the trip detection technique would help in the monitoring process [124–126].

*Inter-tripping.* Figured on a special communication between sensors and generating units, this method detects any open-circuits at the points of disconnection and generates a feedback signal to the sites' data monitors [127,128].

#### Local islanding techniques

*Passive techniques.* This area of research has four main categories of measurements that help revealing a local islanding fault. The first method takes into consideration the voltage and frequency fluctuations, above and under optimum values. It is considered as a primitive method in detecting unbalances, using protective relays that indicate a fault based on the power flow at Points of Common Coupling (PCC) between the utility and the inverter [129].

The second detects any voltage phase jump, where it monitors the difference between the current and the terminal voltage of the inverter to identify any surge occurrence [130].

The third category in this part is about harmonics measurements. It measures any change in the Total Harmonic Distortion (THD) at PCC, where the careful selection of the basis threshold reduces any false tripping [131]. Extra monitoring parameters can be added as THD of the current and unbalanced voltage to detect any islanding fault [132] that in turns present a harmonic impedance measuring [133] of the electric system, what results in islanding fault detection.

The last sub-part of this set of techniques operates by detecting the voltage unbalance, due to changes in the network topology and load [134,135] that could result in islanding sub-parts of the PV systems. Such operation is achieved by continuously analyzing the output three-phase voltage at low time cycles [136].

*Active techniques.* Beginning with the impedance measurement technique, where source impedance is calculated using short circuit current and reduced supply voltage (due to islanding) [137], islanding detection zones can be identified, but not all of them, as this method have Non Detection Zones (NDZ) [138]. On the other hand, the Slip Mode frequency Shift (SMS) is considered as an active technique used to detect islanding, by taking advantage of a positive feedback carrying info about frequency, amplitude, and phase detection.

An improvement to this method (since it presents phase shift perturbation leading to measurement inaccuracy) is called improved SMS [139] where an additional phase shift is maintained that results in lower NDZ.

*Hybrid techniques.* Presenting a total of four different hybrid techniques, the first hybrid IDT bases on the voltage unbalance and THD, to identify an islanded AC zone due to CBs tripping. It can be added to a positive feedback based technique [140]. The limitation of each technique (hybrid-positive feedback) is overcome when both of the methods operate simultaneously.

A second hybrid technique is based on voltage and real power shifting where it is considered as a solution to overcome the limitations of other IDT techniques and takes advantages of individual passive and active techniques. This method uses an average rate of the real power shift in active technique and voltage change in passive one [141]. Such working methodology can lead to islanding detection even for multiple generating units.

The third method states that after the injection of an intentional voltage fluctuation by means of a high impedance load [142], a rate of change is afterwards calculated for voltage and a correlation factor, using digital signal processing, yielding eventually to islanding detection.

The last one represents a curve modeling for islanding detection, based on Sandia Frequency Shift (SFS) and reactive power versus frequency (Q-f) proposal [143]: this method reduces the NDZ by

calculating the optimum SFS where the bacterial foraging algorithm is used to derive the optimal SFS gain.

#### Residual current monitoring devices (RCD)

Any residual between entering and leaving currents from a node inside the AC network, indicates a leakage, where the RCD's coil is sufficiently energized and tripped to stop that phenomenon. For a PV system, an RCD protects against L-L and L-G faults where it can be installed either for the entire string or one complete array [213]. The RCD sensitivity must be carefully chosen to avoid any false tripping [214].

#### Ground fault detection and interruption fuse (GFDI)

In a complete circuit, the current created from the supply feeds the load and returns in the ground conductor. When there is any abnormality in this return current, the GFDI operates to immediately switch off the inverter [215,216]. Sometimes leakage currents exist, inducting a false GFDI tripping. There are also certain environmental conditions such as relative humidity, ambient temperature, and salt mist, which negatively affect a proper operation of a GFDI fuse, causing a false tripping. Therefore, the sensitivity of the GFDI must also be properly selected [217,218].

The classification of AITs (Artificial Intelligence Techniques) sub-methods rely on the algorithm of implementation. Whether ANN, DT, KELM or others, the back-propagation, data-mining, and decision making with the corresponding degrees of accuracy and data acquisition time is what characterize each. They all share a complex programming process in common. Different RDM based techniques aim to detect various electrical faults. Beginning with open-circuit/short-current faults, arriving at detecting failures in power conditioning units, they differentiate in their accuracy and data acquisition time.

Regardless that FTDI attributed methods might contain implemented artificial intelligence algorithms, they differentiate from AIT with their case-specified algorithms. The learning/decision algorithms are driven according to each converter datasheet. On the AC side of a PV system, the CBs are a must to neglect any form of overloading. This in turn reduces the potential of equipment damaging and cable burning. The islanding detection techniques give the possibility to figure out the faulty zone, hence restoring normal functioning at the load side (e.g., reduce any form of partial/complete blackout). The application of IDT gives the system a more reliable and consistent performance.

The RCDs and GFDI based techniques refer to fault detection methods by means of safety switchgear. From one side, RCDs reduce any possibility of current leakages, hence avoiding any risk of personnel electrocution. On the other hand, GFDI ensures that no current is present in the ground. This avoids in turn any voltage unbalancing. The safety switchgear (CBs, RCDs, GFDI) cannot be avoided in the AC side of the PV system. No fault detection at the AC side of the PV system can be set for execution without such devices (whether actively or remotely via SCADA). The electro-mechanical tripping phenomenon of these devices is the clear indicator for a fault detection.


The islanding detection technique can be mixed with RCDs and GFDI by means of Residual Current Breaker with Over-current devices (RCBOs). When RCBOs are used, any trip can be detected using islanding detection, at the same time while avoiding any personnel electrocution, voltage unbalancing and equipment (wires, loads) damaging. This would reduce the need of extra components, causing a more financially affordable PV protective system. Table 6 reveals the potential need for applying different fault detection methods and the consequences when not being applied.

#### Detection at DC side

With DC detection techniques, the entire DC zone within a PV system is monitored. The blue dashed area in Fig. 10 entitles the corresponding region for fault detection. The received DC power from the solar module

**Table 6**  
Consequences of not applying different AC fault detection techniques.

Detection technique	Necessity for application	Consequences when <i>not</i> applied	Effects
AIT	Optional	Errors between measured and predicted electrical quantities	Reduction in system's financial competencies
RDM	Optional	Errors between measured and calculated electrical quantities	Reduction of system overall efficiency
FDTI	Medium to high	Converters internal failure	Distorted AC waveforms
IDT	Must	CBs excessive false tripping	Partial/complete blackout
RCD	Must	Presence of current leakages	Personnel electrocution
GFDI	Must	Abnormal quantities of return current	Voltage unbalancing



**Fig. 10.** DC detection zone.

in Fig. 10 is fed into the charge controller. DC loads are supplied from the charge controller, at the same time while the battery bank gets charged and monitored.

#### Statistical monitoring method

Statistical monitoring based fault detection methods for PV systems rely on collecting PV performance data, calculate a statistic test to define the acceptance/rejection regions of the data set, then draw a final conclusion accordingly. A statistical monitoring method relying on Modified Exponentially Weighted Moving Average (MEWMA) algorithm can detect non-recoverable faults at the DC side of a PV system. The tactic starts with the one-diode model identification, to simulation of PV system, and end up with applying the algorithm [169]. Fig. 11 exposes the fault detection/identification phases of MEWMA algorithm.

The procedure shown in Fig. 11, indicates that the PV system is running optimally if no residuals from the compared outputs exist between the simulated version of the prototype and the real hardware itself. In case of any differences in the outputs, the MEWMA algorithm can classify the existence of a fault, as either faulty module, faulty string, or partial shading due to ageing. This strategy was tested experimentally on a GCPV showing a good capacity in PV fault detection [169].

#### Electrical methods

This set of methods rely on Current–Voltage (I–V) characteristics analysis, to detect a fault in the DC detection zone. It covers up the following sub-methods:

- a) Model Based Difference Measurement (MBDM)
  - 1 DC to AC power ratio monitoring

- 2 Comparison between DC voltage/current deviated error with respect to reference values
- 3 Base fault diagnosis combined with Wald-test technique
- 4 Comparison of simulated I–V characteristic curve with experimental data
- 5 Comparison of measured values with model prediction results
- 6 MPPT fault locator
- 7 Shading fault detector based on Deviation Error (DE)
- 8 Short circuit current detector
- 9 Dynamic I–V characteristics based fault diagnosis
- 10 Shading and electrical faults detector based on Bishop model
- 11 Experimentally Weighted Moving Average (EWMA) control for shading effect on PV modules detection
- 12 T-test statistical method for physical fault detection/algorithm for fault detection
- 13 Electrical and environmental fault detection based on WOEWMA
- 14 OPC monitoring
- 15 Comparison between Measured and Modeled (CMM) PV system outputs
- 16 Analysis of solar photovoltaic power generation
- b) Spread Spectrum Time Domain Reflectometry (SSTDR)
- c) Estimating Randomness in the Voltage signal (ERV)
- d) Power Loss Analysis technique (PLA)
- e) Electrical current-voltage I–V Measurement (EM)
- f) Open/Short-Circuited modules in PV string (OC/SC)
- g) High/Low Voltage fault diagnosis sections (HV/LV)
- h) Partial/Complete Shading fault detector (PS/CS)
- i) Online/offline model (Onm/offm)
- j) Degradation Fault Identification (DFI) based on string current
- k) DC–DC converters Fault Identification (DC-DCF)

**Model based difference measurement (MBDM).** Model based difference measurement methods consist of modeling the optimum cases (theoretical) for current/voltage values (reference values). The second modeling includes the actual experimental values for the quantities being studied. The difference between these two models yields to a clear representation of the deviation error. The value of the deviated error represents in turn a clear sign of the fault's type.

**DC to AC power ratio monitoring.** By monitoring the DC to AC power ratio, the location of a fault in a Grid Connected PhotoVoltaic (GCPV) system is located. Accompanied with a developed software tool the identification of different sub-faults in the different regions of the PV system (on the level of PV string, module, MPPT, etc.) is enabled. The failures taking place at the DC side of the system are indicated by means of capture losses  $L_c$  given in the following equation.

$$L_c = Y_r - Y_a \quad (10)$$

where  $Y_r$  and  $Y_a$  denote the reference yield and energy produced by PV array over a specific time period respectively. Accordingly, the calculated values of losses yield in a clear representation of the fault's type and its causals (e.g., soil, electrical interconnections, etc.) [187].

**Comparison between DC voltage/current deviated error with respect to reference values.** Relying on the comparison between the simulated and measured data of the PV system's performance a fault is detected then identified by analyzing and comparing the number of errors deviated between the DC voltage and current with respect to the evaluated thresholds of a reference fault-free system. For capture losses monitoring, the error parameter  $EL_c$  is established as shown in the following equation.

$$EL_c = |L_{c\text{meas}} - L_{c\text{sim}}| \quad (11)$$

with  $L_{c\text{meas}}$  and  $L_{c\text{sim}}$  correspond to measured and simulated power losses respectively. The different established thresholds for fault detection and diagnosis procedures the most likely occurring fault can be determined




Fig. 11. MEWMA flowchart [169].

[188].

Base fault diagnosis combined with Wald-test technique. Targeting for Residential Photovoltaic System (RPS) fault detection, an algorithm emphasizing on active and passive parts of the PV system, is used to first diagnose the problem using a base fault diagnosis to check for any fault's alarm signal using an arbitrary data. After so, in the passive part, and in order to investigate the temporary mismatch resulting fault, Wald-test technique is statistically used. Then a proposed Flash Test Driver (FTD) device is used on the power conditioning units to increase the efficiency as well as the reliability of the RPS. The suggested flash test method can be integrated with artificial intelligence-based techniques, thus expanding its PV fault detection types, cost-effectively [189].

Comparison of simulated I-V characteristic curve with experimental data. Targeting the faults that might occur on the level of a PV array such as temporary mismatch and electrical faults, different intended fault scenarios were exerted on the system. The comparison between the Matlab simulated I-V characteristic curve and the generated experimental data of the same PV system, helps in identifying the nature of the fault. The categorization of different faults is generated from normal operation to bypass diode fault. Such PV fault detection technique can lead designers to an accurate prediction of possible faults [191]. From another part, the single diode model (projected to regional environmental inputs, such as temperature and irradiance) can be first estimated. Then, the type of the fault to be identified will be based on a threshold approach: a 10 % deviation of the PV cell's measured power

do not indicate any presence of a fault. Contrarily, any significant decrease/increase (by more than 90 %) in the measured voltage and/or current, indicates the presence of a fault. Similarly, a difference of more than 10 % between the measured/estimated fill factors leads also to a fault declaration by the algorithm [296].

*Online comparison of measured values with model prediction results.* On the level of PV panels, a fault detector is established by comparing the measured values with model prediction results. The prediction relies on the theoretically calculated PV power production resulting from solar irradiance and PV panel temperature measurements. With a low complexity and high fault detection rate, this method results in a fault detection rate greater than 90 % for different irradiance intervals models [192].

*MPPT fault locator.* For shading and converter faults in PV arrays, when comparing the Maximum Power Point Tracker (MPPT) output under shading conditions with respect to the same output under normal irradiance, faults are detected (e.g., the PV power output is smaller compared to standard conditions). If the PV load is too small, the fault cannot be accurately identified, hence, a defined voltage ratio technique takes place over the normal difference method [193].

From another point of view, the modification of the MPPT algorithm is another way to detect the PV faults in the DC region. Basing the algorithm on the variation of the aspect ratio of the rectangle parameterized by the origin (0;0) and the Maximum Power Point (MPP) ( $V_{MPP}; I_{MPP}$ ) within the Power–Voltage (P–V) characteristic curve, the non-recoverable faults as faulty interconnections, bridge earth, and shunt path development can be detected [262]. The MPPT algorithm can be adjusted as well to detect different physical faults on the level of PV cell, such as shading, aging, degradation, and possible hotspots, due to environmental triggers [263]. On the other hand, a faulty MPPT can negatively affect the PV system's efficiency and reliability (i.e., false decision making, inaccurate duty ratios signaling, etc.). Accordingly, in order to restore a proper MPPT operation, the standard activation must be allowed [70].

*Shading fault detector based on deviation error (DE).* When partial shading occurs on the level of PV cells, the PV modules in turn overheat and bypass diodes get activated. Accordingly, the mathematical equation corresponding to the normalized error DE resulting from comparing the actual I–V curve data with reference ones can lead to error identification. By means of this method, shading faults can be online dissociated between homogeneous and non-homogeneous. In addition, the bypass diodes activation is detected with a derivative calculation between the standard error and the PV module voltage [194].

*Short circuit current detector.* The output current of a PV system is highly dependable on external climatic conditions, therefore faulty currents can be misinterpreted by PV current fluctuation (high values under high irradiance profiles, low values under cloudy days). In order to eliminate such confusion, a dynamic state estimation-based algorithm can be a solution to identify the short circuit currents especially when the series fuse is not operating due to the reduced value of the short circuit current which is limited by the blocking diode. The proposed algorithm is effective for a PV fault on the cellular level [195].

*Dynamic current–voltage characteristics based fault diagnosis.* A simultaneous way of investigation between sampled data of voltage–current characteristics of a PV panel and the determination of its intrinsic parameters can lead to a dynamic fault diagnosis. With a fast parameter estimation, this technique allows a deep knowledge upon the state of the PV panel, what reflects as identifying the different sorts of external faults [196].

*Shading and electrical faults detector based on bishop model.* By relying on the least squares method, the diagnosis of Solar Energy Production Source System (SEPSS), based on Bishop model is exposed where shading faults, as well as different electrical faults are taken into consideration. When the direct signal analysis (i.e., by temporal power/voltage variations) does not contribute well in the PV fault detection, the proposed least square based fault detection overcomes such obstacles. In

the process of fault detecting decision, a fuzzy logic approach is employed, with less needed time for calculation and ease of implementation [197].

*Experimentally weighted moving average (EWMA) control for shading effect on PV modules detection.* For an early detection of shading effects on PV modules, as well as other faults on the DC side of the system, the usage of a mixed combination of the simple one-diode model in collaboration with the extended capacity of the EWMA control scheme, can detect the mentioned faults [199]. First, the one-diode model is used to make a reference of a healthy PV array maximum power coordinates. Then, all residuals (resulting from the difference of measurements between predicted and actually measured data) serve as fault indicators. When uncorrelated residuals exist, EWMA executes to identify the fault's type.

*T-test statistical method for physical fault detection/algorithm for fault detection.* To detect faults on the DC sides of a Grid Connected Photo-Voltaic (GCPV) system, a fault detection algorithm based on T-test statistical method is used to detect different types of physical faults [201] where for a given solar irradiance and temperature inputs, attributes such as voltage and power ratio of the PV strings, are measured. The needed inputs of the algorithm are solar irradiance, modules temperatures, voltage, and power ratios [166].

*Electrical and environmental fault detection based on WOEWMA.* Using the upgraded Wavelet Optimized Exponentially Weighted Moving Average (WOEWMA) algorithm, electrical as well as environmental faults of PV grid connected systems can be detected [163]. The overall system can classify false alarms and missed detection rates. Fig. 12 presents the two online/offline monitoring phases for the WOEWMA algorithm. Control limits are calculated from the off-line modeling phase and compared with the detection chart obtained during the on-line monitoring phase. The fault is declared after violating the permissible threshold between the detection chart and its control limits.

*OPC monitoring.* In an Object linking and embedding for Process Control (OPC) environment for PV simulation, a remote supervision and fault detection technique based on voltage/current comparison tactic is proposed [165]. The system itself is a decision maker where it analyses the monitored data and evaluates the expected behavior of PV arrays in terms of output voltage, current and produced power. The current and voltage indicators that were used for fault detection are shown in Eq. (12) and Eq. (13) respectively.

$$NR_c = \frac{I_m}{I_{scg}} \quad (12)$$

$$NR_v = \frac{V_m}{V_{ocg}} \quad (13)$$

with  $I_m$  and  $V_m$  representing the current and voltage quantities at the maximum power point respectively while  $I_{scg}$  and  $V_{ocg}$  representing the real-time measured current and voltage quantities. This method was experimentally tested on a real PV system, where the root mean square errors between real/simulated data were below 3.6 % [165].

*Comparison between measured and modeled PV system outputs (CMM).* The analysis of the difference between actual PV measured values (i.e., DC current and voltage) and modeled ones, could predict the electrical fault within a PV system. Predictive models get simulated with aid of computers, to fabricate a theoretical threshold. In other words, a reference value for which all non-equal values, represents a specific fault type. Based on the reference thresholds for fault detection as well as diagnosis procedures, the most likely PV fault to occur can be identified [251]. Under the same perspective, based on an extended correlation function and on the matter model [253] predictive PV faults detection are improved.

*Analysis of solar photovoltaic power generation.* Under dynamic PV systems operations, sometimes exists an inability to distinguish between the effects of undesirable environmental conditions (i.e., clouds, snow




Fig. 12. General diagram of detector scheme [163].

accumulation, etc.), which lead to the same results of fault conditions (i.e., decrease in power generation capacity). Accordingly, for a proper operation description the test method based on the analysis of solar photovoltaic power generation performance reveals a voltage and current based fault detection method. Unlike conventional voltage/current based PV fault detection methods, this scheme is able to distinguish between environmental factors and concrete PV cell faults [69].

**Spread spectrum time domain reflectometry (SSTDR).** The fault is detected using a plot, which in turns is created using the incident and reflected signals. Referred to as “auto-correction plot”, it can be used to identify different faults without the need to disconnect the inverter, as it checks the losses/disturbances between the two signals. The fault is hence identified after the analysis of the plot’s changes [204].

From the same perspective, the incorporation of a fault detection algorithm with SSTDR results in a tool to detect wiring faults even with the existence of impedance varieties throughout the PV system. Such combined system can detect PV ground faults for different PV systems’ architectures and distinguish ground faults that GFDI cannot detect [205].

Similarly, mixing the Time Domain Reflectrometry (TDR) principle with Earth Capacitance Measurement (ECM) a fault detector for disconnection and degradation problem is achieved [247]. The model investigated can be implemented in a PV system in two ways, the first as a fault inspector, the second as a temporary detector to find the

degradations in the PV system.

**Estimating randomness in the voltage signal (ERV).** A Finite Impulse Response Band Pass Filter (FIRBPS) can detect an arc fault in the DC wiring, by estimating the corruption between the output signal with reference to the input signal. If the difference is low/high in comparison with a threshold, arc faults’ existence can be investigated [206].

The randomness in the voltage signal can be estimated as well by means of a modified one-diode model. The one-diode model can be completed by combining the Artificial Bee Colony Optimization (ABCO) and Differential Evolution (DE) algorithms to digitally model a PV array and extract the ABCO-DE parameter [207]. Hence, an I-V curve based PV module fault detector can be launched as a fault detector using ABCO-DE parameter extraction technique.

**Power loss analysis technique (PLA).** PV Faults can be detected based on power losses. This can be done by comparing the monitored data (e.g., DC output power) with the simulation outcomes [242]. Basing on PLA, the faults occurring between the PV array and the converter can be detected [250,243]. Current and voltage ratios can also be used as a skeleton for PLA based fault detection algorithm [244].

**Electrical current–voltage I–V measurement (EM).** PV faults can be detected by depending only on I–V measurements on the output level

[255]. The EM based methods can be as well ameliorated using a micro-controller [256] as a central decision making unit [257]. Such methods are also applicable for GCPV [258], where the derivatives of I-V indicators signal the detection partial shading phenomenon [259]. The addition of other performance indicators (e.g., Fill Factor (FF)), and electrical characteristics (e.g., Shunt Resistance (SR)) to the crude I-V measurements, yields in a wider overview of the PV system's performance [260].

Following the same perspective, by comparing the actual electrical parameters (e.g., voltage, current) from the I-V characteristic curve and theoretical ones, faulty connections can be investigated. The technique relies on analyzing the shape of the I-V characteristic of a PhotoVoltaic Array (PVA) [254].

**Open/short-circuited modules in PV string (OC/SC).** By emphasizing only on the quantity of transducers, such as the number of sensors and power meters, a simple diagnostic technique is achieved [71] to detect the number of open/short circuited modules in a PV string.

Also based on current and voltage indicators, a procedure to calculate the thresholds needed to identify the fault is presented [72] where the PV array that is formed from series and parallel interconnection of PV modules, forms a reference for the thresholds' calculation. For an automatic process to identify OC/SC modules, without any manual interventions, the design's principles and runtime control algorithm are presented [73] to detect the bypass PV cell faults.

**High/low voltage fault diagnosis sections (HV/LV).** The localization of the defected PV modules is done by analyzing the terminal I-V curve, which is divided into high and low voltage fault diagnosis sections. In each section, the healthy and defected working points of string modules are analyzed for both of I-V sides [74] where at the end, any faulty PV module is located by probing into different working points.

Therefore, faulty conditions are regionally characterized inside the detection zones within the I-V characteristic curves [75]. Such zones are defined after subtracting the measured from the maximum set point values of I-V signals.

**Partial/complete shading fault detector (PS/CS).** Using three input variables, such as measured values of array voltage, current and irradiance, a method to detect faults and partial shading under every irradiance situation is established [76]. Such method is able to classify the status of PV arrays into three states as normal, partially shaded, or faulty mode. From another side, and based on DC power measurements, shading faults are detected by focusing on real-time fault diagnosis (i.e., instantaneous power measurement under real PV working conditions). Accordingly, the detection, location, and identification of different types of PV shadows patterns are injected to the output DC power analysis, hence yielding in timely PV fault detections [77].

**Online/offline model (Onn/offm).** After evaluating three PV coefficients (current, voltage, and power coefficients), a two-step model relies first on an offline step that uses a PV simulated model. From the other side, the online step compares real measured PV coefficients with respect to those obtained in offline step. The combination of both online and offline steps results in a differential PV fault detector [78].

**Degradation fault identification based on string current (DFI).** Based on the degradation faults, a fault diagnostic method that takes into account the relationship between the level of degradation and PV plant faults (including current faults), identifies the process between PV degradation and the decrease in a PV string current. In other words, the relationship between the level of PV modules' degradation and the PV plant's faults is investigated. After intentional short circuit scenarios, this method succeeds in identifying different PV faults, that were undetectable when using conventional protection settings [79].

**DC-DC converters fault identification (DC-DCFI).** Apart from MPPTs, old techniques for battery charging control relies on Pulse Width Modulation (PWM). The purpose of PWM is to efficiently extract power from PV arrays while safely charging the battery bank [203], providing various ranges of output stages [248]. Labeled as DC-DC converters, such devices can encounter faults, preventing them from functioning or implying an erroneous behavior [249]. To detect the fault within such devices, the diagnosis can rely on:

- Magnetic component voltages equation [170]
- Short-circuit fault diagnosis [171]
- DC-link current pulse shapes [172]

To conclude on this section, Table 7 encapsulates a comparative assessment of different electrical sub-methods.

#### Signal processing methods (SPM)

PV faults can be detected by the analysis of the output signals, such as current and voltage waveforms, by means of mathematical interpretation and the recordings of measured quantities. The synthesis of the recorded signals gives a clear representation on its status (whether normal or corrupted), what results in various faults detection. This set of methods contains the following sub-methods:

- a) Wavelet transform/Wavelet transform with multi-level decomposition/GCPV fault detector
- b) S-transform
- c) Local Outlier Factor LOF/PVLOF
- d) High Impedance Ground Fault detection HIGF
- e) Generalized local likelihood ratio test algorithm
- f) Differential current based fault detection

**Wavelet transform with multi-level decomposition.** The wavelet transform represents a mathematical modeling for dynamic signals using small waves [144]. It comprehends both frequency and time information simultaneously, which accordingly, it can detect discontinuities in the varying signals that are results to islanding. By correlating discontinuities with respect to time, the localization of islanding is performed for PV systems [145], using five decomposition levels [146].

When the raw wavelet transform is decomposed to a multi-level decomposition wavelet transformation, different faults can be detected using a diagnostic function based on the normalized standard deviation of the wavelet coefficients [153]. Since wavelet-based transforms are accurate at detecting discontinuities in signal waveforms, the random, dynamic, and non-periodic arc faults are efficiently discovered. In a particular case, the wavelet decomposition and arc discrimination are presented as algorithms for an arc detector platform using Digital Signal Processor (DSP) [159]. The fault identification accuracy of a wavelet based PV fault detector can be as well improved by means of wavelet packets using the available data of the PV array's I-V curve [162]. Accordingly, the fault detector becomes then able to distinguish between undesired environmental conditions and PV faults.

When creating a modification on the Wavelet Packet Transform (WPT), the resultant tool becomes able to detect the disturbances resulting from faults in Grid Connected PhotoVoltaic System (GCPVS) [167], as shown in Fig. 13. Such scheme compares the results between WPT and Modified Wavelet Packet Transform (MWPT), yielding in fault identification by means of indices' calculation, such as energy and standard deviation.

**S-transform.** The S-transform is simply an improved version of the previous WT transform, which eliminates the inability of islanding detection under noisy conditions [147,148]. It produces dual axis representation of time: the real and the frequency dependent resolution

**Table 7**

Comparative assessment of different electrical based fault detection methods.

Detection manner	Targeted faults	Scalability of PV system	Detection level	Algorithm-based	Simulation	Model-type
MBDM	1. [187]	GCPV	PV string/module/MPPT	●		
	2. [188]					Deviated error
	3. [189]	RPS		●		Comparative
	4. [191]	Bypass Diode	PV array	●	●	Statistical
	[296]	Open-circuit, short-circuit, mismatch	PV string/module/ MPPT	●		Deviated error
	5. [192]		PV panel			Experimental Predictive
	6. [193,262,263,70]	External, PPUs	DC/DC DC/AC	●		
	7. [194]		PV cells			Deviated error, Mathematical
	8. [195]	Short-Circuit		●		
	9. [196]	External	PV Panel			Experimental Tabulated data
	10. [197]	Shading electrical	PV module	●		
	11. [199]		PV module	●		Deviated error
	12. [166,201]	External	GCPV	●		Statistical Experimental
	13. [163]	Electrical External	Grid-tied	●		
	14. [165]	Electrical	PV array	●		
	15. [251,253]					Deviated error, Experimental Experimental
SSTDR	16. [69]	External	PV array	●	●	Hardware
	[204,205,247]	Electrical External				
ERV	[206,207]	Arc		●		Deviated error
PLA	[242,244,250]		PV array converter	●		
EM	[254–260]	Partial shading	GCPV			Mathematical, software
OC/SC	[71,73]	Electrical	PV string			Hardware
HV/LV	[74,75]	Electrical	PV string			Experimental
PS/CS	[76,77]		PV array			Comparative
Onm/offm	[78]		PV array		●	Comparative
DFI	[79]	External	PV string			Mathematical
DC-DCF	[170–172,248,249, 203]	Electrical	DC/DC	●	●	Real-time Hardware Comparative

which constitutes the imaginary spectra. During an islanding, the voltage sequence becomes negative (backward on the x-y plane). In order to calculate both voltage and current sequences, they are both processed through the S-transform and the spectral energy content is used within the calculation [149].

**Local outlier factor (LOF/PVLOF).** By relying on the instantaneous PV string current, without the need for weather measurement inputs, outlier detection rules are proposed as fault diagnostic methods. Specifically, the ‘Hampel’ identifier and Boxplot rule are the most recommended among other outlier detection based methods to detect faults in PV systems [150].

When discussing the transient state and post-fault behavior in the DC side of the PV system, it can be noticed that some of the hotspots becomes undiscoverable (i.e., the occurring fault is not detectable by an Over Current Protection Device (OCPD)). When outlier statistic rules are applied, false alarms may be caused. Accordingly, the Local Outlier Factor (LOF) is developed inside a PV installation [151]. The addition of a specific algorithm to the LOF based on PV string current (PVLOF) to determine the electrical and shading faults on smaller scaled PV plants,

the fault detection rate is better enhanced where the fault range is identified through seven steps [168].

**High impedance ground fault detection (HIGF).** With cost efficiency improvement, apart from the GFDI and SSTDR based PV fault detection methods, while implying on the Common Mode (CM) model of the full-wave inverter, the High Impedance Ground Fault (HIGF) detection scheme is accomplished. The CM model includes a simplified model for the transformer-less circuitry employed in a PV system architecture. This model includes the CM voltage source, ground capacitors and a capacitive path for an Electro Magnetic Interference (EMI) filter. This model detects the ground faults in PV systems [152].

**Generalized local likelihood ratio test algorithm.** By imposing a change detection algorithm (based on the generalized local likelihood ratio test) on the vector Auto Regressive (AR) model, the time correlation of the faulty signal and signal correlation among different meters (that are employed to measure different output signals of the system) are exploited. Hence this framework detects any sequential change and provide a PV fault detection algorithm [156].




Fig. 13. MWPT flowchart [167].

*Differential current based fault detection.* A differential current-based fault detection, with a fast acting DC switch as an actuator can calculate the distance to fault by calculating the unknown cable resistance, relying on non-iterative Moore-Penrose pseudo inverse technique. In addition, with the special DC cable connected to the PV system, the DC arc faults could also be identified [160].

#### Machine learning (ML) techniques

Enabling PV systems to learn from past experiences of faults existence, Machine Learning (ML) techniques allow such systems to learn new knowledge which is not already pre-programmed. This happens by means of large observations, learning algorithms and data mining [279]. Through this survey, twenty different ML techniques were found as follows:

- a) Takagie-Sugeno Kahn Fuzzy Rule (TSKFR)
- b) Decision Tree algorithm (DT)
- c) Probabilistic Neural Network (PNN)
- d) Multiple-layer ANN
- e) LAterally Primed Adaptive Resonance Theory based Fault Detection (LAPART-FD)
- f) Nelder-Mead optimization technique
- g) Adaptive Neuro-Fuzzy Inference System-Sugeno Model (ANFIS-SM)
- h) Fuzzy logic
- i) Random Forest algorithm (RF)
- j) DC arc faults
  - 1 Based on Tsallis entropy factor
  - 2 Based on electromagnetic radiation

- 3 Based on a joint detection method
- 4 Based on Frequency Spectrum Analysis (FSA) of V/I waveforms
- k) Partially Shaded Modules Fault Detector (PSMFD)
- l) GISTEL combined with fuzzy logic
- m) ANN based fault locator using electrical attributes
- n) String Current Algorithm for OC/SC fault detection
- o) Mamdani-Sugeno fuzzy Logic
- p) Electrical and Partial Shading faults based on kNN rule
- q) Neuro-fuzzy bypass/blocking diodes faults classifier
- r) Third-order polynomial function samples with fuzzy logic classification
- s) Multiresolution signal decomposition
- t) Multiresolution signal decomposition with two-stage support vector machine
- u) Logistic regression

*Takagie-Sugeno kahn fuzzy rule (TSKFR).* This ML based technique inspire learning by training, then occupying the acquainted information into the central processor unit (e.g., microprocessor, microcontroller, etc.). Each new faulty scenario (e.g., decreased power generation) can be referred to an old existing one [221]. This is done using a recursive algorithm that could train a model for several power input/output patterns, to eliminate the difficulty of detecting a fault in changing climatic conditions [222]. To classify the obtained fault within a PV array, Artificial Neural Network (ANN) is used [223].

*Decision tree algorithm (DT).* In the Decision Tree (DT) algorithm, the PV array voltage, current, operating temperature, and irradiance (referred

as attributes) are used in the training and test sets where DT accurately detect and classify PV faults during the test set. This particular process of model training is easy to implement, where the resultant trained model detects PV faults by an accuracy up to 99.98 %, and a classification accuracy of 99.8 % [232].

**Probabilistic neural network (PNN).** To detect and classify PV faults as short/open-circuit in real time, the Probabilistic Neural Network (PNN) is used, which requires specific information from the PV manufacturers' datasheet under Normal Operating Cell Temperature (NOCT) conditions and STCs [233]. Such model is able to represent the characteristics of PV systems under different environmental as well as electrical conditions.

**Multi-layer (ANN).** To overcome the low PV fault detection efficiency of manual checking, and to ensure that the PV system is functioning at its best, a three-layered ANN is injected into a fault diagnostic algorithm [234]. The performance of this three-layered ANN model surpasses the single ANN model which does not provide accurate precision for PV fault detection.

Similarly, and using only a two-layered ANN model, an automatic fault detector can provide detailed fault information with high accuracy about PV fault's types and locations. The multi-layered ANN plays the role of a comparator between both predicted power and the measured one. Based on this diagnosis, tasks are achieved in a way that the open circuit voltage and short circuit current of each PV string are to be determined using analytical equations. The resultant current/voltage data end up categorizing six different fault types [235]. In recent research, the multi-output ANN based technique, has shown the ability to be flexibly incorporated with other PV faults detection method, such as the exploration of the characteristic I-V curve [297]. Other algorithms such as Takagie-Sugeno Kahn Fuzzy Rule Based System (TSKFRBS), three-layered ANN can be found in [224–231].

**Laterally primed adaptive resonance theory based fault detection (LAPART-FD).** To increase the reliability of PV systems an important factor is to design the PV fault detection system with the minimum number of sensors and data acquisition for Reliability Centered Maintenance (RCM) [237]. Accordingly, a Fault Detection and Diagnosis (FDD) tool based on Laterally Primed Adaptive Resonance Theory based Fault Detection (LAPART-FD) can be used. This tool automatically discovers different PV faults, such as temporary mismatch faults on the module level, and it relies on the algorithm which in turns is based on actual and synthetic data tests. The LAPART-FD PV fault detection probability recorded at highest an efficiency value of 86% [236].

**Nelder-Mead optimization technique.** The physical faults (i.e., degradation, partial shading, and short/open-circuit faults) in a PV system can be detected using the I-V characteristics' curves. Such a process requires the implementation of these characteristics on a Kernel extreme learning machine with the addition of Nelder-Mead simplex optimization technique [238]. The resultant fault detections can be simulated on a Single Hidden Layer Feedforward Neural Networks (SHLFNNs) based fault diagnosis model. The algorithm begins with the fundamentals of Extreme Learning Machine (ELM), returns to parameter optimization of the Kernel Extreme Learning Machine (KELM), heads toward data pre-processing and feature selection, and finally, establishes the fault diagnosis model.

**Adaptive neuro-fuzzy inference system-sugeno model (ANFIS-SM).** Combining the Adaptive Neuro-Fuzzy Inference System (ANFIS) with its common architecture, the Sugeno model, a faulty curve can be drawn inside the MPPT rectangle to identify shading faults, such as the reduction in the power extractability area. For this purpose, the model has to have six attributes to work accordingly, such as maximum power point current ( $I_{Mpp}$ ), maximum power point voltage ( $V_{Mpp}$ ), short

circuit current ( $I_{SC}$ ), open circuit voltage ( $V_{OC}$ ), I-V step curve, S1 and S2 [239]. The sets of inputs/outputs are firstly classified, then the ANFIS is generated, to later on trains and tests itself.

**Fuzzy logic.** A fuzzy logic algorithm based model detects PV short circuits faults by taking voltage and power ratios as inputs. The correspondent fuzzy logic consists of voltage/power ratio inputs, where the membership for each input is decomposed into five fuzzy sets. Including machine learning and targeting for Grid Connected PhotoVoltaic System (GCPVS), the proposed system can detect Short Circuit Faults (SCF) by means of theoretical curves of voltage and power ratios. Additionally, the suggested algorithm is capable of detecting hotspots formation in PV system, where its minimum detection accuracy is of 98.8 % [240].

**Random forest algorithm (RF).** A Random Forest (RF) algorithm detects PV array faults using array voltage and string currents. Implemented in Matlab, the system can detect electrical faults as well as temporary mismatch faults, as presented in its flowchart in Fig. 14. The RF combines multiple learning algorithms and takes only real-time values of voltage and current. The results of such algorithm indicate its superiority over the DT algorithm in detecting and classifying a PV array's faults [241].

**DC arc faults.** The detection of DC arc faults can be achieved with a method that uses Fast Fourier Transform (FFT), Short Time Fourier Transform (STFT) and wavelet transforms to create a statistic model under Artificial Neural Network (ANN) routine [59]. The decision making takes its final step after sensing elements and acquaint different PV physical data, while the model simulation is injected for signal processing purposes. Under the same point of view, and by using the time and frequency characteristics of a parallel capacitor current, DC arc faults are detected and classified as series and switch arc faults, where this entire system is upgradable to easily investigate harmonics [264]. Generally, DC arc faults in PV systems are detected according to the four following major schemes:




Fig. 14. The RF flowchart [241].

*Based on Tsallis entropy factor.* The presence of an arc fault is identified by calculating the modified Tsallis entropy factor of the PV panel's current under the quantum probability model theory [154]. When the current fluctuations are random, the algorithm can differentiate between arc and no-arc states, as it does not need any prior information about the PV system working in progress.

*Based on electromagnetic radiation.* Electromagnetic radiation signals can detect DC arc faults with the help of a fourth order Hilbert curve fractal antenna, which captures Electro Magnetic Resonance (EMR) signals resulting from DC arcs [161]. As for the detection parameter of a DC arc fault, the characteristic frequency of the EMR signal distinguishes between PV arc fault from switch operation.

*Based on joint detection method.* To notice series arc faults in PV systems, a joint detection method is provided to an Arc Fault Circuit Interrupter (AFCI). Series PV arc faults are hence recorded by an Intensified Charge Coupled Device (ICCD). The fault definitions and diagnostics are hence derived by a statistic method from the time domain and Short Time Fourier Transform (STFT). For each sub-method a detection variable is proposed for an accurate arc fault identification [158].

*Based on frequency spectrum analysis (FSA) of V/I waveforms.* PV arc faults are related to frequency contents. Due to signal variations induced by environmental conditions (i.e., irradiance, partial shading, etc.) certain lower frequencies limit ranges are not taken into consideration for false tripping [208]. Also, the upper frequency range is also excluded for its interactions with Radio Frequency (RF) noise. Between lower and upper borderlines, the middle frequency range is partially excluded since converters and charge controllers provide harmonics that affect the frequency [209]. The choice of AFCIs activating frequencies must be well studied according to the FFrequency Spectrum Analysis (FRSA), mainly to ignore the disturbances and neglect false tripping [210,211].

*Partially shaded modules fault detector (PSMFD).* By comparing between reference I-V and measured values, the proposed ANN model can detect faulty conditions on PV modules when being partially shaded. If the residual error between the estimated values developed by the ANN model and the measured ones exceeds thresholds values, this indicates that the PV module is subject to PSC [64].

*GISTEL combined with fuzzy logic.* Using experimental parameters (i.e., temperature, irradiance, etc.) PV electrical faults are located, by means of a hybrid model, which is created by combining GIsement Solaire par TELEDetection (GISTEL) model and fuzzy logic based fabricated algorithm. This system estimates solar radiation data using GISTEL, and has its overall efficiency improved by fuzzy logic algorithm [58]. By estimating on solar radiation, the GISTEL model is introduced to remotely locate and inform about any fault occurring on the level of PV battery bank [245], as revealed in Fig. 15. By comparing the estimated solar irradiance data from satellite images with actual DC power output, failures within a PV system can be identified [190,252]. The detection technique relies on comparing the simulated in verses with real measured DC output power.

*ANN based fault locator using electrical attributes.* Based on a Field Programmable Gate Array (FPGA), a sum of eight different PV operating faults are detected, using electrical attributes identification. For a set of PV working conditions, such as solar irradiance and working temperature, electrical attributes (i.e., voltage, current, etc.) are simulated first then later on compared with field measurement [60]. Fig. 16 presents the attributes' calculation for a two-layer ANN algorithm. The attributes are calculated by differential comparison between the physical quantities of voltage, and current data, with the simulated ones. Resultant attributes are injected into the double layer ANN algorithm, in order to classify the detected faults.

*String current algorithm for OC/SC fault detection.* A model for Open Circuit/ Short Circuit (OC/SC) PV fault detection is established using real tabulated data to store backup info in the system. This model relies on Genetic Algorithm, Tabu Search and grey Wolf Optimization algorithms as strategies to program the ANN to be able to detect OC and SC with less needed monitoring parameters [61]. Fig. 17 represents the flowchart for the string current algorithm, where its included error estimation, is the result of comparing between both simulated and actual power received by the solar system, representing hence the fault indicator.

*Mamdani-Sugeno fuzzy logic.* By taking advantages from the ANN





Fig. 15. GISTEL steps [245].



**Fig. 16.** Two-algorithm ANN proposed fault classifier [60].

topology and fuzzy logic system interface combination, an environmental as well as electrical PV fault detector is created. The method begins by data acquisition from the PV plant, modeling the DC side of the PV system using five-parameter model, creation of power and voltage ratios, to finally implement the ANN model. The suggested algorithm is able to detect different PV faults such as faulty PV modules and PSC with a maximum detection accuracy of 92.1 % [65].

**Electrical and partial shading faults based on kNN rule.** A Fault Detection and Classification (FDC) technique relies on machine learning, dictated by the k-Nearest Neighbors (kNN) rule, traces the abnormalities within the I-V characteristic curve. The FDC models and simulates the PV system using STCs and NOCT, yielding in PV fault localization and characterization. The absolute error between the measured data and the developed in the range 0.61–6.5 % with an average fault classification's accuracy of 98.70 % [67].

**Neuro-fuzzy bypass/blocking diodes faults classifier.** A neuro-fuzzy classifier detects faults at the PV cells' level, such as series losses, bypass and blocking diode faults, basing on electrical parameters such as maximum power, and open circuit voltage deviations. The corresponding fault identification/discrimination processes take into consideration four electrical parameters, where the classifier has shown an ability to work with different irradiance/temperature levels [198].

**Third-order polynomial function samples with fuzzy logic classification.** After that different attributes are measured, a third-order polynomial function is used to classify higher and lower detection limits for PV voltage and power ratios faults. Samples are aftermath processed by a fuzzy logic classification to gain one output membership function. The correspondent maximum detection accuracy for this algorithm is equal to 95.27 % [202].

**Multiresolution signal decomposition.** In a cascaded PV system, a fuzzy inference system indicates if a fault has occurred by giving an order decision to a multiresolution signal decomposition technique which in turns extracts the needed necessary features. Such method is based on a pattern recognition approach. The system uses fuzzy logic to interpret the monitored data and an online resource to acknowledge the faults. The suggested fault detection scheme is able to detect the DC-sided short

circuit fault of a PV system, which are generally undetectable under low irradiance conditions [157].

**Multi-resolution signal decomposition with two-stage support vector machine.** To reduce the fire hazards due to faulty PV currents (being undetected in low irradiance conditions) with the presence of a MPPT, the multi-resolution signal decomposition for fault extraction is combined with two-stage Support Vector Machine (SVM) classifiers to detect the occurrence of Line-to-Line (L-L) faults. The required data for the algorithm is obtained from the total voltage and current from a PV array, with other labeled data to train the SVM. This method is found to be economical for requiring a smaller number of sensors, yet effective in detecting L-L faults under various operating conditions [186].

**Logistic regression.** Based on ML, all of open-circuit, short-circuit, and mismatch faults can be predictively (i.e., during early stages of formation) identified by means of an algorithm relying on logistic regression with cross validation. Trained with a yearly data of irradiance and temperature, the suggested algorithm shows an accuracy of 97.11 % in detecting the specified types of PV faults, with a fast operational speed [298].

#### Insulation monitoring relays (IMR)

A continuous monitoring measurement is held between Current Carrying Conductor (CCC) and ground: whenever the resulting resistance value is smaller than a threshold, an alarm is set, thus informing that a short circuit exists in the PV system. Such instrumentation is effective in detecting short circuited paths in PV systems, preventing further electrical complications [212].

#### Heat exchange and temperature based model (HET)

The Heat Exchange and Temperature based model (HET) detects a PV fault according to the change in the PV module temperature, due to the correlation between a PV fault and its temperature changing like in the case of hotspots. All heat exchange is scheduled within the fault detection technique. Using a finite element method, the physical defects of different types of PV cells are modeled [219,220].

#### Climatic data independent technique (CDIT)

The Climatic Data Independent Technique (CDIT) is attributes-




Fig. 17. Solution flowchart [61].

independent, where it does not need any solar irradiance, temperature, humidity, and other climatic data. It relies coarsely on external meters as Inductance Capacitance Resistance (ICR) meters, Earth Capacitance Measurement (ECM) [265], Time Domain Reflectometry (TDR) [266], and ANalysis Of VAriance (ANOVA) [267] techniques. Fault detection is hence accomplished after analyzing the different effects of signal generators on the PV system, without any dependability on climatic factors, such as irradiance and temperature.

#### Infrared/thermal imaging (In/ThI)

Across a resistor, any power loss is noted as joule loss, where current passed is transformed into heat. Similarly, any loose contact shortening across PV cells can result to the same effect: loss in terms of overheating where affected cells produce less current as compared with normal ones and become reverse biased. Through temperature monitoring, the fault can be identified, in two ways: Forward Bias Imaging/Reverse Bias Imaging (FBI/RBI). Each of FBI/RBI techniques has its private method

for calculating the shorted/faulty current in order to identify hotspots creation. This can be done in both methods by using Infra-Red (IR) cameras to record IR images, then performing image processing which results in identifying the PV fault nature and locating it within the PV system [268].

As a first approach, to identify the PV fault's type, and its frequency of occurrence, an IR thermography considers the panels' attributes under investigation, leading to fault identification [269], with the ability to investigate the existence of dust accumulated particles [261].

For hotspot cells exerting a reverse voltage with opened bypass diode, the inability to identify which PV module is defected, is solved by a technique described in the reference [270]. PV modules correspondingly do not need to be tested individually, where the detection relies on the observation of the total modules' surface temperature changes. Hence, the abnormal PV modules with open bypass diodes are identified using DC power supply and an IR camera [270].

To acknowledge the PV modules' actual temperature values, a

thermal camera is connected in cascade with electrical sensor which measure different V-I values. Therefore, a diagnostic model can identify different PV faults using the established parameter based model, which in turn is composed of an electrical model expressed by an energy balance equation of a PV module [271]. The measured parameters are compared to a reference performance estimation model, and the derived error can indicate the occurrence of a PV fault. Fig. 18 exposes the process of fault identification using a thermal camera over a PV module. A model parameter calculation is thus achieved by combining the data captured from the electrical sensors with the values captured from the thermal camera. Fault diagnosis is hence completed after evaluating the performance estimation model [271].

#### *Electroluminescence imaging (EI)*

To detect the aging process of PV modules, related to time entropy or reactions with the front glass cover, 2D-luminescence imaging can detect any defected PV modules by reflecting inhomogeneous luminescence patterns [272]. This type of detection reveals the degradation pattern of the encapsulation material, which gives a clear idea about the modules' lifetime energy output efficiency. The amount of light harvested by the PV modules, and its translation into DC power generation, reflects an indicator upon the health of PV modules [273].

When the excited carriers recombine within a PV cell, their emitted photons retrieve the EI imaging. An EI effect happens then by means of an injected current, which in turn yields to the carriers' excitation [275]. The Photo Luminescence (PL) effect can also give a clear idea about the amount of light beam being absorbed by the PV modules [276]. The emission intensity of EI images is proportional to the PV current density and carrier lifetime, hence the ability to detect non-uniform currents sourced from poor PV inter-connections.

#### *Ultrasonic inspection method (UIM)*

When cracks/micro-cracks are present in the cells of a PV module, their response to ultrasonic vibrations followed by an excitation, is different from healthy cells. There are two modes to detect cracked PV cells by Ultrasonic Inspection Method (UIM): pulse-echo and transmission [274]. An ultrasonic transducer is present in both techniques to

generate and distribute the pulses. In the first mode, the pulses are passed through a PV module to record the reflected pulses from the defected cells. In the second mode, the attenuated signals are recorded, yielding in locating the defected PV cells [200].

#### *Lock in thermography (LIT)*

Lateral PV power loss is found using the Lock In Thermography (LIT) after injection of discontinuous pulsed currents into solar cells. Corrupted cells respond to these pulsed currents by appearing as local temperature generators, where by using different modulations, the defected PV cells appear. The pre-breakdown sites' visibility in LIT was better than that in reverse-bias EI [277].

The different fault detection methods of IMR, HET, CDIT, In/ThI, UIM, EI and LIT share all in common the need for external devices (transducers, cameras, etc.) in order to detect a fault. This fact could add extra financial burden on the fault detection prototype what decreases the cost efficiency of the PV system.

#### **Discussion and recommendation**

The surveyed types of PV faults would present a rich background to be fed into any PV fault detector database. As compared to other PV faults recurrence dataset, as in the work of [295], this paper did not estimate/record the frequency of occurrence of different PV faults, as posted in Table 8: the recorded data from real PV systems under operation, concerning the frequency of occurrence of PV faults would be treasurable for PV fault detection methods' databases, especially the ones classified under the AIT. The presented data in Table 8 for instance [295], would accelerate the learning paths for ML based PV fault detection methods, requiring the last for less self-learning processes. On the other side, however, the work in [295] focused only on specific PV faults and did not take into consideration broader types of faults, such as MPPT and inverter failures, contrarily to the surveyed PV faults in this paper.

Concerning the fault detection methods, not a set of techniques can replace the other. For instance, AC faulty scenarios cannot be detected by means of DC sensors, transducers, or any form of DC data capturers. Likewise, for DC faulty conditions, CBs, RCDs and GFDIs for example cannot trip or declare any form of fault detection based on continuous signals. From another side, online (real-time) PV fault diagnosis offers a higher fault detection accuracy than offline diagnosis, but in turns require extra hardware equipment in order to be able to cope with the larger amount of instantaneous operational data from the PV system. To only implement one form of fault detection techniques leaves a full region within the PV system (whether it was the AC zone or DC zone) unmonitored with a probability to excessively have repeated faulty scripts.

Recent research in the field of PV faults detection methods emphasize on identifying untraditional PV faults. For example, by means of a wave shape based statistical algorithm, which analyzes the superimposed PV array power curve shape using the kurtosis function, short-circuit faults (i.e., electrical) of low values can be detected. Other types of faults (i.e., internal, external) can be as well detected, such as partial shading, blocking diodes, and others [282]. By following the same concern of detecting PV faults with small magnitudes, the triple exponentially weighted moving average statistical monitoring technique, when fused with other latent variable regression methods shows a good efficiency. Such incorporated method can detect string faults, inverter disconnection, circuit breakers faults, short circuit faults and others, from an actual 9,54 kW PV plant [283]. As a form of PV preventive maintenance, the statistical monitoring approach, initiated by a Hartigan's dip test, can identify any PV abnormal operating conditions, priorly than becoming actual failures [284], as similar is the case for the work in [285] where the suggested models offer quick and accurate prediction of different fault conditions. From another perspective, both DC and AC parts of a PV system can be monitored through a





Fig. 18. Thermal imaging [271].

**Table 8**

PV faults occurrence recording data [295].

Frequency of occurrence (number of times)	Time $t$ (in years: duration of the PV system installation)									
	1	2	3	4	5	6	7	8	9	10
1	Corrosion	Degradation, burn marks, defective backsheet	Discoloration, corrosion	Delamination, cell cracks, burn marks	Disconnections, discoloration	Corrosion, disconnections, degradation, burn, delamination	Corrosion	Discoloration, delamination	–	Defective bypass diode
1.5	–	–	–	–	–	degradation	–	Burn marks	–	–
2	Potential induced shunts	Defective bypass diode, Corrosion	Cell cracks, bypass diode	Bypass diode	–	–	–	–	–	–
2.5	Glass breakage,	–	–	–	–	–	–	–	–	–
3	–	–	–	–	Disconnections	–	–	–	–	–
3.5	–	–	–	–	–	Cell cracks	–	–	–	–
4	Cell cracks	Cell cracks	Degradation	Degradation	–	–	–	Glass breakage, bypass diode	–	–

**Fig. 19.** The suggested AC-DC fault detection general overview.

nonparametric approach using kernel density estimation, where different types of faults can be detected, such as string fault, partial shading, and loss of energy due to an inverter's disconnection [286]. Similarly, faults at both the DC side of the PV system, such as soiling and partial shading, as well as on its AC side, such as circuit breaker faults and inverter disconnection, can be detected via parametric models with double exponentially smoothing based scheme [287]. Contrarily, in order to have better focused PV faults detection on the DC side of a PV system (e.g., short circuit, open circuit, and shading faults), the generated residuals of current, voltage, and power, capture the difference between the actual and maximum power point of the same quantities. Successively, when the resulting fault indicators are subjected to an exponentially weighted moving average algorithm, the stated DC faults are identified [169], and better acknowledged due to the reduced measurement noise after the usage of a multiscale representation [289].

Despite the numerous advantages presented by the recent PV faults detection research field, very few methods from the massive presented literature review, present any solution in troubleshooting the PV system from its both AC and DC sides. Under working conditions, a PV system may encounter having multiple faults in both AC as well in DC regions. Accordingly, and for an efficient fault tracking process, a dual AC-DC fault detector is recommended to be installed in the PV system as shown in Fig. 19.

The dual fault detector shown in Fig. 19, implies some sensors/transducers installation at the DC side of the PV system in order to capture various DC faults. On the other hand, RCBOs and different AC switchgear can be coordinated with remoted applications, IoT-based (Internet of Things) to remotely access to AC-sided faults. In other terms, future directions are recommended based on the utilization of addressable protective switchgear for both sides of the PV systems, that can be remotely networked, controlled, and current-state acknowledged. Such protective devices can for example be assigned to a local area network, and accessed via internet protocol addressing (as an example), with an ability for a remote access through a virtual private network certification. A registered user can hence configure and read the different states of the AC as well as the DC protective switchgear. Therefore, the actual states of these tripping devices can hence be network sent to a SCADA, over the same local area network, through a data block messenger that actually carries the "status" of the tripping devices (i.e., open contacts reflect the presence of a fault through a logic TRUE; closed contacts reflect normal working conditions through a logic FALSE). Other information (i.e., integer data type) can be as well carried to the SCADA from other protective devices, such as under/over-voltage sensors, temperature sensors (i.e., to acknowledge the states of electrical cables overheating), and power factor recorders.

The SCADA in turns gather the processed acquainted data with a distinguishing algorithm between the two-sided faults zones in the PV system's regions, and set accordingly the corresponding needed fault alarms, signals, and switching mechanisms to declare the detected fault. The obtained fault type can be graphically represented on a Liquid Crystal Display (LCD) or any Human Machine Interface (HMI), with an ability to set sirens for heavy/risky faults. Accordingly, the bottom line of the suggested AC-DC dual fault diagnostic tool for PV systems consists of network addressable protective switchgear for both sides of the PV systems, connected (database-wise) to a SCADA (that can be programmed via visual basic application for example) through a data block carrier over the same network. Each zone of the PV system can be uniquely graphed, where each protective device would have its own representative graphical images, that is to be animated according to the real-time status of the device (i.e., intermittent red colored animations denote the presence of a short circuit, where static green colors indicate a non-tripping mechanism, for example). With the aforementioned suggested architecture, such fault diagnostic tool can be set to be controlled by means of programmable logic controllers, which in turn can be remotely accessed via web servers, thus enabling the ability for PV system fault detection/monitoring from smartphones.

The proceeding step which comes after the fault identification and detection is the corresponding fault maintenance technique, that is classified under four different topologies [280], for different types of PV cell raw materials [281]:

- Corrective maintenance
- Urgent case maintenance
- Preventive maintenance
- Predictive maintenance

**Table 9** encapsulates a comparative characterization of different PV maintenance techniques. The different PV faults acknowledgement, with various fault detection methods, and fault maintenance represent a complete package, which yields in a more robust performance for PV systems.

## Conclusions

PV systems are a lifetime investment with a great cost of installation. In order to grant the predicted energy saving during a PV system's lifecycle, and to ensure a reliable payback period, the PV system is assumed to work optimally, with no faults occurrence. However, PV systems often interact with various faulty scenarios that reduce their competencies and prohibit their cost effectiveness.

Throughout this paper, the different PV faults were classified as either internal, external, or electrical faults. Internal faults are mainly due to the manufacturer's defects: the impurities in the PV cells raw material, as well as the low semiconductor's quality used during the fabrication process, yield eventually to further complications under the operation of the PV system. With that being said, their probability of occurrence is indirectly proportional to the fabrication's quality class (i.e., higher PV raw materials reflect lower probability of internal faults occurrence), where they affect the performance of the PV system from its DC side. On the other hand, external faults are directly related to undesired environmental conditions: weather fluctuations, accumulation of dust, soil, and snow, for example, affect the proper functioning of PV system also from its DC side: the PV cells are not able as supposedly to convert light into a DC voltage, due either to the presence of physical obstacles (i.e., temporary mismatch faults), or to the damage induced on the level of the PV modules (i.e., permanent mismatch faults). External faults are the most common for PV systems, mainly due to the chaotic and random aspects of the PV systems' environmental surroundings. In addition, electrical fault can affect both the DC and the AC sides of the PV system: possessing a spontaneous criteria, electrical faults provoke abnormal quantities of currents (i.e., in the events of short circuits) and voltages (i.e., in the event of open circuits, voltage superimposing, etc.), thus affecting furtherly the load dissipation, as well as the safety of the

**Table 9**  
Overview of different maintenance methods [280].

Maintenance strategy	Description	Goals
Corrective	Takes place after a failure event, and includes fixing, repairing, replacing and other correction tasks	Make corrections to avoid major equipment damaging
Urgent case	Takes places after a major force event, and requires fixing, replacing and other correction tasks	Make corrections in a hurry, prior to anything else to prevent bigger damages
Predictive	Evaluates the conditions of the system by performing scheduled/continuous real-time monitoring	Predict the optimal time to perform maintenance and hence elevating the equipment uptime
Preventive	Performs maintenance on a pre-scheduled time interval regardless of the condition	Reduce the possibility of any failure

wiring circuits.

The presented PV fault characterization helped in investigating the applicability of a corresponding fault detection system on both sides of a PV system. The DC-sided fault detection methods, on the first hand, in majority rely on sensory data acquisition- the statistical monitoring methods for example collect the PV performance data, that when compared to a reference, a fault can be detected. Electrical based methods are the most abundant in the literature, where such methods can detect each of the three major types of faults. Signal processing and ML based techniques are the most complex, since they imply on waveforms interpretation and data mining respectively. The easiest DC detection methods correspond to IMR, HET, CDIT, In/ThI, EI, UIM, LIT, since they are based only on installing readily available hardware. For that, such techniques, when incorporated with a SCADA, would present the most efficient and reliable PV fault detection method at the DC side of a PV system. .

As concerning the PV fault detection methods at the AC side of the PV system, unlike AIT and RDM based methods that are complex to implement and require heavy computational facilities respectively, the IDT, RCD, GFDI have more priority for installation in a PV system, while at the same time being the easiest to adapt: higher reliability is presented using these techniques, since they rely only on ready equipment. The keynote is that newer RCD and GFDI and other relevant equipment are fabricated with a small embedded system in each, where they can be address assigned and remote controlled (i.e., networked). With that being said, such devices can be graphically assigned to the SCADA, in a way that when an RCD trips for example, a site operator can graphically visualize this issue, directly locate the source of error, and be able to send remote alarms for further fault acknowledgement. Therefore, through this paper, it has been seen that a dual AC-DC fault detection system can be easily applied to a PV system, simply by the usage of fault indicator devices (e.g., RCD, RCBO, MCB, LIT, etc.) that possess the feature of remote addressing (e.g., through local area network, peer-to-peer communication, etc.). Such devices, hence, serving on both sides of the PV system, can be thus reflected to a visual SCADA which also have its own set of data blocks to be networked with. The tripping mechanisms can be hence inspected remotely, while directly localizing the source of error, for further on-site commissioning.

The reliability, durability, and sustainability of PV systems are greatly improved by continuous monitoring, and faults' identification processes. When equipped with fault detecting tools, like the one suggested in this paper, PV systems ensure robust power production, and a safer performance.

## Declaration of Competing Interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

## Data availability

No data was used for the research described in the article.

## References

- [1] R. Venkateswari, S. Sreejith, Factors influencing the efficiency of photovoltaic systems, *Renew. Sustain. Energy Rev.* 101 (2019) 376–394.
- [2] S. Sulaemany, E. Brown, R. Quispe-Abad, N. Muller, Floating PV system as an alternative pathway to the amazon dam underproduction, *Renew. Sustain. Energy Rev.* 135 (2019) 1–5.
- [3] K.K. Jaiswal, C.R. Chowdhury, D. Yadav, R. Verma, S. Dutta, K.S. Jaiswal, B. Sangmesh, K.S.K. Karuppasamy, Renewable and sustainable clean energy development and impact on social, economic, and environmental health, *Energy Nexus* 7 (2022), 100118.
- [4] M.H. Shubbak, Advances in solar photovoltaics: technology review and patent trends, *Renew. Sustain. Energy Rev.* 115 (2019) 1–5.
- [5] M. Adar, M.-A. Babay, S. Touairi, Y. Najih, M. Mabrouki, Experimental validation of different PV power prediction models under Beni Mellal climate, implications for the energy nexus, *Energy Nexus* 5 (2022), 100050.
- [6] N. Yarar, M. Yagci, S. Bahceci, A. Onen, T.S. Ustun, Artificial neural networks based harmonics estimation for real university microgrids using hourly solar irradiation and temperature data, *Energy Nexus* 9 (2023), 100172.
- [7] M. Dida, S. Boughali, D. Bechki, H. Bouguettaa, Output power loss of crystalline silicon photovoltaic modules due to dust accumulation in Saharan environment, *Renew. Sustain. Energy Rev.* 124 (2020) 1–3.
- [8] A. Juaidi, H.H. Muhammad, R. Abdallah, R. Albatayneh, F. Kawa, Experimental validation of dust impact on-grid connected PV system performance in Palestine: an energy nexus perspective, *Energy Nexus* 6 (2022), 100082.
- [9] T.K. Roy, M.A.H. Pramanik, S.K. Ghosh, Design of an integral terminal-based sliding mode controller for PV and BESS-based DC microgrids, *Energy Nexus* 7 (2022), 100130.
- [10] K. Osmani, A. Haddad, T. Lemenand, B. Castanier, M. Ramadan, An investigation on maximum power extraction algorithms from PV systems with corresponding DC-DC converters, *Energy* 224 (2021), 120092.
- [11] K. Osmani, A. Haddad, H. Jaber, T. Lemenand, B. Castanier, M. Ramadan, Mitigating the effects of partial shading on PV system's performance through PV array reconfiguration: a review, *Therm. Sci. Eng. Prog.* 31 (2022), 101280.
- [12] K. Osmani, M. Ramadan, A. Haddad, T. Lemenand, B. Castanier, An overview on the use of phase change material (PCM) for PV cooling, *Key Eng. Mater.* 922 (2022) 3–9.
- [13] K. Osmani, M. Ramadan, T. Lemenand, B. Castanier, A. Haddad, Optimization of PV array tilt angle for minimum levelized cost of energy, in: *Computers & Electrical Engineering*, 96, Elsevier, 2021. Part A 107474.
- [14] S.R. Madeti, S.N. Singh, Monitoring system for photovoltaic plants: a review, *Renew. Sustain. Energy Rev.* 67 (2017) 1180–1207.
- [15] P. Hacke, S. Lokanath, P. Williams, A. Vasan, P. Sochor, G.S.T. Mani, H. Shinohara, S. Kurtz, A status review of photovoltaic power conversion equipment reliability, safety, and quality assurance protocols, *Renew. Sustain. Energy Rev.* 82 (2018) 1097–1112.
- [16] S. Shivashankar, S. Mekhilef, H. Mokhlis, M. Karimi, Mitigating methods of power fluctuations of photovoltaic (PV) sources – a review, *Renew. Sustain. Energy Rev.* 59 (2016) 1170–1184.
- [17] A. Colli, Failure mode and effect analysis for photovoltaic systems, *Renew. Sustain. Energy Rev.* 50 (2015) 804–809.
- [18] A. Dhoke, R. Sharma, T.K. Saha, An approach for fault detection and location in solar PV systems, *Sol. Energy* 194 (2019) 197–208.
- [19] T. Pei, J. Zhang, L. Li, X. Hao, A fault locating method for PV arrays based on improved voltage sensor placement, *Sol. Energy* 201 (2020) 279–297.
- [20] Y. Zhao, B. Lehman, J.F. de Palma, J. Mosesian, R. Lyons, Fault analysis in solar PV arrays under: low irradiance conditions and reverse connections, in: *Proceedings of the 37th Photovoltaic Specialists' Conference (PVSC)*, IEEE, 2011, pp. 2–4.
- [21] M. Davarifar, A. Rabhi, A. El-hajjaji, Comprehensive modulation and classification of faults and analysis their effect in DC side of photovoltaic system, *Energy Power Eng.* 5 (2013) 230–236.
- [22] A. Triki-Lahiani, A.B.B. Abdelghani, I. Slama-Belkhodja, Fault detection and monitoring systems for photovoltaic installations: a review, *Renew. Sustain. Energy Rev.* 82 (2018) 2680–2692.
- [23] E. Diaz-Dorado, J. Cidras, C. Carrillo, Discretized model for partially shaded PV arrays composed of PV panels with overlapping bypass diodes, *Sol. Energy* 157 (2017) 103–115.
- [24] S.N. Deshkar, S.B. Dhale, J.S. Mukherjee, T.S. Babu, N. Rajasekar, Solar PV array reconfiguration under partial shading conditions for maximum power extraction using genetic algorithm, *Renew. Sustain. Energy Rev.* 43 (2015) 102–110.
- [25] B.I. Rani, G.S. Ilango, C. Nagamani, Enhanced power generation from PV array under partial shading conditions by shade dispersion using Su Do Ku configuration, *IEEE Trans. Sustain. Energy* 4 (2013) 594–601.
- [26] J.P. Ram, N. Rajasekar, A new global maximum power point tracking technique for solar photovoltaic (PV) system under partial shading conditions (PSC), *Energy* 118 (2017) 512–525.
- [27] J.P. Ram, N. Rajasekar, A novel flower pollination based global maximum power point method for solar maximum power point tracking, *IEEE Trans. Power Electron.* 32 (2017) 8486–8499.
- [28] X.H. Nguyen, Matlab/Simulink based modeling to study effect of partial shadow on solar photovoltaic array, *Environ. Syst. Res.* 4 (2015) 1–5.
- [29] Y. Hu, J. Zhang, W. Cao, J. Wu, G.Y. Tian, S.J. Finney, J.L. Kirtley, Online two section PV array fault diagnosis with optimized voltage sensor locations, *IEEE Trans. Ind. Electron.* 62 (2015) 7237–7246.
- [30] N. Heidari, J. Gwamuri, T. Townsend, J.M. Pearce, Impact of snow and ground interference on photovoltaic electric system performance, *IEEE J. Photovolt.* 5 (2015) 1680–1685.
- [31] M.S. Arani, M. Akhavanhejazi, The comprehensive study of electrical faults in PV arrays, *J. Electr. Comput. Eng.* (2016), 8712960.
- [32] A.M. Omer, Renewable energy resources for electricity generation in Sudan, *Renew. Sustain. Energy Rev.* 11 (2007) 1481–1497.
- [33] V. Sharma, S.S. Chandel, Performance and degradation analysis for long term reliability of solar photovoltaic systems: a review, *Renew. Sustain. Energy Rev.* 27 (2013) 753–767.
- [34] D.S. Pillai, N. Rajasekar, A comprehensive review on protection challenges and fault diagnosis in PV systems, *Renew. Sustain. Energy Rev.* 91 (2018) 18–40.
- [35] H. Liu, M. Mitolo, J. Qiu, Ground-fault loop impedance calculations in low-voltage single-phase systems, *IEEE Trans. Ind. Appl.* 50 (2013) 1331–1337.

- [36] W.I. Bower, J.C. Wiles, Analysis of grounded and ungrounded photovoltaic systems, in: Proceedings of 1994 IEEE 1st World Conference on Photovoltaic Energy Conversion - WCPEC, IEEE, 1994, pp. 809–812.
- [37] D.E. Collier, T.S. Key, Electrical fault protection for a large photovoltaic power plant inverter, in: Conference Record of the Twentieth IEEE Photovoltaics Specialists Conference, 2002.
- [38] S.E. Forman, Performance of experimental terrestrial photovoltaic modules, *IEEE Trans. Reliab.* 31 (1982) 235–245.
- [39] Y. Zhao, R. Lyons, Ground-fault analysis and protection in PV arrays, in: Proceedings of Photovoltaics Protection, 2011, pp. 1–4.
- [40] A. McEvoy, T. Markvart, L. Castaner, Practical Handbook of Photovoltaics: Fundamentals and Applications, 2nd edition, Elsevier, 2011.
- [41] M.K. Alam, F. Khan, J. Johnson, J. Flicker, A comprehensive review of catastrophic faults in PV arrays: types, detection, and mitigation techniques, *IEEE J. Photovolt.* 5 (2015) 982–997.
- [42] M. Cotterell, 2012. Installation guidelines: electrical. Practical Handbook of Photovoltaics, 2nd edition, chapter 3. pp. 819–34.
- [43] Y. Zhao, J.F. de Palma, J. Mosesian, R. Lyons, B. Lehman, Line-line fault analysis and protection challenges in solar photovoltaic arrays, *IEEE Trans. Ind. Electron.* 60 (2012) 3784–3795.
- [44] D.S. Pillai, R. Natarajan, A compatibility analysis on NEC, IEC, and UL standards for protection against line-line and line-ground faults in PV arrays, *IEEE J. Photovolt.* 9 (2019) 864–871.
- [45] S.R. Madeti, S.N. Singh, A comprehensive study on different types of faults and detection techniques for solar photovoltaic system, *Sol. Energy* 158 (2017) 161–185.
- [46] K.M. Armijo, J. Johnson, M. Hibbs, A. Fresquez, Characterizing fire danger from low power PV arc-faults, in: 2014 IEEE 40th Photovoltaic Specialist Conference (PVSC), IEEE, 2014.
- [47] J. Johnson, J. Kang, Arc-fault detector algorithm evaluation method utilizing prerecorded arcing signatures, in: 2012 38th IEEE Photovoltaic Specialist Conference, IEEE, 2012, pp. 1378–1382.
- [48] J. Flicker, J. Johnson, Electrical simulations of series and parallel PV arc-faults, in: 2013 IEEE 39th Photovoltaic Specialist Conference (PVSC), IEEE, 2013, pp. 3165–3172.
- [49] D.A. Dini, P.W. Brazis, K.H. Yen, Development of arc-fault circuit-interrupter requirements for photovoltaic systems, in: 2011 37th IEEE Photovoltaic Specialist Conference, IEEE, 2012, pp. 1790–1794.
- [50] F. Chan, H. Calleja, Reliability: a new approach in design of inverters for PV systems, in: 2006 IEEE International Power Electronics Congress, IEEE, 2006, pp. 1–6.
- [51] A. Omazic, G. Oreski, M. Halwachs, G.C. Eder, C. Hirschl, L. Neumaier, G. Pinter, M. Erceg, Relation between degradation of polymeric components in crystalline silicon PV module and climatic conditions: a literature review, *Sol. Energy Mater. Sol. Cells* 192 (2019) 123–133.
- [52] K. Osmani, A. Haddad, M. Alkhedher, T. Lemenand, B. Castanier, M. Ramadan, A novel MPPT-based lithium-ion battery solar charger for operation under fluctuating irradiance conditions, *Sustainability* 15 (12) (2023), 9839.
- [53] Z. Alam, L. Khan, Q. Khan, S. Ullah, S. Ahmed, M.A. Khan, Integrated fault-diagnoses and fault-tolerant MPPT control scheme for a photovoltaic system, in: 2019 15th International Conference on Emerging Technologies (ICET), IEEE, 2020, pp. 2–5.
- [54] K. Osmani, M. Alkhedher, M. Ramadan, D.S. Choi, L.K.B. Li, M.H. Doranegard, A.-G. Olabi, Recent progress in the thermal management of lithium-ion batteries, *J. Clean. Prod.* 389 (2023), 136024.
- [55] K.-H. Chao, C.-T. Chen, A remote supervision fault diagnosis meter for photovoltaic power generation systems, *Measurement* 104 (2017) 93–104.
- [56] R. Benkercha, S. Moulahoum, Fault detection and diagnosis based on C4.5 decision tree algorithm for grid connected PV system, *Sol. Energy* 173 (2018) 610–634.
- [57] W. Chine, A. Mellit, A.M. Pavan, S.A. Kalogirou, Fault detection method for grid-connected photovoltaic plants, *Renew. Energy* 66 (2014) 99–110.
- [58] M. Tadj, K. Benmouiza, A. Cheknane, S. Silvestre, Improving the performance of PV systems by faults detection using GISTEL approach, *Energy Convers. Manage.* 80 (2014) 298–304.
- [59] S. Lu, B.T. Phung, D. Zhang, A comprehensive review on DC arc faults and their diagnosis methods in photovoltaic systems, *Renew. Sustain. Energy Rev.* 89 (2018) 88–98.
- [60] W. Chine, A. Mellit, V. Lugh, A. Malek, G. Sulligoi, A.M. Pavan, A novel fault diagnosis technique for photovoltaic systems based on artificial neural networks, *Renew. Energy* 90 (2016) 501–512.
- [61] A. Hazra, S. Das, M. Basu, An efficient fault diagnosis method for PV systems following string current, *J. Clean. Prod.* 154 (2017) 220–232.
- [62] Y. Wu, Z. Chen, L. Wu, P. Lin, S. Cheng, P. Lu, An intelligent fault diagnosis approach for PV array based on SA-RBF kernel extreme learning machine, *Energy Proc.* 105 (2017) 1070–1076.
- [63] M. De Bendetti, F. Leonardi, F. Messina, C. Santoro, A. Vasilakos, Anomaly detection and predictive maintenance for photovoltaic systems, *Neuro Comput.* 310 (2018) 59–68.
- [64] H. Mekki, A. Mellit, H. Salhi, Artificial neural network-based modelling and fault detection of partial shaded photovoltaic modules, *Simul. Modell. Pract. Theory* 67 (2016) 1–13.
- [65] M. Dhimish, V. Holmes, B. Mehrdadi, M. Dales, Comparing Mamdani Sugeno fuzzy logic and RBF ANN network for PV fault detection, *Renew. Energy* 117 (2018) 257–274.
- [66] F.A.O. Polo, J.F. Bermejo, J.C.G. Fernandez, A.C. Marquez, Failure mode prediction and energy forecasting of PV plants to assist dynamic maintenance tasks by ANN based models, *Renew. Energy* 81 (2015) 227–238.
- [67] S.R. Madeti, S.N. Singh, Modeling of PV system based on experimental data for fault detection using kNN method, *Sol. Energy* 173 (2018) 139–151.
- [68] T. Shimakage, K. Nishioka, H. Yamane, M. Nagura, M. Kudo, Development of fault detection system in PV system, in: Proceedings of 33rd International Telecommunications Energy Conference (INTELEC), IEEE, 2011, pp. 1–5.
- [69] X. Xu, H. Wang, X. Xu, Y. Zuo, Method for diagnosing photovoltaic array fault in solar photovoltaic system, in: Proceedings of Asia-Pacific Power and Energy Engineering Conference (APPEEC), IEEE, 2011, pp. 1–5.
- [70] M. Omana, D. Rossi, G. Collepalumbo, C. Metra, F. Lombardi, Faults affecting the control blocks of PV arrays and techniques for their concurrent detection, in: Proceedings of International Symposium on Defect and Fault Tolerance in VLSI and Nanotechnology Systems (DFT), IEEE, 2012, pp. 199–204.
- [71] N. Gokmen, E. Karatepe, B. Celik, S. Silvestre, Simple diagnostic approach for determining of faulted PV modules in string based PV arrays, *Sol. Energy* 86 (2012) 3364–3377.
- [72] S. Silvestre, M.A. da Silva, A. Chouder, D. Guasch, E. Karatepe, New procedure for fault detection in grid connected PV systems based on the evaluation of current and voltage indicators, *Energy Convers. Manag.* 86 (2014) 241–249.
- [73] X. Lin, Y. Wang, M. Pedram, J. Kim, N. Chang, Designing fault-tolerant photovoltaic systems, *IEEE Design Test* 31 (2013) 76–84.
- [74] Y. Hu, J. Zhang, W. Cao, J. Wu, G.Y. Tian, S.J. Finney, J.L. Kirtley, Online two-section PV array fault diagnosis with optimized voltage sensor locations, *IEEE Trans. Ind. Electron.* 62 (2015) 7237–7246.
- [75] M. Alajmi, I. Abdel-Qader, Fault detection and localization in solar photovoltaic arrays using the current-voltage sensing framework, in: Proceedings of International Conference on Electro Information Technology (EIT), IEEE, 2016, pp. 307–312.
- [76] R. Hariharan, M. Chakkaranpani, G.S. Ilango, C. Nagamani, A method to detect photovoltaic array faults and partial shading in PV systems, *IEEE J. Photovolt.* 6 (2016) 1278–1285.
- [77] M. Bressan, Y. El-Basri, C. Alonso, A new method for fault detection and identification of shadows based on electrical signature of defects, in: Proceedings of the 17th European Conference on Power Electronics and Applications (EPE'15 ECCE-Europe), IEEE, 2015, pp. 1–8.
- [78] E. Garoudja, K. Kara, A. Chouder, S. Silvestre, S. Kichou, Efficient fault detection and diagnosis procedure for photovoltaic systems, in: Proceedings of the 8th International Conference on Modelling, Identification and Control (ICMIC), IEEE, 2016, pp. 851–856.
- [79] A. Dhoke, R. Sharma, T.K. Saha, PV module degradation analysis and impact on settings of overcurrent protection devices, *Sol. Energy* 160 (2018) 360–367.
- [80] D. Kastha, B.K. Bose, Investigation of fault modes of voltage-fed inverter for induction motor drive, *IEEE Trans. Ind. Appl.* 30 (1994) 1028–1038.
- [81] J.H. Choi, S. Kim, D.S. Yoo, K.H. Kim, A diagnostic method of simultaneous open-switch faults in inverter-fed linear induction motor drive for reliability enhancement, *IEEE Trans. Ind. Electron.* 62 (2015) 4065–4077.
- [82] A.R. Haitham, S.K.M. Ahmed, A. Iqbal, M. Rahimian, H.A. Toliyat, Incipient bearing fault diagnostics for inverter fed induction motor drive using ANFIS, in: Electrical Machines (ICEM) International Conference, IEEE, 2010, pp. 1–5.
- [83] Q.T. An, L.Z. Sun, K. Zhao, L. Sun, Switching function model-based fast-diagnostic method of open-switch faults in inverters without sensors, *IEEE Trans. Power Electron.* 126 (2011) 119–126.
- [84] X. Zhang, A new diagnostic method of open switch faults in inverters using sliding mode observer and MLD model, in: 2015 IEEE Magnetics Conference (INTERMAG), IEEE, 2015, pp. 1–2.
- [85] A. Babel, A. Muetze, R. Seebacher, K. Krischan, E.G. Strangas, Condition monitoring and failure prognosis of IGBT inverters based on on-line characterization, in: 2015 IEEE 2nd Conference Future Energy Electronics Conference (IFEEC), IEEE, 2014, pp. 1–7.
- [86] S.C. Yang, On-line stator turn fault detection for inverter-fed electric machines using neutral point voltage differences, in: 2015 IEEE 2nd International, Future Energy Electronics Conference (IFECC), IEEE, 2015, pp. 1–7.
- [87] R. Riberio, C. Jacobina, E. Da Silva, A. Lima, Fault detection of open-switch damage in voltage-fed PWM motor drive systems, *IEEE Trans. Power Electron.* 18 (2003) 587–593.
- [88] F.W. Fuchs, Some diagnosis methods for voltage source inverters in variable speed drives with induction machines-A survey, in: Proceedings of IEEE/IE Annual Meeting, IEEE, 2003, pp. 1378–1385.
- [89] V.F. Pires, D. Foito, T.G. Amaral, Fault detection and diagnosis in a PV grid-connected T-type three level inverter, in: International Conference on Renewable Energy Research and Applications (ICRERA), IEEE, 2015, pp. 1–5.
- [90] O.J. Aworo, A. Kwasinski, Fault detection strategy for grid-tie three-phase photovoltaic inverter, in: International Conference on Renewable Energy Research and Applications (ICRERA), IEEE, 2018, pp. 1–6.
- [91] A.F. Ebrahim, T. Youssef, S.M.W. Ahmed, S.E. Elmasry, O.A. Mohammed, Fault detection and compensation for a PV system grid tie inverter, in: North American Power Symposium (NAPS), IEEE, 2014, pp. 1–6.
- [92] Z. Li, T. Peng, J. Yang, Z. Lin, P. Zhang, Open fault detection for interleaved flyback micro-inverter based on state observer, in: Proceedings of the 33rd Chinese Control Conference, IEEE, 2014, pp. 1–4.
- [93] Z. Huang, Z. Wang, H. Zhang, Multiple open-circuit fault diagnosis based on multistate data processing and subsection fluctuation analysis for photovoltaic inverter, *Trans. Instrum. Meas.* 67 (2018) 516–526.

- [94] M. Dong, H. Dong, L. Wang, J. Yang, L. Li, Y. Wang, A simple open-circuit detection strategy for a single-phase grid-connected PV inverter fed from power optimizers, *IEEE Trans. Power Electron.* 33 (2017) 2798–2802.
- [95] J.A.P. Sanchez, D.U. Campos-Delgado, D.R. Espinoza-Trejo, A.A. Valdez-Fernandez, C.H. De Angelo, Fault diagnosis in grid-connected PV NPC inverters by a model-based and data processing combined approach, *Power Electron. IET* 12 (2019) 3254–3264.
- [96] R. Peuget, S. Courtine, J. Rognon, Fault detection and isolation on a PWM inverter by knowledge-based model, *IEEE Trans. Ind. Appl.* 34 (1998) 1318–1326.
- [97] A.C. Renfrew, J.X. Tian, The use of a knowledge-based system in power electronic circuit fault diagnosis, in: Proceedings of the 5th European Conference on Power Electronics & Applications, Brighton, UK, 1993, pp. 57–62.
- [98] C. Hang, L. Ying, N. Shu, Transistor open-circuit fault diagnosis in two-level three-phase inverter based on similarity measurement, *Microelectron. Reliab.* 91 (2018) 291–297.
- [99] C. Yong, J.J. Zhang, Z.Y. Chen, Current observer-based online open-switch fault diagnosis for voltage-source inverter, *ISA Trans.* 99 (2020) 445–453.
- [100] M. Wang, J. Zhao, F. Wu, H. Yang, Transistor open-circuit fault diagnosis of three phase voltage-source inverter fed induction motor based on information fusion, in: 12th IEEE Conference on Industrial Electronics and Applications (ICIEA), IEEE, 2017, pp. 1–4.
- [101] H. Weiwei, Q. Jin, M. Haowen, S. Yufeng, Information fusion method in fault modes, in: 2012 IEEE Conference on Prognostics and System Health Management (PHM), IEEE, 2012, pp. 1–5.
- [102] Z. Yao, H. Pan, Engine fault diagnosis based on the weighted DS evidence theory, in: IEEE 7th International Workshop on Computational Intelligence and Applications (IWCA), IEEE, 2014, pp. 219–223.
- [103] Z. Lin, Z. Feng, Z. Xiao, Q. Zhong, Method of analog circuits fusion diagnosis based on BP network and DS theory, in: 2010 6th International Conference on Natural Computation, IEEE, 2010, pp. 389–393.
- [104] K. Rothenhagen, F.W. Fuchs, Performance of diagnosis methods for IGBT open circuit faults in three phase voltage source inverters for ac variable speed drives, in: 2005 European Conference on Power Electronics and Applications, IEEE, 2005, pp. 1–10.
- [105] H. Yan, Y. Xu, F. Cai, H. Zhang, W. Zhao, C. Gerada, PWM-VSI fault diagnosis for a PMSM drive based on the fuzzy logic approach, *IEEE Trans. Power Electron.* 34 (2019) 759–768.
- [106] N.M.A. Freire, J.O. Estima, A.J.M. Cardoso, Multiple open-circuit fault diagnosis in voltage-fed PWM motor drives using the current park's vector phase and the currents polarity, in: 8th IEEE Symposium on Diagnostics for Electrical Machines, Power Electronics & Drives, IEEE, 2011, pp. 1–5.
- [107] R.P.S. Ventura, A.M.S. Mendes, A.J.M. Cardoso, Fault detection in multilevel cascaded inverter using park's vector approach with balanced battery power usage, in: Proceedings of the 2011 14th European Conference on Power Electronics and Applications, IEEE, 2011, pp. 2–4.
- [108] D.U. Campos-Delgado, D.R. Espinoza-Trejo, An observer-based diagnosis scheme for single and simultaneous open-switch faults in induction motors drives, *IEEE Trans. Ind. Electron.* 58 (2010) 671–679.
- [109] S.M. Jung, J.S. Park, H.W. Kim, K.Y. Cho, M.J. Yoon, An MRAS-based diagnosis of open-circuit fault in PWM voltage-source inverters for PM synchronous motor drive systems, *IEEE Trans. Power Electron.* 28 (2012) 2514–2526.
- [110] S. Karimi, A. Gaillard, P. Poure, S. Saadate, FPGA-based real-time power converter failure diagnosis for wind energy conversion systems, *IEEE Trans. Ind. Electron.* 55 (2008) 4299–4308.
- [111] R.L.A. Ribeiro, C.B. Jacobina, E.R.C. da Silva, A.M.N. Lima, Fault detection of open-switch damage in voltage-fed PWM motor drive systems, *IEEE Trans. Power Electron.* 18 (2003) 587–593.
- [112] O.S. Yu, N.J. Park, D.S. Hyun, A novel fault detection scheme for voltage fed PWM inverter, in: Proceedings of Industrial Electronics Society Conference, 2006, pp. 2654–2659.
- [113] A.Q.T. Sun, L.Z. Zhao, K.L. Sun, Switching function model based fast diagnostic method of open-switch faults in inverters without sensors, *IEEE Trans. Power Electron.* 26 (2011) 119–126.
- [114] M. Trabelsi, M. Boussak, M. Gossa, PWM-switching pattern-based diagnosis scheme for single and multiple open-switch damages in VSI-fed induction motor drives, *ISA Trans.* 51 (2012) 333–344.
- [115] M. Trabelsi, M. Boussak, P. Mestre, M. Gossa, An improved diagnosis technique for IGBTs open-circuit fault in PWM-VSI-fed induction motor drive, in: Proceedings of International Symposium on Industrial Electronics Conference, 2011, pp. 2111–2117.
- [116] U.M. Choi, H.G. Jeong, K.B. Lee, F. Blaabjerg, Method for detecting an open-switch fault in a grid-connected NPC inverter system, *IEEE Trans. Power Electron.* 27 (2012) 2726–2739.
- [117] A.M.S. Mendes, A.J.M. Cardoso, Fault diagnosis in a rectifier-inverter system used in a variable speed ac drives, by the average current Park's vector approach, in: Proceedings of European Conference on Power Electronics and Applications, 1999, pp. 1–9.
- [118] S. Abramik, W. Sleszynski, J. Nieznanski, H. Piquet, A diagnostic method for online fault detection and localization in VSI-fed ac drives, in: Proceedings of European Conference on Power Electronics and Applications, 2003, pp. 2–4.
- [119] K. Rothenhagen, F.W. Fuchs, Performance of diagnosis methods for IGBT open-circuit faults in voltage source active rectifiers, in: Proceedings of Power Electronics Specialists Conference, 2004, pp. 4348–4354.
- [120] X. Chen, J. Liu, Z. Deng, S. Song, S. Du, D. Wang, A diagnosis strategy for multiple IGBT open-circuit faults of modular multilevel converters, *IEEE Trans. Power Electron.* 36 (2020) 191–203.
- [121] L.J. Balaguer-Alvarez, E.I. Ortiz-Rivera, Survey of distributed generation islanding detection methods, *IEEE Lat. Am. Trans.* 8 (2010) 565–570.
- [122] A. Llaria, O. Curea, J. Jimenez, H. Camblong, Survey on Microgrids: analysis of technical limitations to carry out new solutions, in: 13th European Conference on Power Electronics and Applications, EPE'09, 2009, pp. 1–8.
- [123] A. Timbus, A. Oudalov, C.N. Ho, Islanding detection in smart grids, in: Energy Conversion Congress and Exposition (ECCE), 2010, pp. 3631–3637.
- [124] P. Mahat, Z. Chen, B. Bak-Jensen, Review of islanding detection methods for distributed generation. Electric utility deregulation and restructuring and power technologies, in: DRPT Third International Conference, 2008, pp. 2743–2748.
- [125] R.S. Kunte, W. Gao, Comparison and review of islanding detection techniques for distributed energy resources, in: 40th North American Power Symposium, NAPS'08, 2008, pp. 1–8.
- [126] M. Ezzt, M.I. Marei, M. Abdel-Rahman, M.M. Mansour, A hybrid strategy for distributed generators islanding detection, in: 2007 IEEE Power Engineering Society Conference and Exposition in Africa, Power Africa, IEEE, 2007, pp. 1–7.
- [127] S.P. Chowdhury, S. Chowdhury, P.A. Crossley, Islanding protection of active distribution networks with renewable distributed generators: a comprehensive survey, *Electr. Power Syst. Res.* 79 (2009) 984–992.
- [128] F. Coffele, P. Moore, C. Booth, A. Dysko, G. Burt, T. Spearing, P. Dolan, Centralised Loss of Mains protection using IEC-61850, *Developments in Power System Protection* (2010) 3–5. IET.
- [129] H.H. Zeineldin, E.F. El-Saadany, M.M. Salama, Impact of DG interface control on islanding detection and non-detection zones, *IEEE Trans. Power Deliv.* 21 (2006) 1515–1523.
- [130] W. Hu, Y.L. Sun, A compound scheme of islanding detection according to inverter, in: Power and Energy Engineering Conference, Asia-Pacific, 2009, pp. 1–4.
- [131] G. Yin, A distributed generation islanding detection method based on artificial immune system, in: Transmission and Distribution Conference and Exhibition: Asia and Pacific, IEEE/PES, 2005, pp. 1–4.
- [132] S.I. Jang, K.H. Kim, An islanding detection method for distributed generations using voltage unbalance and total harmonic distortion of current, *IEEE Trans. Power Deliv.* 19 (2004) 745–752.
- [133] R.R.S. de Oliveira, H.M. Monteiro, R.R. Alexio, L.R.M. Silva, C.A. Duque, Islanding detection using impedance measurements techniques based on wavelet injection, in: 2017 Brazilian Power Electronics Conference (COBEP), IEEE, 2017, pp. 1–5.
- [134] P. Mahat, Z. Chen, B. Bak-Jensen, Review on islanding operation of distribution system with distributed generation, in: Power and Energy Society General Meeting, IEEE, 2011, pp. 1–8.
- [135] H.J. Kim, D.H. Kim, B.M. Han, Islanding detection method with negative-sequence current injection under unbalanced voltage grid, in: International Future Energy Electronics Conference (IFEEC), IEEE, 2015, pp. 1–5.
- [136] P.P. Vergara, J.M. Rey, H.R. Shaker, J.M. Guerrero, B.N. Jorgensen, L.C.P. da Silva, Distribution strategy for optimal dispatch of unbalanced three-phase islanded microgrids, *Trans. Smart Grid* 10 (2018) 3210–3225.
- [137] N. Liu, A.S. Aljankaway, C.P. Diduch, L. Chang, M. Mao, P. Yazdkhasti, J. Su, Performance evaluation for grid impedance based islanding detection method, in: International Power Electronics Conference (IPEC-Hiroshima 2014 – ECCE Asia), IEEE, 2014, pp. 1–5.
- [138] M. Ropp, J. Ginn, J. Stevens, W. Bower, S. Gonzalez, Simulation and experimental study of the impedance detection anti-islanding method in the single-inverter case, in: Photovoltaic Energy Conversion, Conference Record of the IEEE 4th World Conference 2, 2006, pp. 2379–2382.
- [139] F. Liu, Y. Kang, Y. Zhang, S. Duan, X. Lin, Improved SMS islanding detection method for grid-connected converters, *IET Renew. Power Gener.* 4 (2010) 36–42.
- [140] V. Menon, M.H. Nehrir, A hybrid islanding detection technique using voltage unbalance and frequency set point, *IEEE Trans. Power Syst.* 22 (2007) 442–448.
- [141] G.K. Hung, C.C. Chang, C.L. Chen, Automatic phase-shift method for islanding detection of grid-connected photovoltaic inverters, *IEEE Trans. Energy Convers.* 18 (2003) 169–173.
- [142] W.Y. Chang, A hybrid islanding detection method for distributed synchronous generators, in: International Power Electronics Conference – ECCE ASIA, IEEE, 2010, pp. 1326–1330.
- [143] H. Vahedi, R. Noroozian, A. Jalilvand, G.B. Gharehpetian, Hybrid SFS and Q-f islanding detection method for inverter-based DG, in: International Conference on Power and Energy, IEEE, 2010, pp. 672–676.
- [144] R. Polikar, The story of wavelets, *Phys. Mod. Top. Mech. Electr. Eng.* (1999) 192–197.
- [145] A. Pigazo, V.M. Moreno, M. Liserre, A. Dell'Aquila, Wavelet-based islanding detection algorithm for single-phase photovoltaic (PV) distributed generation systems, in: IEEE International Symposium on Industrial Electronics, ISIE 2007, 2007, pp. 2409–2413.
- [146] A. Pigazo, M. Liserre, R.A. Mastromauro, V.M. Moreno, A. Dell'Aquila, Wavelet based islanding detection in grid-connected PV systems, *IEEE Trans. Ind. Electron.* 56 (2009) 4445–4455.
- [147] P.K. Ray, S.R. Mohanty, N. Kishor, H.C. Dubey, Coherency determination in grid connected distributed generation based hybrid system under islanding scenarios, in: IEEE International Conference on Power and Energy (PECon), 2010, pp. 85–88.
- [148] P.K. Ray, N. Kishor, S.R. Mohanty, S-transform based islanding detection in grid connected distributed generation based power system, in: IEEE International

- Conference on Energy Conference and Exhibition (EnergyCon), 2010, pp. 612–617.
- [149] S.R. Samantaray, A. Samui, B.C. Babu, S-transform based cumulative sum detector (CUSUM) for islanding detection in distributed generations, in: 2010 Joint International Conference on Power Electronics, Drives and Energy Systems (PEDES) & 2010 Power India, 2010, pp. 1–6.
- [150] Y. Zhao, B. Lehman, R. Ball, J. Mosesian, J.F. de Palma, Outlier detection rules for fault detection in solar photovoltaic arrays, in: Proceedings of Twenty-eighth Annual Applied Power Electronics Conference and Exposition (APEC), IEEE, 2013, pp. 2913–2920.
- [151] Y. Zhao, F. Balboni, T. Arnaud, J. Mosesian, R. Ball, B. Lehman, Fault experiments in a commercial-scale PV laboratory and fault detection using local outlier factor, in: Proceedings of 40th Photovoltaic Specialist Conference (PVSC), IEEE, 2014, pp. 3398–3403.
- [152] G. Wang, C.C. Youn, A.M. Stankovic, DC-side high impedance ground fault detection for transformerless single-phase PV systems, in: Proceedings of North American Power Symposium (NAPS), IEEE, 2015, pp. 1–6.
- [153] I.S. Kim, On-line fault detection algorithm of a photovoltaic system using wavelet transform, *Sol. Energy* 126 (2016) 137–145.
- [154] N.L. Georgijevic, M.V. Jankovic, S. Srdic, Z. Radakovic, The detection of series arc fault in photovoltaic systems based on the arc current entropy, *IEEE Trans. Power Electron.* 31 (2016) 5917–5930.
- [155] K.A. Kim, G.-S. Seo, B.-H. Cho, P.T. Krein, Photovoltaic hot-spot detection for solar panel substrings using AC parameter characterization, *IEEE Trans. Power Electron.* 31 (2016) 1121–1130.
- [156] L. Chen, S. Li, X. Wang, Quickest fault detection in photovoltaic systems, *IEEE Trans. Smart Grid* 9 (2016) 1835–1847.
- [157] Z. Yi, A.H. Etemadi, Fault detection for photovoltaic systems based on multi-resolution signal decomposition and fuzzy inference systems, *IEEE Trans. Smart Grid* 8 (2017) 1274–1283.
- [158] S. Chen, X. Li, PV series arc fault recognition under different working conditions with joint detection method, in: Proceedings of the 62nd Holm Conference on Electrical Contacts (Holm), IEEE, 2016, pp. 25–32.
- [159] H. Zhu, Z. Wang, R.S. Balog, Real time arc fault detection in PV systems using wavelet decomposition, in: Proceedings of 43rd Photovoltaic Specialists Conference (PVSC), IEEE, 2016, pp. 1761–1766.
- [160] S. Dhar, R.K. Patnaik, P.K. Dash, Fault detection and location of photovoltaic based DC microgrid using differential protection strategy, *IEEE Trans. Smart Grid* 9 (2017) 4303–4312.
- [161] Q. Xiong, S. Ji, L. Zhu, L. Zhong, Y. Liu, A novel DC arc fault detection method based on electromagnetic radiation signal, *IEEE Trans. Plasma Sci.* 45 (2017) 472–478.
- [162] B.P. Kumar, G.S. Ilango, M.J. Reddy, N. Chilakapati, Online fault detection and diagnosis in photovoltaic systems using wavelet packets, *IEEE J. Photovolt.* 8 (2018) 257–265.
- [163] M. Mansouri, A. Al-khazraji, M. Hajji, M.F. Harkat, H. Nounou, M. Nounou, Wavelet optimized EWMA for fault detection and application to photovoltaic systems, *Sol. Energy* 167 (2018) 125–136.
- [164] C. Ventura, G.M. Tina, Utility scale photovoltaic plant indices and models for online monitoring and fault detection purposes, *Electr. Power Syst. Res.* 136 (2016) 43–56.
- [165] S. Silvestre, L. Mona-Lopez, S. Kichou, F. Sanchez-Pacheco, M. Dominguez-Pumar, Remote supervision and fault detection on OPC monitored PV systems, *Sol. Energy* 137 (2016) 424–433.
- [166] M. Dhimish, V. Holmes, M. Dales, Parallel fault detection algorithm for grid-connected photovoltaic plants, *Renew. Energy* 113 (2017) 94–111.
- [167] P.K. Ray, A. Mohanty, B.K. Panigrahi, P.K. Rout, Modified wavelet transform based fault analysis in a solar photovoltaic system, *Optik (Stuttg.)* 168 (2018) 754–763.
- [168] H. Ding, K. Ding, J. Zhang, Y. Wang, L. Gao, Y. Li, F. Chen, Z. Shao, W. Lai, Local outlier factor-based fault detection and evaluation of photovoltaic system, *Sol. Energy* 164 (2018) 139–148.
- [169] F. Harrou, Y. Sun, B. Taghezouit, A. Saidi, M.-E. Hamlati, Reliable fault detection and diagnosis of photovoltaic systems based on statistical monitoring approaches, *Renew. Energy* 116 (2018) 22–37.
- [170] S. Nie, X. Pei, Y. Chen, Y. Kang, Fault diagnosis of PWM DC–DC converters based on magnetic component voltages equation, *IEEE Trans. Power Electron.* 29 (2014) 4978–4988.
- [171] X. Pei, S. Nie, Y. Kang, Switch short-circuit fault diagnosis and remedial strategy for full-bridge DC–DC converters, *IEEE Trans. Power Electron.* 30 (2015) 996–1004.
- [172] S.Y. Kim, K. Nam, H.S. Song, H.G. Kim, Fault diagnosis of a ZVS DC–DC converter based on DC-link current pulse shapes, *IEEE Trans. Ind. Electron.* 55 (2008) 1491–1494.
- [173] W. Sleszynski, J. Nieznanski, Open-transistor fault diagnostics in voltage-source inverters by analyzing the load currents, in: Proceedings of International Symposium on Diagnosis for Electric Machines, 2007, pp. 70–73.
- [174] W. Sleszynski, J. Nieznanski, A. Cichowski, Open-transistor fault diagnostics in voltage-source inverters by analyzing the load currents, *IEEE Trans. Ind. Electron.* 56 (2009) 4681–4688.
- [175] B.G. Park, K.J. Lee, R.Y. Kim, T.S. Kim, J.S. Ryn, D.S. Hyun, Simple fault diagnosis based on operating characteristic of brushless direct-current motor drives, *IEEE Trans. Ind. Electron.* 58 (2011) 1586–1593.
- [176] M.S. Kanniche, Wavelet-fuzzy based algorithm for condition monitoring of voltage source inverters, *Electron. Lett.* 40 (2004) 267–268.
- [177] C.M. Wolf, M.W. Degner, F. Briz, Analysis of current sampling errors in PWM VSI drives, *IEEE Trans. Ind. Appl.* 51 (2015) 1551–1560.
- [178] Z. Li, P. Wheeler, A. Watson, A. Costabeber, B. Wang, Y. Ren, Z. Bai, H. Ma, A fast diagnosis method for IGBT faults and current sensor faults in grid-tied three-phase inverters with two current sensors, *IEEE Trans. Power Electron.* 35 (2020) 5267–5278.
- [179] J.O. Estima, A.J.M. Cardoso, A new algorithm for real-time multiple open-circuit fault diagnosis in voltage-fed PWM motor drivers by the reference current errors, *IEEE Trans. Ind. Electron.* 28 (2013) 3496–3505.
- [180] F. Zidani, D. Diallo, M.E.H. Benbouzid, R. Nait-Said, A fuzzy-based approach for the diagnosis of fault modes in a voltage-fed PWM inverter induction motor drive, *IEEE Trans. Ind. Electron.* 55 (2008) 586–593.
- [181] Q.T. An, L.Z. Sun, K. Zhao, L. Sun, Current residual vector-based open-switch fault diagnosis of inverters in PMSM drive systems, *IEEE Trans. Power Electron.* 30 (2015) 2814–2827.
- [182] N. Senroy, G.T. Heydt, V. Vittal, Decision tree assisted controlled islanding, *IEEE Trans. Power Syst.* 21 (2006) 1790–1797.
- [183] K. El-Arroudi, G. Joos, I. Kamwa, D.T. McGillis, Intelligent-based approach to islanding detection in distributed generation, *IEEE Trans. Power Deliv.* 22 (2007) 828–835.
- [184] N.W. Lidula, A.D. Rajapakse, A pattern recognition approach for detecting power islands using transient signals—part I: design and implementation, *IEEE Trans. Power Deliv.* 25 (2010) 3070–3077.
- [185] J.P. Pham, N. Denboer, N.W. Lidula, N. Perera, A.D. Rajapakse, Hardware implementation of an islanding detection approach based on current and voltage transients, in: Electrical Power and Energy Conference (EPEC), 2011, pp. 152–157.
- [186] Z. Yi, A.H. Etemadi, Line-to-line fault detection for photovoltaic arrays based on multiresolution signal decomposition and two-stage support vector machine, *IEEE Trans. Ind. Electron.* 64 (2017) 8546–8556.
- [187] E. Kymakis, S. Kalykakis, T.M. Papazoglou, Performance analysis of a grid connected photovoltaic park on the island of Crete, *Energy Convers. Manag.* 50 (3) (2009) 433–438.
- [188] S. Silvestre, A. Chouder, E. Karatepe, Automatic fault detection in grid connected PV systems, *Sol. Energy* 94 (2013) 119–127.
- [189] M. Davarifar, A. Rabhi, A. El Hajjaji, M. Dahmane, New method for fault detection of PV panels in domestic applications, in: Proceedings of the 3rd International Conference on Systems and Control (ICSC), IEEE, 2013, pp. 727–732.
- [190] J.M. Bright, S. Killinger, D. Lingfors, N.A. Engerer, Improved satellite-derived PV power nowcasting using real-time power data from reference PV systems, *Sol. Energy* 168 (2018) 118–139.
- [191] W. Chine, A. Mellit, A.M. Pavan, V. Lugh, Fault diagnosis in photovoltaic arrays, in: Proceedings of International Conference on Clean Electrical Power (ICCEP), IEEE, 2015, pp. 67–72.
- [192] R. Platon, J. Martel, N. Woodruff, T.Y. Chau, Online fault detection in PV systems, *IEEE Trans. Sustain. Energy* 6 (2015) 1200–1207.
- [193] M. Hosseini-zadeh, F.R. Salmasi, Determination of maximum solar power under shading and converter faults—a prerequisite for failure-tolerant power management systems, *Simul. Model. Pract. Theory* 62 (2016) 14–30.
- [194] M. Bressan, Y. El Basri, A.G. Galeano, C. Alonso, A shadow fault detection method based on the standard error analysis of IV curves, *Renew. Energy* 99 (2016) 1181–1190.
- [195] A. Umana, A.S. Meliopoulos, Detection of cell-level fault conditions within a photovoltaic array system, in: Proceedings of Transmission and Distribution Conference and Exposition (T&D), IEEE/PES, IEEE, 2016, pp. 1–5.
- [196] W. Wang, A.C.-F. Liu, H.S.-H. Chung, R.W.-H. Lau, J. Zhang, A.W.-L. Lo, Fault diagnosis of photovoltaic panels using dynamic current–voltage characteristics, *IEEE Trans. Power Electron.* 31 (2016) 1588–1599.
- [197] T. Andrianajaina, E.J.R. Sambrata, C.B. Andrianirina, T.D. Razafimahef, N. Heraud, PV fault detection using the least squares method, in: Proceedings of International Conference and Exposition on Electrical and Power Engineering (EPE), IEEE, 2016, pp. 846–851.
- [198] A. Belaout, F. Krim, A. Mellit, A Neuro-fuzzy classifier for fault detection and classification in photovoltaic module, in: Proceedings of the 8th International Conference on Modelling, Identification and Control (ICMIC), IEEE, 2016, pp. 144–149.
- [199] E. Garoudja, F. Harrou, Y. Sun, K. Kara, A. Chouder, S. Silvestre, Statistical fault detection in photovoltaic systems, *Sol. Energy* 150 (2017) 485–499.
- [200] B. Du, R. Yang, Y. He, F. Wang, S. Huang, Nondestructive inspection, testing and evaluation for Si-based, thin film and multi-junction solar cells: an overview, *Renew. Sustain. Energy Rev.* 78 (2017) 1117–1151.
- [201] M. Dhimish, V. Holmes, B. Mehrdadi, M. Dales, Simultaneous fault detection algorithm for grid-connected photovoltaic plants, *IET Renew. Power Gener.* 11 (2017) 1565–1575.
- [202] M. Dhimish, V. Holmes, B. Mehrdadi, M. Dales, Multi-layer photovoltaic fault detection algorithm, *High Volt.* 2 (2017) 244–252.
- [203] M.E. Basoglu, B. Cakir, Comparisons of MPPT performances of isolated and non-isolated DC–DC converters by using a new approach, *Renew. Sustain. Energy Rev.* 60 (2016) 1100–1113.
- [204] M.K. Alam, F.H. Khan, J. Johnson, J. Flicker, PV arc-fault detection using spread spectrum time domain reflectometry (SSTDR), in: IEEE Conference on Energy Conversion Congress and Exposition (ECCE), 2014, pp. 3294–3300.
- [205] S. Roy, M.K. Alam, F. Khan, J. Johnson, J. Flicker, An irradiance independent, Robust ground fault detection scheme for PV arrays based on spread spectrum time domain reflectometry (SSTDR), *IEEE Trans. Power Electron.* 33 (2017) 7046–7057.

- [206] F. Schimpf, L.E. Norum, Recognition of electric arcing in the DC-wiring of photovoltaic systems, in: International IEEE Conference on Telecommunications Energy (INTELEC), IEEE, 2009, pp. 1–6.
- [207] O. Hachana, G.M. Tina, K.E. Hemdas, PV array fault diagnostic technique for BIPV systems, *Energy Build.* 126 (2016) 263–274.
- [208] J. Johnson, S. Kuszmaul, W. Bower, D.A. Schoenwald, Using PV module and line frequency response data to create robust arc fault detectors, in: Proceedings of the 26th European Photovoltaic Solar Energy Conference and Exhibition, 2011, pp. 5–9.
- [209] J.C. Gu, D.S. Lai, J.M. Wang, J.J. Huang, M.T. Yang, Design of DC series arc fault detector for photovoltaic system protection, *IEEE Trans. Ind. Appl.* 55 (2019) 2464–2471.
- [210] G.S. Seo, H. Bae, B.H. Cho, K.C. Lee, Arc protection scheme for DC distribution systems with photovoltaic generation, in: IEEE International Conference on Renewable Energy Research and Applications (ICRERA), 2012, pp. 1–5.
- [211] M. Kavi, Y. Mishra, M. Vilathgama, DC arc-fault detection in PV systems using multistage morphological fault detection algorithm, in: IECON 2018 – 44th Annual Conference of the IEEE Industrial Electronics Society, IEEE, 2018, pp. 1–5.
- [212] D.K.J.S. Jayamaha, N.W.A. Lidula, A.D. Rajapakse, Protection and grounding methods in DC microgrids: comprehensive review and analysis, *Renew. Sustain. Energy Rev.* 120 (2020) 12–14.
- [213] S. Czapp, K. Borowski, Verification of safety in low-voltage power systems without nuisance tripping of residual current devices, *Electr. Power Syst. Res.* 172 (2019) 260–268.
- [214] J.C. Hernandez, P.G. Vidal, F. Jurado, Guidelines for protection against electric shock in PV generators, *IEEE Power Eng. Soc. Gen. Meet.* 24 (1) (2005) 274–282.
- [215] J. Flicker, J. Johnson, Photovoltaic ground fault detection recommendations for array safety and operation, *Sol. Energy* 140 (2016) 34–50.
- [216] J.C. Hernández, P.G. Vidal, A. Medina, Characterization of the insulation and leakage currents of PV generators: relevance for human safety, *Renew. Energy* 35 (2010) 593–601.
- [217] D.S. Pillai, J.P. Ram, N. Rajasekar, A. Mahmud, Y. Yang, F. Blaabjerg, Extended analysis on Line-Line and Line-Ground faults in PV arrays and a compatibility study on latest NEC protection standards, *Energy Convers. Manag.* 196 (2019) 988–1001.
- [218] J. Flicker, J. Johnson, M. Albers, G. Ball, Recommendations for isolation monitor ground fault detectors on residential and utility-scale PV systems, in: 2015 IEEE 42nd Photovoltaic Specialist Conference (PVSC), IEEE, 2015, pp. 4–6.
- [219] J.F. Martinez, M. Steiner, M. Wiesenfarth, S.W. Glunz, F. Dimroth, Thermal analysis of passively cooled hybrid CPV module using Si cell as heat distributor, *IEEE J. Photovolt.* 9 (2018) 160–166.
- [220] S. Vergura, G. Acciani, O. Falcone, A finite-element approach to analyze the thermal effect of defects on silicon-based PV cells, *IEEE Trans. Ind. Electron.* 59 (2012) 3860–3867.
- [221] L. Liu, M. Zan, Y. Bai, A recursive ensemble model for forecasting the power output of photovoltaic systems, *Sol. Energy* 189 (2019) 291–298.
- [222] Y. Yagi, H. Kishi, R. Hagihara, T. Tanaka, S. Kozuma, T. Ishida, M. Waki, M. Tanaka, S. Kiyama, Diagnostic technology and an expert system for photovoltaic systems using the learning method, *Sol. Energy Mater. Sol. Cells* 75 (2003) 655–663.
- [223] Z. Li, Y. Wang, D. Zhou, C. Wu, An intelligent method for fault diagnosis in photovoltaic array, *System Simul. Sci. Comput.* 327 (2012) 10–16.
- [224] P. Ducange, M. Fazzolari, B. Lazzarini, F. Marcelloni, An intelligent system for detecting faults in photovoltaic fields, in: 11th International Conference on Intelligent Systems Design and Applications (ISDA), IEEE, 2011, pp. 1341–1346.
- [225] A. Belaout, F. Krim, A. Mellit, B. Talbi, A. Arabi, Multiclass adaptive neuro-fuzzy classifier and feature selection techniques for photovoltaic array fault detection and classification, *Renew. Energy* 127 (2018) 548–558.
- [226] A. Ameur, A. Berrada, K. Loudiyi, M. Aggour, Forecast modeling and performance assessment of solar PV systems, *J. Clean. Energy Prod.* 267 (2020) 5–10.
- [227] E. Garoudja, A. Chouder, K. Kara, S. Silvestre, An enhanced machine learning based approach for failures detection and diagnosis of PV systems, *Energy Convers. Manag.* 151 (2017) 496–513.
- [228] M. Dhimish, V. Holmes, B. Mehrrad, M. Dales, Diagnostic method for photovoltaic systems based on six layer detection algorithm, *Electr. Power Syst. Res.* 151 (2017) 26–39.
- [229] M. Mittal, B. Bora, S. Saxena, A.M. Gaur, Performance prediction of PV module using electrical equivalent model and artificial neural network, *Sol. Energy* 176 (2018) 104–117.
- [230] I.E. Kaid, A. Hafaifa, M. Guemana, N. Hadroug, A. Kouzou, Photovoltaic system failure diagnosis based on adaptive neuro fuzzy inference approach: south Algeria solar power plant, *J. Clean. Prod.* 204 (2018) 169–182.
- [231] Y. Zhao, R. Ball, J. Mosesian, J.-F. de Palma, B. Lehman, Graph-based semi-supervised learning for fault detection and classification in solar photovoltaic arrays, *IEEE Trans. Power Electron.* 30 (2015) 2848–2858.
- [232] Y. Zhao, L. Yang, B. Lehman, J.-F. de Palma, J. Mosesian, R. Lyons, Decision tree-based fault detection and classification in solar photovoltaic arrays, in: Proceedings of Twenty-Seventh Annual Applied Power Electronics Conference and Exposition (APEC), IEEE, 2012, pp. 93–99.
- [233] M.N. Akram, S. Lotifard, Modeling and health monitoring of DC side of photovoltaic array, *IEEE Trans. Sustain. Energy* 6 (2015) 1245–1253.
- [234] E.K. Syafaruddin, T. Hiyama, Controlling of artificial neural network for fault diagnosis of photovoltaic array, in: Proceedings of the 16th International Conference on Intelligent System Application to Power Systems (ISAP), IEEE, 2011, pp. 1–6.
- [235] L.L. Jiang, D.L. Maskell, Automatic fault detection and diagnosis for photovoltaic systems using combined artificial neural network and analytical based methods, in: Proceedings of International Joint Conference on Neural Networks (IJCNN), IEEE, 2015, pp. 1–8.
- [236] C.B. Jones, J.S. Stein, S. Gonzalez, B.H. King, Photovoltaic system fault detection and diagnostics using laterally primed adaptive resonance theory neural network, in: Proceedings of the 42nd Photovoltaic Specialist Conference (PVSC), IEEE, 2015, pp. 1–6.
- [237] G. Han, F.M. Ham, L.V. Fausett, Fuzzy LAPART supervised learning through inferencing for stable category recognition, in: Proceedings of 1994 IEEE 3rd International Fuzzy Systems Conference, IEEE, 1994, pp. 1–5.
- [238] Z. Chen, L. Wu, S. Cheng, P. Lin, Y. Wu, W. Lin, Intelligent fault diagnosis of photovoltaic arrays based on optimized kernel extreme learning machine and I-V characteristics, *Appl. Energy* 204 (2017) 912–931.
- [239] L. Bonsignore, M. Davarifar, A. Rabhi, G.M. Tina, A. Elhajjaji, Neuro-fuzzy fault detection method for photovoltaic systems, *Energy Proc.* 62 (2014) 431–444.
- [240] M. Dhimish, V. Holmes, B. Mehrrad, M. Dales, Photovoltaic fault detection algorithm based on theoretical curves modelling and fuzzy classification system, *Energy* 140 (2017) 276–290.
- [241] Z. Chen, F. Han, L. Wu, J. Yu, S. Cheng, P. Lin, H. Chen, Random forest based intelligent fault diagnosis for PV arrays using array voltage and string currents, *Energy Convers. Manag.* 178 (2018) 250–264.
- [242] Y. Ueda, K. Kurokawa, T. Tanabe, K. Kitamura, H. Sugihara, Analysis results of output power loss due to the grid voltage rise in grid-connected photovoltaic power generation systems, *IEEE Trans. Ind. Electron.* 55 (2008) 2744–2751.
- [243] S.R. Madeti, S.N. Singh, Comparative analysis of solar photovoltaic monitoring systems, *AIP Conf. Proc.* 1859 (1) (2017), 020116.
- [244] L. Shen, Z. Li, T. Ma, Analysis of the power loss and quantification of the energy distribution in PV module, *Appl. Energy* 260 (2020) 4–8.
- [245] M. Tadj, K. Benmouiza, A. Cheknane, An innovative method based on satellite image analysis to check fault in a PV system lead-acid battery, *Simul. Modell. Pract. Theory* 47 (2014) 236–247.
- [246] S. Silvestre, Advances in Renewable Energies and Power Technologies. Advances in Renewable Energies and Power Technologies, 2018, pp. 231–255. Book Chapter.
- [247] T. Takashima, J. Yamaguchi, K. Otani, T. Oozeki, K. Kato, M. Ishida, Experimental studies of fault location in PV module strings, *Sol. Energy Mater. Sol. Cells* 93 (2009) 1079–1082.
- [248] T. Arunkumari, V. Indragandhi, An overview of high voltage conversion ratio DC-DC converter configurations used in DC micro-grid architectures, *Renew. Sustain. Energy Rev.* 77 (2017) 670–687.
- [249] A. Nouri, I. Salhi, S. El Beid, N. Essounbouli, E. Elwarraki, A fault tolerant strategy for multilevel dc-dc converters to improve the PV system efficiency, *IFAC-PapersOnLine* 49 (2016) 704–709.
- [250] A. Chouder, S. Silvestre, Automatic supervision and fault detection of PV systems based on power losses analysis, *Energy Convers. Manag.* 51 (2010) 1929–1937.
- [251] K. Osmani, M. Ramadan, A. Haddad, T. Lemenand, B. Castanier, A short review on mathematical algorithms for predictive maintenance techniques and anomaly detection in PV systems, in: Proceedings of the 31st European Safety and Reliability Conference, ESREL, Angers, France, 2021, pp. 3222–3229.
- [252] A. Drews, A.C. de Keizer, H.G. Beyer, E. Lorenz, J. Betcke, W.G.J.H.M. van Sark, W. Heydenreich, E. Wiemken, S. Stettler, P. Toggweiler, S. Bofinger, M. Schneider, G. Heilscher, D. Heinemann, Monitoring and remote failure detection of grid-connected PV systems based on satellite observations, *Sol. Energy* 81 (2007) 548–564.
- [253] K.H. Chao, S.H. Ho, M.H. Wang, Modeling and fault diagnosis of a photovoltaic system, *Electr. Power Syst. Res.* 78 (2008) 97–105.
- [254] A. Mellit, G.M. Tina, S.A. Kalogirou, Fault detection and diagnosis methods for photovoltaic systems A review, *Renew. Sustain. Energy Rev.* 91 (2018) 1–17.
- [255] P. Lin, Y. Lin, Z.C. Chen, L. Wu, L. Chen, S. Cheng, A density peak-based clustering approach for fault diagnosis of photovoltaic arrays, *Int. J. Photoenergy* 9 (2017) 1–14.
- [256] M. Benghanem, A. Maafi, Data acquisition system for photovoltaic systems performance monitoring, *IEEE Trans. Instrum. Meas.* 47 (1998) 30–33.
- [257] R. Mukaro, D. Tinarwo, Performance evaluation of a hot-box reflector solar cooker using a microcontroller-based measurement system, *Int. J. Energy Res.* 32 (2008) 1339–1348.
- [258] M.A. Eltawil, Z. Zhao, Grid-connected photovoltaic power systems: technical and potential problems—a review, *Renew. Sustain. Energy Rev.* 14 (2010) 112–129.
- [259] M. Miwa, S. Yamamoto, H. Kawamura, H. Ohno, Diagnosis of a power output lowering of PV array with a  $(-\Delta I/dV)$ -V characteristic, in: Conference Record of the IEEE 4th World Conference on Photovoltaic Energy Conversion 2, IEEE, 2006, pp. 2442–2445.
- [260] S. Kaplani, E. Kaplani, Energy performance and degradation over 20 years performance of BP c-Si PV modules, *Simul. Modell. Pract. Theory* 19 (2011) 1201–1211.
- [261] Z.A. Jeffery, A.K. Dubey, A.H. Irshad, Scheme for predictive fault diagnosis in photo-voltaic modules using thermal imaging, *Infrared Phys. Technol.* 83 (2017) 182–187.
- [262] B. Nehme, N.C. Msirdi, A. Naamane, T. Akiki, Analysis and characterization of faults in PV systems, *Energy Proc.* 111 (2017) 1020–1029.
- [263] J. Solorzano, M.A. Egido, Automatic fault diagnosis in PV systems with distributed MPPT, *Energy Convers. Manag.* 76 (2013) 925–934.
- [264] Q. Xiong, S. Ji, X. Liu, X. Feng, F. Zhang, L. Zhu, A.L. Gattozi, R.E. Hebner, Detecting and localizing series arc fault in photovoltaic systems based on time and frequency characteristics of capacitor current, *Sol. Energy* 170 (2018) 788–799.

- [265] T. Takashima, J. Yamaguchi, K. Otani, K. Kato, M. Ishida, Experimental studies of failure detection methods in PV module strings, in: Photovoltaic Energy Conversion, Conference Record of the IEEE 4th World Conference 2, 2006, pp. 2227–2230.
- [266] L. Schirone, F.P. Califano, M. Pastena, Fault detection in a photovoltaic plant by thermal effect of defects on silicon-based PV cells, *IEEE Trans. Ind. Electron.* 59 (1994) 3860–3867.
- [267] S. Vergura, G. Acciani, V. Amoruso, G. Patrono, Inferential statistics for monitoring and fault forecasting of PV plants, in: IEEE International Symposium on Industrial Electronics, IEEE, 2008, pp. 2414–2419.
- [268] E. Kaplani, Detection of degradation effects in field-aged c-Si solar cells through IR thermography and digital image processing, *Int. J. Photoenergy* (2012) 3–10.
- [269] F. Ancuta, C. Cepisca, Fault analysis possibilities for PV panels, in: Proceedings of the 3rd International Youth Conference on Energetics (IYCE), IEEE, 2011, pp. 1–5.
- [270] R. Kase, S. Nishikawa, Fault detection of bypass circuit of PV module—detection technology of open circuit fault location, in: Proceedings of the 19th International Conference on Electrical Machines and Systems (ICEMS), IEEE, 2016, pp. 1–4.
- [271] Y. Hu, B. Gao, X. Song, G.Y. Tian, K. Li, X. He, Photovoltaic fault detection using a parameter based model, *Sol. Energy* 96 (2013) 96–102.
- [272] J.C. Schlothauer, K. Gräbmayer, I. Hintersteiner, G.M. Wallner, B. Roder, Non-destructive 2D-luminescence detection of EVA in aged PV modules: correlation to calorimetric properties, additive distribution and a clue to aging parameters, *Sol. Energy Mater. Sol. Cells* 159 (2017) 307–317.
- [273] Z. Liu, M. Peters, V. Shanmugam, Y.S. Khoo, S. Guo, R. Stangl, A.G. Aberle, J. Wong, Luminescence imaging analysis of light harvesting from inactive areas in crystalline silicon PV modules, *Sol. Energy Mater. Sol. Cells* 144 (2016) 523–531.
- [274] P. Acevedo, M. Vasquez, J. Duran, R. Petrearce, A pulse generator based on an arduino platform for ultrasonic applications, *Phys. Proc.* 70 (2015) 1096–1099.
- [275] T. Kirchartz, A. Helbig, W. Reetz, M. Reuter, J.H. Werner, U. Rau, Reciprocity between electroluminescence and quantum efficiency used for the characterization of silicon solar cells, *Prog. Photovolt. Res. Appl.* 17 (2009) 394–402.
- [276] M. Kasemann, D. Grote, B. Walter, W. Kwapił, T. Trupke, Y. Augarten, R. A. Bardos, E. Pink, M.D. Abbott, W. Warta, Luminescence imaging for the detection of shunts on silicon solar cells, *Prog. Photovolt. Res. Appl.* 16 (2008) 297–305.
- [277] O. Breitenstein, J. Bauer, T. Trupke, R.A. Bardos, On the detection of shunts in silicon solar cells by photo-and electroluminescence imaging, *Prog. Photovolt. Res. Appl.* 16 (2008) 325–330.
- [278] G. Kayakutlu, E. Mercier-Laurent, Chapter 3: Intelligence for Energy, *Intelligence in Energy*, Elsevier, 2016, pp. 37–77.
- [279] M. Sharifzadeh, A. Sikinio-Lock, N. Shah, Machine-learning methods for integrated renewable power generation: a comparative study of artificial neural networks, support vector regression, and Gaussian process regression, *Renew. Sustain. Energy Rev.* 108 (2019) 513–538.
- [280] K. Osmani, A. Haddad, T. Lemenand, B. Castanier, M. Ramadan, A review on maintenance strategies for PV systems, *Sci. Total Environ.* 746 (2020) 3–4.
- [281] K. Osmani, A. Haddad, T. Lemenand, B. Castanier, M. Ramadan, Material based fault detection methods for PV systems, *Key Eng. Mater.* 865 (2020) 111–115.
- [282] A. Maleki, I. Sadeghkhani, B. Fani, Statistical sensorless short-circuit fault detection algorithm for photovoltaic arrays, *J. Renew. Sustain. Energy* 11 (2019), 053501.
- [283] B. Bouyeddu, F. Harrou, B. Taghezouit, Y. Sun, A.H. Arab, Improved semi-supervised data-mining-based schemes for fault detection in a grid-connected photovoltaic system, *Energies* 15 (21) (2022), 7978.
- [284] S. Vergura, A statistical tool to detect and locate abnormal operating conditions in photovoltaic systems, *Sustainability* 10 (3) (2018), 608.
- [285] M. Green, C.B. Jones, J. Dore, E. Brill, Improving Efficiency of PV Systems Using Statistical Performance Monitoring, International Energy Agency, 2017. Photovoltaic Power Systems Programme. ISBN 978-3-906042-48-0.
- [286] B. Taghezouit, F. Harrou, Y. Sun, A.H. Arab, C. Larbes, Multivariate statistical monitoring of photovoltaic plant operation, *Energy Convers. Manag.* 205 (2020), 112317.
- [287] B. Taghezouit, F. Harrou, Y. Sun, A.H. Arab, C. Larbes, A simple and effective detection strategy using double exponential scheme for photovoltaic systems monitoring, *Sol. Energy* 214 (2021) 337–354.
- [288] F. Harrou, B. Taghezouit, Y. Sun, Robust and flexible strategy for fault detection in grid-connected photovoltaic systems, *Energy Convers. Manag.* 180 (2019) 1153–1166.
- [289] Y.-Y. Hong, R.A. Pula, Methods of photovoltaic fault detection and classification: a review, *Energy Rep.* 8 (2022) 5898–5929.
- [290] A. Malik, A. Haque, V.S.B. Kurukuru, M.A. Khan, F. Blaabjerg, Overview of fault detection approaches for grid connected photovoltaic inverters. e-Prime – advances in electrical engineering, *Electron. Energy* 2 (2022), 100035.
- [291] B. Li, C. Delpha, D. Diallo, A. Migan-Dubois, Application of artificial neural networks to photovoltaic fault detection and diagnosis: a review, *Renew. Sustain. Energy Rev.* 138 (2021), 110512.
- [292] I. Hoiaas, K. Grujic, A.G. Imenes, I. Burud, E. Olsen, N. Belbachir, Inspection and condition monitoring of large-scale photovoltaic power plants: a review of imaging technologies, *Renew. Sustain. Energy Rev.* 161 (2022), 112353.
- [293] N. Bansal, S.P. Jaiswal, G. Singh, Comparative investigation of performance evaluation, degradation causes, impact and corrective measures for ground mount and rooftop solar PV plants – a review, *Sustain. Energy Technol. Assessm.* 47 (2021), 101526.
- [294] M. Köntges, G. Oreski, U. Jahn, M. Herz, P. Hacke, K.-A. Weiss, G. Razonges, M. Paggi, D. Parlevliet, T. Tanahashi, R.H. French, Assessment of Photovoltaic Module Failures in the Field, International Energy Agency, 2017. Photovoltaic Power Systems Programme. ISBN 978-3-906042-54-1.
- [295] S. Voutsinas, D. Karolidis, I. Voyatzis, M. Samarakou, Development of a fault detection algorithm for photovoltaic systems, in: Proceedings of the 25th Pan-Hellenic Conference on Informatics, 2021, pp. 84–87.
- [296] S. Voutsinas, D. Karolidis, I. Voyatzis, M. Samarakou, Development of a multi-output feed-forward neural network for fault detection in photovoltaic systems, *Energy Rep.* 8 (Supplement 9) (2022) 33–42.
- [297] S. Voutsinas, D. Karolidis, I. Voyatzis, M. Samarakou, Development of a machine-learning-based method for early fault detection in photovoltaic systems, *J. Eng. Appl. Sci.* 70 (2023), 27.