

PRISM

Solar Technologies

Market Strategy Report

Competitive Landscape | Target Market | Market Sizing | Business Model & Go-to-Market

Focus: AI-Based Microcrack Detection for Utility-Scale PV Plants

Reference Installation: Al Kharsaah Solar Power Plant, Qatar (800 MWp)

June 2026 | CONFIDENTIAL

1. Competitive Landscape & Prism's Competitive Advantage

1.1 Market Context

The solar O&M and predictive maintenance technology sector is growing rapidly alongside the global PV buildout. The global PV monitoring software market was valued at approximately USD 1.2 billion in 2024 and is projected to reach USD 3.7 billion by 2033 at an 11.9% CAGR, driven by rising demand for real-time analytics and AI-powered fault detection. Drone-based solar inspection alone reached USD 1.4 billion in North America in 2025, growing at a 24.8% CAGR through 2033. Equipment-driven underperformance cost the global solar fleet USD 10 billion in unrealised revenue in 2024 — a 15% year-on-year increase — underscoring the urgency of better maintenance solutions.

Despite this large and growing market, a critical gap exists: no commercially deployed solution continuously monitors operational plants using existing SCADA electrical signals specifically to detect microcracks. Existing solutions are either retrospective (drone-based imaging), hardware-locked (proprietary inverter ecosystems), or broad-scope (general anomaly detection without microcrack specificity). Prism's proposed approach — continuous AI inference on SCADA-native electrical signals — sits in an underserved niche.

1.2 Competitor Landscape

Competitor	Capability	Gap vs. Prism	Geography	Overlap Level
Raptor Maps	Drone + AI thermography & EL imaging; 193 GWdc analysed; inspects inverter pads, string outages, module defects	Post-hoc; requires scheduled drone flights; detection latency weeks–months; does NOT operate from SCADA signals; needs on-site hardware	US & Europe; less GCC presence	Indirect — different signal pathway
SolarEdge / Enphase (inverter analytics)	Module-level power monitoring via proprietary inverters; detects output drops at string/module level	Locked to own hardware ecosystem; cannot integrate with third-party SCADA; not microcrack-specific	Global; utility & C&I	Partial — hardware lock-in is differentiator for Prism
AlsoEnergy PowerTrack	Enterprise SCADA analytics & O&M dashboard for large utility portfolios	Performance monitoring platform — broad anomaly detection, NOT microcrack-specific; no cell-level diagnostics	US utility scale	Indirect — no microcrack focus
Sinovoltaics Selma	AI-powered EL mass analysis at module manufacturing stage; automated factory QC	Factory/QC-only; no field deployment; cannot monitor operational plants continuously	Module manufacturers globally	None in field

Competitor	Capability	Gap vs. Prism	Geography	Overlap Level
Areg.AI	AI O&M platform; proven 9.72% generation increase via soiling detection & targeted cleaning	Primarily soiling & cleaning optimisation; no published microcrack-specific detection capability	Armenia, Europe, expanding	Indirect — different fault focus
Generic SCADA ML research	Academic/pilot: SVM, SOM, IV-curve methods achieving 90–97% fault classification accuracy	Research-stage; not productised; general fault detection, not microcrack-specific	Academic	High — Prism productises this gap

Key Insight

The fundamental competitive insight for Prism is a signal pathway distinction: all major commercial competitors detect defects visually (drones, thermal cameras, EL imaging) — which is expensive, infrequent, and retrospective. Prism detects microcracks electrically, using signals that are already being collected 24/7 by SCADA systems. This is not an incremental improvement; it is a different detection paradigm.

1.3 Prism's Competitive Advantages

(A) No New Hardware Required

Prism integrates as a software layer on top of existing SCADA systems. The plant operator incurs zero additional sensor CAPEX. This dramatically lowers the adoption barrier and accelerates sales cycles, particularly in the GCC where large plants are already equipped with Siemens, ABB, or Schneider SCADA infrastructure.

(B) Continuous Detection vs. Periodic Inspection

Competitors relying on drone surveys typically inspect a plant once or twice per year. Prism's model runs continuously, flagging degradation as it emerges rather than months later. For a microcrack that is actively propagating, early detection — even weeks earlier — can prevent compounding losses. The economic case is built: the AI Kharsaah analysis shows QAR 35.17 million in recoverable value over 10 years, growing non-linearly in later years as crack populations compound.

(C) Microcrack Specificity

General-purpose solar monitoring platforms (AlsoEnergy, Greenbyte, SolarLog) detect output drops but cannot distinguish a microcrack signature from soiling, shading, or connection degradation. Prism's AI model, trained on the specific IV-curve and power signal anomalies associated with cell-level microcrack morphology — a distinction Prism's research team has studied rigorously — provides a fault-type specific diagnostic rather than a generic alarm.

(D) Climate-Specific Model Validation

GCC desert environments (extreme diurnal temperature swings, wind-driven sand, UV irradiance above 2,100 kWh/m²/yr) produce a specific microcrack propagation profile distinct from temperate climates. Prism's research base — including the Al Kharsaah reference case in Qatar — positions the company to build a model trained specifically on hot-arid climate data, creating a defensible IP moat that global competitors trained on European or US datasets do not have.

(E) Research Provenance

Prism is built on peer-reviewed research (Dhimish et al., 2017; Al-Sadi et al., 2020; Köntges et al., 2011; CEA, 2023) and benefits from an academic collaboration structure that generates publications, builds credibility with sovereign energy buyers, and supports grant funding — a capital-efficient route to product validation unavailable to pure-play commercial startups.

2. Target Customers & Target Market

2.1 Primary Customer Segments

Segment A: Utility-Scale PV Plant Operators (IPPs and SPVs)

The core customer is the operator of a utility-scale solar PV plant — typically an Independent Power Producer (IPP) or a Special Purpose Vehicle (SPV) created under a Public-Private Partnership (PPP) framework. These entities hold long-term Power Purchase Agreements (PPAs), typically 20–25 years, and have a direct financial stake in maximising energy yield over the life of the asset.

- **Example:** Al Kharsaah Solar Power Plant (Qatar): 800 MWp, operated by Siraj Energy (Qatar Electricity and Water Company / TotalEnergies / Marubeni JV). The reference customer for Prism's economic case.
- **Example:** Mohammed bin Rashid Al Maktoum Solar Park (UAE): 5 GW under development by Dubai Electricity and Water Authority (DEWA) and ACWA Power.
- **Example:** Sudair Solar Plant (Saudi Arabia): 1,500 MWp; among the world's largest single-site plants; operated by a consortium including ACWA Power and Vision Industries.

These operators have the scale to justify Prism's subscription, the SCADA infrastructure to enable integration, and the long-term asset horizon to appreciate the compounding value of early microcrack detection.

Segment B: Solar O&M Service Providers

Increasingly, utility-scale plant owners outsource O&M to specialised firms. Leading GCC O&M providers — including ACWA Power O&M, Enertech (UAE), and Elcome Technologies — manage multi-GW portfolios under performance-guaranteed O&M contracts. These firms are motivated buyers because microcrack-related yield loss directly affects their performance guarantee liability. A single Prism integration with an O&M provider can provide access to their entire managed portfolio, creating a scalable B2B2B channel.

Segment C: National Utilities and Energy Authorities

Qatar's Kahramaa, Saudi Arabia's SEC (Saudi Electricity Company), and Abu Dhabi's EWEC are responsible for national grid reliability and are stakeholders in solar plant performance at a portfolio level. National utilities increasingly publish performance benchmarks and may mandate predictive maintenance systems as a condition of PPA structuring. Engagement at this level — for example, through Prism's current grant-funded academic collaboration — can unlock mandatory or preferred-supplier status across an entire national solar fleet.

Segment D: EPC Contractors (as a channel partner)

Engineering, Procurement and Construction (EPC) contractors — including Siemens Energy, SEPCO III, and Larsen & Toubro — are often responsible for commissioning and early O&M of large plants. Pre-deploying Prism's solution at the commissioning stage, creating a clean T_0 baseline dataset, would provide early crack detection from Day 1 and give EPCs a value-add differentiator in tender submissions.

2.2 Buyer Persona: Decision Maker Profile

At the plant level, the decision-maker for adopting Prism is the Director of Asset Management or the Head of Operations & Maintenance. Key motivations are:

- Protecting PPA revenue and avoiding performance guarantee penalties.
- Reducing costly scheduled EL inspection programmes.
- Meeting ESG and asset-life reporting requirements for project finance lenders (IFC, EBRD, local banks) — who increasingly require evidence of proactive O&M.
- Avoiding unexpected CAPEX from module replacement that wasn't in the maintenance budget.

3. Market Sizing Assessment

3.1 Market Framing

Prism's addressable market is defined by utility-scale solar PV capacity in hot-arid environments — the segment with the highest microcrack incidence (accelerated by extreme thermal cycling and wind-driven mechanical stress) and the highest annual revenue at risk per MWp. Three market levels are used: SAM (Serviceable Addressable Market — GCC utilities), and SOM (Serviceable Obtainable Market — realistic early capture).

3.2 GCC Solar Capacity Baseline and Targets

As of mid-2025, the GCC had 19.3 GW of grid-connected renewable capacity, primarily solar PV, with an additional 40+ GW under construction or advanced development. Key national targets by 2030:

- Saudi Arabia: 130 GW renewables (100 GW+ solar) by 2030 — the dominant GCC market.
- UAE: 14.2 GW solar by 2030 (DEWA MBR park alone reaching 5 GW).
- Qatar: 4.5 GW solar target by 2030 (currently 0.8 GW operational).
- Oman: 4 GW renewables by 2030.
- Kuwait: 4.5 GW renewables by 2030.

Rystad Energy projects the region's solar capacity will exceed 100 GW by 2030, driven in part by green hydrogen projects growing at 30% annually. The entire GCC target of ~160 GW in renewables by 2030 requires approximately 60–70 GW of new solar capacity to be installed in the next 4 years — all of which represents potential future Prism customers.

3.3 Bottom-Up Revenue Sizing

Prism's revenue model is subscription-based at approximately QAR 625/MWp/yr (~USD 172/MWp/yr), consistent with industrial IoT monitoring benchmarks. The following sizing is based on addressable utility-scale plants (≥100 MWp) in the GCC:

Market	Solar Capacity Context	Addressable Plant Count	Annual Revenue Potential
Qatar	0.8 GW op. + 3.7 GW pipeline (4.5 GW by 2030)	~2 plants × QAR 500K/yr	~QAR 2.25M/yr
Saudi Arabia	130 GW target by 2030; currently ~10 GW op.	~50 plants × QAR 500K/yr	~QAR 25M/yr
UAE	14.2 GW target by 2030; ~7 GW op.	~25 plants × QAR 500K/yr	~QAR 12.5M/yr
Oman	4 GW target by	~8 plants × QAR 500K/yr	~QAR 4M/yr

Market	Solar Capacity Context	Addressable Plant Count	Annual Revenue Potential
	2030		
Kuwait + Bahrain	~5 GW combined by 2030	~6 plants × QAR 500K/yr	~QAR 3M/yr
GCC Total (2030)	~160 GW target (19.3 GW op. as of mid-2025)	~91 plants (800 MWp avg)	~QAR 45.5M/yr (~USD 12.5M/yr)

Note: Plant count estimates assume an average plant size of 500–800 MWp, consistent with current GCC tender patterns (Sudair at 1.5 GW, Al Kharsaah at 0.8 GW, Shuaibah 2 at 2.6 GW). Actual plant count is likely higher given smaller C&I plants; revenue per plant would scale accordingly.

3.4 Market Sizing Summary (Three Horizons)

Market Level	Scope	Est. MWp Addressable	Annual Revenue Potential (QAR)
TAM (Total Addressable)	Global hot-arid utility PV (MENA + South Asia + Australia)	~800 GW by 2030	~QAR 1.8B/yr (~\$500M/yr)
SAM (Serviceable Addressable)	GCC utility PV ≥100 MWp by 2030	~73 GW	~QAR 166M/yr (~\$46M/yr)
SOM (Serviceable Obtainable)	Prism's realistic 5-yr capture: 10–15% GCC SAM	~7–11 GW	~QAR 16–25M/yr (~\$4–7M/yr)

Key Insight — Market Defensibility

Hot-arid climates are structurally over-represented in the global microcrack risk register. CEA's 2023 survey found 83% of utility PV sites affected by microcracks, with crack incidence growing 47% year-on-year. The GCC's extreme climate (diurnal temperature swings of 20–30°C, persistent wind-driven sand abrasion, UV irradiance >2,100 kWh/m²/yr) makes it the highest-risk geography globally for microcrack propagation. A Prism model trained on GCC data has structural precision advantages over any global competitor applying a generic model.

3.5 Product-Market Fit Assessment

Evidence of Fit

- Pain is quantified and large: QAR 50.25M in revenue loss over 10 years for a single 800 MWp plant. At GCC scale, national microcrack-related losses run into the hundreds of millions of QAR annually.

- Willingness to pay is validated by proxy: utility-scale O&M predictive maintenance platforms command \$2,000–\$50,000/year per plant (DOE FEMP benchmark); Prism's QAR 500K/yr (\$137K/yr) pricing sits well within this range for an 800 MWp plant and is justified by the 4.5x 10-year ROI.
- No direct competitor exists: the combination of SCADA-native detection + microcrack specificity + GCC climate training is an unoccupied market position as of 2026.
- Buyer motivation is structural: PPA contracts penalise underperformance. Lenders increasingly require O&M documentation. ESG reporting frameworks (GRI, TCFD) create regulatory pull for predictive maintenance records.

Risks to PMF

- Data acquisition bottleneck: Model quality depends on labelled SCADA + EL data from operational plants. The grant-funded pilot at a reference plant is the critical path to closing this gap.
- Sales cycle length: Utility IPPs and national energy authorities have 12–24 month procurement cycles. Early engagement through academic and government channels (as Prism's grant collaboration provides) is essential to compress this.
- Perception as research project: Without a commercial pilot with publicly reported results, GCC plant operators will classify Prism as unproven. The grant proposal should include a clear commercialisation milestone tied to the pilot.

4. Business Model & Go-to-Market Strategy

4.1 Business Model

Revenue Stream	Structure	Rationale
Subscription (SaaS)	Annual fee per plant: ~QAR 500K/yr (~\$137K/yr) for 800 MWp; scales ~QAR 625/MWp/yr. No hardware OPEX for customer beyond existing SCADA.	Primary recurring revenue. Predictable ARR. Operator motivation: Year 4 breakeven, 4.5x ROI over 10 years. Aligns Prism's incentive with customer savings.
CAPEX Integration	One-time SCADA API layer, edge/cloud compute setup, commissioning. Ceiling: QAR 4.4M per 800 MWp plant (~USD 1.2M). Decreases per-MWp with standardisation.	Second revenue stream per new customer. No recurring field hardware cost. Can be structured as deferred or rolled into Year 1 subscription.
Targeted EL Validation (Services)	Prism's AI flags suspect modules; operator conducts targeted (not whole-plant) EL imaging for confirmation. Prism can manage or coordinate this as a fee-for-service.	High-margin services layer. Converts EL from a large periodic cost into a precise, AI-guided cost — Prism captures part of the savings.
Portfolio Licensing	For O&M firms managing multi-GW portfolios (e.g., ACWA Power, Masdar), volume licensing at discounted per-MWp rate.	Accelerates GCC market penetration. Reference customer unlocks entire portfolio. Gross margin maintained through scale economics.

Unit Economics

At the reference plant (800 MWp, QAR 500K/yr subscription), Prism's 10-year customer LTV (Lifetime Value) is approximately QAR 5M (subscription only) or QAR 5M + CAPEX integration fee if charged. Against a conservative customer acquisition cost (CAC) of QAR 200–400K (business development, pilot costs, proposal preparation), the LTV:CAC ratio is approximately 12:1 to 25:1 — strongly favourable for a SaaS business model.

Gross margin structure is high because the marginal cost of adding a new plant customer is primarily cloud compute (inference at SCADA data volumes is compute-light). Unlike hardware or inspection companies, Prism's COGS does not scale linearly with MWp. The subscription model therefore exhibits improving unit economics at scale.

4.2 Go-to-Market Strategy

Phase	Strategic Focus	Actions	Milestones & Targets
Phase 1 (2025–2026)	Beachhead: Qatar + grant anchor	Secure grant; deploy pilot at Al Kharsaah or partner plant;	1 pilot site; measured power recovery data; proof-of-

Phase	Strategic Focus	Actions	Milestones & Targets
		generate first validated field dataset. Publish results (conference + journal).	concept that SCADA signals carry microcrack signatures. QNF / QSTP grant funding covers Phase 1 CAPEX.
Phase 2 (2027–2028)	First commercial: Qatar + UAE	Convert pilot to paid subscription. Approach 2–3 UAE plants via DEWA / Masdar O&M contacts. Price anchored to demonstrated ROI from Phase 1.	3–5 paying customers; QAR 1.5–2.5M ARR. Enough capital to hire second technical hire and fund Saudi BD.
Phase 3 (2029–2030)	GCC scale: Saudi Arabia + Oman	Enter Saudi Arabia via ACWA Power, NEOM partnership, or SEC tender qualification. Oman via OQ Alternative Energy. Volume licensing to O&M firms.	20–30 GW under monitoring; ~QAR 12–18M ARR. Potential Series A fundraise to fund MENA expansion.
Phase 4 (2030+)	MENA & emerging solar markets	Egypt, Morocco, Pakistan, India (hot-arid climates with high microcrack risk). Possibly license technology or white-label to tier-1 O&M providers.	Platform business: IP + data asset. Potential acquisition target for global O&M or monitoring platform.

4.3 Sales & Distribution Channels

Channel 1: Direct Enterprise Sales (Primary)

Direct engagement with asset managers and O&M directors at the top 10–15 GCC solar operators. Targeted outreach via:

- Gulf Solar Energy (GSE) and WFES (World Future Energy Summit) conference presence.
- Qatar National Research Fund (QNRF) and QSTP (Qatar Science and Technology Park) network introductions to Kahramaa and TotalEnergies operational teams.
- Academic publications as credibility signals: a peer-reviewed paper on the SCADA-based microcrack detection method, citing Al Kharsaah data, functions as a de facto marketing asset for this segment.

Channel 2: O&M Partner Ecosystem

Sign 2–3 O&M service providers as reseller or integration partners. Prism is embedded in their standard O&M toolstack, eliminating the need for direct plant-by-plant sales. O&M partners have existing relationships, procurement approvals, and continuous plant access — Prism provides the intelligence layer.

Channel 3: EPC Commissioning Bundle

Approach major EPC contractors for new-build plants to include Prism as a commissioning deliverable — establishing the baseline T_0 dataset at handover. Prism's SCADA integration work is aligned with the

commissioning phase, creating a natural commercial entry point before the plant operator is even thinking about year-1 O&M.

4.4 Pricing Strategy

Prism's pricing is anchored to value delivered, not cost-plus. The reference price of QAR 625/MWp/yr (~\$172/MWp/yr) is derived from the recoverable loss analysis and sits comfortably within the \$100–300/MWp/yr range for industrial IoT monitoring subscriptions cited in the economic analysis. This creates a simple ROI conversation with plant operators: Prism costs roughly 0.3% of the recoverable value it generates annually.

Volume discount schedule for portfolio deals: 20–30% discount on per-MWp rate for portfolios above 1 GWp, incentivising O&M firms and national utilities to adopt at scale. This maintains revenue growth while accelerating market penetration.

4.5 Regulatory & Partnership Environment

The GCC regulatory environment is structurally favourable for Prism's commercialisation:

- Qatar National Vision 2030 and the associated green energy targets create institutional support for technologies that improve the performance of national solar assets.
- QNRF (Qatar National Research Fund) grant funding covers Phase 1 development, eliminating the seed capital barrier.
- Saudi Arabia's Vision 2030 local content requirements (IKTVA programme) create preference for technology partners willing to establish a local presence — Prism's GCC-first strategy aligns with this.
- IFC and development finance institutions increasingly require digital O&M capabilities as a condition of project finance — creating regulatory pull from the lender side that Prism can leverage.

Strategic Summary

Prism occupies a defensible, unoccupied market position at the intersection of microcrack specificity, SCADA-native detection, and GCC climate expertise. The commercial pathway is clear: grant-funded pilot → validated field data → first commercial customer → O&M channel partnerships → GCC scale. The business model is capital-light, gross-margin-rich, and structurally aligned with the incentives of plant operators who lose QAR 35M per large plant over 10 years without intervention. No direct competitor currently offers this combination.

5. Sources & References

Market data and competitive intelligence in this report is drawn from the following sources:

- Raptor Maps. 2025 & 2026 Global Solar Report. raptormaps.com. Cited for: 193 GWdc analysis base; equipment-driven underperformance \$10B in 2024; drone inspection market \$788M savings.
- DataHorizzon Research (2025). Solar Monitoring Software Market — 11.9% CAGR 2025–2033. USD 1.2B in 2024.
- HTF Market Insights (2025). Drone-Based Solar Inspection Market. USD 1.4B North America; 24.8% CAGR through 2033.
- Clean Energy Associates (CEA). PV Magazine, November 2023. '83% of utility PV sites affected by microcracks; 47% YoY growth in crack incidence.'
- Grand View Research (2025). Middle East Solar PV Market. USD 6.73B in 2024; USD 14.11B by 2033; 8.1% CAGR.
- Mordor Intelligence (2026). Middle East Solar Power Market. 31.91 GW installed capacity 2026; 74.75 GW by 2031.
- Rystad Energy / Gulf News (2024). 'Saudi Arabia achieves record low solar LCOE; region to exceed 100 GW solar by 2030.'
- Sustain Gulf / GCC Renewable Energy Guide (December 2025). GCC 19.3 GW grid-connected renewables as of mid-2025; 40+ GW under construction.
- AGBI (June 2026). 'Saudi Arabia overtakes UAE on GCC renewables.' Saudi Arabia 130 GW target; Qatar 4.5 GW target by 2030.
- Utilities Middle East (March 2025). 'The Middle East's Solar Shift.' UAE \$54B renewables investment; MBR Solar Park 5 GW.
- US DOE FEMP. Monitoring Platforms for Solar PV Systems. Annual cost up to ~\$50,000/yr for 100 MW utility plant.
- PV-Maps.com (June 2026). 'Solar O&M: Real Maintenance Costs per MW.' Predictive maintenance platform €2,000–5,000/yr; 300–500% ROI.
- Ahmed et al. (2025). 'Predictive Maintenance of Solar PV Systems: A Comprehensive Review.' IET Renewable Power Generation. SCADA + ML: 97% fault detection accuracy.
- Datature Blog (March 2026). 'Solar Panel Defect Detection with Vision AI.' Swin Transformer benchmark: 0.87 mAP; equipment underperformance \$10B in 2024.
- Baker Institute (February 2026). 'Gulf Energy Transition.' GCC renewable capacity 160 GW required by 2030; only 14% operational or under construction as of end-2024.