

Government of Bihar
Public Health Engineering Department
Water Quality Report

District:- Nawada Division Name:- Public Health Engineering Division, Nawada

Sample Code:- DL/NWD/256

Sample Collected by:- Gyanoday Vidyalaya, Kashichak (Kunal Gautam)						Date of Sampling:- 11-05-2026												
Sl. NO.	Block	Panchayat	Village	Name of School	Scheme	Test Report										Source of water	Remarks	
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	F			
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
1	Kashichak	Kashichak	Tilak Nagar, Shahpur more	Gyanoday Vidyalaya, Kashichak	Tubewell	7.21	0.62	471	305	140	48	4.8	35	130	0.52	(Tap Water)	Tested Parameters are within permissible Limit.	
						Desirable Limit (IS:10500:2012)												
Permissible Limit in absence of alternate						6.5	1	500	500	200	75	30	250	200	1.0			
						8.5	5	2000	2000	600	200	100	1000	600	1.5			

[Signature]
P.H. Division, Nawada

[Signature]
Assistant Engineer
P.H. Sub, Division, Nawada

[Signature]
Executive Engineer
P.H. Division, Nawada

