



Letter No. HBT-1648-SO-NCR-2025/0441

Date:11.04.2025

To,
Authorized Signatory,
Rajureshwar Infrastructure in JV with V. P. Sethi Construction Pvt Ltd.
Email: srinfraplanning@gmail.com

Name of Work: Improvement to Yeola Nandgaon Pilkhod SH-25 Road (EPC NSK-II (Pkg-20A)) in the state of Maharashtra on EPC Mode. **Subject: Regarding Unsuitable material for Emb. and subgrade layer dumped at site.**

Dear Sir,

Please find here enclosed NCR no.2 issued vide CA clause 11.12 of Article 11 regarding unsuitable material dumped at Ch. 128+900 to 129+100 RHS, 127+000 to 127+400 RHS & 136+100 to 136+650 LHS for Embankment and Subgrade work which are not Conforming to MoRT&H clause 305.2.1.

Hence, remove & relay with fresh material conforming to above mention clause.

Thanks & Regards

(Sanjay Sharma)
TEAM LEADER
Rodic Consultants Pvt. Ltd.
in JV with M/s Geo Designs and Research Pvt. Ltd

Attachment: NCR and Photographs.

CC:1. SE, MSIDC, Mumbai for Information
2. EE, MSIDC, Nashik for Information.

Name of Work: NSK-II (20A) Improvement to Yevla to Nandgaon Pilkhod Road SH- 25 Road Dist. Nashik.																			
Authority Maharashtra State Infrastructure Development Corporation (MSIDC)	Authority Engineer Rodic Consultants Pvt. Ltd. in JV with M/s Geo Designs and Research Pvt. Ltd	ITF	Rajureshwar Infrastructure (75%) in JV with V.P. Sethi Construction Pvt. Ltd. (25%)																
NCR No. C²																			
Department Audited: HW/STR/QC/Safety																			
NCR Date: - 10.04.2025		NCR No. 032																	
Resident Engineer:																			
Team leader:																			
Non-Conformance statement:(Ref Clause 11.12 of CA) Unsuitable Material dumped for EMB and Sub-Grade Layer are not meeting the criteria set forth in clause 305.2.1.4 of MoRT&H. From Ch. 136+100 to 136+650 LHS 128+900 to 129+100 RHS and Ch. 127+000 to 127+400 RHS.																			
Objective Evidence: - Site Photograph																			
EPC Contractor Rep (Sign)	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="8" style="padding: 2px;">NCR Category (Tick One)</th> </tr> <tr> <td style="width: 12.5%; text-align: center;">01</td> <td style="width: 12.5%;"></td> <td style="width: 12.5%;"></td> <td style="width: 12.5%;"></td> <td style="width: 12.5%;"></td> <td style="width: 12.5%;"></td> <td style="width: 12.5%;"></td> <td style="width: 12.5%;"></td> </tr> </table>	NCR Category (Tick One)								01								An ISO 9001 Reference:	
NCR Category (Tick One)																			
01																			
Proposed Remedial Action: Remove and redo the activity as per Standard Specification																			
Proposer.....		Completion																	
Target Date:																			
Corrective/Preventive action																			
Checked by.....		Completion Date:																	
NCR Closed by:																			
EPC Contractor Rep.....		Date																	




[Signature]
RE
PKG- 20A




Copy
RE
PKG- 20-A



[Handwritten signature]
RE
PKG- 20A



[Signature]
RE
PKG- 20-A



08 Apr 2025 04:55:37 PM

Nashik


NSK-II (20A)

Improvement to Yevla Nandgaon Pilkhod Road SH-25

Road Dist. Nashik

Ch :- 136+400 LHS

[Signature]
RE
20-A



[Handwritten Signature]
 RE
 PKG- 20-A



RE
 PKG-20-A