



Letter No. HBT-1648-SO-NCR-2025/0410

Date:02.04.2025

To,

**Authorised Signatory,
Rajureshwar Infrastructure in JV with V. P. Sethi Construction Pvt Ltd.
Email: srinfraplanning@gmail.com**

Name of Work: Improvement to Yeola Nandgaon Pilkhod SH-25 Road (EPC NSK-II (Pkg-20A)) in the state of Maharastra on EPC Mode.

Subject: Regarding Unsuitable material for Emb. And subgrade layer dumped at site.

Dear Sir,

Please find the enclosed NCR no.1 issued vide CA clause 11.12 of Article 11 regarding unsuitable material dumped from Ch. 127+700 to 127+750 LHS, 127+650 LHS, 126+050 to 126+100 LHS, 128+260 to 128+260 to 128+500 LHS, 130+490 to 131+390 LHS, 130+300 to 130+350 RHS. which are not Conforming to MoRT&H clause 305.2.1.

Hence, remove & relay with fresh material conforming to above mention clause.

Thanks & Regards

(Sanjay Sharma)
TEAM LEADER
Rodic Consultants Pvt. Ltd.
in JV with M/s Geo Designs and Research Pvt. Ltd

Attachment: NCR and Photographs.

CC:1. SE, MSIDC, Mumbai for Information
2. EE, MSIDC, Nashik for Information.

Name of Work: NSK-II (20A) Improvement to Yevla to Nandgaon Pilkhod Road SH- 25 Road Dist. Nashik Reg: Obligation of Schedule (P) of CA.

**Authority Maharashtra
State Infrastructure
Development Corporation
(MSIDC)**

**Authority Engineer
Rodric Consultants Pvt.
Ltd. in JV with M/s
Geo Designs and
Research Pvt. Ltd**

ITF

**Rajureshwar Infrastructure
(75%) in JV with V.P. Sethi
Construction Pvt. Ltd.
(25%)**

NCR No.
Env

Department Audited: HW/STR/QC/Safety

NCR Date: - 02.04.2025

NCR No. 01

Resident Engineer

Team leader: -

Non-Conformance statement:(Ref Clause 11.12 of CA) Unsuitable Material dumped for EMB and Sub-Grade Layer are not meeting the criteria set forth in clause 305.2.1.4 of MoRT&H. From Ch. 127+700 to 127+750 LHS, 127+600 to 127+650 LHS, 126+050 to 126+100 LHS, 128+260 to 128+500 LHS, 130+490 to 131+390 LHS, 130+300 to 130+350 RHS.

Objective Evidence: - Site Photograph

EPC Contractor
Rep (Sign)

NCR Category (Tick One)

An ISO 9001 Reference:

01

Proposed Remedial Action: Remove and redo the activity as per Standard Specification

Proposer.....

Completion

Target Date:

Corrective/Preventive action

Checked by.....

Completion Date:







