SOP for Selection of NABL and creation of Gatepass and TRF

1. Open website https://qcportal.mpcz.in choose user login click on submit



2) Login Using Mobile No->Select User Type (TKC Site store)->Enter Registered Mobile No.->Submit



3) Enter the otp and captcha click on SIGN-IN button



4.Click on Select NABL from Side Bar Received material Details page will get open



4. Click on NABL to choose NABL for testing



5. Click on Dropdown to select NABL



6. Select NABL and click on SAVE Button



7. After selection of NABL Click on create TRF for NABL from side bar click on create Gate pass



8. Enter All the Details to create gate pass and click on create Gate pass





9 After Generation of gate pass user can print the gate pass by clicking on print gate pass





10. Again click on create TRF for NABL than click on Send to NABL button


qcuat.mpcz.in:8080/tkc/tkc_wo_trf_create
Incognito
SITE STORE
Site Store Details
Material Receving
Create TRF For NABL
Outward Gatepass
Gatepass History
https://qcuat.mpcz.in:8080/tkc/tkc_wo_trf_create
NO
NUMBER
NAME
NUMBER
GATEPASS FOR NABL
MD/CZ/RDSS/Pck -II (Aug & Addl)/ NoA/118
692
Dispatch Instruction for various size control cable at the work place of vendor M/s NEC Wire & Cables Pvt. Ltd., GB Nagar for Package-II (Additional/ Augmentation of PTR) under RDSS.
STAR DELTA TRANSFORMERS LIMITED
COPPER CONTROL CABLE 12 CORE, 2.5 SQMM PVC UNARMOURED
View
Create Gatepass
Gatepass Not Create
Gatepass/TRF Not Create or Wait for other division
MD/CZ/RDSS/Pck -II (Aug & Addl)/ NoA/118
691
Dispatch Instruction for 140 Kg., 8.0 Mtrs. Long PCC Pole at the works of vendor M/s Malwa Concrete Udyog, Sehore for Package-II (Additional/Augmentation of PTR) under RDSS.
STAR DELTA TRANSFORMERS LIMITED
140 Kg., 8.0 Mtrs. long PCC Poles
View
Create Gatepass
Gatepass Not Create
Gatepass/TRF Not Create or Wait for other division
MD/CZ/RDSS/Pck -II (Aug & Addl)/ NoA/118
434
Dispatch Instruction for 5 MVA Power Transformer at the works of vender M/s Star Delta Tra
STAR DELTA TRANSFORMERS LIMITED
33/11 KV Power transformer , OFTC Type 5000 KVA Loss (4 KW + 23 KW)
View
Gatepass Created
TRF Created
Send Material For Testing


qcuat.mpcz.in:8080/tkc/tkc_wo_trf_create
Incognito
SITE STORE
Site Store Details
WORK ORDER NO
DI NUMBER
DI DESCRIPTION
CONTRACTOR NAME
ITEM
VIEW ITEMS NUMBER
CREATE GATEPASS FOR NABL
CREATE TRF
NABL STATUS
MD/CZ/RDSS/Pck -II (Aug & Addl)/ NoA/118
692
Dispatch Instruction for various size control cable at the work place of vendor M/s NEC Wire & Cables Pvt. Ltd., GB Nagar for Package-II (Additional/ Augmentation of PTR) under RDSS.
STAR DELTA TRANSFORMERS LIMITED
COPPER CONTROL CABLE 12 CORE, 2.5 SQMM PVC UNARMOURED
View
Create Gatepass
Gatepass Not Create
Gatepass/TRF Not Create or Wait for other division
MD/CZ/RDSS/Pck -II (Aug & Addl)/ NoA/118
691
Dispatch Instruction for 140 Kg., 8.0 Mtrs. Long PCC Pole at the works of vendor M/s Malwa Concrete Udyog, Sehore for Package-II (Additional/Augmentation of PTR) under RDSS.
STAR DELTA TRANSFORMERS LIMITED
140 Kg., 8.0 Mtrs. long PCC Poles
View
Gatepass Created
Send To NABL
Gatepass/TRF Not Create or Wait for other division
MD/CZ/RDSS/Pck -II (Aug & Addl)/ NoA/118
434
Dispatch Instruction for 5 MVA Power
STAR DELTA TRANSFORMERS LIMITED
33/11 KV Power transformer , OFTC
View
Gatepass Created
TRF Created
Send Material For Testing

11. After clicking on Send to NABL TRF will open fill all the details and click on Submit



After Clicking On Submit user will get a POPUP click on "OK"



12. User can print the TRF by Clicking on print Button





13. Status will get change into TRF Created



NOTE:

Further Process will be done by NABL