

C150 -Unitrol 1000 parameters

```
-----  
; ABB Switzerland Ltd  
; CMT 1000 v4.111  
;  
; UNITROL 1000 Parameter File  
; Saved: 09.10.2020, 01:15  
; AVR Serial Number: 30091783/0045  
; Control Software Version: 4.310  
; Panel Software Version: 0.000  
-----
```

[SYSTEM DATA]

Ie Nominal=11.2A
Potential Transformer=Three_Phase
UM Nominal=11.000kV
UM Primary=11.000kV
UM Secondary=110.0V
IM2 Nominal=1961A
IM2 Primary=2000A
IM2 Secondary=1.000A
Ie No Load=30.7%
Kceiling=6.70
Xq=1.26

[FIELD FLASHING]

Off Level=0.0%

[SOFTSTART]

Starting Level=0.0%
Hold Time=0.0s
Ramp Time=10.0s

[V/Hz LIMITER]

fKnee=48.0Hz
Slope=100.0%/fknee

[IeMin LIMITER]

Minimum=23.0%
Active=TRUE

[IeMax LIMITER]

Maximum=200.0%
Maximum Hold Time=5.0s
Delayed=120.0%
Delayed Hold Time=60.0s
Continuous=100.0%
Active=TRUE

[PQ LIMITER]

Minimum Q (P @ 0%)=-2.0%
Minimum Q (P @ 25%)=-4.0%
Minimum Q (P @ 50%)=-6.0%
Minimum Q (P @ 75%)=-8.0%
Minimum Q (P @ 100%)=-10.0%
Voltage Dependency=TRUE
Active=TRUE

[UM LIMITER]

Minimum=90.0%
Maximum=110.0%
Minimum Active=TRUE
Maximum Active=TRUE

[BOOST]

Threshold=80.0%
Hold Time=3.0s
Hysteresis=15.0%

C150 -Unitrol 1000 parameters

[AUTO SETPOINT]
Minimum=90.0%
Maximum=110.0%
Ramp Rate=0.30%/s

[PF SETPOINT]
Minimum=-0.9900
Maximum=0.9000
Ramp Rate=0.0100/s

[Var SETPOINT]
Minimum=0.0%
Maximum=100.0%
Ramp Rate=1.00%/s

[MANUAL SETPOINT]
Minimum=30.7%
Maximum=100.0%
Ramp Rate=2.77%/s

[OPEN LOOP SETPOINT]
Minimum=0.0%
Maximum=100.0%
Ramp Rate=1.00%/s

[VDC]
Primary Net ID=1
Secondary Net ID=2
Ramp Up Time=10.0s

[DIGITAL I/O HYSTERESIS]
Low Level=12.0V
High Level=16.0V

[DIGITAL I/O 1]
Input=None
Polarity=Normal
Output=None
Direction=In

[DIGITAL I/O 2]
Input=None
Polarity=Normal
Output=None
Direction=In

[DIGITAL I/O 3]
Input=Decrease
Polarity=Normal
Output=None
Direction=In

[DIGITAL I/O 4]
Input=Increase
Polarity=Normal
Output=None
Direction=In

[DIGITAL INPUT 5]
Input=PF_Enable
Polarity=Normal

[DIGITAL INPUT 6]
Input=Manual_Enable
Polarity=Normal

[DIGITAL INPUT 7]
Input=Gen_CB_Closed

C150 -Unitrol 1000 parameters

Polarity=Normal

[DIGITAL INPUT 8]
Input=Excitation_ON
Polarity=Normal

[DIGITAL INPUT 9 from +AI]
Input=None
Polarity=Normal

[DIGITAL INPUT 10 from -AI]
Input=None
Polarity=Normal

[DIGITAL INPUT 11 from +AI]
Input=None
Polarity=Normal

[DIGITAL INPUT 12 from -AI]
Input=Parallel_With_Grid
Polarity=Inverted

[DIGITAL INPUT 13 from +AI]
Input=None
Polarity=Normal

[DIGITAL INPUT 14 from -AI]
Input=None
Polarity=Normal

[ANALOG INPUT]
Ie Ext Minimum=0.0A
Ie Ext Maximum=30.0A
UM Aux Minimum=-10.0%
UM Aux Maximum=10.0%

[ANALOG INPUT 1]
Input=None
Uin 0%=0.0V
Uin 100%=10.0V

[ANALOG INPUT 2]
Input=None
Uin 0%=0.0V
Uin 100%=10.0V

[ANALOG INPUT 3]
Input=None
Uin 0%=0.0V
Uin 100%=10.0V

[ANALOG OUTPUT]
Output1=None
Output2=None
Uout1 0%=0.0V
Uout1 100%=10.0V
Uout2 0%=0.0V
Uout2 100%=10.0V
Ie 0%=0.0%
Ie 100%=300.0%
Fbias 0%=-3.0Hz
Fbias 100%=3.0Hz

[TUNE AUTO]
Proportional Gain (Vp)=21.5
Derivation Time (Tb)=0.20s
Integration Time (Ta)=3.85s
Droop (Kq)=0.0%

C150 -Unitrol 1000 parameters

[TUNE PF/Var/PQ LIMITER]

Proportional Gain (Vp)=13.0

Integration Time (Ta)=2.00s

[TUNE MANUAL/Ie LIMITER]

Proportional Gain (Vp)=20.0

Integration Time (Ta)=1.00s

[COMMUNICATION]

AVR ID=1

[SYNCHRONIZATION]

Min Slip=0.00Hz

Max Slip=-0.40Hz

MaxDeltaU=5.00%

Max Delta Angle=10deg

Tot CB Close Time=90ms

[DIODE MONITORING]

f Nominal=50.00Hz

f Exc Nominal=50Hz

Tconst Exc=350ms

Active=FALSE

Alarm Level=5.0%

Alarm Delay=10.0s

Trip Level=20.0%

Trip Delay=0.3s