

## Annexure D

### BUILDING SAFETY CERTIFICATE

No. 96/1G (AE-II)/2024

Dated: 06-03-2024

It is certified that the existing building Scholar's Pride Public School (name of the building or premises) at Vill - Mirzapur Pujneki, Block Muzaaffarabad Teh Behet Distt - S.R.E. (address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block (1) ✓	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	(02) Ground + First Floor	—	—	—	—	—

The building is owned/occupied by Scholar's Pride Public School (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of P.D., P.W.D. Saharanpur (Name of Department/ Govt.) on 05-03-2024 (date of inspection) in the presence of Mr. Bhupendra Singh, Chairman, S.P.S., Vill - Mirzapur Pujneki (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 01-03-2024 for a period of 01-03-2029 years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.
- 2.
- 3.
- 4.

Issued on 06-03-2024 at Saharanpur by

\* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal :

Name :

Designation :

Name & Address of Department/ Office:

66 | Page

Reetu

Manager

Scholar's Pride Public School  
Vill-Mirzapur Pujneki (Karondi)  
Saharanpur-247120 (U.P.)

Principal

Scholar's Pride Public School  
Vill. Mirzapur Pujneki (Karondi)  
Saharanpur-247001

APPENDIX- X

**BUILDING SAFETY CERTIFICATE**

No. 96/IC(AE-II)/2024

Dated: 06-03-2024

Certified that the **Scholar's Pride Public School** (name of the building or premises) at **Village Mirjapur Pujneki Block Muzaffarabad, Tehsil Behat, Distt Saharanpur** (address) comprised of basement(s) N.A. and Ground + First Floor (upper floors) owned/occupied by **Scholar's Pride Public School** (name of the Institution) have complied with the Building Bye Laws in accordance with rule of State/UT, and incorporate the provisions of building safety as specified in National Building Code 2005, 2016 and as amended thereafter and has been verified by the concerned officer of **P.D., P.W.D., Saharanpur** (Name of Department/Govt) on **05-03-2024** (date of inspection) in the presence of **Mr. Bhupender Singh, Chairman, Scholar's Pride Public School, Village Mirjapur Pujneki Block Muzaffarabad, Tehsil Behat, Distt Saharanpur** (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes 1st to 12<sup>th</sup> with effect from 01.03.2024 for a period of 5 years in accordance with rules and subject to compliance of the specific conditions as appended.

Issued on **06-03-2024** at Saharanpur by Er. Praveen Gairi, Assistant Engineer, P.D., P.W.D. Saharanpur

Reetu

Manager

Scholar's Pride Public School  
Vill-Mirjapur Pujneki (Karondi)  
Saharanpur-247120 (U.P.)

Building Code Check list

सहायक अभियन्ता  
प्रादेशीय खण्ड लोनिवि  
सहारनपुर

Principal

Scholar's Pride Public School  
Vill. Mirjapur Pujneki (Karondi)  
Saharanpur-247001



# विद्यालयों में सुरक्षा विशेषकर अग्नि से सुरक्षा सम्बन्धी चेकलिस्ट

## (क) उच्चतर माध्यमिक विद्यालय (कक्षा-1 से कक्षा-12)

स्कूलर्स प्राइड पब्लिक स्कूल,  
ग्राम मिर्जापुर पुजनेकी, तहसील बेहट, जनता रोड, सहारनपुर

क्र० सं०	सुरक्षा सम्बन्धी तकनीकी बिन्दु	निरीक्षण आख्या
	<b>भवन की चेक लिस्ट</b>	
1	क्या भवन का मानचित्र पंजीकृत आर्किटेक्ट/इंजीनियर से बनवाया गया है?	हाँ
2	क्या भवन मानचित्र स्थानीय निकाय/प्राधिकरण/सक्षम अधिकारी द्वारा स्वीकृत है?	नहीं
3	क्या भवन एक मंजिल से ऊंचा है?	हाँ
4	क्या हेतु भूमि का न्यूनतम क्षेत्रफल 0.4 हेक्टेयर (4000 वर्गमी०) है?	नहीं (3968 वर्गमी०)
5	क्या भवन के चारों तरफ 6.0 मी० खुला स्थान है अथवा नहीं?	हाँ
6	क्या भवन का ओरिएन्टेशन ऐसा है कि पर्याप्त प्रकाश एवं हवा का सर्कुलेशन है?	हाँ
7	क्या मुख्य पहुंच मार्ग (Approach Road) की चौड़ाई न्यूनतम 12 मी० है?	हाँ
8	क्या भवन की छत R.C.C. की बनी है? यदि नहीं तो क्या छत निर्माण में ज्वलनशील सामग्री तो प्रयोग में नहीं लाई गयी?	हाँ
9	क्या भवन की दीवारें ईट या पत्थर की सिमेंट मसाले से बनी हैं?	हाँ
10	क्या भवन की दीवारों/ छतों में क्रैक है?	नहीं
11	क्या कक्षों की छतों की ऊंचाई फर्श से न्यूनतम 3.6 मी० (ठंडे क्षेत्रों में 3.0 मी०) है?	हाँ
12	क्या विद्यालय के मुख्य प्रवेश द्वार (बाण्डीवाल गेट) की चौड़ाई 4.5 मी० एवं ऊंचाई 4.5 मी० है?	हाँ
13	क्या खिड़कियों का क्षेत्रफल कक्ष के फर्श क्षेत्रफल का न्यूनतम 10 प्रतिशत है?	हाँ
14	क्या कक्षा में न्यूनतम दो दरवाजे हैं?	हाँ
15	क्या कक्षा में दरवाजों की न्यूनतम माप (चौड़ाई 1.0 मी० ऊंचाई 2.0 मी०) है?	हाँ
16	क्या एक मंजिल से अधिक उंचे भवन में जीने की चौड़ाई न्यूनतम 1200 मिमी०, ट्रेड 210 मिमी० तथा राइजर 150 मिमी० है?	हाँ
17	क्या भवन के कोरीडोर की उंचाई न्यूनतम 2400 मिमी० है?	हाँ
18	क्या भवन के कक्षों से जीने की अधिकतम दूरी 22.50 मी० है?	हाँ

Building Code Check list

Reetu  
Manager

Scholar's Pride Public School  
Vill-Mirzapur Pujneki (Karondi)  
Saharanpur-247120 (U.P.)


Principal

Scholar's Pride Public School  
Vill. Mirzapur Pujneki (Karondi)  
Saharanpur-247001

सहायक अभियन्ता,  
प्रादेशिक खण्ड स्० नि० वि०  
सहारनपुर



19	क्या भवन में रसोई घर मुख्य भवन में स्थित है?	हाँ
20	क्या भवन में कोई ज्वलनशील पदार्थ अथवा जहरीला रसायन रखा जाता है?	नहीं
21	क्या भवन की आंतरिक फिनिश में शीघ्र ज्वलनशील सामग्री का प्रयोग तो नहीं किया गया?	नहीं
22	क्या भवन की छत पर पानी की टंकी है?	हाँ (3x1000)
23	क्या भवन में मुख्य द्वार के अतिरिक्त आकस्मिक निकास की व्यवस्था है?	नहीं
24	क्या सक्षम अधिकारी से भवन का Structural Stability प्रमाण पत्र प्राप्त किया गया है या नहीं?	नहीं
25	क्या दस वर्ष के उपरान्त भवन निरीक्षण की पुनः आवश्यकता है अथवा नहीं	हाँ

  
 सहायक अभियन्ता  
 प्रांतीय खण्ड लो०नि०वि०  
 सहारनपुर

Reetu  
 Manager  
 Scholar's Pride Public School  
 Vill-Mirzapur Pujneki (Karondi)  
 Saharanpur-247120 (U.P.)

  
 Principal  
 Scholar's Pride Public School  
 Vill. Mirzapur Pujneki (Karondi)  
 Saharanpur-247001