

SOP FOR TURBO BLOWER SHUTDOWN:

In case of excessive blade vibration exceeding 6.8 mm/s, execute manual bypass.

Emergency officer: Mr. Alok Sharma at 555-0811.