

Project:

REPLACE 56" ABQAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.
SA-AYPP-MTA-009

SAUDI ARABIAN OIL COMPANY

CONTRACT FOR THE
ENGINEERING, PROCUREMENT AND CONSTRUCTION

**REPLACE 56" ABQAIQ YANBU PIPELINE (AY-1L) –
SECTION 7**

SOLAR POWER SYSTEM

S.A. DUMMY #:
LZIK-K18-17-A065-DA

PREPARED BY

WORLEY

FOR

BIN QURAYA COMPANY LIMITED

Revision - 00 -



Project:

REPLACE 56" ABQAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

Section 1

Scope Of Supply

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

TABLE OF CONTENTS

1.1. SCOPE OF SUPPLY - SOLAR POWER SYSTEM	1-3
1.2. EQUIPMENT / MATERIAL DESCRIPTION	1-4
<u>A. LINE-ITEM NO. 001: SOLAR POWER SYSTEM</u>	<u>1-4</u>
A.1 MATERIAL DESCRIPTION	1-4
A.2 BILL OF MATERIALS: 01 BOM SA-AYPP-MTA-009 SOLAR POWER SYSTEM	1-6
A.3 SUBCOMPONENT LIST:	1-6
A.4 NOTES:	1-6
A.5 REFERENCES	1-6
1.3. SPARE PARTS DATA PACKAGE	1-7
1.4. START-UP COMMISSIONING SPARE PARTS	1-7
1.5. INCIDENTAL SERVICES (IF REQUIRED)	1-8
1.5.1 DETAILED SCOPE OF WORK	1-8
1.5.2 ESTIMATED DATE OF INSTALLATION	1-8
1.5.3 EXPECTED DURATION (NUMBER OF DAYS OR WEEKS) OF THE INCIDENTAL SERVICES	1-8
1.5.4 JOB TITLES AND RATES	1-8
1.6. LIST OF ATTACHMENT	1-9

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

1.1. **SCOPE OF SUPPLY - SOLAR POWER SYSTEM**

Vendor shall be responsible for the design, engineering, supply of materials, manufacturing, assembly, shop testing and packing for delivery of materials listed in the present requisition.

Vendor shall assume responsibility for the design, engineering, fabrication, inspection testing and shipment.

Items shall comply with all the applicable standards code and regulations.

All items not specifically mentioned in this specification, but necessary and required to form an operational system as described herein, shall be identified and provided by the Vendor as part of the system.

Any errors or omissions in this specification shall not absolve the Vendor from the responsibility of designing and providing complete and fully functional equipment as described in this requisition.

The design / manufacturing of the Items / Materials shall be in accordance to all specifications, drawings, procedures, standards and other documents attached hereto and with the best modern practice and shall be such to facilitate inspection, cleaning, maintenance and repair to ensure satisfactory operation of the Items / Materials under all service Conditions

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.
SA-AYPP-MTA-009 Rev. 00

1.2. EQUIPMENT / MATERIAL DESCRIPTION

A. LINE-ITEM NO. 001: SOLAR POWER SYSTEM

9COM	DESCRIPTION OF 9COM	LOI
6000001239	POWER SUPPLY SYSTEM: SOLAR, PHOTOVOLTAIC TYPE, OFF-GRID, INCLUDING ALL COMPONENTS & ACCESSORIES	NON-INSPECTABLE

A.1 MATERIAL DESCRIPTION

SOLAR SYSTEM: 24VDC, PHOTOVOLTAIC, SYSTEM UNIT CONSISTS OF THE FOLLOWING PRIMARY COMPONENTS:

- AN ARRAY OF PHOTOVOLTAIC MODULES. (EACH STRING OF SOLAR PHOTOVOLTAIC MODULE SHALL BE EQUIPPED WITH A SHOTTKY BLOCKING DIODE). MODULES SHOULD BE MONO-CRYSTALLINE AND POLY-CRYSTALLINE TYPE ONLY.
- AN ARRAY CONTROL CENTER (CONSISTING OF PMW CHARGE CONTROLLER, METERING & CONTROL CIRCUITS, INTERCONNECTING HARDWARE, WIRING AND ENCLOSURES, COMBINER JUNCTION BOX, SOLAR MODULE JUNCTION BOXES)
- SUPPORTING STRUCTURES, HOT-DIPPED GALVANIZED PER ASTM A123.
- 24VDC POWER PANEL

SOLAR ARRAY ANGLE CALCULATION

BATTERIES SHALL BE NICKEL CADMIUM AND IN COMPLIANCE WITH 17-SAMSS-511.

GROUNDING & LIGHTNING PROTECTION FOR COMPLETE SOLAR SYSTEM AS PER SAES-P-111.

THE PROVIDED PHOTOVOLTAIC SYSTEM SHOULD BE FULLY COMPLIANCE WITH SAES-P-128 & SAES-P-103.

FUSED DISCONNECT COMBINER BETWEEN PV ARRAYS AND CHARGE CONTROLLER.

VENDOR SHALL BE RESPONSIBLE FOR SOLAR SYSTEM DESIGN, ASSEMBLY AND SUPPLY OF MATERIALS, ASSISTANCE AND SUPERVISION FOR INSTALLATION, TESTING AND COMMISSIONING OF 24VDC SOLAR SYSTEM.

ALL REQUIRED HARDWARE, SOFTWARE SYSTEM ENGINEERING AND SERVICES, DOCUMENTATION AND ACCESSORIES TO FORM A COMPLETE AND FUNCTIONAL WORKING SYSTEM TO PROVIDE POWER TO THE NEW EQUIPMENT IN ACCORDANCE WITH SAUDI ENGINEERING STANDARD SAES-P-128 & SAES-P-103.

SOLAR (PHOTOVOLTAIC) POWER SUPPLY SHALL BE SUPPLIED IN ACCORDANCE WITH THE BELOW DATA.

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

SYSTEM DESIGN OPERATION:

BATTERY CAPACITY: FULLY CHARGED - 5 DAYS FULL OPERATION OF ELECTRONIC LOAD WITHOUT SOLAR CHARGING. THE SOLAR PANELS TO BE USED SHALL HAVE DEMONSTRATED AT LEAST FIVE (5) YEARS OF FIELD USE IN SAUDI ARABIA OR OTHER MIDDLE EASTERN DESERT ENVIRONMENTS. THE PHOTOVOLTAIC BATTERY SYSTEM SHALL BE DESIGNED AND SIZED IN ACCORDANCE WITH SAUDI ENGINEERING STANDARD SAES-P-103.

SOLAR PANEL STRUCTURE AND MOUNTING

THE SOLAR PANEL STRUCTURE AND MOUNTING SHALL MEET THE FOLLOWING REQUIREMENTS:

1. ALL SUPPORTING STRUCTURE AND HARDWARE SHALL BE OF NON-CORROSIVE MATERIALS.
2. THE ENTIRE STRUCTURE SHALL BE CAPABLE OF WITHSTANDING WIND VELOCITIES IN EXCESS OF 145 KM/HOUR WITHOUT DAMAGE.
3. THE SOLAR PANEL SUPPORT STRUCTURE SHALL BE MOUNTED AT THE OPTIMUM AZIMUTH AND TILT ANGLE FOR MAXIMUM ELECTRICAL OUTPUT DURING THE WINTER SOLSTICE.
4. SOLAR PHOTOVOLTAIC ARRAY SHALL BE DIRECTED TOWARD THE GEOGRAPHICAL SOUTH (± 5 DEGREES).
5. SUPPORTING STRUCTURE SHALL BE DESIGNED IN ACCORDANCE WITH 12-SAMSS-007

FOUNDATION DESIGN DATA

THE VENDOR SHALL PROVIDE ALL DATA REQUIRED FOR PERFORMING THE FOUNDATION DESIGN. AS A MINIMUM, THE VENDOR SHALL PROVIDE BEARING LOADS AND WIND INDUCED FORCES ON THE FOUNDATION FOR THE SOLAR PANEL ARRAY FOUNDATIONS.

THE VENDOR SHALL PROVIDE ANCHOR BOLT SPECIFICATIONS, SIZE, TYPE, LOCATION AND PROJECTION. REFER TO ARAMCO STANDARD DRAWING AA-036322.001 REV. 08 FOR ANCHOR BOLT DETAILS.

SERVICE CONDITIONS:

THE PHOTOVOLTAIC (SOLAR) POWER SUPPLY ASSEMBLY SHALL BE WEATHERPROOF, CORROSIVE RESISTANT, SUITABLE FOR CONTINUOUS OPERATION AT 56°C EFFECTIVE AMBIENT TEMPERATURE AND IN ACCORDANCE WITH SAUDI ENGINEERING STANDARD SAES-A-112.

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

A.2 BILL OF MATERIALS: 01 BOM SA-AYPP-MTA-009 SOLAR POWER SYSTEM

A.3 SUBCOMPONENT LIST:

VENDOR SHALL PROCURE THE SUBCOMPONENT THROUGH THE FOLLOWING 9COM

9COM	DESCRIPTION	SAMSS	SA-175 FORM	IR LEVEL
6000001076	BATTERY: NICKEL-CADMIUM STA. STORAGE	17-SAMSS-511	NA	Level 0
6000000859	PANELBOARD; LOW VOLTAGE, NON-XPROOF	16-SAMSS-518	NA	Level 0

A.4 NOTES:

- THE ATTACHED BILL OF MATERIAL IS AS PER 60% DESIGN DOCUMENTS AT THIS STAGE AND IS SUBJECT TO CHANGES AS PER DETAILED DESIGN DEVELOPMENT.
- FINAL TAG NUMBERS, DESIGN PARAMETERS, AND TECHNICAL SPECIFICATIONS SHALL BE AS PER APPROVED IFC DESIGN PACKAGE.
- FINAL COUNT WILL BE CONFIRMED UPON PLACEMENT OF PURCHASE ORDER.
- SUB-ORDERS SHALL BE UNDER PROJECT STANDARD CUT-OFF **31 MAY 2023**.
- VENDOR SHALL SUBMIT SVL FOR THE ARAMCO APPROVAL AND ALL SUB ITEMS SHALL BE PROCURED FROM ARAMCO APPROVED SOURCE.

A.5 REFERENCES

NOTE-1:

SAUDI ARAMCO STANDARDS CUT-OFF DATE - **31 MAY 2023**.

NOTE-2:

REFERENCES TO SAUDI ARAMCO REQUIREMENTS, PROJECT SPECIFIC DOCUMENTS AND SPECIFICATIONS ARE LISTED IN PARA 1.6

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

1.3. **SPARE PARTS DATA PACKAGE**

The Spare Part Data Package (SPDP) requirements for this enquiry / purchase requisition shall be based on the vendors recommendations for two (2) years operating spare parts.

The SPDP is required to be submitted in accordance with SAUDI ARAMCO procedure SAEP-31:

Appendix B - Spare Parts Data Package Submittal Plan Format

Appendix C - Supplier Instructions

Appendix D - General Cataloguing Criteria & Equipment Templates

Appendix E - Equipment Prices Spare Parts List - Request for Waiver from SPDP (SAEP-302)

A capital spare parts list for two (2) years operation is also required.

The SPDP, unless specified to the contrary, requires delivery of both hard copy (as referenced above) and electronic copy data (via CD). The SPDP is to be submitted no later than 90 calendar days prior to the shipment date of the equipment.

The supplier shall note that at least 20% of the full value of this purchase order will be withheld until all of the applicable SPDP requirements have been delivered and accepted by SAUDI ARAMCO or BIN QURAYA COMPANY LIMITED.

Supplier must use the forms and formats provided for the data to be considered acceptable.

The SPDP shall be prepared in accordance with:

SAUDI ARAMCO SPARE PARTS DATA PACKAGE (SPDP)

SAEP-31 - Corporate Equipment and Spare Parts Data Requirements and Responsibilities

Data Requirements Appendices - For LSTK CONTRACTOR Procured Equipment

Hard copies 3 nos. and soft copy 1 no.

1.4. **START-UP COMMISSIONING SPARE PARTS**

Start-up and Commissioning Spare Parts, being parts or components required during construction, pre-commissioning and commissioning.

Start-up and Commissioning Spare Parts shall be advised by the supplier and agreed by SAUDI ARAMCO Spare parts data shall be submitted in accordance with Spare Data Package (SPDP) appendices C and D.

The supplier shall provide a list of start-up spares required for commissioning and start-up. This shall also be provided in electronic media via CD. This list shall identify all materials required by:

- Manufacturer Part Number
- Description
- Quantity recommended

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.
SA-AYPP-MTA-009 Rev. 00

- Unit Of
- Issue Price
- Volume
- Unit weight of each item if greater than one pound (1 lb)

Spare parts and data shall be in accordance with attached documents listed below and technical specification attached.

1.5. INCIDENTAL SERVICES (IF REQUIRED)

1.5.1 Detailed Scope of Work

Technical / Commissioning assistance from the vendor is required to include in the following:

- Installation Supervision – if required
- Commissioning / site acceptance testing – if required
- Training and system support – if required
- Other assistance required in the technical specification – if required

1.5.2 Estimated Date of Installation

Vendor to advise

1.5.3 Expected Duration (Number of Days or Weeks) of the Incidental Services

Vendor to advise

1.5.4 Job Titles and Rates

Vendor to provide the Job Title and rates of all required personnel

Project:

 REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
 SOLAR POWER SYSTEM

 Contract No. (SA)
6601019567

 SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

1.6. LIST OF ATTACHMENT

Note: Any of the Engineering Standards, Procedures, Specifications, Mandatory Drawings cross referenced in the following Standards and Documents shall be taken from **31 MAY 2023** issue of **SAUDI ARAMCO** Desktop Standards.

DOCUMENT	SHT.	REV.	ISSUE DATE	TITLE
ENGINEERING DATA SHEETS / TECH SPECS / DRAWINGS/ETC				
BOM				BILL OF MATERIAL
VE -077567	001	B	10/19/2025	DATA SHEET - POWER PANEL K18-(SP-001)-PP-0001
VE-077568	001-004	B	10/19/2025	DATA SHEET: STATIONARY BATTERIES K18-(SP-001)-SB-0001
VE-077552	001	B	10/19/2025	DATA SHEET - POWER PANEL K18-(SP-002)-PP-0001
VE-077553	001-004	B	10/19/2025	DATA SHEET: STATIONARY BATTERIES K18-(SP-002)-SB-0001
VE -077582	001	B	10/19/2025	DATA SHEET - POWER PANEL K18-(SP-003)-PP-0001
VE-077583	001-004	B	10/19/2025	DATA SHEET: STATIONARY BATTERIES K18-(SP-003)-SB-0001
VA-077561	001	B	10/19/2025	EIL-MLIV STATION @ KM. 3.40
VA-077546	001	B	10/19/2025	EIL-MLIV STATION @ KM.19.400
VA-077576	001	B	10/19/2025	EIL-MLIV STATION @ KM. 34.00
VE- 200705	001-017	B	10/19/2025	SOLAR SYSTEM SIZING CALCULATION
SAUDI ARAMCO MATERIAL SYSTEM SPECIFICATIONS				
16-SAMSS-518			08/24/2021	Low Voltage Panel boards
17-SAMSS-511			11/23/2021	Stationary Storage Batteries
SAUDI ARAMCO ENGINEERING STANDARDS				
SAES-M-001			05/30/2022	Structural Design Criteria for Non-Building Structures
SAES-A-112			06/27/2022	Meteorological and Seismic Design Data
SAES-A-202			12/12/2022	Saudi Aramco Engineering Drawing Preparation
SAES-J-902			03/26/2020	Electrical Systems for Instrumentation
SAES-P-100			04/28/2022	Basic Power System Design Criteria
SAES-P-103			03/27/2022	UPS and DC Systems
SAES-P-104			12/29/2021	Wiring Methods and Materials
SAES-P-111			11/09/2021	Grounding
SAES-P-128			02/28/2022	Off-grid Solar Photovoltaic (PV) System with Battery Storage
SAUDI ARAMCO ENGINEERING PROCEDURES				

Project:

REPLACE 56" ABOAIQ YANBU PIPELINE (AY-1L) – SECTION 7
SOLAR POWER SYSTEM

Contract No. (SA)
6601019567

SA BI No.
BI-10-01575

Document No.

SA-AYPP-MTA-009 Rev. 00

DOCUMENT	SHT.	REV.	ISSUE DATE	TITLE
SAEP-31			03/16/2023	Corporate Equipment and Spare Parts Data Requirements and Responsibilities
SAEP-302			03/15/2023	Waiver of a Mandatory Saudi Aramco Engineering Requirement
SAEP-350			03/22/2021	Regular Maintenance and Testing for Industrial Stationary Batteries
SAEP-385			02/25/2021	Preservation of Project Materials and Equipment
SAEP-1142			04/17/2022	Qualification of non-Saudi Aramco NDT Personnel
SAEP-1151			01/12/2021	Inspection Requirements for Contractor Procured Materials and Equipment
SAUDI ARAMCO STANDARD DRAWINGS				
AA-036322	001	08	12/2020	Anchor Bolt Details, Inch and Metric Sizes
DD-950022	008	00	-	Ground Connections Details Structural Steel to Ground Grid
SAUDI ARAMCO INSPECTION FORMS				
175-000003			09/2021	Detailed Instructions of Inspection and Testing Requirements
NON-MATERIAL REQUIREMENT FORMS				
SA-7930-1		00	10/21/2025	Non-Material Requirements for Stationary Battery
SA-7930-2		00	10/21/2025	Non-Material Requirements for LV Panelboards
SA-7930-3		00	10/21/2025	Non-Material Requirements for Solar System
WPECC-SDS-0001				Supplier Document Schedule
SAUDI ARAMCO PACKING SPECIFICATIONS				
MS 8314-00			05/2005	General Packing Specification for Containerizable, Air Shipment, and Overland Transport Cargo
MS 8314-02			05/2005	General Packing Specification for Break Bulk Cargo
MS 8314-04			05/2005	Wooden Crate Packing Specification
MS 8314-10			05/2005	General Packing Specification for Spare Parts
MS 8444-14			05/2005	Additional Packing, Packaging and/or Marking Requirements

**BILL OF MATERIALS - SOLAR POWER SYSTEM
AY-1L PIPELINE SECTION - 7**

REFERENCE MR [SA.AYPP-MTA-009](#)

Rev. 00

MR L/I	9COM	LOI	PLANT No.:	PIPELINE	LOCATION	MATL / EQPT TYPE	SOLAR CHARGER CONTROLLER TAG NUMBER	RATING	ELECTRICAL ONE-LINE DIAGRAM	STATIONARY STORAGE BATTERIES TAG NUMBER	COMPONENTS DATA SCHEDULE		POWER PANEL TAG NO.	DATA SCHEDULE OF POWER PANEL	SOLAR SIZING CALCULATION	TOTAL MR QTY		Remarks
											CHARGE REGULATOR	STATIONARY STORAGE BATTERIES				QTY	UNIT	
1.1	6000001239	NI	K18	AY-1L PIPELINE	MLIV - 1 @KM. 3.40	SOLAR (PHOTOVOLTAIC)	K18-(SP-001)-BC-0001	24 VDC 400 AMP 1400 AH (4 SETS) @ C5	VA-077561.001	K18-(SP-001)-SB-0001	VENDOR TO PROVIDE DATA SHEET OR PRODUCT CATALOG FOR CHARGER CONTROLLER	VE-077568	K18-(SP-001)-PP-0001	VE - 077567.001	VE-200705	1	SET	
1.2	6000001239	NI	K18	AY-1L PIPELINE	MLIV - 2 @KM. 19.40	SOLAR (PHOTOVOLTAIC)	K18-(SP-002)-BC-0001	24 VDC 30 AMP 325 AH (1 SET) @ C5	VA-077546.001	K18-(SP-002)-SB-0001	VENDOR TO PROVIDE DATA SHEET OR PRODUCT CATALOG FOR CHARGER CONTROLLER	VE-077553	K18-(SP-002)-PP-0001	VE - 077552.001	VE-200705	1	SET	
1.3	6000001239	NI	K18	AY-1L PIPELINE	MLIV - 3 @KM. 34.00	SOLAR (PHOTOVOLTAIC)	K18-(SP-003)-BC-0001	24 VDC 400 AMP 1400 AH (4 SETS) @ C5	VA-077576.001	K18-(SP-003)-SB-0001	VENDOR TO PROVIDE DATA SHEET OR PRODUCT CATALOG FOR CHARGER CONTROLLER	VE-077583	E31-E31-SOLAR-PP-003 E31-E31-SOLAR-PP-004	VE-077582.001	VE-200705	1	SET	