Supporting Information for "Measure missingness where the statistic lives: a continuous screening law for gap-affected stream-temperature records"

AUTHOR ONE[1]

[1]AFFILIATION PENDING AUTHOR CONFIRMATION

Contents of this file

1. Text S1 to S6
2. Figures S1 to S5
3. Table S1

Introduction

This supporting information records what belongs to the record rather than to the argument: data provenance, protocol history, the predictions declared for this round that were not met, the runs that were discarded and why, and the reproduction path. Nothing here is required to follow the article.

S1 Data sources

Daily water-temperature series were assembled from nine public providers (Table S1). All are open archives; none required a data-use agreement.

Station coordinates were assembled for all 457 stations: from the providers' own catalogues already held in the repository for FOEN, CHMI, SYKE, LUBW, GKD Bayern, NVE and Rijkswaterstaat and for nine USGS gauges; from the USGS NWIS site service for the remaining 195 United States gauges; and from ARSO's public station feed for all 47 Slovenian stations. Every row of the coordinate table in the repository records its source.

Daily 2 m air temperature is NASA POWER (MERRA-2), 1 January 1981 to 31 August 2026, one point per station at the product's native resolution: 16,679 days for each of the 457 stations. An earlier version of this study used a much smaller forcing ta-

Table S1. Providers and their role in the study.

provider	country	role
ARSO	Slovenia	development and reserved
CHMI	Czechia	development and reserved
FOEN	Switzerland	development
GKD Bayern	Germany (Bavaria)	development and reserved
LUBW	Germany (Baden-Württemberg)	development and reserved
NVE	Norway	development and reserved
Rijkswaterstaat	Netherlands	development
SYKE	Finland	development
USGS	United States	development and reserved

ble covering 2.3% of development cases; both are retained and Section 5.7 of the article compares them.

Basin characteristics for the United States subset are GAGES-II, joined on the eight-digit gauge identifier and matching 140 of 204 eligible stations.

S2 Quality control and the definition of a network

A *network* is a provider's group of stations on a common river system, which is the unit at which donor stations are available to one another. Networks are the clustering unit for every interval in the article, because station-years within a network share weather, regulation and instrumentation.

Waterbody class was assigned per network from the provider's own naming and an explicit map; seas, lakes, canals, estuaries and deltas are listed and excluded rather than averaged into a river result. Reference series are never imputed: a calendar year with any missing day contributes no truth. Stations with fewer than four fully observed calendar years are excluded, because the leave-one-year-out estimator protocol requires them. The resulting denominator, with every exclusion and its count, is in the repository. The same stations contribute 2422 station-years with at least 360 daily slots and at least one missing day; those form the deployment panel of Section 5.10 of the article.

S3 Protocol history

The study was pre-registered before the reserved networks were opened on 2026-09-23. Three aspects of that freeze were incomplete or wrong and are recorded here rather than silently repaired.

The incumbent's imputed limit was mis-stated. An earlier version placed the comparison at a thirteen-week (91-day) limit attributed to Johnson et al. (2021). The source says twenty weeks. The analysis code now uses 140 days and every artifact that used the old value was re-run; Section 5.6 of the article reports the corrected operating point. The direction of the error flattered the incumbent at that point, so correcting it reduces the screen's advantage there from 6.2 to 4.4 percentage points.

The weighting between outage arms was not declared. The case set mixes an empirical arm, drawn from the outage geometry the same networks experience, with a stratified arm built to span the decision space. Their base rates differ by an order of magnitude. The pre-registered test was run on the pooled set, as declared; Section 5.9 reports the decomposition and states that the declared effect is not met on the empirical arm alone.

The natural scale of the peak has two values. Computed over the full eligible roster it is 1.06 °C; recomputed inside the development case table it is 1.08 °C. The primary tolerance is 0.50 °C throughout except in cross-metric comparisons, where each endpoint's scale is recomputed on the same footing. The tolerance sweep shows the axis ordering is unchanged between 0.25 and 1.0 standard deviations.

S4 Predictions that failed

Three predictions were written down before the analyses that tested them and were not met. All three are in the article; they are gathered here because a reader looking for them should not have to hunt.

1. *The support-restricted advantage will decay monotonically in the support width.*
   It does not: it is a hump peaking at a 60-day support.
2. *The estimand's own support is the best conditioning set at every support width.*
   It is not: below 30 days a fixed 30-day window beats it.

3. *For the sine-fit phase, two hand-chosen transition windows will beat both peak-window overlap and outage length.* They beat peak overlap decisively and tie outage length.

Failures 1 and 2 have one cause, which we then measured: the support's location is itself uncertain, so the conditioning set has to be the support dilated by that uncertainty. Failure 3 has a related cause: a hand-drawn window is a crude approximation to an influence function that is spread over half the year.

A fourth statement was *withdrawn* rather than falsified. An earlier version framed the standing guidance as getting an ordering backwards. On the guidance's own estimands it does not; Section 5.4 of the article reports that a completeness threshold is the correct axis for the sine-fit mean and within 0.02 AUC of the best for the phase.

S5 Runs that were discarded

Two defects made specific artifacts unusable and both were repaired before the reserved panel was opened: outage realizations were seeded from a process-salted hash, so the case table could not be regenerated, and worker results were concatenated in completion order, so the row order was not reproducible even though the content was. A third defect affected the calibration rather than the data: an additive, per-estimator conformal scheme under-covered, because selecting the smallest of several bounds is a winner's curse that per-estimator calibration cannot see. In all three cases the affected numbers were discarded rather than reported alongside the repaired ones, and the pipeline was re-run in full.

S6 Verification and reproduction

- The case table is byte-reproducible including row order, pinned by a test.
- The extended endpoint table regenerates the same 51,524 realizations from the same deterministic seeds, which is how its rows line up with the main case table; a test checks the alignment.
- No feature may read a day the outage hides; enforced in the feature constructor and pinned by a test.
- Every table cell and audited inline number in the article is re-derived from the artifacts by an audit script that the test suite runs.




Figure S1. The evidence chain by research question. Every link is labelled with the section that establishes it; the deployment and consequence links, drawn open in earlier versions of this work, are closed here, and the consequence link carries the finding that the regional aggregate barely moves.

- The schematic figures are generated from editable draw.io sources held in the repository; a test checks that each exported PDF is newer than its source.

Figure S1 lays the study out as a chain and labels each link with the research question that establishes it, including the two links that earlier versions of this work left open and this one closes.

S7 Supporting figures




Figure S2. The screening system in detail. Left: the features visible at decision time, under an information barrier that forbids any feature from reading a day the gap hides. Centre: the estimator library with per-case support, the risk model, estimator selection, and the selection-conditional multiplicative conformal calibration. Bottom: the two action spaces the same calibrated object supports.




Figure S3. Multi-year trend error (a) and the donor controls (b). The panel averages eleven complete years per station, which is too short to resolve a decadal trend; the slope error is reported as a diagnostic of the reconstruction rather than as a trend estimate.




Figure S4. Network-clustered intervals on the axis contrasts (a), the reference-noise perturbation (b), and the exceedance-threshold sweep (c).




Figure S5. What an agency does with the result: which endpoint, where the peak window comes from, the three numbers of the deployable rule, the representativeness guardrail, and what the substitution buys on networks never used for fitting.