NOTES:
1. ALL NOTES AND SYMBOLS ON DRAWING 10-055-E000 APPLY TO THIS DRAWING.
2. PROVIDE CONTROL WIRING FROM AUXILIARY CONTACT IN THE DISCONNECT SWITCH TO DISABLE THE VFD WHEN THE SWITCH IS OPENED.
3. CONTRACTOR SHALL LOCATE AND MOUNT LIGHT FIXTURES, TYPE L11 AND WEATHER PROOF LIGHT SWITCH ON THE EQUIPMENT IN A LOCATION TO FACILITATE MAINTENANCE ACTIVITIES.
4. ALL CONDUIT INSTALLED OUTDOORS SHALL BE RIGID ALUMINUM.
5. ALL WIRING TO HVAC SENSORS AND CONTROL ELEMENTS IS TO BE PROVIDED BY THE BMS CONTRACTOR, AND CONNECTED TO THE BMS. THE BMS SHALL BE INTERCONNECTED TO THE PLANT NETWORK.
6. ISOLATOR FANS SHALL BE WIRED TO THE ISOLATOR CONTROL PANELS PER THE ISOLATOR VENDOR'S INSTRUCTIONS.

PLAN NORTH

14

S

T.5

V

W.5

Y

SF-2

AHU-1

RH-2

UH-3

RH-1

HU-3 ABOVE

MAIN EXHAUST FROM N-AQUEOUS

LINE OF EXISTING HVAC PENTHOUSE UNIT

LINE OF EXISTING ELEVATED STEEL PLATFORM

DRUG ISOLATOR EXHAUST

NOTE 6

1A
SN-711KCMR0T995
MODEL-ARUN053GSS4
3GEN-0015-PAN01-24,26

2B
SN-711KCDG0T994
MODEL-ARUN053GSS4
3GEN-0015-PAN01-28,30

2B | 1A

LG COMPRESSOR ROOM N3030

AHU-6

2" HHWS/R DN

3" CHWS/R DN

FUTURE AHU

POWER FOR AHU INTERNAL LIGHTS AND RECEPTACLES

TO PANEL RP-N3-EB CKT #36

OSA

3PAN0706 CKT #39

NOTE 3 L11 SWP

ELEVATOR (BELOW)

SUPPLY FANS VFD PANEL

TO NEW 480V STANDBY POWER PANEL SPP-N3-EB 3RD FLOOR

AHU-10 CONTROL PANEL SRP-72

TO NEW 480V STANDBY POWER PANEL SPP-N3-EB 3RD FLOOR

EXH

131

27

AHU-10

EF3

EF4

RETURN FANS VFD PANEL

Drain Conn.

3PAN0706 CKT #39

3-HO-NL-0014

SIEMENS CONTROL POWER RP-37

INTAKE HOOD
3AHU-0702-H01

1-1/2" ø CHW/CHWR

2"ø CHW/CHWR

NOTE 6

FILL ISOLATOR SUPPLY

NOTE 6

FILL ISOLATOR EXHAUST

AHU-4

AHU-5

EXHAUST FAN EF-1A TO VFD IN 3rd FLOOR ELEC. ROOM NOTE 2

EXHAUST FAN EF-1B TO VFD IN 3rd FLOOR ELEC. ROOM NOTE 2

CONTRACTOR SHALL PROVIDE POWER TO RECEPTACLE FURNISHED BY CHILLER VENDOR

RP-N3-EB CKT #42

RP-N3-EB CKT #44

3PAN0706 CKT #39

NOTE 3 L11 SWP

EXISTING SWITCH PANEL N450 DP 480V, 1st FLOOR, ROOM N1100A AT COLUMNS V & 23. REFER TO N1 PROJECT DRAWINGS 10-082-E012 AND 12-082-E001.

CHILLER PUMP

CONTRACTOR SHALL PROVIDE POWER TO ELECTRIC HEATERS FURNISHED BY CHILLER VENDOR

TO VFD IN 3RD FLOOR ELECTRICAL ROOM NOTE 2

3"ø VENT

3"ø VENT

3"ø VENT

FAN RACK

TABLETING QC HOOD
3-HO-NL-0014

3F-NL-0009 (EF-9)

CAPPED 2"ø FOR FUTURE

HOOD IN SLOP ROOM 1ST FLOOR IMMUNO
3-HO-NL-0001

HOOD IN ORGAN. LAB 1ST FLOOR IMMUNO
3-HO-NL-0005

HOOD IN ORGAN. LAB

3"ø VENT

3"ø VENT

3"ø VENT

4"ø VENT

3"ø VENT

3"ø VENT

SLOPE AWAY FROM AHU (TYP.)

A/C

STRUCTURE PIPES

STRUCTURE PIPES

14 15 16 17 18 19 20 21 22 23

PLAN VIEW
SCALE: 3/16"=1'-0"

0 2' 4' 6' 8'

J ISSUE DATE 06/16/15

EXISTING BUILDING

KEYPLAN

| NO | REVISIONS | APPROVED | DATE |
|---|---|---|---|
| 3 | AS BUILT PER PROJECT #17-2060 ECM #50000000567 | BB/RGF | 05/21/18 |
| 2 | FOR RECORD ECM #50000002491 | DEH | 06/15/15 |
| 1 | RE-ISSUE FOR BID – N3 ADC PROJECT | DEH | 06/27/14 |
| 0 | ISSUE FOR BID | DEH | 06/11/14 |

THIS RECORD DRAWING ISSUE (REVISION #2) HAS BEEN DRAFTED BY CE&IC BASED ON CONTRACTOR RED-LINED MARKUPS PROVIDED BY THE OWNER.

CONSULTING ENGINEER

CE&IC
serving the pharmaceutical, biotech & chemical industries since 1989
two tant lane • suite 13 • bethlehem, new jersey • 08018
phone 610-317-1150 • fax 610-317-1227 • e-mail ce@ceic.com
ENGINEERING DESIGN BETWEEN MODERN PROCESS UNITS/ CONTROL ROOM

CHEMICAL ENGINEERING & INSTRUMENTATION CONSULTANTS, INC.

ENGINEERING CERTIFICATE OF AUTHORITY NO. F01363794

SEAL

PROJECT LOCATION

SIGMA-ALDRICH
BUILDING N
3300 S. SECOND STREET
SAINT LOUIS, MO
63118
USA

SIGMA-ALDRICH MANUFACTURING LLC

TITLE: N3 ADC FACILITY MODIFICATION PROJECT
ELECTRICAL PLAN
EAST BAY – ROOF

PLANT: CHEROKEE BLDG: N FLOOR: ROOF

DRAWN: LAD SCALE: 3/16"=1'-0" DATE: 03/21/14

CHECKED: – APPROVED: DATE: –

10-055-E101

F:\BC-WORKSPACE\S186888\M-USSLW0002_D-SIGMARCH\MASTERS\CHEROKEE\N\ELEC\10-055-E101.DWG