

SHORT CIRCUIT LABORATORY

Log sheet for routine tests on Transformers

8

Test Series Number	25T1656	Sample Number :	HVD2550857
Customer / Manufacturer	AP Transformers, Chennai	Date : BT	29.10.25
		AT	4-11-25
Sample details:	250 KVA Distribution Transformer 1 Φ /3 Φ		
In accordance with :	Customer's instructions / IEC / IS / ANSI		
Serial Number :	1098	BT	AT
Condition of the sample :	New / Re- conditioned / After test / Good	Atmospheric conditions - Amb $^{\circ}$ C	24.8
		RH- %	79.8
Type :	000I		24.7
			71.0

Description of test		BT			AT		
Vector Group		Dyn11			Dyn11		
I/R test	H.V. to Earth	4.14 μ s			6.11 μ s		
	L.V. to Earth	1.22 μ s			1.35 μ s		
	H.V. to L.V.	6.56 μ s			7.81 μ s		
Induced over voltage test	Voltage - V	866			866		
	Current - A	1.58			1.66		
	Frequency - Hz	100			100		
	Duration - Seconds	60			60		
	Observation	No disruptive discharge withstood			No disruptive discharge withstood		
High voltage power frequency test	H.V.	28 kV for 60 seconds. (22 mA)			28 kV for 60 seconds. (22 mA)		
	Observation	No disruptive discharge withstood			No disruptive discharge withstood		
	L.V.	3 kV for 60 seconds. (04 mA)			3 kV for 60 seconds. (04 mA)		
	Observation	No disruptive discharge withstood			No disruptive discharge withstood		
Voltage ratio	Tap number	A(U)	B(V)	C(W)	A(U)	B(V)	C(W)
	1	46.38	46.36	46.26	46.37	46.37	46.25
	2	45.22	45.22	45.12	45.23	45.23	45.13
	3	44.10	44.09	44.06	44.11	44.09	44.07
	4	43.02	43.01	42.96	43.03	43.05	43.00
	5	41.92	41.92	41.92	41.93	41.92	41.92
	6	40.82	40.86	40.86	40.81	40.86	40.81
	7	39.73	39.72	39.72	39.73	39.72	39.72

Customer's Signature

Tested by

Test Engineer

Instruments / Equipment used	Serial Number	Instruments / Equipment used	Serial Number
I/R test kit		DVDF Test kit	
DTM/ RH Indicator		Time interval meter	
Turns ratio meter		DMM	
H.V. Test kit		DMM	

APPROVED BY:

DOCUMENT : FORMS & FORMATS
SECTION : 45 PAGE NO.: 1 of 1

ISSUE NO.: 2

REVISION No.: 00
DATE : 01-08-2014