ARCHITECTURAL SUBMISSION DRAWINGS & SCHEDULE OF SPECIFICATIONS
(SYNTHETIC DEMO FOR TESTING NIRMAANTRA AI PIPELINE - HOSPITAL OCCUPANCY)
==========

Project Name: Max Care Multi-Speciality Hospital
Location: Plot No. 14, Institutional Area, Sector 19, Dwarka, New Delhi - 110075
Jurisdiction: Delhi Development Authority (DDA) / Delhi Fire Service (DFS)
Occupancy Classification: Hospital (Institutional - Healthcare Facility)

SITE DIMENSIONS & DEVELOPMENT CONTROLS:
- Plot Area: 3500.0 sq. m.
- Total Built-up Area: 7000.0 sq. m.
- Ground Floor Plinth Coverage: 1100.0 sq. m. (31.4%)
- Front Road Width: 24.0 metres
- Proposed Building Height: 18.0 metres (Ground + 5 Storeys)
- Parking Spaces Provided: 150 Equivalent Car Spaces (ECS)

SETBACK DETAILS & HOSPITAL LIFE SAFETY PROVISIONS
==========

PROPOSED SETBACK DISTANCES:
- Front Setback: 12.5 metres (statutory institutional setback)
- Rear Setback: 9.5 metres
- Side Setback 1 (Left boundary): 6.2 metres (fire tender driveway)
- Side Setback 2 (Right boundary): 6.0 metres (fire tender driveway)

HOSPITAL & FIRE SAFETY SCHEDULE:
- Primary Emergency Staircase Width: 2.10 metres (bed/stretcher evacuation compliant)
- Secondary Emergency Staircase Width: 2.10 metres
- Hospital Patient Corridor Clear Width: 2.50 metres (min 2.40m statutory)
- Evacuation Ramp: Continuous anti-skid evacuation ramp provided connecting all upper patient floors to ground
- Portable ABC Fire Extinguishers: Provided on each floor corridor
- Automatic Smoke Detection & Fire Alarm System: Fully installed across all wards
- Automatic Sprinklers: Installed throughout all patient and public areas
- Wet Riser & Yard Hydrant: Proposed as per NBC 2016 Part 4
- Emergency Exits Count: 4 exit doors on ground floor