NIRMAANTRA AI

REPORT ID:
43fddec8-eb76-480a-ae73-9c881d747eea
DATE: 26-Oct-2026 20:08 UTC

BUILDING SAFETY & REGULATORY COMPLIANCE AUDIT CERTIFICATE

Unified Building Bye-Laws for Delhi 2016 (UBBL-2016) • Delhi Fire Service Act • NBC 2016

REQUIRES REVIEW

100.0%
COMPLIANCE SCORE

Requirements Evaluated: 10 | **Passed:** 9 | **Failed:** 0 | **Review:** 1

Project Title:	**Max Care Multi-Speciality Hospital**	**Jurisdiction:**	**Delhi NCT, India**
Site Address:	Plot No. 14, Institutional Area, Sector 19, Dwarka, New Delhi - 110075	**Source Document:**	demo_max_care_hospital.pdf

STATUTORY COMPLIANCE EVALUATION FINDINGS

Statutory Rule & Code	Status	Audit Findings & Evaluation	Delhi Citation
Minimum Front Setback Requirement DELHI_UBBL_2016_SETBACK_FRONT	PASS	Front setback of 12.50 m meets or exceeds the required minimum of 12.00 m for plot area 3500.0 sq.m. Verified in accordance with Unified Building Bye-Laws for Delhi 2016 Clause 7.13 & MPD 2021 (Commercial & Institutional Setbacks). Cross-referenced with statutory provision Section 1.	*Unified Building Bye-Laws for Delhi 2016 Clause 7.13 & MPD 2021 (Commercial & Institutional Setbacks)*
Minimum Rear Setback Requirement DELHI_UBBL_2016_SETBACK_REAR	PASS	Rear setback of 9.50 m meets or exceeds the required minimum of 9.00 m for plot 3500.0 sq.m. Verified in accordance with Unified Building Bye-Laws for Delhi 2016 Clause 7.13 & MPD 2021 (Commercial & Institutional Setbacks). Cross-referenced with statutory provision Section 1.	*Unified Building Bye-Laws for Delhi 2016 Clause 7.13 & MPD 2021 (Commercial & Institutional Setbacks)*
Maximum Permissible Floor Area Ratio (FAR) DELHI_UBBL_2016_FAR_MAX	PASS	Calculated FAR of 200.0 (Built-up: 7000.0 sq.m / Plot: 3500.0 sq.m) is within the maximum permissible limit of 375.0. Verified in accordance with Master Plan for Delhi 2021 & UBBL 2016, Health Infrastructure Controls (Hospitals). Cross-referenced with statutory provision 1.4.48 Floor Area Ratio (F AR): The quotient obtained by di.	*Master Plan for Delhi 2021 & UBBL 2016, Health Infrastructure Controls (Hospitals)*
Maximum Permissible Ground Coverage DELHI_UBBL_2016_GROUND_COVERAGE_MAX	PASS	Ground coverage of 1100.0 sq.m (31.4%) is within the permissible ceiling of 35.0% for plot 3500.0 sq.m. Verified in accordance with Master Plan for Delhi 2021 & UBBL 2016, Health Infrastructure Controls (Hospitals). Cross-referenced with statutory provision 1.4.57 Ground Coverage: The portion of the building within .	*Master Plan for Delhi 2021 & UBBL 2016, Health Infrastructure Controls (Hospitals)*
Delhi Fire Service (DFS) Clearance Trigger DELHI_DFS_CLEARANCE_REQUIRED	NEEDS REVIEW	Hospital / Healthcare Facility: Building height of 18.00 m exceeds 9.0 m. Mandatory Prior Fire Clearance / NOC from the Delhi Fire Service (DFS) is legally required before approval/occupancy. Verified in accordance with Delhi Fire Service Rules 2010 (Rule 27) & UBBL-2016 Clause 9.3 (Hospitals & Healthcare Facilities DFS Clearance). Cross-referenced with statutory provision 1.4.45 Fire Service Inlets: A connection provided at the ba.	*Delhi Fire Service Rules 2010 (Rule 27) & UBBL-2016 Clause 9.3 (Hospitals & Healthcare Facilities DFS Clearance)*

Statutory Rule & Code	Status	Audit Findings & Evaluation	Delhi Citation
Minimum Emergency Staircase Width DELHI_UBBL_2016_FIRE_STAIRCASE_WIDTH	**PASS**	Emergency staircase width of 2.10 m meets or exceeds the required 2.00 m minimum. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Table 8.1 (Hospitals / Healthcare: Min 2.00 m). Cross-referenced with statutory provision 8.4.3.	*Unified Building Bye-Laws for Delhi 2016, Table 8.1 (Hospitals / Healthcare: Min 2.00 m)*
Fire Detection and Extinguisher Equipment DELHI_UBBL_2016_FIRE_EQUIPMENT	**PASS**	Both portable fire extinguishers and an automatic fire alarm system are documented. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Clause 9.5 & NBC 2016 Part 4. Cross-referenced with statutory provision 9.3 Fire Safety.	*Unified Building Bye-Laws for Delhi 2016, Clause 9.5 & NBC 2016 Part 4*
Minimum Side Setback Requirement (Emergency Access) DELHI_UBBL_2016_SETBACK_SIDE	**PASS**	Side setbacks (Side 1: 6.2 m, Side 2: 6.0 m) satisfy the required minimum of 6.00 m for hospital. Verified in accordance with UBBL-2016 Clause 8.4.1 (Mandatory 6m Clear Driveway for Institutional/Commercial). Cross-referenced with statutory provision Section 1.	*UBBL-2016 Clause 8.4.1 (Mandatory 6m Clear Driveway for Institutional/Commercial)*
Statutory Parking Provision (ECS Standards) DELHI_UBBL_2016_PARKING_ECS	**PASS**	Hospital / Healthcare Facility: Provided 150 parking spaces meets or exceeds the statutory requirement of 140 ECS (2.0 ECS per 100 sq.m for 7000.0 sq.m built-up area). Verified in accordance with UBBL-2016 Clause 10.1 & MPD-2021 Table 17.1 (Hospitals: 2.0 ECS / 100 sqm). Cross-referenced with statutory provision 7.24 Special Provisions for Other Buildings which are not c.	*UBBL-2016 Clause 10.1 & MPD-2021 Table 17.1 (Hospitals: 2.0 ECS / 100 sqm)*
Hospital Stretcher Corridor & Evacuation Ramp DELHI_UBBL_2016_HOSPITAL_SAFETY	**PASS**	Hospital corridor width of 2.50 m satisfies statutory minimum (2.40 m), and evacuation ramp is confirmed for bed/stretcher patient evacuation. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Clause 8.4.2 & NBC 2016 Part 4 (Institutional - Hospitals). Cross-referenced with statutory provision Section 1.	*Unified Building Bye-Laws for Delhi 2016, Clause 8.4.2 & NBC 2016 Part 4 (Institutional - Hospitals)*

ACTIONABLE REMEDIATION RECOMMENDATIONS

- **Action:** Maintain current dimensions in final submission drawings.
- **Action:** Manual physical inspection of site drawings is required by a licensed professional.
- **Action:** If building exceeds 15.0m, initiate formal application with Delhi Fire Service (DFS).

MANDATORY STATUTORY & LEGAL DISCLAIMER: DISCLAIMER & LEGAL LIMITATION: This document is an automated AI-assisted preliminary compliance advisory report generated by NIRMAANTRA for informational and pre-screening purposes only. It does NOT constitute official building plan sanction, permit approval, structural fitness certification, or legal clearance under the Delhi Municipal Corporation Act, Delhi Development Act, or Unified Building Bye-Laws for Delhi 2016. All findings, calculations, and recommendations must be verified and endorsed by a licensed Architect registered with the Council of Architecture (COA) or an empanelled Structural Engineer before submission to MCD, DDA, NDMC, or Delhi Fire Service.

PREPARED & VERIFIED BY LICENSED ARCHITECT:	STRUCTURAL / LIFE SAFETY ENGINEER ENDORSEMENT:
Name: _____ COA Registration No: CA / _____ / _____ Signature & Seal: _____	Name: _____ Empanelment / MCD Reg. No: _____ Signature & Seal: _____