# NIRMAANTRA AI

**REPORT ID:**
f24ae5d4-8a60-48f9-8d4a-eb1d2c51d332
**DATE:** 26-Oct-2026 18:47 UTC

## BUILDING SAFETY & REGULATORY COMPLIANCE AUDIT CERTIFICATE

Unified Building Bye-Laws for Delhi 2016 (UBBL-2016) • Delhi Fire Service Act • NBC 2016

**NON-COMPLIANT**

**66.7%**
COMPLIANCE SCORE

**Requirements Evaluated:** 7 | **Passed:** 4 | **Failed:** 2 | **Review:** 1

| | | | |
|---|---|---|---|
| **Project Title:** | **Suryoday Apartments** | **Jurisdiction:** | **Delhi NCT, India** |
| **Site Address:** | Plot No. 88, Sector 19, Dwarka, New Delhi - 110075 | **Source Document:** | demo_suryoday_apartments.pdf |

## STATUTORY COMPLIANCE EVALUATION FINDINGS

| Statutory Rule & Code | Status | Audit Findings & Evaluation | Delhi Citation |
|---|---|---|---|
| **Minimum Front Setback Requirement**<br>DELHI_UBBL_2016_SETBACK_FRONT | FAIL | Front setback of 5.20 m is deficient by 0.8 m (statutory minimum is 6.00 m for plot area 450.0 sq.m). Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Clause 7.14.1, Table 7.1. Cross-referenced with statutory provision 1.4.10 Sanctioning Authority: The Delhi Development Authori. | *Unified Building Bye-Laws for Delhi 2016, Clause 7.14.1, Table 7.1* |
| **Minimum Rear Setback Requirement**<br>DELHI_UBBL_2016_SETBACK_REAR | PASS | Rear setback of 3.50 m meets or exceeds the required minimum of 3.00 m for plot 450.0 sq.m. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Clause 7.14.1, Table 7.1. Cross-referenced with statutory provision 1.4.10 Sanctioning Authority: The Delhi Development Authori. | *Unified Building Bye-Laws for Delhi 2016, Clause 7.14.1, Table 7.1* |
| **Maximum Permissible Floor Area Ratio (FAR)**<br>DELHI_UBBL_2016_FAR_MAX | FAIL | Calculated FAR of 255.6 exceeds the maximum permissible limit of 225.0 by 30.6 (statutory limit violated). Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Table 7.1 (Residential Plotted). Cross-referenced with statutory provision Section 1. | *Unified Building Bye-Laws for Delhi 2016, Table 7.1 (Residential Plotted)* |
| **Maximum Permissible Ground Coverage**<br>DELHI_UBBL_2016_GROUND_COVERAGE_MAX | PASS | Ground coverage of 310.0 sq.m (68.9%) is within the permissible ceiling of 75.0% for plot 450.0 sq.m. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Table 7.1. Cross-referenced with statutory provision 1.4.57 Ground Coverage: The portion of the building within . | *Unified Building Bye-Laws for Delhi 2016, Table 7.1* |
| **Delhi Fire Service (DFS) Clearance Trigger**<br>DELHI_DFS_CLEARANCE_REQUIRED | NEEDS REVIEW | Building height of 16.20 m exceeds 15.0 m. Mandatory Prior Fire Clearance / NOC from the Delhi Fire Service (DFS) is legally required before approval/occupancy. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Clause 9.3 & Delhi Fire Service Act. Cross-referenced with statutory provision 1.4.45 Fire Service Inlets: A connection provided at the ba. | *Unified Building Bye-Laws for Delhi 2016, Clause 9.3 & Delhi Fire Service Act* |

| Statutory Rule & Code | Status | Audit Findings & Evaluation | Delhi Citation |
|---|---|---|---|
| **Minimum Emergency Staircase Width**<br>DELHI_UBBL_2016_FIRE_STAIRCASE_WIDTH | **PASS** | Emergency staircase width of 1.35 m meets or exceeds the required 1.25 m minimum. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Clause 9.3. Cross-referenced with statutory provision 8.4.3. | *Unified Building Bye-Laws for Delhi 2016, Clause 9.3* |
| **Fire Detection and Extinguisher Equipment**<br>DELHI_UBBL_2016_FIRE_EQUIPMENT | **PASS** | Both portable fire extinguishers and an automatic fire alarm system are documented. Verified in accordance with Unified Building Bye-Laws for Delhi 2016, Clause 9.5 & NBC 2016 Part 4. Cross-referenced with statutory provision 9.3 Fire Safety. | *Unified Building Bye-Laws for Delhi 2016, Clause 9.5 & NBC 2016 Part 4* |

## ACTIONABLE REMEDIATION RECOMMENDATIONS

- **Action:** Revise architectural drawings to bring Minimum Front Setback Requirement within statutory limits.
- **Action:** Consult a certified structural engineer / architect to adjust plinth and layout geometry.
- **Action:** Increase Minimum Front Setback Requirement by at least 0.80 m (current: 5.2 m, statutory min: 6.0 m).
- **Action:** Maintain current dimensions in final submission drawings.
- **Action:** Revise architectural drawings to bring Maximum Permissible Floor Area Ratio (FAR) within statutory limits.
- **Action:** Reduce Maximum Permissible Floor Area Ratio (FAR) by 30.56 index to stay within maximum permissible cap of 225.0 index.
- **Action:** Manual physical inspection of site drawings is required by a licensed professional.
- **Action:** If building exceeds 15.0m, initiate formal application with Delhi Fire Service (DFS).

**MANDATORY STATUTORY & LEGAL DISCLAIMER:** DISCLAIMER & LEGAL LIMITATION: This document is an automated AI-assisted preliminary compliance advisory report generated by NIRMAANTRA for informational and pre-screening purposes only. It does NOT constitute official building plan sanction, permit approval, structural fitness certification, or legal clearance under the Delhi Municipal Corporation Act, Delhi Development Act, or Unified Building Bye-Laws for Delhi 2016. All findings, calculations, and recommendations must be verified and endorsed by a licensed Architect registered with the Council of Architecture (COA) or an empanelled Structural Engineer before submission to MCD, DDA, NDMC, or Delhi Fire Service.

| PREPARED & VERIFIED BY LICENSED ARCHITECT: | STRUCTURAL / LIFE SAFETY ENGINEER ENDORSEMENT: |
|---|---|
| Name: _____<br>COA Registration No: CA / _____ / _____<br>Signature & Seal: _____ | Name: _____<br>Empanelment / MCD Reg. No: _____<br>Signature & Seal: _____ |