

1. Building description

Two-storey school for 220 pupils and 26 staff. Gross area 2 480 m².
Construction is steel frame with concrete floors. Building class 2.

2. Escape

Two protected stair cores, north and south, each discharging directly to open air. Maximum travel distance to a protected route is 28 m against a permitted 35 m. Classroom doors open in the direction of escape. Final exit widths total 4.8 m against a required 3.6 m.

3. Compartmentation

Stair cores are EI60. Classrooms are separated from the corridor at EI30. The plant room and refuse store are EI60. The kitchen is EI30 with an EI30 shutter to the servery.

4. Detection and alarm

Category L1 automatic detection throughout, with sounders achieving 65 dB(A) at the bedhead equivalent position in all occupied rooms. Manual call points at each final exit and at each stair core on each level.

5. Fire service access

A hardstanding within 18 m of the north entrance accommodates a pumping appliance. A dry riser is not required at this height.

6. Outstanding items

Confirmation of the smoke ventilation opening area to the south stair remains outstanding pending the facade contractor's shop drawings. Sign-off is programmed for 9 October 2026.