

A Review of Active Filters for Power Quality Improvement

Bhim Singh, Kamal Al-Haddad, *Senior Member, IEEE*, and Ambrish Chandra, *Member, IEEE*

Abstract—Active filtering of electric power has now become a mature technology for harmonic and reactive power compensation in two-wire (single phase), three-wire (three phase without neutral), and four-wire (three phase with neutral) ac power networks with nonlinear loads. This paper presents a comprehensive review of active filter (AF) configurations, control strategies, selection of components, other related economic and technical considerations, and their selection for specific applications. It is aimed at providing a broad perspective on the status of AF technology to researchers and application engineers dealing with power quality issues. A list of more than 200 research publications on the subject is also appended for a quick reference.

Index Terms—Active power filters, active power line conditioners, harmonics and reactive power compensation, power quality.

I. INTRODUCTION

SOLID-STATE control of ac power using thyristors and other semiconductor switches is widely employed to feed controlled electric power to electrical loads, such as adjustable-speed drives (ASD's), furnaces, computer power supplies, etc. Such controllers are also used in HV dc systems and renewable electrical power generation. As nonlinear loads, these solid-state converters draw harmonic and reactive power components of current from ac mains. In three-phase systems, they could also cause unbalance and draw excessive neutral currents. The injected harmonics, reactive power burden, unbalance, and excessive neutral currents cause low system efficiency and poor power factor. They also cause disturbance to other consumers and interference in nearby communication networks. Extensive surveys [1]–[15] have been carried out to quantify the problems associated with electric power networks having nonlinear loads. Conventionally passive L - C filters were used to reduce harmonics and capacitors were employed to improve the power factor of the ac loads. However, passive filters have the demerits of fixed compensation, large size, and resonance. The increased severity of harmonic pollution in power networks has attracted the attention of power electronics and power system engineers to develop dynamic and adjustable solutions to the power quality problems. Such equipment, generally known as active filters (AF's) [16]–[20], are also called active power line conditioners (APLC's), in-

stantaneous reactive power compensators (IRPC's), active power filters (APF's), and active power quality conditioners (APQC's). In recent years, many publications have also appeared [21]–[25] on the harmonics, reactive power, load balancing, and neutral current compensation associated with linear and nonlinear loads.

This paper aims at presenting a comprehensive survey on the subject of AF's. More than 200 publications [1]–[223] are reviewed and classified in six categories. The first [1]–[25] is on general development and survey of harmonic problems, while the second to fourth categories are on two-wire (single phase) [26]–[55], three-wire (three phase without neutral) [56]–[155], and four-wire (three phase with neutral) [156]–[166] AF's. The fifth category [167]–[192] includes the publications on theories of harmonics and reactive power associated with nonlinear loads. The sixth and final category of publications [193]–[223] is on the reactive power and load-balancing compensators. However, some publications belong to more than one category and have been classified based on their dominant contribution.

This paper is presented in seven parts. Starting with an introduction, the subsequent sections cover the state of the art of the AF technology, the different configurations used, the control methodologies, the economic and technical considerations, their selection for specific applications, and the concluding remarks.

II. STATE OF THE ART

The AF technology is now mature for providing compensation for harmonics, reactive power, and/or neutral current in ac networks. It has evolved in the past quarter century of development with varying configurations, control strategies, and solid-state devices. AF's are also used to eliminate voltage harmonics, to regulate terminal voltage, to suppress voltage flicker, and to improve voltage balance in three-phase systems. This wide range of objectives is achieved either individually or in combination, depending upon the requirements and control strategy and configuration which have to be selected appropriately. This section describes the history of development and present status of the AF technology.

Following the widespread use of solid-state control of ac power, the power quality issues became significant. There are a large number of publications covering the power quality survey, measurements, analysis, cause, and effects of harmonics and reactive power in the electric networks [1]–[25]. AF's are basically categorized into three types, namely, two-wire (single phase), three-wire, and four-wire three-phase configurations to meet the requirements of the three types of nonlinear loads on

Manuscript received May 4, 1998; revised October 8, 1998. Abstract published on the Internet June 18, 1999.

B. Singh is with the Department of Electrical Engineering, Indian Institute of Technology, New Delhi 110016, India.

K. Al-Haddad and A. Chandra are with the GREPCI Department of Electrical Engineering, École de Technologie Supérieure, Montréal, P.Q. H3C 1K3, Canada (e-mail: kamal@ele.etsmtl.ca).

Publisher Item Identifier S 0278-0046(99)07254-8.

supply systems. Single-phase loads, such as domestic lights and ovens, TV's, computer power supplies, air conditioners, laser printers, and Xerox machines behave as nonlinear loads and cause power quality problems. Single-phase (two wire) AF's are investigated [26]–[55] in varying configurations and control strategies to meet the needs of single-phase nonlinear loads. Starting in 1971, many configurations, such as the active series filter [48], active shunt filter [26]–[47], and combination of shunt and series filter [39] have been developed and commercialized also for uninterruptible power supply (UPS) applications [50], [52], [53]. Both concepts based on a current-source inverter (CSI) with inductive energy storage and a voltage-source inverter (VSI) with capacitive energy storage are used to develop single-phase AF's.

Since major amounts of ac power are consumed by three-phase loads such as ASD's with solid-state control. Lately, many ASD systems incorporate AF's in their front-end design. A substantial number of publications have reported on three-phase three wire AF's [56]–[155], starting in 1976. Active shunt, active series, and combinations of both, named as active power quality conditioners [138], [152], as well as passive filters combined with active shunt and active series AF's are some typical configurations used. Many control strategies such as instantaneous reactive power theory initially developed by Akagi *et al.* [63], synchronous frame $d-q$ theory [145], synchronous detection method [143], and notch filter method are used in the development of three-phase AF's.

The problem of excessive neutral current [3], [4] is observed in three-phase four-wire systems, mainly due to nonlinear unbalanced loads, such as computer power supplies, fluorescent lighting, etc. Resolving the problems of neutral current and unbalanced load currents has been attempted in [156]–[166] for four-wire systems. These attempts are of varying nature, like elimination/reduction of neutral current, harmonic compensation, load balancing, reactive power compensation, and combinations of these.

A major volume of work is reported [167]–[192] on the theories related to the detection and measurement of the various quantities, such as real power, reactive power, etc., in the presence of harmonics in the supply systems with nonlinear loads. These theories and concepts are quite relevant to extract the control signals for AF's and for the development of instruments to measure conventional and newly defined quantities in the presence of harmonics and unbalance. For quantifying the effectiveness of AF's, it is important to develop good measuring systems, and these new concepts have given a new impetus to instrumentation technology in this field.

The problems of reactive power and load unbalance were recognized long ago, and they became aggravated in the presence of nonlinear loads. Many publications [193]–[223] report on solid-state compensators for voltage flicker, reactive power, and balancing the nonlinear reactive loads, such as arc furnace, traction loads, etc. Many more terminologies, such as static var compensators, static flicker compensators, static var generators, etc., have been used in the literature.

One of the major factors in advancing the AF technology is the advent of fast self-commutating solid-state devices. In the initial stages, thyristors, bipolar junction transistors (BJT's)




Fig. 1. Current-fed-type AF.

and power MOSFET's were used for AF fabrication; later, static induction thyristors (SIT's) and gate-turn-off thyristors (GTO's) were employed to develop AF's. With the introduction of insulated gate bipolar transistors (IGBT's), the AF technology got a real boost and, at present, they are considered as ideal solid-state devices for AF's. The improved sensor technology has also contributed to the enhanced performance of the AF. The availability of Hall-effect sensors and isolation amplifiers at reasonable cost and with adequate ratings has improved the AF performance.

The next breakthrough in AF development has resulted from the microelectronics revolution. Starting from the use of discrete analog and digital components [162], the progression has been to microprocessors, microcontrollers [64], and digital signal processors (DSP's) [50], [148]. Now, it is possible to implement complex algorithms on-line for the control of the AF at reasonable cost. This development has made it possible to use different control algorithms such as, proportional integral (P-I) [40], [87], [149], variable-structure control [51], [127], [141], fuzzy logic, and neural nets [46] for improving the dynamic and steady-state performance of the AF. With these improvements, the AF's are capable of providing fast corrective action, even with dynamically changing nonlinear loads. Moreover, these AF's are found to compensate quite a sum of higher order harmonics (typically up to the 25th) [25].

III. CONFIGURATIONS

AF's can be classified based on converter type, topology, and the number of phases. The converter type can be either CSI or VSI bridge structure. The topology can be shunt, series, or a combination of both. The third classification is based on the number of phases, such as two-wire (single phase) and three- or four-wire three-phase systems.

A. Converter-Based Classification

There are two types of converters used in the development of AF's. Fig. 1 shows the current-fed pulsewidth modulation (PWM) inverter bridge structure. It behaves as a nonsinusoidal current source to meet the harmonic current requirement of the nonlinear load. A diode is used in series with the self commutating device (IGBT) for reverse voltage blocking. However, GTO-based configurations do not need the series diode, but they have restricted frequency of switching. They




Fig. 2. Voltage-fed-type AF.




Fig. 3. Series-type AF.

are considered sufficiently reliable [68], [79], but have higher losses and require higher values of parallel ac power capacitors. Moreover, they cannot be used in multilevel or multistep modes to improve performance in higher ratings.

The other converter used as an AF is a voltage-fed PWM inverter structure, as shown in Fig. 2. It has a self-supporting dc voltage bus with a large dc capacitor. It has become more dominant, since it is lighter, cheaper, and expandable to multilevel and multistep versions, to enhance the performance with lower switching frequencies. It is more popular in UPS-based applications, because in the presence of mains, the same inverter bridge can be used as an AF to eliminate harmonics of critical nonlinear loads.

B. Topology-Based Classification

AF's can be classified based on the topology used as series or shunt filters [48], [106], [115], [121], [146], and unified power quality conditioners [19], [27], [135], [138], [152] use a combination of both. Combinations of active series and passive shunt filtering are known as hybrid filters [20], [94], [96], [99], [132], [134], [142], [152], [154]. Fig. 2 is an example of an active shunt filter, which is most widely used to eliminate current harmonics, reactive power compensation (also known as STATCON), and balancing unbalanced currents. It is mainly used at the load end, because current harmonics are injected by nonlinear loads. It injects equal compensating currents, opposite in phase, to cancel harmonics and/or reactive components of the nonlinear load current at the point of connection. It can also be used as a static var generator (STATCON) in the power system network for stabilizing and improving the voltage profile.

Fig. 3 shows the basic block of a stand-alone active series filter. It is connected before the load in series with the mains,




Fig. 4. Unified power quality conditioner as universal AF.




Fig. 5. Hybrid filter as a combination of active series and passive shunt filters.

using a matching transformer, to eliminate voltage harmonics [48], and to balance and regulate the terminal voltage of the load or line. It has been used to reduce negative-sequence voltage and regulate the voltage on three-phase systems [115], [121]. It can be installed by electric utilities to compensate voltage harmonics and to damp out harmonic propagation caused by resonance with line impedances and passive shunt compensators.

Fig. 4 shows a unified power quality conditioner (also known as a universal AF), which is a combination of active shunt and active series filters [19], [39], [133], [135], [138], [152]. The dc-link storage element (either inductor [19], [39] or dc-bus capacitor [19], [135]) is shared between two current-source or voltage-source bridges operating as active series and active shunt compensators. It is used in single-phase [19], [39] as well as three-phase configurations [19], [133], [135], [152]. It is considered an ideal AF which eliminates voltage and current harmonics and is capable of giving clean power to critical and harmonic-prone loads, such as computers, medical equipment, etc. It can balance and regulate terminal voltage and eliminate negative-sequence currents. Its main drawbacks are its large cost and control complexity because of the large number of solid-state devices involved.

Fig. 5 shows the hybrid filter, which is a combination of an active series filter and passive shunt filter [20], [94], [109], [120], [134], [137], [139], [142], [145], [152], [154]. It is quite popular because the solid-state devices used in the active series part can be of reduced size and cost (about 5% of the load size) and a major part of the hybrid filter is made of the passive shunt L - C filter used to eliminate lower order harmonics. It has the capability of reducing voltage and current harmonics at a reasonable cost. There are many more hybrid configurations [136], [152], [153], but for the sake of brevity, they are not discussed here; however, details can be found in the respective references.




Fig. 6. Two-wire series AF with current-source converter.




Fig. 7. Two-Wire shunt AF with current-source converter.

C. Supply-System-Based Classification

This classification of AF's is based on the supply and/or the load system having single-phase (two wire) and three-phase (three wire or four wire) systems. There are many nonlinear loads, such as domestic appliances, connected to single-phase supply systems. Some three-phase nonlinear loads are without neutral, such as ASD's, fed from three-wire supply systems. There are many nonlinear single-phase loads distributed on four-wire three-phase supply systems, such as computers, commercial lighting, etc. Hence, AF's may also be classified accordingly as two-wire [26]–[55], three-wire [56]–[155], and four-wire types [156]–[166].

1) *Two-Wire AF's*: Two-wire (single phase) AF's [19], [26]–[55] are used in all three modes as active series [27], [48], active shunt [26]–[38], [40]–[47], [49]–[55], and a combination of both as unified line conditioners [19], [27], [39]. Both converter configurations, current-source PWM bridge [19], [27], [38], [39] with inductive energy storage element and voltage-source PWM bridge [19], [27]–[38], [40]–[55] with capacitive dc-bus energy storage elements, are used to form two-wire AF circuits. In some cases, active filtering is included in the power conversion stage [36], [40], [41] to improve input characteristics at the supply end.

Figs. 6–8 show three configurations of active series, active shunt, and a combination of both with current-source bridge, using inductive storage elements. Similar configurations, based on a VSI bridge, may be obtained by considering only two wires (phase and neutral) at each stage of Figs. 2–4. In the case of a series AF with voltage-fed converter, sometimes the transformer is removed and load is shunted with passive L – C components [48]. The series AF is normally used to eliminate




Fig. 8. Two-wire unified power quality conditioner with current-source converter.

voltage harmonics, spikes, sags, notches, etc., while the shunt AF is used to eliminate current harmonics and reactive power compensation.

2) *Three-Wire AF's*: Three-phase three-wire nonlinear loads, such as ASD's, are major applications of solid-state power converters and, lately, many ASD's, etc., incorporate AF's in their front-end design. A large number of publications [15]–[20], [56]–[155] have appeared on three-wire AF's with different configurations. All the configurations shown in Figs. 1–5 are developed, in three-wire AF's, with three wires on the ac side and two wires on the dc side. Active shunt AF's are developed in the current-fed type (Fig. 1) or voltage-fed type with single-stage (Fig. 2) or multistep/multilevel and multiseries [65], [66], [85], [86] configurations. Active shunt AF's are also designed with three single-phase AF's with isolation transformers [18] for proper voltage matching, independent phase control, and reliable compensation with unbalanced systems. Active series filters are developed for stand-alone mode (Fig. 3) or hybrid mode with passive shunt filters (Fig. 5). The latter (hybrid) has become quite popular [20], [99], [105], [109], [110], [120], [133], [139], [142], [143], [145], [153], [154] to reduce the size of power devices and cost of the overall system. A combination of active series and active shunt is used for unified power quality conditioners (Fig. 4) and universal filters [19], [135], [138], [152].

3) *Four-Wire AF's*: A large number of single-phase loads may be supplied from three-phase mains with neutral conductor [3], [4], [10], [11]. They cause excessive neutral current, harmonic and reactive power burden, and unbalance. To reduce these problems, four-wire AF's have been attempted [156]–[166]. They have been developed as: 1) active shunt mode with current feed [156] and voltage feed [157], [158], [160], [165]; 2) active series mode [163], [165]; and 3) hybrid form with active series and passive shunt [164] mode. Figs. 9–11 show three typical configurations of shunt AF's [158]. The first configuration of a four-wire shunt AF is known as the capacitor midpoint type, used in smaller ratings. Here, the entire neutral current flows through dc-bus capacitors which are of a large value. Fig. 10 shows another configuration known as the four-pole switch type, in which the fourth pole is used to stabilize the neutral of the AF. The three single-phase bridge configuration, shown in Fig. 11, is quite common [157], [159], [162], and this version allows the proper voltage




Fig. 9. Capacitor midpoint four-wire shunt AF.




Fig. 10. Four-pole four-wire shunt AF.




Fig. 11. Three-bridge four-wire shunt AF.

matching for solid-state devices and enhances the reliability of the AF system. A detailed comparison of the features of these three configurations (Figs. 9–11), is given in [158].

IV. CONTROL STRATEGIES

Control strategy is the heart of the AF and is implemented in three stages. In the first stage, the essential voltage and current signals are sensed using power transformers (PT's), CT's, Hall-effect sensors, and isolation amplifiers to gather accurate system information. In the second stage, compensating commands in terms of current or voltage levels are derived

based on control methods [167]–[192] and AF configurations. In the third stage of control, the gating signals for the solid-state devices of the AF are generated using PWM, hysteresis, sliding-mode, or fuzzy-logic-based control techniques. The control of the AF's is realized using discrete analog and digital devices or advanced microelectronic devices, such as single-chip microcomputers, DSP's, etc.

A. Signal Conditioning

For the purpose of implementation of the control algorithm, several instantaneous voltage and current signals are required. These signals are also useful to monitor, measure, and record various performance indexes, such as total harmonic distortion (THD), power factor, active and reactive power, crest factor, etc. The typical voltage signals are ac terminal voltages, dc-bus voltage of the AF, and voltages across series elements. The current signals to be sensed are load currents, supply currents, compensating currents, and dc-link current of the AF. Voltage signals are sensed using either PT's or Hall-effect voltage sensors or isolation amplifiers. Current signals are sensed using CT's and/or Hall-effect current sensors. The voltage and current signals are sometimes filtered to avoid noise problems. The filters are either hardware based (analog) or software based (digital) with either low-pass, high-pass, or bandpass characteristics.

B. Derivation of Compensating Signals

Development of compensating signals either in terms of voltages or currents is the important part of AF control and affects their rating and transient, as well as steady-state performance. The control strategies to generate compensation commands are based on frequency-domain or time-domain correction techniques.

1) *Compensation in Frequency Domain:* Control strategy in the frequency domain is based on the Fourier analysis of the distorted voltage or current signals to extract compensating commands [50], [56], [60], [64], [74], [81], [88], [92], [97]. Using the Fourier transformation, the compensating harmonic components are separated from the harmonic-polluted signals and combined to generate compensating commands. The device switching frequency of the AF is kept generally more than twice the highest compensating harmonic frequency for effective compensation. The on-line application of Fourier transform (solution of a set of nonlinear equations) is a cumbersome computation and results in a large response time.

2) *Compensation in Time Domain:* Control methods of the AF's in the time domain are based on instantaneous derivation of compensating commands in the form of either voltage or current signals from distorted and harmonic-polluted voltage or current signals. There is a large number of control methods in the time domain, which are known as instantaneous “ $p-q$ ” theory [59], [63], [65], [66], [75], [85], [86], [89], [91], synchronous $d-q$ reference frame method [19], [20], [109], [132], [154], synchronous detection method [157], [159], [162], flux-based controller [144], notch filter method [139], [158], [160], [164], P-I controller [51], [87], [149], sliding-mode controller [51], [112], [127], [141], etc.

The instantaneous active and reactive power ($p-q$) theory [178] has been widely used and is based on “ $\alpha-\beta$ ” transformation of voltage and current signals to derive compensating signals. The instantaneous active and reactive power can be computed in terms of transformed voltage and current signals. From instantaneous active and reactive powers, harmonic active and reactive powers are extracted using low-pass and high-pass filters. From harmonic active and reactive powers, using reverse “ $\alpha-\beta$ ” transformation, compensating commands in terms of either currents or voltages are derived. In the synchronous $d-q$ reference frame and flux-based controllers, voltage and current signals are transformed to a synchronously rotating frame, in which fundamental quantities become dc quantities, and then the harmonic compensating commands are extracted. The dc-bus voltage feedback is generally used to achieve a self-supporting dc bus in voltage-fed AF's. In the notch-filter-based method, the compensating commands are extracted using notch filters on distorted voltage or current signals. In P-I and sliding-mode controllers, either dc-bus voltage (in a VSI) or dc-bus current (in a CSI) is maintained to the desired value and reference values for the magnitudes of the supply currents are obtained. Subtracting load currents from reference supply currents, compensating commands are derived. The different theories and concepts reported to support the various control methods can be found in [167]–[192].

C. Generation of Gating Signals to the Devices of the AF

The third stage of control of the AF's is to generate gating signals for the solid-state devices of the AF based on the derived compensating commands, in terms of voltages or currents. A variety of approaches, such as hysteresis-based current control, PWM current or voltage control, deadbeat control, sliding mode of current control, fuzzy-based current control, etc., are implemented, either through hardware or software (in DSP-based designs) to obtain the control signals for the switching devices of the AF's.

V. SELECTION OF COMPONENTS AND ADDITIONAL FEATURES OF AF'S

The selection of components of the AF's is an important factor to achieve improved performance. The main component of the AF is the solid-state device. In the earlier days, BJT's followed by MOSFET's were used in small ratings. Nowadays, the IGBT is an ideal choice up to medium ratings, and GTO's are used in higher ratings. A series inductor (L_c) at the input of a VSI bridge working as an AF is normally used as the buffer between supply terminal voltage and PWM voltage generated by the AF's. The value of this inductor is very crucial in the performance of the AF's. If a small value of L_c is selected, then large switching ripples are injected into the supply currents, and a large value of L_c does not allow proper tracking of the compensating currents close to the desired values. An optimum selection of L_c is essential to obtain satisfactory performance of the AF. Generally, a passive ripple filter is used at the terminal of the supply system, which compensates for switching harmonics and improves the THD of the supply voltage and current. The design of the passive

ripple filter is also important, because source impedance can cause an interaction with its components. The dc-bus capacitor value C_{dc} of the AF's is another important parameter. With a small value of C_{dc} , large ripples in the steady state and wide fluctuations in the dc-bus voltage under transient conditions are observed. A higher value of C_{dc} reduces ripples and fluctuations in the dc-bus voltage, but increases the cost and size of the system.

In general, AF's are used to compensate current and voltage harmonics, but in most cases, they also have additional functions, such as compensation for reactive power, current and voltage unbalance, neutral current, voltage flicker, voltage spikes, and for voltage regulation. Most of the voltage-related compensations (voltage unbalance, regulation, flicker, etc.) are carried out using series AF's, while current-related compensations (reactive power, current unbalance, etc.) are made using shunt AF's. Sometimes, the structure similar to AF's is used exclusively for additional features, such as reactive power compensation [193]–[223], load balancing [193], [197], [209], [210], [212], voltage regulation and voltage unbalance compensation [151], [181], [219], etc.

VI. TECHNICAL AND ECONOMIC CONSIDERATIONS

Technical literature on the AF's has been reported since 1971 [26] and, in the last two decades, has boomed. Around 1990, many commercial development projects were completed [16]–[18] and put into practice. A number of configurations discussed earlier have been investigated, but could not be developed commercially because of cost and complexity considerations. Initially reported configurations were quite general and the rating of solid-state devices involved was substantial, which resulted in high cost. Due to these reasons, the technology could not be translated to field applications. Later on, the rating of active filtering was reduced by the introduction of supplementary passive filtering [20], [94], [96], without deteriorating the overall filter performance. Moreover, modern AF's are capable of compensating quite high orders of harmonics (typically, the 25th) dynamically. However, as high-order harmonics are small, they are compensated by using a passive ripple filter [66]. This approach has given a boost to field applications, and in countries such as Japan and the U.S., AF acceptability for field applications has increased up to the 1000-kVA range. Another major attempt has been to separate out various compensation aspects of the AF's to reduce the size and cost. However, additional features get included on specific demand. Economic considerations were the hindrance at the initial stages of AF development, but now they are becoming affordable due to a reduction in the cost of the devices used. With the harmonic pollution in present-day power systems, the demand for the AF is increasing. Recommended standards such as IEEE-519 [15], will result in the increased use of AF's in the coming years.

VII. SELECTION CONSIDERATIONS OF AF'S FOR SPECIFIC APPLICATIONS

Selection of the AF for a particular application is an important task for end users and application engineers. There are

widely varying application requirements, such as single-phase or three-phase, three-wire and four wire systems, requiring current- or voltage-based compensation. Moreover, there is a number of AF configurations which may cater to the needs of individual users. A brief list of criteria for selection of an appropriate AF for a specific application is discussed in this section. Table I shows a brief summary of selection of suitable AF's for specific users.

A. Current-Based Compensation

Current-based compensation is classified as current harmonics compensation, reactive power compensation, load balancing, and neutral current compensation. This compensation may either be required individually or in a combination by the individual users. For the current harmonics compensation, the active shunt filter is an ideal device, but a hybrid of active series with passive shunt filter is considered most suitable because of its reduced cost, caused due to the low rating of power electronics (typically 4%–5% of load). Reactive power compensation is carried out by using active shunt filters (similar to a STATCON) for adjustable loads and by using ac capacitors for fixed load. Load balancing in either three-wire or four-wire systems is generally done by using an active shunt filter configuration. Neutral current compensation is carried out by employing an active shunt filter [161]. For most of the combinations of these current-based compensations, the active shunt filter is technically the right choice, but a hybrid of active series with passive shunt filter is the most preferable choice, because of the reduced cost for the combination of these compensation methods.

B. Voltage-Based Compensation

Voltage-based compensation is categorized as voltage harmonics compensation, improving voltage regulation, voltage balancing, voltage flicker reduction, and removing voltage sags and dips. Voltage-based compensation, in general, is carried out by using active series filters. However, the voltage flicker is compensated by using the active shunt filters. Table I shows a brief summary of AF's for compensation in order of preference. Nowadays, the AF's can also correct voltage compensation of momentary voltage dips or sags of very short duration.

C. Voltage- and Current-Based Compensation

Many applications require a compensation of a combination of voltage- and current-based problems, a few of them being interrelated. A hybrid of active series with active shunt filters is an ideal choice for such mixed compensation. Moreover, this hybrid of both AF's (also known as a unified power quality conditioner, UPQC) is also quite suitable for individual current- or voltage-based compensation. However, the rating, size, and cost of this UPQC is on the higher side, therefore, for few combinations of compensation such as voltage and current harmonics, other AF's (active series with passive shunt) are considered most suitable. Table I gives brief guidelines for the proper selection of AF's suited to the needs of individual requirements. It is only a basic preliminary guide for selection

TABLE I
SELECTION OF AF'S FOR SPECIFIC APPLICATION CONSIDERATIONS

Compensation for Specific Application	Active Filters			
	Active Series	Active Shunt	Hybrid of Active Series and Passive Shunt	Hybrid of Active Shunt and Active Series
A. Current Harmonics		**	***	*
B. Reactive Power		***	**	*
C. Load Balancing		*		
D. Neutral Current		**	*	
E. Voltage Harmonics	***		**	*
F. Voltage Regulation	***	*	**	*
G. Voltage Balancing	***		**	*
H. Voltage Flicker	**	***		*
I. Voltage Sag&Dips	***	*	**	*
J. (A + B)		***	**	*
K. (A+B+C)		**		*
L. (A+B+C+D)		*		
M. (E+F)	**			*
N. (E+F+H+I)	**			*
O. (A+E)			**	*
P. (A+B+E+F)			*	**
Q. (F+G)	**		*	
R. (B+C)		*		
S. (B+C+D)		*		
T. (A+B+G)		**	*	
U. (A+C)		*		
V. (A+D+G)		*	**	

AF Configuration with higher number of * is more preferred

of suitable AF's. Since nowadays many industries (ABB, Toshiba, Fuji, Mitsubishi, Westinghouse, etc.) are manufacturing AF's, more details for suitable selection of AF's may also be found in their application notes.

VIII. CONCLUSION

An extensive review of AF's has been presented to provide a clear perspective on various aspects of the AF to the researchers and engineers working in this field. The substantial increase in the use of solid-state power control results in harmonic pollution above the tolerable limits. Utilities are finding it difficult to maintain the power quality at the consumer end, and consumers are paying the penalties indirectly in the form of increased plant downtimes, etc. At present, AF technology is well developed, and many manufacturers [16]–[18] are fabricating AF's with large capacities. The utilities in the long run will induce the consumers with nonlinear loads to use the AF's for maintaining the power quality at acceptable levels. A large number of AF configurations are available to compensate harmonic current, reactive power, neutral current, unbalance current, and harmonics. The consumer can select the AF with

the required features. It is hoped that this survey on AF's will be a useful reference to the users and manufacturers.

REFERENCES


- [1] IEEE Working Group on Power System Harmonics, "Power system harmonics: An overview," *IEEE Trans. Power App. Syst.*, vol. PAS-102, pp. 2455–2460, Aug. 1983.
- [2] T. C. Shuter, H. T. Vollkommer, Jr., and J. L. Kirkpatrick, "Survey of harmonic levels on the American electric power distribution system," *IEEE Trans. Power Delivery*, vol. 4, pp. 2204–2213, Oct. 1989.
- [3] A. C. Liew, "Excessive neutral currents in three-phase fluorescent lighting circuits," *IEEE Trans. Ind. Applicat.*, vol. 25, pp. 776–782, July/Aug. 1989.
- [4] T. M. Gruz, "A survey of neutral currents in three-phase computer power systems," *IEEE Trans. Ind. Applicat.*, vol. 26, pp. 719–725, July/Aug. 1990.
- [5] J. S. Subjak Jr. and J. S. Mcquilk, "Harmonics-causes, effects, measurements, analysis: An update," *IEEE Trans. Ind. Applicat.*, vol. 26, pp. 1034–1042, Nov./Dec. 1990.
- [6] M. E. Amoli and T. Florence, "Voltage, current harmonic control of a utility system—A summary of 1120 test measurements," *IEEE Trans. Power Delivery*, vol. 5, pp. 1552–1557, July 1990.
- [7] H. M. Beides and G. T. Heydt, "Power system harmonics estimation, monitoring," *Elect. Mach. Power Syst.*, vol. 20, pp. 93–102, 1992.
- [8] A. E. Emanuel, J. A. Orr, D. Cyganski, and E. M. Gulchenski, "A survey of harmonics voltages, currents at the customer's bus," *IEEE Trans. Power Delivery*, vol. 8, pp. 411–421, Jan. 1993.
- [9] P. J. A. Ling and C. J. Eldridge, "Designing modern electrical systems with transformers that inherently reduce harmonic distortion in a PC-rich environment," in *Proc. Power Quality Conf.*, Sept. 1994, pp. 166–178.
- [10] P. Packebush and P. Enjeti, "A survey of neutral current harmonics in campus buildings, suggested remedies," in *Proc. Power Quality Conf.*, Sept. 1994, pp. 194–205.
- [11] A. Mansoor, W. M. Grady, P. T. Staats, R. S. Thallam, M. T. Doyle, and M. J. Samotyj, "Predicting the net harmonic currents produced by large numbers of distributed single-phase computer loads," *IEEE Trans. Power Delivery*, vol. 10, pp. 2001–2006, Oct. 1994.
- [12] IEEE Working Group on Nonsinusoidal Situations, "A survey of North American electric utility concerns regarding nonsinusoidal waveforms," *IEEE Trans. Power Delivery*, vol. 11, pp. 73–78, Jan. 1996.
- [13] A. Domijan Jr., E. E. Santander, A. Gilani, G. Lamer, C. Stiles, and C. W. Williams Jr., "Watt-hour meter accuracy under controlled unbalanced harmonic voltage, current conditions," *IEEE Trans. Power Delivery*, vol. 11, pp. 64–72, Jan. 1996.
- [14] IEEE Working Group on Nonsinusoidal Situations, "Practical definitions for powers in systems with nonsinusoidal waveforms, unbalanced loads: A discussion," *IEEE Trans. Power Delivery*, vol. 11, pp. 79–101, Jan. 1996.
- [15] C. K. Duffey and R. P. Stratford, "Update of harmonic standard IEEE-519: IEEE recommended practices, requirements for harmonic control in electric power systems," *IEEE Trans. Ind. Applicat.*, vol. 25, pp. 1025–1034, Nov./Dec. 1989.
- [16] *Active Filters: Technical Document, 2100/1100 Series*, Mitsubishi Electric Corp., Tokyo, Japan, 1989, pp. 1–36.
- [17] "Harmonic currents, static VAR systems," ABB Power Systems, Stockholm, Sweden, Inform. NR500-015E, Sept. 1988, pp. 1–13.
- [18] A. H. Kikuchi, "Active power filters," in *Toshiba GTR Module (IGBT) Application Notes*, Toshiba Corp., Tokyo, Japan, 1992, pp. 44–45.
- [19] S. A. Moran and M. B. Brennen, "Active power line conditioner with fundamental negative sequence compensation," U.S. Patent 5 384 696, Jan. 1995.
- [20] S. Bhattacharya and D. M. Divan, "Hybrid series active/parallel passive power line conditioner with controlled harmonic injection," U.S. Patent 5 465 203, Nov. 1995.
- [21] T. J. E. Miller, *Reactive Power Control in Electric Systems*. Toronto, Canada: Wiley, 1982, pp. 32–48.
- [22] J. W. Clark, *AC Power Conditioners-Design, Applications*. San Diego, CA: Academic, 1990.
- [23] J. Arrillaga, D. A. Bradley, and P. S. Bodger, *Power System Harmonics*. Chichester, U.K.: Wiley, 1985.
- [24] G. T. Heydt, *Electric Power Quality*. West Lafayette, IN: Stars in a Circle, 1991.
- [25] D. A. Paice, *Power Electronic Converter Harmonics-Multipulse Methods for Clean Power*. New York: IEEE Press, 1996.
- [26] H. Sasaki and T. Machida, "A new method to eliminate AC harmonic currents by magnetic flux compensation-considerations on basic design," *IEEE Trans. Power App. Syst.*, vol. PAS-90, pp. 2009–2019, Jan. 1971.
- [27] L. Gyugyi and E. Strycula, "Active AC power filters," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1976, pp. 529–535.
- [28] F. Harashima, H. Inaba, and K. Tsuboi, "A closed-loop control system for the reduction of reactive power required by electronic converters," *IEEE Trans. Ind. Electron. Contr. Instrum.*, vol. IECI-23, pp. 162–166, May 1976.
- [29] E. Epstein, A. Yair, and A. Alexandrovitz, "Analysis of a reactive current source used to improve current drawn by static inverters," *IEEE Trans. Ind. Electron. Contr. Instrum.*, vol. IECI-2, pp. 172–177, Aug. 1979.
- [30] J. Uceda, F. Aldana, and P. Martinez, "Active filters for static power converters," *Proc. Inst. Elect. Eng.*, vol. 130, pt. B, no. 5, pp. 347–354, Sept. 1983.
- [31] V. Rajagopalan, A. Jacob, A. Sévigny, T. N. Nguy, and L. Andy, "Harmonic currents compensation-scheme for electrical distribution systems," in *Proc. IFAC Control in Power Electronics and Electric Drives Conf.*, Lausanne, Switzerland, 1983, pp. 683–690.
- [32] P. L. A. Drouin, A. Sévigny, A. Jacob, and V. Rajagopalan, "Studies on line current harmonics compensation scheme suitable for an electric distribution system," *Can. Elect. Eng. J.*, vol. 8, no. 4, pp. 123–129, 1983.
- [33] A. Alexandrovitz, A. Yair, and E. Epstein, "Analysis of a static VAR compensator with optimal energy storage element," *IEEE Trans. Ind. Electron.*, vol. IE-31, pp. 28–33, Feb. 1984.
- [34] G. H. Choe and M. H. Park, "Analysis, control of active power filter with optimized injection," in *Proc. IEEE PESC'86*, 1986, pp. 401–409.
- [35] C. P. Henze and N. Mohan, "A digitally controlled AC to DC power conditioner that draws sinusoidal input current," in *Proc. IEEE PESC'86*, 1986, pp. 531–540.
- [36] K. K. Sen and A. E. Emanuel, "Unity power-factor single-phase power conditioning," in *Proc. IEEE PESC'87*, 1987, pp. 516–524.
- [37] E. Tironi, D. Zaninelli, and G. Ubezio, "Compensation of the reactive power by means of a current-controlled transistor inverter," in *Proc. 2nd European Power Electronics Conf.*, 1987, pp. 1293–1299.
- [38] S. M. Williams and R. G. Hoft, "Discrete controlled harmonic, reactive power compensator," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1988, pp. 881–887.
- [39] S. Moran, "A line voltage regulator/conditioner for harmonic-sensitive load isolation," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1989, pp. 945–951.
- [40] C. Chen and D. M. Divan, "Simple topologies for single-phase AC line conditioning," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1991, pp. 911–917.
- [41] M. Kazerani, P. D. Ziogas, and G. Joos, "A novel active current wave-shaping technique for solid-state input power factor conditioners," *IEEE Trans. Ind. Electron.*, vol. 38, pp. 72–78, Feb. 1991.
- [42] P. Enjeti, W. Shireen, and I. Pitel, "Analysis, design of an active power filter to cancel harmonic currents in low voltage electric power distribution systems," in *Proc. IEEE IECON'92*, 1992, pp. 368–373.
- [43] C. Tutas, "Compensation of capacitive loads by a voltage-source active filter," *Eur. Trans. Elect. Power Eng.*, vol. 2, no. 1, pp. 15–19, Jan./Feb. 1992.
- [44] R. M. Duke and S. D. Round, "The steady state performance of a controlled current active filter," *IEEE Trans. Power Electron.*, vol. 8, pp. 140–146, Apr. 1993.
- [45] S. D. Round and R. M. Duke, "Real time optimization of active filter energy savings," in *Proc. IEEE IECON'93*, 1993, pp. 1088–1092.
- [46] S. D. Round and N. Mohan, "Comparison of frequency, time domain neural network controllers for an active power filter," in *Proc. IEEE IECON'93*, 1993, pp. 1099–1104.
- [47] V. John, N. Mohan, E. Persson, and R. Nilssen, "High frequency isolation in standby power supplies which compensate load harmonic currents," in *Proc. IEEE IECON'93*, 1993, pp. 1264–1268.
- [48] J. Nastran, R. Cajhen, M. Seliger, and P. Jereb, "Active power filter for nonlinear AC loads," *IEEE Trans. Power Electron.*, vol. 9, pp. 92–96, Jan. 1994.
- [49] G. H. Rim, Y. Kang, W. H. Kim, and J. S. Kim, "Performance improvement of a voltage source active filter," in *Proc. IEEE APEC'95*, 1995, pp. 613–619.
- [50] J. H. Choi, G. W. Park, and S. B. Dewan, "Standby power supply with active power filter ability using digital controller," in *Proc. IEEE APEC'95*, 1995, pp. 783–789.
- [51] D. A. Torrey and A. M. A. M. Al-Zamel, "Single-phase active power filters for multiple nonlinear loads," *IEEE Trans. Power Electron.*, vol. 10, pp. 263–272, May 1995.
- [52] Y. Qin and S. Du, "A DSP based active power filter for line interactive UPS," in *Proc. IEEE IECON'95*, 1995, pp. 884–888.

- [53] J. C. Wu and H. L. Jou, "A new UPS scheme provides harmonic suppression, input power factor correction," *IEEE Trans. Ind. Electron.*, vol. 42, pp. 629–635, Dec. 1995.
- [54] C. Y. Hsu and H. Y. Wu, "A new single-phase active power filter with reduced energy storage capacitor," in *Proc. IEEE PESC'95*, 1995, pp. 202–208.
- [55] C. Y. Hsu and H. Y. Wu, "A new single-phase active power filter with reduced energy storage capacity," *Proc. Inst. Elect. Eng.—Elect. Power Applicat.*, vol. 143, no. 1, pp. 25–30, Jan. 1996.
- [56] A. Ametani, "Harmonic reduction in thyristor converters by harmonic current injection," *IEEE Trans. Power App. Syst.*, vol. 95, pp. 441–449, Mar./Apr. 1976.
- [57] D. E. Steeper and R. P. Stratford, "Reactive compensation, harmonic suppression for industrial power systems using thyristor converters," *IEEE Trans. Ind. Applicat.*, vol. 12, pp. 232–254, May/June 1976.
- [58] N. Mohan, H. A. Peterson, W. F. Long, G. R. Dreifuerst, and J. J. Vithayathil, "Active filters for AC harmonic suppression," in *Proc. IEEE-PES Winter Meeting*, 1977, pp. 168–174.
- [59] I. Takahashi and A. Nabae, "Universal power distortion compensator of line commutated thyristor converter," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1980, pp. 858–864.
- [60] H. Kawahira, T. Nakamura, S. Nakazawa, and M. Nomura, "Active power filter," in *Proc. IPEC-Tokyo*, 1983, pp. 981–992.
- [61] S. Miyairi, S. Iida, M. Takimoto, and S. Masukawa, "A new method of reducing harmonics in input AC line currents of thyristor rectifier circuit," in *Proc. IPEC-Tokyo*, 1983, pp. 993–1004.
- [62] I. Takahashi, "A flywheel energy storage system having distorted power compensation," in *Proc. IPEC-Tokyo*, 1983, pp. 1072–1083.
- [63] H. Akagi, Y. Kanazawa, and A. Nabae, "Instantaneous reactive power compensators comprising switching devices without energy storage components," *IEEE Trans. Ind. Applicat.*, vol. IA-20, pp. 625–630, May/June 1984.
- [64] K. Hayafune, T. Ueshiba, E. Masada, and Y. Ogiwara, "Microcomputer controlled active power filter," in *Proc. IEEE IECON'84*, 1984, pp. 1221–1226.
- [65] H. Akagi, A. Nabae, and S. Atoh, "Control strategy of active power filters using multiple voltage-source PWM converters," *IEEE Trans. Ind. Applicat.*, vol. IA-22, pp. 460–465, May/June 1986.
- [66] H. Akagi, S. Atoh, and A. Nabae, "Compensation characteristics of active power filter using multiseried voltage-source PWM converters," *Elect. Eng. Jpn.*, vol. 106, no. 5, pp. 28–36, 1986.
- [67] K. Komatsugi and T. Imura, "Harmonic current compensator composed of static power converter," in *Proc. IEEE PESC'86*, 1986, pp. 283–290.
- [68] L. Malesani, L. Rossetto, and P. Tenti, "Active filter for reactive power, harmonic compensation," in *Proc. IEEE PESC'86*, 1986, pp. 321–330.
- [69] T. Nakajima, E. Masada, and Y. Ogiwara, "Compensation of the cyclo-converter input current harmonics using active power filters," in *Conf. Rec. 2nd EPE Conf.*, 1987, pp. 1227–1232.
- [70] M. Kohata, T. Shiota, and S. Atoh, "Compensator for harmonics, reactive power using static induction thyristors," in *Conf. Rec. 2nd EPE Conf.*, 1987, pp. 1265–1270.
- [71] R. Fisher and R. Hoft, "Three-phase power line conditioner for harmonic compensation, power-factor correction," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1987, pp. 803–807.
- [72] M. Takeda, K. Ikeda, and Y. Tominaga, "Harmonic current compensation with active filter," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1987, pp. 808–815.
- [73] P. W. Hammond, "A harmonic filter installation to reduce voltage distortion from static power converter," *IEEE Trans. Ind. Applicat.*, vol. 24, pp. 53–58, Jan./Feb. 1988.
- [74] J. H. Choe and M. H. Park, "A new injection method for AC harmonic elimination by active power filter," *IEEE Trans. Ind. Electron.*, vol. 35, pp. 141–147, Feb. 1988.
- [75] F. Z. Peng, H. Akagi, and A. Nabae, "A novel harmonic power filter," in *Proc. IEEE PESC'88*, 1988, pp. 1151–1159.
- [76] T. Nakajima, M. Tamura, and E. Masada, "Compensation of non-stationary harmonics using active power filter with Prony's spectral estimation," in *Proc. IEEE PESC'88*, 1988, pp. 1160–1167.
- [77] A. Nakajima, K. Oku, J. Nishidai, T. Shiraishi, Y. Ogiwara, K. Mizuki, and M. Kumazawa, "Development of active filter with series resonant circuit," in *Proc. IEEE PESC'88*, 1988, pp. 1168–1173.
- [78] M. Takeda, K. Ikeda, A. Teramoto, and T. Aritsuka, "Harmonic current, reactive power compensation with an active filter," in *Proc. IEEE PESC'88*, 1988, pp. 1174–1179.
- [79] Y. Hayashi, N. Sato, and K. Takahashi, "A novel control of a current source active filter for AC power system harmonic compensation," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1988, pp. 837–842.
- [80] M. Kohata, T. Shiota, Y. Watanabe, S. Atoh, A. Nabae, and Y. Akagi, "A novel compensation using static induction thyristors for reactive power, harmonics," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1988, pp. 843–849.
- [81] G. H. Choe, A. K. Wallace, and M. H. Park, "Control technique of active power filter for harmonic elimination, reactive power control," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1988, pp. 859–866.
- [82] F. Z. Peng, H. Akagi, and A. Nabae, "A new approach to harmonic compensation in power systems," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1988, pp. 874–880.
- [83] C. Wong, N. Mohan, S. E. Wright, and K. N. Mortensen, "Feasibility study of AC, DC-side active filters for HVDC converter terminals," *IEEE Trans. Power Delivery*, vol. 4, pp. 2067–2075, Oct. 1989.
- [84] L. T. Moran, P. D. Ziogas, and G. Joos, "Analysis, design of a novel 3-phase solid-state power factor compensator, harmonic suppressor system," *IEEE Trans. Ind. Applicat.*, vol. 25, pp. 609–619, July/Aug. 1989.
- [85] F. Z. Peng, H. Akagi, and A. Nabae, "A study of active power filters using quad-series voltage-source PWM converters for harmonic compensation," *IEEE Trans. Power Electron.*, vol. 5, pp. 9–15, Jan. 1990.
- [86] H. Akagi, Y. Tsukamoto, and A. Nabae, "Analysis, design of an active power filter using quad-series voltage source PWM converters," *IEEE Trans. Ind. Applicat.*, vol. 26, pp. 93–98, Jan./Feb. 1990.
- [87] T. Furuhashi, S. Okuma, and Y. Uchikawa, "A study on the theory of instantaneous reactive power," *IEEE Trans. Ind. Electron.*, vol. 37, pp. 86–90, Feb. 1990.
- [88] W. M. Grady, M. J. Samotyj, and A. H. Noyola, "Survey of active power line conditioning methodologies," *IEEE Trans. Power Delivery*, vol. 5, pp. 1536–1542, July 1990.
- [89] L. Rossetto and P. Tenti, "Using AC-fed PWM converters as instantaneous reactive power compensators," in *Proc. IEEE PESC'90*, 1990, pp. 855–861.
- [90] S. Fukuda and M. Yamaji, "Design, characteristics of active power filter using current source converter," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1990, pp. 965–970.
- [91] F. Z. Peng, H. Akagi, and A. Nabae, "A new approach to harmonic compensation in power systems—A combined system of shunt passive, series active filters," *IEEE Trans. Ind. Applicat.*, vol. 26, pp. 983–990, Nov./Dec. 1990.
- [92] W. M. Grady, M. J. Samotyj, and A. H. Noyola, "Minimizing network harmonic voltage distortion with an active power line conditioner," *IEEE Trans. Power Delivery*, vol. 6, pp. 1690–1697, Oct. 1991.
- [93] L. Malesani, L. Rossetto, and P. Tenti, "Active power filter with hybrid energy storage," *IEEE Trans. Power Electron.*, vol. 6, pp. 392–397, July 1991.
- [94] S. Bhattacharya, D. M. Divan, and B. Banerjee, "Synchronous frame harmonic isolator using active series filter," in *Conf. Rec. 4th EPE Conf.*, 1991, pp. 1230–1240.
- [95] S. M. Williams and R. G. Hoft, "Adaptive frequency domain control of PWM switched power line conditioner," *IEEE Trans. Power Electron.*, vol. 6, pp. 665–670, Oct. 1991.
- [96] H. Fujita and H. Akagi, "A practical approach to harmonic compensation in power systems—series connection of passive, active filters," *IEEE Trans. Ind. Applicat.*, vol. 27, pp. 1020–1025, Nov./Dec. 1991.
- [97] W. M. Grady, M. J. Samotyj, and A. H. Noyola, "The application of network objective functions for actively minimizing the impact of voltage harmonics in power systems," *IEEE Trans. Power Delivery*, vol. 7, pp. 1379–1386, July 1992.
- [98] B. Acharya, D. M. Divan, and R. W. Gascoigne, "Active power filters using resonant pole inverters," *IEEE Trans. Ind. Applicat.*, vol. 28, pp. 1269–1276, Nov./Dec. 1992.
- [99] B. B. Banerjee, D. Pileggi, D. Atwood, D. Divan, S. Bhattacharya, and R. Zavadil, "Design of an active series/passive parallel harmonic filter for ASD loads at a wastewater treatment plant," in *Proc. PQA Conf.*, 1992, pp. 1–7.
- [100] H. Akagi, "Trends in active power line conditioners," in *Proc. IEEE IECON'92*, 1992, pp. 19–24.
- [101] L. Moran, M. Diaz, V. Higuera, R. Wallace, and J. Dixon, "A three-phase active power filter operating with fixed switching frequency for reactive power, current harmonic compensation," in *Proc. IEEE IECON'92*, 1992, pp. 362–367.
- [102] E. H. Song and B. H. Kwon, "A novel digital control for active power filter," in *Proc. IEEE IECON'92*, 1992, pp. 1168–1173.
- [103] P. F. Wojciak and D. A. Torrey, "The design, implementation of active power filters based on variable structure system concepts," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1992, pp. 850–857.

- [104] A. E. Emanuel and M. Yang, "On the harmonic compensation in non-sinusoidal systems," *IEEE Trans. Power Delivery*, vol. 8, pp. 393–399, Jan. 1993.
- [105] F. Z. Peng, H. Akagi, and A. Nabae, "Compensation characteristics of the combined system of shunt passive, series active filters," *IEEE Trans. Ind. Applicat.*, vol. 29, pp. 144–152, Jan./Feb. 1993.
- [106] V. B. Bhavaraju and P. N. Enjeti, "Analysis, design of an active power filter for balancing unbalanced loads," *IEEE Trans. Power Electron.*, vol. 8, pp. 640–647, Oct. 1993.
- [107] J. F. Chicharo, D. Dejsakulrit, and B. S. P. Perera, "A centroid based switching strategy for active power filters," *IEEE Trans. Power Electron.*, vol. 8, pp. 648–653, Oct. 1993.
- [108] L. Moran, P. Godoy, R. Wallace, and J. Dixon, "A new current control strategy for active power filters using three PWM voltage source inverters," in *Proc. IEEE PESC'93*, 1993, pp. 3–9.
- [109] S. Bhattacharya, D. M. Divan, and B. B. Banerjee, "Control, reduction of terminal voltage total harmonic distortion (THD) in a hybrid series active, parallel passive filter system," in *Proc. IEEE PESC'93*, 1993, pp. 779–786.
- [110] N. Balbo, D. Sella, R. Penzo, G. Bisiach, D. Cappellieri, L. Malesani, and A. Zuccato, "Hybrid active filter for parallel harmonic compensation," in *Conf. Rec. EPE Conf.*, 1993, pp. 133–138.
- [111] S. Fukuda and J. Endoh, "Control method, characteristics of active power filters," in *Conf. Rec. EPE Conf.*, 1993, pp. 139–144.
- [112] C. Tutas, "Sliding mode control of a voltage-source active filters," in *Conf. Rec. EPE Conf.*, 1993, pp. 156–161.
- [113] M. X. Wang, H. Pouliquen, and M. Grandpierre, "Performance of an active filter using PWM current source inverter," in *Conf. Rec. EPE Conf.*, 1993, pp. 218–223.
- [114] J. H. Xu, C. Lott, S. Saadate, and B. Davat, "Compensation of AC-DC converter input current harmonics using a voltage-source active power filter," in *Conf. Rec. EPE Conf.*, 1993, pp. 233–238.
- [115] V. B. Bhavaraju and P. Enjeti, "A novel active line conditioner for a three-phase system," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1993, pp. 979–985.
- [116] J. W. Dixon, J. C. Garcia, and L. T. Moran, "A control system for a three-phase active power filter which simultaneously compensates power factor, unbalanced loads," in *Proc. IEEE IECON'93*, 1993, pp. 1083–1087.
- [117] P. Humberto and Z. C. Albenes, "A simple control strategy for shunt power line conditioner with inductive energy storage," in *Proc. IEEE IECON'93*, 1993, pp. 1093–1098.
- [118] K. Hoffman and G. Ledwich, "Fast compensation by a pulsed resonant current source active power filter," in *Proc. IEEE IECON'93*, 1993, pp. 1297–1302.
- [119] J. N. Le, M. Pereira, K. Renz, and G. Vaupel, "Active damping of resonances in power systems," *IEEE Trans. Power Delivery*, vol. 9, pp. 1001–1008, Apr. 1994.
- [120] H. Akagi, "Trends in active power line conditioners," *IEEE Trans. Power Electron.*, vol. 9, pp. 263–268, May 1994.
- [121] A. Campos, G. Joos, P. D. Ziogas, and J. F. Lindsay, "Analysis, design of a series voltage unbalance compensator based on a three-phase VSI operating with unbalanced switching functions," *IEEE Trans. Power Electron.*, vol. 9, pp. 269–274, May 1994.
- [122] A. Cavallini and G. C. Montanari, "Compensation strategies for shunt active-filter control," *IEEE Trans. Power Electron.*, vol. 9, pp. 587–593, Nov. 1994.
- [123] D. Vincenti, H. Jin, and P. Ziogas, "Design, implementation of a 25 kVA three-phase PWM AC line conditioner," *IEEE Trans. Power Electron.*, vol. 9, pp. 384–389, July 1994.
- [124] D. Dejsakulrit, B. S. P. Perera, and J. F. Chicharo, "A novel equal sampling switching strategy for active power filters," *Elect. Mach. Power Syst.*, vol. 22, pp. 405–421, Apr. 1994.
- [125] J. H. Xu, C. Lott, S. Saadate, and B. Davat, "Simulation, experimentation of a voltage source active filter compensating current harmonics, power-factor," in *Proc. IEEE IECON'94*, 1994, pp. 411–415.
- [126] J. O. Krah and J. Holtz, "Total compensation of line side switching harmonics in converter fed AC locomotives," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1994, pp. 913–920.
- [127] Z. Radulovic and A. Sabanovic, "Active filter control using a sliding mode approach," in *Proc. IEEE PESC'94*, 1994, pp. 177–182.
- [128] C. Pahmer, G. A. Capolino, and H. Henao, "Computer-aided design for control of shunt active filter," in *Proc. IEEE IECON'94*, 1994, pp. 669–674.
- [129] F. Le Magoarou and F. Monteil, "Influence of the load on the design process of an active power filter," in *Proc. IEEE IECON'94*, 1994, pp. 416–421.
- [130] P. Verdelho and G. D. Marques, "Design, performance of an active power filter, unbalanced current compensator," in *Proc. IEEE IECON'94*, 1994, pp. 422–427.
- [131] G. Ledwich and P. Doulai, "Multiple converter performance, active filtering," *IEEE Trans. Power Electron.*, vol. 10, pp. 273–279, May 1995.
- [132] S. Bhattacharya, D. M. Divan, and B. B. Banerjee, "Active filter solutions for utility interface," in *Proc. IEEE ISIE'95*, 1995, pp. 1–11.
- [133] A. V. Zyl, J. H. R. Enslin, W. H. Steyn, and R. Spee, "A new unified approach to power quality management," in *Proc. IEEE PESC'95*, 1995, pp. 183–188.
- [134] S. Bhattacharya and D. Divan, "Design, implementation of a hybrid series active filter system," in *Proc. IEEE PESC'95*, 1995, pp. 189–195.
- [135] F. Kamran and T. G. Habetler, "Combined deadbeat control of a series-parallel converter combination used as a universal power filter," in *Proc. IEEE PESC'95*, 1995, pp. 196–201.
- [136] N. R. Raju, S. S. Venkata, R. A. Kagalwala, and V. V. Sastry, "An active power quality conditioner for reactive power, harmonics compensation," in *Proc. IEEE PESC'95*, 1995, pp. 209–214.
- [137] Z. Yao, S. Lahaie, and V. Rajagopalan, "Robust compensator of harmonics, reactive power," in *Proc. IEEE PESC'95*, 1995, pp. 215–221.
- [138] F. Kamran and T. G. Habetler, "A novel on-line UPS with universal filtering capabilities," in *Proc. IEEE PESC'95*, 1995, pp. 500–506.
- [139] M. Rastogi, N. Mohan, and A. A. Edris, "Filtering of harmonic currents, damping of resonances in power systems with a hybrid-active filter," in *Proc. IEEE APEC'95*, 1995, pp. 607–612.
- [140] H. Akagi and H. Fujita, "A new power line conditioner for harmonic compensation in power systems," *IEEE Trans. Power Delivery*, vol. 10, pp. 1570–1575, July 1995.
- [141] S. Saetio, R. Devaraj, and D. A. Torrey, "The design, implementation of a three-phase active power filter based on sliding mode control," *IEEE Trans. Ind. Applicat.*, vol. 31, pp. 993–1000, Sept./Oct. 1995.
- [142] M. Rastogi, N. Mohan, and A. A. Edris, "Hybrid-active filtering of harmonic currents in power systems," *IEEE Trans. Power Delivery*, vol. 10, pp. 1994–2000, Oct. 1995.
- [143] C. E. Lin, W. F. Su, S. L. Lu, C. L. Chen, and C. L. Huang, "Operation strategy of hybrid harmonic filter in demand-side system," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1995, pp. 1862–1866.
- [144] S. Bhattacharya, A. Veltman, D. M. Divan, and R. D. Lorenz, "Flux based active filter controller," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1995, pp. 2483–2491.
- [145] S. Bhattacharya and D. Divan, "Synchronous frame based controller implementation for a hybrid series active filter system," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1995, pp. 2531–2540.
- [146] J. Dixon, G. Venegas, and L. Moran, "A series active power filter based on a sinusoidal current controlled voltage source inverter," in *Proc. IEEE IECON'95*, 1995, pp. 639–644.
- [147] S. G. Jeong and M. H. Woo, "DSP based active power filter with predictive current control," in *Proc. IEEE IECON'95*, 1995, pp. 645–650.
- [148] Z. Li, H. Jin, and G. Joos, "Control of active filters using digital signal processors," in *Proc. IEEE IECON'95*, 1995, pp. 651–655.
- [149] H. L. Jou, "Performance comparison of the three-phase active power-filter algorithms," *Proc. Inst. Elect. Eng.—Generation, Transmission, Distribution*, vol. 142, no. 6, pp. 646–652, Nov. 1995.
- [150] J. W. Dixon, J. J. Garcia, and L. Moran, "Control system for three-phase active power filter which simultaneously compensates power factor, unbalanced loads," *IEEE Trans. Ind. Electron.*, vol. 42, pp. 636–641, Dec. 1995.
- [151] M. Taleb, A. Kamal, A. J. Sowaied, and M. R. Khan, "An alternative active power filter," in *Proc. IEEE PEDES'96*, 1996, pp. 410–416.
- [152] H. Akagi, "New trends in active filters for improving power quality," in *Proc. IEEE PEDES'96*, 1996, pp. 417–425.
- [153] G. H. Rim, I. Kang, W. H. Kim, and J. S. Kim, "A shunt hybrid active filter with two passive filters in tandem," in *Proc. IEEE APEC'96*, 1996, pp. 361–366.
- [154] P. T. Cheng, S. Bhattacharya, and D. M. Divan, "Hybrid solutions for improving passive filter performance in high power applications," in *Proc. IEEE APEC'96*, 1996, pp. 911–917.
- [155] L. Malesani, P. Mattavelli, and P. Tamasin, "High-performance hysteresis modulation technique for active filters," in *Proc. IEEE APEC'96*, 1996, pp. 939–946.
- [156] G. Van Schoor and J. D. V. Wyk, "A study of a system of current fed converters as an active three-phase filter," in *Proc. IEEE PESC'87*, 1987, pp. 482–490.
- [157] C. E. Lin, C. L. Chen, and C. H. Huang, "Reactive, harmonic current compensation for unbalanced three-phase system," in *Proc. Int. Conf. High Technology in the Power Industry*, 1991, pp. 317–321.
- [158] C. A. Quinn and N. Mohan, "Active filtering of harmonic currents in three-phase, four-wire systems with three-phase, single-phase nonlinear loads," in *Proc. IEEE APEC'92*, 1992, pp. 829–836.

- [159] C. E. Lin, C. L. Chen, and C. L. Huang, "Calculating approach, implementation for active filters in unbalanced three-phase system using synchronous detection method," in *Proc. IEEE IECON'92*, 1992, pp. 374–380.
- [160] C. A. Quinn, H. Mohan, and H. Mehta, "A four-wire, current controlled converter provides harmonic neutralization in three-phase, four-wire systems," in *Proc. IEEE APEC'93*, 1993, pp. 841–846.
- [161] P. Enjeti, W. Shireen, P. Packebush, and I. Pitel, "Analysis, design of a new active power filter to cancel neutral current harmonics in three-phase four-wire electric distribution systems," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1993, pp. 939–946.
- [162] C. L. Chen, C. E. Lin, and C. L. Huang, "An active filter for unbalanced three-phase system using synchronous detection method," in *Proc. IEEE PESC'94*, 1994, pp. 1451–1455.
- [163] L. Moran, P. Werlinger, J. Dixon, and R. Wallace, "A series active power filter which compensates current harmonics, voltage unbalance simultaneously," in *Proc. IEEE PESC'95*, 1995, pp. 222–227.
- [164] G. Kamath, N. Mohan, and D. Albertson, "Hardware implementation of a novel reduced rating active filter for 3-phase, 4-wire loads," in *Proc. IEEE APEC'95*, 1995, pp. 984–989.
- [165] M. Aredes and E. H. Watanabe, "New control algorithms for series, shunt three-phase four-wire active power filter," *IEEE Trans. Power Delivery*, vol. 10, pp. 1649–1656, July 1995.
- [166] F. Z. Peng and J. S. Lai, "Generalized instantaneous reactive power theory for three-phase power system," *IEEE Trans. Instrum. Meas.*, vol. 45, pp. 293–297, Feb. 1996.
- [167] D. D. Shipp, "Harmonic analysis, suppression for electrical systems supplying static power converters, other nonlinear loads," *IEEE Trans. Ind. Applicat.*, vol. 15, pp. 453–458, Sept./Oct. 1979.
- [168] H. Akagi, Y. Kanazawa, and A. Nabae, "Generalized theory of the instantaneous reactive power in three-phase circuits," in *Proc. IPEC-Tokyo*, 1983, pp. 1375–1386.
- [169] L. S. Czarnecki, "Orthogonal decomposition of the currents in a 3-phase nonlinear asymmetrical circuit with a nonsinusoidal voltage source," *IEEE Trans. Instrum. Meas.*, vol. 37, pp. 30–34, Mar. 1988.
- [170] J. H. R. Enslin and J. D. V. Wyk, "Measurement, compensation of fictitious power under nonsinusoidal voltage, current conditions," *IEEE Trans. Instrum. Meas.*, vol. 37, pp. 403–408, Sept. 1988.
- [171] J. H. R. Enslin and J. D. V. Wyk, "A new control philosophy for power electronic converters as fictitious power compensators," *IEEE Trans. Power Electron.*, vol. 5, pp. 88–97, Jan. 1990.
- [172] L. S. Czarnecki, "Scattered, reactive current, voltage, power in circuits with nonsinusoidal waveforms, their compensation," *IEEE Trans. Instrum. Meas.*, vol. 40, pp. 563–567, June 1991.
- [173] A. Ferrero and G. S. Furga, "A new approach to the definition of power components in three-phase systems under nonsinusoidal conditions," *IEEE Trans. Instrum. Meas.*, vol. 40, pp. 568–577, June 1991.
- [174] J. L. Willems, "A new interpretation of the Akagi-Nabae power components for nonsinusoidal three-phase situations," *IEEE Trans. Instrum. Meas.*, vol. 41, pp. 523–527, Aug. 1992.
- [175] G. Blaszczak, "Non-active power compensation using time-window method," *Eur. Trans. Elect. Power Eng.*, vol. 2, no. 5, pp. 285–290, Sept./Oct. 1992.
- [176] M. Rastogi, R. Naik, and N. Mohan, "A comparative evaluation of harmonic reduction techniques in three-phase utility interface of power electronic loads," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1993, pp. 971–978.
- [177] J. L. Willems, "The compensation of nonactive currents for three-phase power systems in sinusoidal steady state," *Elect. Mach. Power Syst.*, vol. 21, pp. 663–670, Oct. 1993.
- [178] H. Akagi and A. Nabae, "The p-q theory in three-phase systems under nonsinusoidal conditions," *Eur. Trans. Elect. Power Eng.*, vol. 3, no. 1, pp. 27–31, Jan./Feb. 1993.
- [179] D. A. Marshall, F. P. Venter, and J. D. V. Wyk, "An evaluation of the instantaneous calculation of load current components," *Eur. Trans. Elect. Power Eng.*, vol. 3, no. 1, pp. 53–59, Jan./Feb. 1993.
- [180] J. L. Willems, "Current compensation in three-phase power systems," *Eur. Trans. Elect. Power Eng.*, vol. 3, no. 1, pp. 61–66, Jan./Feb. 1993.
- [181] L. S. Czarnecki, "Power-factor improvement of three-phase unbalanced loads with nonsinusoidal supply voltage," *Eur. Trans. Elect. Power Eng.*, vol. 3, no. 1, pp. 67–74, Jan./Feb. 1993.
- [182] K. Mikolajuk and A. Tobola, "A new method for reduction of current, voltage harmonic distortion in power systems," *Eur. Trans. Elect. Power Eng.*, vol. 3, no. 1, pp. 85–89, Jan./Feb. 1993.
- [183] D. Lauria and E. Tironi, "Some considerations on active compensation devices," *Eur. Trans. Elect. Power Eng.*, vol. 3, no. 3, pp. 235–240, May/June 1993.
- [184] J. L. Willems and D. Aeyels, "New decomposition for 3-phase currents in power systems," *Proc. Inst. Elect. Eng.*, vol. 140, pt. C, no. 4, pp. 307–310, July 1993.
- [185] X. Dai and R. Gretsche, "Optimal compensator currents for the reduction of the harmonic distortion in networks part 1: Analytical solution," *Eur. Trans. Elect. Power Eng.*, vol. 4, no. 4, pp. 301–307, July/Aug. 1994.
- [186] X. Dai and R. Gretsche, "Optimal compensator currents for the reduction of the harmonic distortion in networks part 2: Graphic solution," *Eur. Trans. Elect. Power Eng.*, vol. 4, no. 4, pp. 304–313, July/Aug. 1994.
- [187] J. L. Willems, "Instantaneous sinusoidal, harmonic active, deactive currents in three-phase power systems," *Eur. Trans. Elect. Power Eng.*, vol. 4, no. 5, pp. 335–346, Sept./Oct. 1994.
- [188] L. S. Czarnecki, "Dynamic, power-quality-oriented approach to power theory, compensation of asymmetrical systems under nonsinusoidal conditions," *Eur. Trans. Elect. Power Eng.*, vol. 4, no. 5, pp. 347–358, Sept./Oct. 1994.
- [189] M. Depenbrock, D. A. Marshall, and J. D. V. Wyk, "Formulating requirements for a universally applicable power theory as control algorithm in power compensators," *Eur. Trans. Elec. Power Eng.*, vol. 4, no. 6, pp. 445–455, Nov./Dec. 1994.
- [190] J. F. Chicharro and H. Wang, "Power system harmonic signal estimation, retrieval for active power filter applications," *IEEE Trans. Power Electron.*, vol. 9, pp. 580–586, Nov. 1994.
- [191] L. Rossetto and P. Tenti, "Evaluation of instantaneous power terms in multi-phase systems: Techniques, application to power-conditioning equipment," *Eur. Trans. Elect. Power Eng.*, vol. 4, no. 6, pp. 469–475, Nov./Dec. 1994.
- [192] L. S. Czarnecki, "Combined time-domain, frequency-domain approach to hybrid compensation in unbalanced nonsinusoidal systems," *Eur. Trans. Elect. Power Eng.*, vol. 4, no. 6, pp. 477–484, Nov./Dec. 1994.
- [193] L. Gyugyi, R. A. Otto, and T. H. Putman, "Principles, applications of static, thyristor controlled shunt compensators," *IEEE Trans. Power App. Syst.*, vol. 97, pp. 1935–1945, Sept./Oct. 1978.
- [194] L. Gyugyi, "Reactive power generation, control by thyristor circuits," *IEEE Trans. Ind. Applicat.*, vol. 15, pp. 521–532, Sept./Oct. 1979.
- [195] Y. Sumi, Y. Harumoto, T. Hasegawa, M. Yano, K. Ikeda, and T. Matsuura, "New static VAR control using force-commutated inverters," *IEEE Trans. Power App. Syst.*, vol. 100, pp. 4216–4224, Sept. 1981.
- [196] R. T. Byerly, D. T. Poznaniak, and E. R. Taylor Jr., "Static reactive compensation for power transmission systems," *IEEE Trans. Power App. Syst.*, vol. 101, pp. 3997–4005, Oct. 1982.
- [197] J. F. Tremayne, "Impedance, phase balancing of mains-frequency induction furnaces," *Proc. Inst. Elect. Eng.*, vol. 130, pt. B, no. 3, pp. 161–170, May 1983.
- [198] E. Vasu, V. V. B. Rao, and P. Sankaran, "An optimization criterion for three-phase reactive power compensation," *IEEE Trans. Power App. Syst.*, vol. 104, pp. 3216–3220, Nov. 1985.
- [199] T. A. Kneschke, "Control of utility system unbalance caused by single-phase electric traction," *IEEE Trans. Ind. Applicat.*, vol. 21, pp. 1559–1570, Nov./Dec. 1985.
- [200] M. D. Cox and A. Mirbod, "A new static VAR compensator for an arc furnace," *IEEE Trans. Power Syst.*, vol. PWRS-1, pp. 110–119, Aug. 1986.
- [201] J. D. V. Wyk, D. A. Marshall, and S. Boshoff, "Simulation, experimental study of a reactively loaded PWM converter as a fast source of reactive power," *IEEE Trans. Ind. Applicat.*, vol. IA-22, pp. 1082–1090, Nov./Dec. 1986.
- [202] L. H. Walker, "Force-commutated reactive-power compensator," *IEEE Trans. Ind. Applicat.*, vol. IA-22, pp. 1091–1104, Nov./Dec. 1986.
- [203] R. M. Hamouda, M. R. Iravani, and R. Hackam, "Coordinated static VAR compensators, power system stabilizers for damping power system oscillations," *IEEE Trans. Power Syst.*, vol. PWRS-2, pp. 1059–1067, Nov. 1987.
- [204] T. N. Le, "Flicker reduction performance of static VAR compensators with arc furnaces," in *Conf. Rec. 2nd EPE Conf.*, 1987, pp. 1259–1263.
- [205] L. Moran, P. Ziogas, and G. Joos, "Analysis, design of a 3-phase current source solid-state VAR compensator," in *Proc. IEEE PESC'87*, 1987, pp. 463–472.
- [206] L. Gyugyi, "Power electronics in electric utilities: Static VAR compensators," *Proc. IEEE*, vol. 76, pp. 483–494, Apr. 1988.
- [207] C. W. Edwards, K. E. Mattern, E. J. Stacey, P. R. Nannery, and J. Gubernick, "Advanced static VAR generator employing GTO thyristors," *IEEE Trans. Power Delivery*, vol. 3, pp. 1622–1627, Oct. 1988.
- [208] G. G. Richards, P. Klinkhachorn, O. T. Tan, and R. K. Hartana, "Optimal L_c compensators for nonlinear loads with uncertain nonsinusoidal source, load characteristics," *IEEE Trans. Power Syst.*, vol. 4, pp. 30–36, Feb. 1989.

- [209] C. E. Lin, T. C. Chen, and C. L. Huang, "A real time calculation method for optimal reactive power compensator," *IEEE Trans. Power Syst.*, vol. 4, pp. 643–652, May 1989.
- [210] L. S. Czarnecki, "Reactive, unbalanced current compensation in three-phase asymmetrical circuits under nonsinusoidal conditions," *IEEE Trans. Instrum. Meas.*, vol. 38, pp. 754–759, June 1989.
- [211] L. T. Moran, P. D. Ziogas, and G. Joos, "Analysis, design of a three-phase synchronous solid-state var compensator," *IEEE Trans. Ind. Applicat.*, vol. 25, pp. 598–608, July/Aug. 1989.
- [212] Y. Baghzouz and M. D. Cox, "Optimal shunt compensation for unbalanced linear loads with nonsinusoidal supply voltages," *Elect. Mach. Power Syst.*, vol. 19, pp. 171–183, Oct. 1991.
- [213] G. Joos, L. Moran, and P. Ziogas, "Performance analysis of a PWM inverter VAR compensator," *IEEE Trans. Power Electron.*, vol. 6, pp. 380–391, July 1991.
- [214] J. Kearly, A. Y. Chikhani, R. Hackam, M. M. A. Salama, and V. H. Quintana, "Microprocessor controlled reactive power compensator for loss reduction in radial distribution feeders," *IEEE Trans. Power Delivery*, vol. 6, pp. 1848–1855, Oct. 1991.
- [215] H. A. Kojori, S. B. Dewan, and J. D. Lavers, "A large-scale PWM solid-state synchronous condenser," *IEEE Trans. Ind. Applicat.*, vol. 28, pp. 41–49, Jan./Feb. 1992.
- [216] C. Schauder and H. Mehta, "Vector analysis, control of advanced static VAR compensators," *Proc. Inst. Elect. Eng.*, vol. 140, pt. C, no. 4, pp. 299–306, July 1993.
- [217] J. Machowski and D. Nelles, "Simple robust adaptive control of static VAR compensator," *Eur. Trans. Elect. Power Eng.*, vol. 3, no. 6, pp. 429–435, Nov./Dec. 1993.
- [218] Y. Tang and L. Xu, "A new converter topology for advanced static VAR compensation in high power applications," in *Conf. Rec. IEEE-IAS Annu. Meeting*, 1993, pp. 947–953.
- [219] C. A. Gross and R. S. Sell, "Near-optimum capacitor allocation on distribution feeder for voltage control," *Elect. Mach. Power Syst.*, vol. 22, no. 4, pp. 311–315, 1994.
- [220] F. Z. Peng and J. S. Lai, "A static VAR generator using a staircase waveform multilevel voltage-source converter," in *Proc. Power Quality Conf.*, 1994, pp. 58–66.
- [221] A. Kern and G. Schroder, "A novel approach to power factor control, balancing problems," in *Proc. IEEE IECON'94*, 1994, pp. 428–433.
- [222] J. B. Ekanayake and N. Jenkins, "A three-level advanced static VAR compensator," *IEEE Trans. Power Delivery*, vol. 11, pp. 540–545, Jan. 1996.
- [223] Y. Yoshioka, S. Konishi, N. Eguchi, and K. Hino, "Self-commutated static flicker compensator for arc furnaces," in *Proc. IEEE APEC'96*, 1996, pp. 891–897.



Bhim Singh received the B.E. degree from the University of Roorkee, Roorkee, India, and the M.Tech. and Ph.D. degrees from the Indian Institute of Technology, New Delhi, India, in 1977, 1979, and 1983, respectively.

In 1983, he joined the Department of Electrical Engineering, University of Roorkee, as a Lecturer. He became a Reader in 1988. In December 1990, he joined the Department of Electrical Engineering, Indian Institute of Technology, New Delhi, India, as an Assistant Professor. He became an Associate

Professor in 1994 and has been a Professor since August 1997. His fields of interest include CAD, power electronics, active filters, static var compensation, and analysis and digital control of electrical machines.

Prof. Singh is a Fellow of the Institution of Engineers (India) and Institution of Electrical and Telecommunications Engineers and a Life Member of the Indian Society of Technical Education, System Society of India, and National Institute of Quality and Reliability.



Kamal Al-Haddad (S'85–M'88–SM'93) received the B.Sc.A. and M.Sc.A. degrees from the Université du Québec à Trois-Rivières, Trois-Rivières, P.Q., Canada, and the Ph.D. degree from the Institut National Polytechnique, Toulouse, France, in 1982, 1984, and 1988, respectively.

From June 1987 to June 1990, he was a Professor in the Engineering Department, Université du Québec à Trois-Rivières. In June 1990, he became a Professor in the Electrical Engineering Department, École de Technologie Supérieure, Montreal, P.Q., Canada. His fields of interest are static power converters, harmonics and reactive power control, and switch-mode and resonant converters, including the modeling, control, and development of industrial prototypes for various applications.

Prof. Al-Haddad is a member of the Order of Engineering of Québec, Canada, and the Canadian Institute of Engineers.



Amrish Chandra (S'85–M'86) received the B.E. degree from the University of Roorkee, Roorkee, India, the M.Tech. degree from the Indian Institute of Technology, New Delhi, India, and the Ph.D. degree from the University of Calgary, Calgary, Alta., Canada, in 1977, 1980, and 1987, respectively.

He was a Lecturer and later a Reader at the University of Roorkee. He is currently a Professor in the Electrical Engineering Department, École de Technologie Supérieure, Montreal, P.Q., Canada. His main research interests are active power filters and FACTS.