
First Line of the Title Second Line of the Title

Nuclear Engineering – Politecnico di Milano

Pagliuca Simone, et al.

my contact, al.'s contacts

Course: Or other indication

Academic Year: Or some time indication

ABSTRACT

Here write you Abstract.

Key-words: Key, Words, Here

CONTENTS

1	Introduction	5
1.1	Context	5
1.2	Case Study	6
1.2.1	Reactor	6
1.2.2	Secondary Plant	7
1.3	Objectives	7
1.3.1	Decarbonization Impact	8
2	Data Collection	9
2.1	Approach	9
2.1.1	Introduction	9
2.1.2	Methodology	9
2.2	Heating and Cooling Demand	10
2.3	Domestic Hot Water Demand	11
2.3.1	Normalization of the Data	11
2.4	Heat Pump distribution and Cooling Demand	11
2.4.1	Photovoltaic System Size	11
2.4.2	Reference Photovoltaic Production	12
2.5	Other Electricity Demand	12
2.6	Validation	13
2.7	Demand Distribution	13
3	Technical Plant Modelling	14
3.1	Main assumptions and plant layout	15
3.1.1	SMR	16
3.1.2	H2 Plant	17
3.1.3	Methanation Reactor Modeling Approach	20
3.1.4	Gas Turbine	20
3.1.5	H_2 and CH_4 buffers	22
3.1.6	Control Room	23
4	Methodology	24
4.1	Dymola simulation features	25
4.1.1	Model inputs	25

4.1.2	Turbine and HTSE load setpoints	25
4.1.3	Rate limiting	27
4.1.4	Steam Tap Flow Setpoint	27
4.2	Results Post-Processing	28
4.2.1	Energy Balances	28
4.2.2	Hydrogen and Syngas production	29
4.2.3	Hydrogen production	29
4.2.4	Syngas production	29
5	Economic Study	29
5.1	Introduction	29
5.2	CAPEX	30
5.2.1	Capex for E-SMRs	30
5.2.2	Capex for HTSE	31
5.2.3	Capex for Hydrogen Storage Buffer	31
5.2.4	Capex for Hydrogen Compressor	32
5.2.5	Capex for Gas Turbine	32
5.2.6	Capex for Methanation Reactor	32
5.3	OPEX	32
5.3.1	Opex for E-SMRs	33
5.3.2	Opex for HTSEs	33
5.3.3	Opex for Hydrogen Storage Buffer	33
5.3.4	Opex for Hydrogen Compressor	34
5.3.5	Opex for Gas Turbine	34
5.3.6	Opex for Methanation Reactor	34
5.4	Revenues	34
5.4.1	Electricity Revenues	35
5.4.2	Hydrogen Revenues	35
5.5	Economic Results: base case	35
5.5.1	Sensitivity Analysis	35
5.6	Economic Results: alternative scenarios	36
6	Results	36
6.1	Environmental Impact	36
6.1.1	GHG Emissions assessment	36
6.1.2	H ₂ O Usage	37

6.1.3	Land Use	37
6.2	Conclusions	37
7	Possible Improvements	37
7.1	On the Data Collection	37
7.2	On the Plant Modelling	38
7.3	On the Economic Study	38
8	Conclusion	38

1 INTRODUCTION

1.1 Context

Italy is facing a significant energy transition, with the aim of achieving net-zero emissions by 2050. The residential sector plays a crucial role in this transition, as it accounts for $\sim 22\%$ of the total energy consumption and emissions [1].

The residential sector shows a high potential for decarbonization through the adoption of renewable energy sources such as solar photovoltaic (PV) systems and heat pumps (HP). However, this transition also introduces significant challenges in terms of monitoring and management, as it leads to a highly distributed production network that complicates national grid operations. Areas with dispersed populations and a high proportion of residential buildings often face particular difficulties during this transition. Solar photovoltaic systems are the primary choice for domestic renewable energy, but single-family houses are likely to feed a significant amount of their production into the grid, unlike apartment blocks of the same area where self-consumption is much higher.

In this context the role of nuclear energy is being reconsidered, especially with the advent of Small Modular Reactors (SMRs). Specifically, the present study focuses on the north-western part of the province of Varese, in the Lombardy region of Italy, where an hybrid system based on the integration of SMRs in a solar powered grid is being evaluated.



Figure 1: Target geographical region for the project.

The integration of SMRs could provide a stable and reliable energy source to complement the intermittent nature of renewable energy sources such as solar PV systems, while also addressing the challenges of grid management and energy distribution in these areas.

1.2 Case Study

This study evaluates the technical and economic feasibility of integrating small modular reactors (SMRs) into the residential sector, considering the area's specific characteristics and the potential benefits and challenges of such implementation.

An Italian energy company specialized in electricity production has been entrusted by the national government with the development of a strategic project supporting the energy transition and decarbonization. The project involves the implementation of a hybrid system combining nuclear power, renewable energy sources, and the production of hydrogen and synthetic CO₂-neutral methane. The presence of hydrogen production is primarily aimed at decarbonizing the land transport sector in the area, while the production of synthetic methane is intended to meet the residual demand for fossil fuels (e.g., heating) with CO₂-neutral gas. It is developed in accordance with European Union guidelines and is part of the EU-sponsored "net-zero" project cluster.

The proposed system consists of two SMRs, each with a nominal power output of 180 MWe, coupled with a secondary system capable of producing hydrogen through high-temperature steam electrolysis (HTSE). This system also includes synthetic gas production via CO₂ methanation, which feeds into the gas mains and powers a small gas turbine with a nominal electrical output of 47 MWe. The electricity generated by this integrated system along with the residential PV production is designed to meet the entire demand of the service area. Additionally, the plant is configured to handle demand peaks and enhance profitability and adaptability to various energy market requirements.



Figure 2: Simple schematic of the proposed hybrid plant integrating SMRs, hydrogen production, methanation, and residential PV.

1.2.1 Reactor

Our plant consists of two SMRs installed in Ispra, where the Joint Research Center (JRC) is located. The JRC is a research facility of the European Commission which has been chosen since

it represents an already nuclearized site. This suggests the possibility of an easier pathway towards the construction of a future nuclear plant.

Moreover, the facility is home to the ESSOR reactor, currently facing decommissioning. The installation of at least one of the two SMRs could take place, technically, within the ESSOR reactor building. The containment was oversized due to the particular use case of the ESSOR reactor: primary and secondary circuits, as well as several laboratories are accommodated within the main building.

1.2.2 Secondary Plant

The secondary plant is designed for dual-purpose hydrogen utilization. Its primary function is to produce hydrogen through high-temperature steam electrolysis (HTSE), with a constant output allocated for market supply. Additionally, the plant uses the remaining hydrogen to produce synthetic gas via CO₂ methanation. This synthetic gas production serves two main purposes: it fuels the gas turbine and creates a surplus that can be stored to reduce the region's dependence on fossil fuels, thereby supporting decarbonization efforts.

1.3 Objectives

The study aims to evaluate both the technical and economic feasibility of the proposed installation.

From a technical perspective, the system's capacity to meet energy demands and adapt to transient conditions will be assessed. From an economic standpoint, the total plant costs will be analyzed to determine the conditions required for achieving a positive net present value (NPV) within a reasonable timeframe.

The evaluation will consider the entire plant operating over a time span of 60 years. The evolution of residential energy and building performance is simplified into four scenarios, each representative of a 15-year period:

- Years 1-15: Current state of the residential sector in the area
- Years 16-30: There is still a significant share of fossil fuel heating systems in the residential sector
- Years 31-45: A middle ground between the optimistic and pessimistic scenarios, with a balanced mix of electrification and fossil fuel systems
- Years 46-60: Residential sector is mostly electrified with highly efficient homes

Given the constraints of the available data, the assessment will consider the plant to be operational as of the current year (2025). At the conclusion of the study, considerations will be made regarding a more realistic starting time. The plan is to abstract from a specific starting time by considering capital and operational costs relative to each other.

The effectiveness of the hybrid system is evaluated with respect to the following key aspects:

- The investment cost to make the plant profitable
- The decarbonization impact
- The effectiveness of integration of the several components of the plant




Figure 3: Distribution of energy classes in the residential sector for the four scenarios.

1.3.1 Decarbonization Impact

The decarbonization impact will be assessed through an analysis of CO_2 emission reductions achieved by implementing the hybrid system. A comparative approach will be adopted, examining emissions from both the current residential sector energy mix and those projected for the proposed system across various scenarios.

The reduction will be quantified based on two primary factors:

- The volume of conventional gas replaced by CO_2 -neutral synthetic gas
- Changes in the overall energy mix composition

Both aspects will be evaluated using grams of CO_2 -equivalent per kilowatt-hour ($\frac{gCO_2-eq}{kWh}$) as the measurement unit. The decarbonization impact will ultimately be expressed as a percentage variation from the current state of the energy mix.

2 DATA COLLECTION

At the basis of this work there is the need to have a realistic energy demand profile for the residential sector in the region under study. Given our focus on the residential sector, the overall energy demand can be seen as the sum of the heating/cooling contribution + all the other electricity consumptions for appliances and lightning. Several simplifications will be made through the following derivation but we point out any possible improvement that could be made but was considered out of the scope of this work.

2.1 Approach

2.1.1 Introduction

In Italy, an APE (Attestato di Prestazione Energetica) is a document that certifies the energy performance of a propriety unit (*unità immobiliare*). This certification must be issued by a qualified technician and is mandatory for all buildings that are sold, rented or refurbished.

The APE classifies buildings in energy class, a letter grade (from A4 to G), that indicates the energy performance of the building, with A4 being the most efficient and G being the least efficient. The certificate includes many informations about the building among which it is possible to find information about geometry, plants, materials as well as the use of the building (commercial, residential, industrial, public, etc.).

Each unit refers to a distinct and identifiable part of a real estate property, such as an apartment, a house, or a commercial space, that can be individually owned, sold, or rented. For instance, a building with three apartments will have three separate APEs, one for each apartment. For this reason we can safely assume that each unit is the residence of a single family.

2.1.2 Methodology

The plan is to determine the demand profile of electricity in the region $P_{e,tot}$ from a distribution of energy classes. To do so it is necessary to first determine the reference demand profile for each energy class $P_{e,ref,i}$ where i is the energy class.

For each energy class there is need to determine:

- Heating thermal demand $\dot{Q}_h$
- Cooling thermal demand $\dot{Q}_c$
- Domestic hot water thermal demand $\dot{Q}_{dhw}$

For each energy class we also need the share of heat pumps $\chi_{HP,i}$ to differentiate between electrified and fossil based heat generation. The primary energy demand (electricity or fossil fuels) are obtained in a simplified manner with average efficiencies.

Regarding the electricity production from photovoltaic system we need to determine the share of buildings with photovoltaic systems for each class $\chi_{PV,i}$ and the average size of the photovoltaic system $P_{e,i}^+$ for each energy class, this last was differentiated between households with and without an heat pump. A reference profile of the PV production for the region is obtained and then weighted on the simulated scenario.

Another electricity contribution is the one from appliances and lighting, $P_{e,other}$ which is assumed to be equal for all classes. The reference demand profile can then be determined for each energy class i as follows:

$$P_{e,ref,i} = \left[\chi_{HP,i} \cdot \left(\frac{\dot{Q}_{h,i} + \dot{Q}_{DHW}}{COP} + \chi_{cooling} \cdot \frac{\dot{Q}_{c,i}}{EER} \right) + (1 - \chi_{HP,i}) \cdot \left(\frac{\dot{Q}_{h,i} + \dot{Q}_{DHW}}{\eta_{fossil}} \right) - \chi_{PV,i} \cdot (\chi_{HP,i} \cdot P_{PV,W/HP} + (1 - \chi_{HP,i}) \cdot P_{PV,W/OHP}) + P_{e,other} \right] \quad (1)$$

Then, this can be multiplied by the number of buildings in the region N_{UI} and the share of each energy class χ_i to obtain the total demand $P_{e,tot}$.

$$P_{e,tot} = \sum_{i=A4}^G N_{UI} \cdot \chi_i \cdot P_{e,ref,i} \quad (2)$$

Data Sources From the CENED database [2] we extracted the information about APEs for the relevant municipalities of the region, which were derived based on the map of primary substations from the national grid operator (GSE) [3]. The data was also filtered to include only residential buildings, excluding commercial and industrial ones. Furthermore, we filtered unhealthy data points at every step of the process, most of the times by only taking the 99^o percentile. This was necessary given the large amount of data from the complete regional database. After this preliminary filtering an easier-to-manage csv file was obtained. The number of buildings was computed from the ISTAT database [4] by extracting the population of the municipalities and dividing by the average household size in the province.

2.2 Heating and Cooling Demand

For each energy class we have taken a real example of a residential building from the region under study and computed the hourly thermal demand for heating and cooling throughout the year. This is obtained by means of a professional software (TERMOLOG) that allows for dynamic simulation of the energy system of the building. This computation is based on the UNI EN ISO 52016 standard. We used one reference building per energy class all with the same utilization profile. The output of the calculation is an hourly profile of the thermal demand for heating and cooling.

2.3 Domestic Hot Water Demand

The domestic hot water demand is assumed to be equal for all energy classes. It has been computed based on the consumption profile depicted in [5], as a reference we choose the profile of switzerland since it is similar to the one of the region under study. It is then scaled based on the average number of people per household in the region, which is 2.25 [4]. This thermal demand is then summed to the heating demand profile.


2.3.1 Normalization of the Data

Given that our data is based on real building we had to normalize the data to obtain a reference value for each energy class. This is done by taking into account the useful heated area of the building and the EP,nren (Primary Energy Demand for non-renewable energy) value of the APE. The EP,nren is the value used to determine the energy class of the building and is defined as energy per unit of area per year. Therefore we multiply the EP,nren by the useful heated area of the building to obtain the total primary energy demand for non-renewable energy. Conversion factor for each energy class are taken as the ratio between said value obtained by the averages extracted from the CENED database [2] and that for our reference buildings.

$$C = \frac{EP_{nren,CENED} \cdot A_{r,CENED}}{EP_{nren,REF} \cdot A_{r,REF}} \quad (3)$$

2.4 Heat Pump distribution and Cooling Demand

We identified the share of heat pumps per energy class. We also determined the share of buildings that have a cooling system installed, which as of today comes up to 9.58%. This is a very low share and is to be expected as the region under investigation is quite chill during summer.



(a) Distribution of heat pumps across energy classes.

(b) Distribution of photovoltaic systems across energy classes.

Figure 4: Distribution of heat pumps and photovoltaic systems across energy classes.

2.4.1 Photovoltaic System Size

Moreover we then divided the data into two groups, those with an heat pump and those without. From these we plotted the distribution of the size of the photovoltaic system installed. And

computed the average (of the P_{99})




Figure 5: Distribution of photovoltaic system sizes based on heat pump presence.

The averages values are: 4.30kW and 3.70kW for the sistem with and without heat pumps respectively.

2.4.2 Reference Photovoltaic Production

We have to obtain a reference value of the photovoltaic production profile, representative of the region under study. First, the list of municipalities is fed to the Nominatim API [6] to obtain the coordinates of the center of each municipality. Then, we use the PVGIS API [7] to obtain the hourly production profile for each municipality. We fixed the angle to an average 22° and a plant size of $1kW$. For each municipaly we obtain a profile every 10° of the azithmut angle, from 0° to 360° . Those are then weighted to a gaussian distribution to represent that it is preferred to point the photovoltaic system to the south. This gives us a reference photovoltaic production profile for each municipality $P_{e,m}^+$ where m is the municipality. Then we can obtain the reference production profile for each energy class $P_{e,ref}^+$ by weighting the production profile of each municipality on the population in that municipality [4].

2.5 Other Electricity Demand

Electrical demand for appliances and lighting is modeled equal for all classes. The definition was manual, hour by hour for an average day, differentiated between the following cases:

- Winter Weekday
- Winter Weekend
- Summer Weekday
- Summer Weekend
- Winter Holiday
- Summer Holiday

Moreover we added an absence factor to take into account when people go on holiday massively during the summer period.

The profile is defined by considering the following contributions:

- standby and always on appliances
- lighting
- appliances

During the summer the need for a cooling fan was added. Moreover we added a parameter to represent the share of buildings with an induction system installed.

2.6 Validation

To verify our method is acceptable we compare the total demand by the data available online, in particular we compared it to the average annual demand, in the residential sector for the province of Varese [8], which happens to be $1931kWh$ in 2023, with a decreasing trend in the last years ($2016kWh$ in 2022 and $2119kWh$ in 2021).




Figure 6: Daily averages throughout the year of the resulting electric demand profile considering today's energy class distribution.

2.7 Demand Distribution

To better visualize the behaviour of the demand we plot the distribution of the demand hour-by-hour for each scenario.




Figure 7: Hourly Distribution of the Electrical Demand in the Four Scenarios.

3 TECHNICAL PLANT MODELLING

The whole plant was modeled in Dymola, a technical software using the Modelica language for the dynamic analysis of complex systems. To meet the overall energy demand of the target region, the plant design combines two 177 MW_e Small Modular Reactors (SMRs) with fifteen High Temperature Steam Electrolyzers (HTSEs) and a Methanation Reactor producing almost CO_2 -neutral syngas for a small Gas Turbine (47 MW_e). The TANDEM project library [9] was widely used to model the entire plant, with the exception of the methanation reactor, which was modeled from scratch in Dymola.



Figure 8: Simple schematic of the proposed hybrid plant in Dymola.

3.1 Main assumptions and plant layout

The number of reactors and HTSE modules is based on the following considerations:

- The minimum number of installed HTSE modules required has to sustain the Gas Turbine operation at the nominal power, guaranteeing a sufficient methane production.
- The maximum number of installed HTSE modules depends on the overall energy excess of the system in the least demanding hour of the year.
- The overall energy excess of the system depends on the number of SMRs.

In order to determine the optimal number of SMRs and HTSE modules that would minimize the overall cost of the plant while meeting the energy demand, an optimization problem would be required. However, for the purpose of this study, such an optimization is not performed due to the complexity of the problem. In particular, defining a direct and accurate functional relationship between the actual revenues of the plant and the number of components would require a highly detailed model, as well as a comprehensive set of equations to represent all operational constraints. Developing and solving such a model would be computationally expensive and disproportionate to the scope and objectives of the current project.

The choice was then made on the number of HTSE modules, simply considering the average between the minimum number of modules required (12) and the maximum allowed (18, with two SMRs). This results in a total of 15 HTSE modules. Accordingly, as the HTSE modules require a significant amount of electricity to operate, the number of SMRs was set to two. This allows for an efficient operation of the whole plant, with the need to import electricity just in less than 10% of the hours in a year.

However, to reduce the computational burden of the simulation in Dymola, the system is modeled using a single SMR and a single HTSE module. The actual electricity output from the SMR and hydrogen production from the HTSE are then scaled by multiplying the simulated values

by the respective number of units within the model. These scaled values are used to evaluate the overall energy balance and to feed the syngas production module.

The SMRs supply electricity to the grid, as well as both electricity and the required heat to the hydrogen production unit. The HTSEs generate hydrogen from water using the thermal and electrical energy provided by the SMRs.

At each time step, 10% of the produced hydrogen is assumed to be stored temporarily in a buffer for future sale. The remaining 90% is sent to the methanation reactor, where it reacts with carbon dioxide to produce methane.

The profile and magnitude of the future hydrogen demand is not known: the only purpose of this simplified assumption is to allow the technical evaluation of the plant's operation, while considering a reasonable amount of hydrogen to be stored and sold. An excessive hydrogen storage would not be feasible in a real-world scenario, as it would require significant investments in storage infrastructure.

The syngas produced by the methanation reactor is ultimately used as fuel in the gas turbine, while any surplus is stored in a buffer tank. The stored syngas can later be used to cover the residual fossil fuel demand of the region (i.e., the remaining heat demand not met by other sources), substantially contributing to the decarbonization of the energy mix.

3.1.1 SMR

The TANDEM library [9] was used to model the SMR, employing a simplified representation of a Small Modular Reactor. Despite being a simplified model, the overall system is quite detailed and includes various components, allowing for a realistic simulation of the reactor's behavior. It captures the dynamics of the primary and secondary loops, the turbines, the condenser, and the associated control systems.

The selected model is part of the POLIMI section of the SMR branch in the TANDEM library. Specifically, the `Test\_BOPfluid\_NSSS` [9] is a test model of the 177 MW_e light-water cooled Small Modular Reactor (SMR), based on the European SMR (E-SMR) design as proposed by the Euratom ELSMOR project [10]. The model is based on elementary components taken from the ThermoPower library [9].

The employed test model was originally designed for cogeneration, providing both electricity and thermal energy. To support this dual purpose, the Balance Of Plant features three steam extraction points—High Pressure (HP), Intermediate Pressure (IP), and Low Pressure (LP)—which allow heat to be drawn from different stages of the turbine. In the present configuration, the heat required for the HTSE is extracted via the IP tap, immediately downstream of the HP turbine stages. The HP and LP extraction lines are disabled and manually set to zero, as they are not utilized in this setup.

For the purpose of this study, the detailed modeling of the primary loop is not discussed, as the focus is on the secondary loop and its interaction with the HTSE modules. However, the detailed explanation of the reactor's core and primary loop modelling can be found in the TANDEM library documentation [10].

Some useful specifics of the SMR model are:

SMR specifics

- Core Thermal Power: 540 MW_{th}
- Core Inlet Temperature: $300 \text{ }^{\circ}\text{C}$
- Core Outlet Temperature: $324.5 \text{ }^{\circ}\text{C}$
- Primary Loop Pressure: 150 bar
- Nominal Coolant Mass Flow Rate: 3700 kg/s
- Thermodynamic Efficiency: 0.33
- Electrical Power Output: 177 MW_e
- Secondary loop: Rankine cycle with multiple turbine stages
- Steam extraction points pressure and temperature [10]:
 - HP: 45 bar, $240 \text{ }^{\circ}\text{C}$
 - IP: 7.5 bar, $150 \text{ }^{\circ}\text{C}$
 - LP: 0.8 bar, $80 \text{ }^{\circ}\text{C}$



Figure 9: Simple schematic of the selected SMR model in Dymola.

3.1.2 H2 Plant

The hydrogen production plant is also modeled using the TANDEM library [9], which provides a detailed representation of a High Temperature Steam Electrolyzer (HTSE) based on the ThermoSysPro library. This Solid Oxide Electrolyser Cell operates at high temperature, and is de-

signed to produce hydrogen from water by utilizing both thermal and electrical energy supplied by the SMR. The model captures the dynamic behavior of the HTSE and simulates the hydrogen production process accordingly.

Water goes through several heat-exchangers to reach the target temperature of 750 °C as steam:

- A pre-heater.
- A boiler, fed by the tap-steam extracted from the SMR BOP (at 150 °C).
- A second pre-heater, fed by the recovery heat from unconverted steam.
- An electrical heater.

Each electrolyser's stack then uses electricity to act on the high temperature steam and produce hydrogen.

The model receives as input a target hydrogen production rate – further defined in the demand section – and the thermal energy extracted from the SMR's steam tapping point.

The electricity consumption is instead related to the hydrogen production rate, according to the relationship $\dot{m}_{H_2} = \frac{P_{e,available}}{214} + 0.197775$, which was found by running a sweep simulation of the HTSE model in Dymola.

A key modeling assumption is that the heat input to the HTSE corresponds to the *Real* value of the heat exchanged in the ideal Heat Exchanger of the Intermediate Pressure (IP) tap loop, once the tap-steam flowrate is defined.



Figure 10: Simple schematic of the Intermediate Pressure (IP) tap loop.

The tap-steam flowrate is defined in the Control Room section, where the setpoint for the steam extraction is computed based on the target H_2 production. Again, the relationship between the tap-steam flowrate and the hydrogen production rate is defined by running a sweep simulation of the HTSE model in Dymola.

Based on the thermal input, along with several operational parameters, the HTSE model calculates the corresponding hydrogen production, resulting in a computed mass flow rate of H_2 . The estimate of the energy consumption associated with hydrogen production is also computed within the model, and subsequently included in the overall energy balance of the system.

Some key characteristics of the HTSE include:

SMR specifics

- Operating Temperature: 750 °C
- Electricity Consumption: related to the hydrogen production rate
- Nominal Production Rate: 0.1 kg/s of H_2 per module
- Number of Modules: 15

The H_2 plant is equipped with a buffer tank used to temporarily store the portion of hydrogen intended for sale, while the remainder is sent directly to the methanation reactor.




Figure 11: Simple schematic of the H_2 plant model in Dymola.

As the model is designed to simulate the operation of a single HTSE module, the target hydrogen production rate (and the effective output production rate) is obtained by dividing (and multiplying) the total input (and output) value by the number of modules (15), through a simple "Gain" component.

3.1.3 Methanation Reactor Modeling Approach

The methanation reactor was modeled to simulate the conversion of hydrogen (H_2) and carbon dioxide (CO_2) into methane (CH_4) and water (H_2O) through the Sabatier reaction:



To estimate the amount of CH_4 produced from a given reactant feed, a dimensionless parameter, *conversionEfficiency*, was introduced. This parameter (default value: 0.78) represents the maximum chemical conversion efficiency of catalytic methanation, as reported by Götz et al. [11]. It defines the fraction of the limiting reactant (either CO_2 or H_2) that is effectively converted into CH_4 , accounting for real-world inefficiencies and the incomplete conversion typical under practical temperature and pressure conditions.

The molar output flows are then determined based on reaction stoichiometry:

$$\begin{aligned} \dot{n}_{CH_4} &= \dot{n}_{lim} \cdot \eta \\ \dot{n}_{H_2O} &= 2 \cdot \dot{n}_{CH_4} \\ \dot{n}_{H_2} &= \dot{n}_{H_2,in} - 4 \cdot \dot{n}_{CH_4} \\ \dot{n}_{CO_2} &= \dot{n}_{CO_2,in} - \dot{n}_{CH_4} \end{aligned}$$

The model is reported in the appendix, along with the other components developed from scratch in Dymola.

Stoichiometry and Output Mixture Given that the reaction is not ideal, if we respect the stoichiometric ratio (1:4), the resulting gas mixture would have a lower lower heating value (LHV) than that of natural gas. To improve the energetic and economic value of our product, we decided to operate with an excess of hydrogen, specifically using a molar ratio of 1:8 between CO_2 and H_2 . This results in an output gas mixture (on a molar basis) approximately composed of:

- 41.1% CH_4
- 30.7% H_2
- 28.2% CO_2

Water is assumed to be completely removed from the product stream. The resulting lower heating value (LHV) of the dry gas mixture is 57.4359 MJ/kg.

CO_2 Usage Based on the product gas composition, we obtain a synthetic gas mass flow rate of 2.6325 kg (reference case). Given the process stoichiometry and conversion efficiency, the corresponding input of CO_2 is 3.7 kg. From this, we deduce that producing 1 kg of synthetic gas requires approximately 1.41 kg of CO_2 .

3.1.4 Gas Turbine

The gas turbine is chosen to be a GE LM6000, an aeroderivative machine able to burn fuel with high hydrogen fractions and change power output quite fast, making it a valuable element for hybrid energy systems with high renewable penetration. This component is modeled



Figure 12: Simple schematic of the Methanation Reactor model in Dymola.

through the modification of the "GasTurbineSimplified" present in the ThermoPower section of the TANDEM library [9]. The original thermopower model is a generic gas turbine model, which was adapted to represent the GE LM6000 by adjusting the relevant parameters by a factor of 1/5 to match the LM6000 nominal specifications reported below. The thermopower model has a power level input only, so it is then given additional inputs and outputs to accomplish its role in the Sette Laghi model.

GE LM6000 specifics

- Nominal Power: 47 MW_e
- Efficiency: 0.4
- Fuel: Syngas (Methane and Hydrogen)
- Mass Flow Rate of Syngas: 2.42 kg/s
- Maximum Ramp Rate : 30 MW/min
- Minimum Load: 35% of the nominal power

The turbine takes as input the fuel heating values and the power load setpoint - which is computed in the Control Room - to calculate the required mass flow rate of syngas, that is then communicated to the Syngas Buffer. Since we are not interested in the detailed modeling of the combustion process, the model is simplified to focus on the mass flow rate of syngas required to meet the setpoint load. Even though they hold a valuable energy content, the flue gases are not modeled - as the main focus is on the syngas production.

The inputs of the Gas Turbine are:

- *turbine_{load}*: the setpoint for the power level (normalized).

- *LHV*: the lower heating value of the syngas.
- *HHV*: the higher heating value of the syngas.

The only output of the Gas Turbine is:

- *fuelFlowRateOut*: the mass flow rate of syngas required to meet the setpoint load



Figure 13: Simple schematic of the Gas Turbine model in Dymola.

3.1.5 H_2 and CH_4 buffers

The H_2 and CH_4 buffers are designed to temporarily store the produced hydrogen and methane, respectively. These two components are modelled in a very simple way, defining a mass balance equation.

- The H_2 buffer receives as input the mass flow rate of the produced hydrogen from the HTSE and sends as output the 90% of the produced hydrogen to the methanation reactor.
- The CH_4 buffer receives as input both the mass flow rate of the produced syngas from the methanation reactor and the mass flow rate required by the gas turbine to guarantee its setpoint load. The turbine's requested mass flow rate is an output of the turbine's model itself.

The instantaneous content of each buffer is then computed through a mass balance equation:

$$\frac{d}{dt} \text{Content} = \dot{m}_{\text{in}} - \dot{m}_{\text{out}} \quad (5)$$

As stated previously, the H_2 buffer is used to store the 10% of the produced hydrogen, which is then sold. The CH_4 buffer is used to store the syngas produced by the methanation reactor, which can later be used to cover the residual fossil fuel demand of the region.




Figure 14: Simple schematics of the H_2 (left) and CH_4 (right) buffers in Dymola.

3.1.6 Control Room

The Control Room is the central component of the plant model, responsible for managing the overall operation of the system. It defines the interconnections between the various components, such as the SMR, HTSE, Methanation Reactor, and Gas Turbine.

The Control Room takes as inputs:

- P_{nuc} : the hourly electrical power produced by the SMR.
- $P_{turbine}$: the hourly electrical power produced by the Gas Turbine.
- $Demand$: the hourly net grid demand, considering the contribution of the PV production.
- P_{HTSE} : the hourly electrical power consumed by the HTSE modules.

The Control Room is responsible for computing the Energy Balance of the system, defined as:

$$\text{EnergyExcess} = n_{\text{reactors}} \cdot P_{nuc} + P_{turbine} - P_{HTSE} \cdot n_{HTSE} - \text{Demand} \quad [\text{MW}] \quad (6)$$

The outputs of the Control Room are:

- $setpoint_{H_2}$: the setpoint for the hydrogen production rate.
- $turbine_{load}$: the setpoint for the turbine load (in percentage).
- $mflow_{tapSteam}$: the setpoint for the mass flow rate of steam extracted from the SMR's intermediate pressure tap.

Within the Control Room, the setpoints for the various components are imported as .csv files. Setpoints are generated beforehand by a Python script focused on the analysis of a single day demand profiles, as described in the next section. The Control Room also computes the instantaneous energy excess based on the Energy Balance Equation, which will then be useful for the economic assessment.



Figure 15: Control Room modelling in Dymola.

4 METHODOLOGY

Using the Dassault Systèmes Dymola software [12], a production model was developed based on the object-oriented Modelica language.

Four representative scenarios were evaluated, as described in Section 1, each representing a 15-year operational phase of the plant, for a total time span of 60 years. The system is assumed to begin operation in 2025 and continue until 2085.

The optimal time horizon for dynamic simulation in this framework is set to 24 hours, in order to capture the daily variations in energy demand and the systems response to them.

The simulation methodology follows the steps outlined below:

1. For each scenario, an annual net electricity demand profile for the regional grid was derived through the data analysis developed in Section 2.
2. The annual profile was then clustered into five groups of days with similar load characteristics. These representative days were then dynamically simulated with Dymola.
3. A Python-based algorithm reconstructed the full annual profile by substituting actual days with the corresponding simulated cluster days.
4. Monthly energy balances — including electricity sold to the community, surplus energy exported to the market, energy deficits covered by purchases from the market — were then extracted and used as input for the economic analysis of the plant.
5. The yearly hydrogen and syngas production was also extracted from the simulation results, and added as input for the economic analysis.




Figure 16: Example of daily average electricity demand profile for the regional grid.

4.1 Dymola simulation features

The Dymola model simulates the dynamic behaviour of the plant over a 24-hour period, but requires pre-processed input data to accurately account for all the relevant phenomena. The pre-processing methodology described below is based on the single-day demand profiles of the clusters previously obtained.

4.1.1 Model inputs

As highlighted in the Control Room subsection 3.1.6, the model requires, in addition to the hourly net grid demand (i.e., one of the cluster profiles), a set of daily setpoints for the following variables:

- Turbine load, constrained between 35% and 100% of the maximum load.
- HTSE load, constrained between 60% and 100% of the maximum load.
- Steam tap flow from the intermediate pressure stage of the SMR.

Both the turbine and HTSE loads are subject to lower operational limits to avoid the risk of damaging the components when operated below their minimum thresholds.

4.1.2 Turbine and HTSE load setpoints

To evaluate the turbine and HTSE load setpoints, the proposed data pre-processing model first computes the electricity available for the hydrogen plant. This is done under the assumption that the SMRs operate continuously at their nominal power output, and that the gas turbine operates at its minimum load of 35%, ensuring it never runs below its allowed operational limit.

$$P_{e,available} = P_{e,SMR} + P_{turbogas}(35\%) - P_{e,grid} \quad (7)$$




Figure 17: Example of clusters for an annual demand profile.

This calculation helps determining the load profile of the H_2 plant, based on the load vs. electric power relationship described in the previous section, which was obtained by performing a sweep simulation of the HTSE model in Dymola.

$$\text{load}_{H_2} = \left(\frac{P_{e,\text{available}}}{214} + 0.197775 \right) \cdot \frac{1}{N_{\text{HTSE}} \cdot 0.1} \quad (8)$$

Where the mass flow rate of hydrogen produced, $\dot{m}_{H_2} = \frac{P_{e,\text{available}}}{214} + 0.197775$, is divided by the nominal mass flow rate produced by one module (0.1 kg/s) multiplied by the number of modules N_{HTSE} .

The HTSE load profile is then clipped to remain within the operational range of 60% to 100%, where 60% represents the lower operational limit.

This clipped HTSE load profile subsequently defines the actual electricity consumption of the H_2 plant.

Based on the updated system energy balance, the turbine load profile is then determined as follows:

$$\text{load}_{\text{turbine}} + P_{e,\text{SMR}} = \text{HTSE}_{\text{consumption}} + P_{e,\text{grid}} \quad (9)$$

The turbine load must also be clipped. In this case, the lower limit was set to 60% instead of the physical minimum of 35%, in order to:

- Increase the overall electricity production available for sale.
- Avoid the more emission-intensive operation associated with lower load levels.

The resulting clipped turbine load profile, together with the actual consumption of the HTSE modules, determines the final electricity balance of the integrated plant.



Figure 18: Example of final output results for 1-year operation.

The calculations show that, depending on the specific scenario, the system needs to import electricity from the grid in only 4% to 7% of the hours in a year, enabling highly efficient operation of the entire plant.

4.1.3 Rate limiting

Ramping up and ramping down rates for both the turbine and the HTSE were taken into account in the calculations.

According to the technical documentation of the selected gas turbine model, the ramping rates for the turbine are essentially unrestricted, as it can quickly reach its nominal power output.

In contrast, the HTSE module is subject to a ramping rate limit of 1% per hour. This constraint allows the model to reflect the physical limitations of the component, which cannot instantaneously adjust its load as the initial computed profile might suggest.

A Python function handles the ramping behaviour of both the turbine and HTSE loads, updating the previously calculated load profiles and corresponding energy balances accordingly.

4.1.4 Steam Tap Flow Setpoint

The steam tap flow setpoint is determined based on the HTSE load profile, computed as described above.

The relationship between the tap steam flowrate and the hydrogen production rate is established by performing a sweep simulation of the HTSE model in Dymola.




Figure 19: Example of 1-day load profile for HTSE.




Figure 20: Example of 1-day load profile for gas turbine.

4.2 Results Post-Processing

The results of the Dymola simulation are post-processed to extract the monthly energy balances of the plant, which are then used for the economic analysis.

First, a .csv file containing the hourly simulation results is generated, and the full year is reconstructed as outlined in the previous section.

4.2.1 Energy Balances

Each annual electricity balance includes:

- Electricity sold to the community.
- Surplus energy exported to the market.
- Energy deficits covered by purchases from the market.
- Energy acquired from the community's photovoltaic excess production.

As the different scenarios progress over the plant's lifetime, a substantial increase is observed in the energy acquired from the community's photovoltaic excess production. This trend reflects the growing share of renewable energy sources in the region.

Monthly aggregate balances were then cumulatively computed to serve as input for the financial analysis.




Figure 21: 1-year energy balance for the last simulated period (year 45 to 60).

4.2.2 Hydrogen and Syngas production

Hydrogen and syngas production data are also extracted from the simulation results and used to calculate the annual product balances.

Focusing on yearly balances simplifies the economic evaluation, as it assumes a stable selling price for these products throughout the year.

4.2.3 Hydrogen production

The yearly hydrogen production is calculated by summing the daily production values over the entire year.

The total hydrogen production is expressed in energy terms (MWh), using the lower heating value (LHV) of hydrogen, which is approximately 36.11 kWh/kg.

4.2.4 Syngas production

The stored syngas is assumed to contribute towards meeting the community remaining fossil fuel demand, thereby supporting the region decarbonization efforts.

Accordingly, the yearly syngas production is converted into energy units (MWh) using the lower heating value (LHV) of the produced gas, which is approximately 57.4539 MJ/kg.

5 ECONOMIC STUDY

5.1 Introduction

This economic assessment focuses on evaluating the investment and operational costs associated with the proposed integrated energy system. The analysis encompasses the estimation of capital expenditures (CAPEX) and operational expenditures (OPEX) for each subsystem,

followed by the calculation of the expected revenues generated by the overall plant. Subsequently, the Net Present Value (NPV) of the investment is determined to assess the economic viability of the solution. Finally, a sensitivity analysis is performed to investigate the impact of key techno-economic parameters on the profitability and robustness of the proposed configuration.

Moreover, the analysis has been conducted from the perspective of a public-sector energy agency, operating as a government-backed institution responsible for implementing decarbonization strategies in the designated geographical region. This agency, due to the hybrid nature of energy generation, is assumed to receive dedicated funding from the Italian government, specifically in the form of zero-interest loans aimed at supporting the deployment of the proposed low-carbon energy infrastructure.

It's also important to underline that the assessment has been conducted over a total project lifespan of 60 years, divided into four incremental scenarios of 20 years each as previously described. The starting year of the analysis has been set to 2025, which is acknowledged as not practically feasible for the commissioning of such a complex infrastructure. However, this assumption has been adopted due to the lack of sufficiently reliable long-term forecasts in the current literature, allowing for a consistent comparative framework. The initial scenario considers the integrated system to be fully operational from the outset, although preliminary calculations indicate that such a configuration would not be economically sustainable under current market conditions. Consequently, a second scenario has been investigated in which the plant initially operates as a fully electric solution, with future integration of hydrogen and syngas production capacities.

5.2 CAPEX

The estimation of capital expenditures (CAPEX) has been carried out for the main components of the proposed energy infrastructure, namely the E-SMRs, high-temperature steam electrolyzers (HTSE), the hydrogen storage buffer, the hydrogen compressor, the gas turbine, and the methanation reactor. It is important to note that the balance of plant (BoP) costs and system integration costs have already been incorporated within the CAPEX figures reported for each of these major subsystems. Consequently, BoP and integration do not constitute separate cost items in this analysis, ensuring that the CAPEX values entirely reflect the overall investment required to deploy each unit as an operational part of the integrated plant.

5.2.1 Capex for E-SMRs

The capital expenditures (CAPEX) for the E-SMRs have been estimated based on existing literature related to the TANDEM project. According to it, both reactors are assumed to have a technical lifetime of 60 years, and the specific investment cost, referred to the year 2023, is estimated at 6,050,000 EUR per MWe. This value emerges from the review conducted by CEA, where different references report investment costs ranging from 3,874,000 EUR/MWe to 7,712,000 EUR/MWe (TANDEM Project Documentation, 2023, Lazard. (2023). Lazard's Levelized Cost of Energy Analysis—Version 16.0., NEA. (2022) The Role of Nuclear Power in the Hydrogen Economy: Cost and Competitiveness. NEA No. 7630, OECD.) This results in a total CAPEX of approximately 2,141.7 million EUR, considering a combined electrical output capacity of 354 MWe and excluding integration and BoP costs. This cost estimation is directly linked to the design choices adopted in the Modelica simulations, where the same libraries used within the TANDEM project framework have been selected, ensuring consistency between technical modeling and economic assessment.

5.2.2 Capex for HTSE

The CAPEX for the HTSEs have been estimated again from the literature of the TANDEM project, in line with the methodology adopted for the E-SMRs. According to the TANDEM documentation, the specific investment cost for HTSE technology is approximately 780,000 EUR per MW of nominal power. Given that our system design includes fifteen electrolyser units, each with a nominal power capacity of 21 MW, this leads to a total CAPEX of approximately 245.7 million EUR for the HTSE section.

Each HTSE unit is assumed to have a technical lifetime of around 20 years, so that considering a 60-year project horizon, the units will need to be replaced twice after the initial investment. It is, however, reasonable to assume that the cost of HTSE technology will decrease over time as the technology matures and economies of scale are realized. The estimation of the future reduction in CAPEX relies on the cost trends observed in the hydrogen market. The report 'The European Hydrogen Market Landscape' (2024) highlights that the production cost of green hydrogen decreased by 0.25 EUR/kg over one year, falling from 6.86 EUR/kg to 6.61 EUR/kg, corresponding to an annual reduction of approximately 3.5%. Conversely, data from the German market indicate a period of price stability between March and June 2025 (European Energy Exchange, 2025). Balancing these observations, an average annual cost reduction of 1.75% is plausible, leading to a decrease of approximately 30% after the first 20-year period. In the subsequent 20-year period, technological improvements will continue, albeit at a slower pace as the technology reaches maturity. Therefore, for the second replacement cycle, a more conservative annual decrease rate of 0.875% has been assumed, corresponding to a cumulative CAPEX reduction of 15% over the second 20-year period. This anticipated decrease is primarily attributed to technological learning curves and increased manufacturing efficiencies as HTSE technology becomes more established in the market.

5.2.3 Capex for Hydrogen Storage Buffer

Also the CAPEX for the hydrogen buffer storage system have been estimated looking at the TANDEM project, consistently with the methodology applied for the other subsystems. In this case the specific investment cost for hydrogen storage is reported as 490 EUR per kg of hydrogen storage capacity. The hydrogen buffer has been sized to accommodate a maximum of one week of hydrogen production at full nominal capacity. Specifically, the storage capacity has been calculated considering a nominal production flow of 0.1 kg/s per electrolyser module, with fifteen modules operating simultaneously, resulting in a weekly storage requirement of approximately 100 tonnes:

$$\text{Storage capacity [kg]} = 0.1 \left[\frac{\text{kg}}{\text{s}} \right] \times 0.1 [-] \times 15 [\#] \times 3600 \left[\frac{\text{s}}{\text{h}} \right] \times 24 \left[\frac{\text{h}}{\text{day}} \right] \times 0.1 [-] \times 7 [\text{day}] \approx 100\text{ton} \quad (10)$$

Based on this storage capacity, the total CAPEX for the hydrogen buffer is estimated at approximately 49 million EUR (TANDEM Project Documentation). Similar to the assumptions made for the HTSE units, the hydrogen buffer is assumed to have a technical lifetime of 20 years, implying that it will need to be replaced twice during the 60-year project horizon, and the same cost reduction assumptions adopted for HTSE technology are applied.

5.2.4 Capex for Hydrogen Compressor

CAPEX have been still estimated based on data from the TANDEM project. The specific investment cost is reported as 1,000,000 EUR per MW of electrical power input, and the required compressor capacity has been determined using TANDEM's reference, which indicates that compressing a hydrogen mass flow rate of 8,257 kg/h requires 17.82 MW of electrical power. Adapting this ratio to mass flow rates results in a required compressor capacity of approximately 1.5 MW, leading to a total CAPEX of around 1,500,000 EUR. The compressor is assumed by TANDEM to have a lifetime of 10 years, meaning it must be replaced five times over the 60-year project horizon. The same cost reduction dynamics assumed for HTSE units have been applied.

5.2.5 Capex for Gas Turbine

The CAPEX for the gas turbine LM6000 have been estimated based on data reported in the study by Riboldi et al. (2020), which analyzed the environmental and economic impacts of off-shore oil platform electrification. According to this study, the investment cost for one LM6000 gas turbine is approximately 23.2 million EUR. Although the system design requires a gas turbine capacity of 47 MW, to adopt a conservative approach, cost figures were retained corresponding to the 57 MW LM6000 unit as reported in Riboldi et al. (2020), given that the model and technology are identical to those implemented in the selected design. Therefore, the CAPEX for the gas turbine has been estimated at 23.2 million EUR. The operational lifetime of the LM6000 gas turbine is assumed to be approximately 20 years, implying that it will need to be replaced twice over the 60-year project horizon.

5.2.6 Capex for Methanation Reactor

The CAPEX for the methanation reactor have been estimated at approximately 8.19 million EUR. This value has been derived based on the work of Götz et al. (2016), who reported that the investment cost of a methanation unit is roughly one-thirtieth of the cost of electrolyzers. Accordingly, the same ratio was applied to specific electrolyser CAPEX figures to estimate the cost of the methanation subsystem in our project. The methanation reactor is assumed to have a technical lifetime of 20 years, implying that it will need to be replaced twice during the 60-year project horizon. Similar to the HTSE units, the methanation reactor is expected to benefit from cost reductions over time as the technology matures.

5.3 OPEX

The estimation of operational expenditures (OPEX) for the proposed energy system has been carried out primarily based on data and assumptions provided in the TANDEM project documentation. This ensures consistency with the methodology used for CAPEX evaluations and aligns the economic assessment with realistic operating conditions and cost structures for each subsystem. The OPEX analysis includes costs related to operation, maintenance, consumables, and other recurring expenses over the plant's lifetime.

5.3.1 Opex for E-SMRs

The operational expenditures (OPEX) for the electrochemical Small Modular Reactors (e-SMRs) have been estimated based primarily on the TANDEM project documentation. According to this source, the variable costs for e-SMR operation—including personnel, operations and maintenance, consumable materials and equipment, replacement costs, and insurance—amount to 24.4 EUR₂₀₂₃ per MWh of electrical output. Additionally, fuel costs are reported as 7.4 EUR₂₀₂₃ per MWh. Therefore, the total operating cost for the e-SMR system is calculated as 31.8 EUR₂₀₂₃/MWh.

Considering a combined electrical capacity of 354 MW for the two e-SMR units, operating for 8,750 hours per year at a load factor of 0.98, the annual OPEX amounts to approximately 96,640,811 EUR:

$$\text{Annual OPEX [EUR/year]} = 354 \times 8,750 \times 0.98 \times 31.8 \approx 96,640,811 \quad (11)$$

Moreover, as highlighted in Riboldi et al. (2024), OPEX for e-SMRs are expected to decrease over time as the technology transitions from First-of-a-Kind (FOAK) to Nth-of-a-Kind (NOAK) status. Specifically, after the initial 15 years of operation, operational costs are projected to decrease by approximately 30% due to increased technological maturity and operational experience. During the subsequent 15 years, a further reduction of 10% is anticipated, reflecting continued but slower learning curve effects. Beyond the first 30 years, OPEX levels are expected to stabilize, approaching their asymptotic lower limit. Unlike CAPEX reductions, these OPEX decreases have been modeled as gradual annual reductions distributed evenly over each 15-year period, ensuring that the cumulative reductions align with the projected total decreases of 30% and 10%, respectively.

5.3.2 Opex for HTSEs

The OPEX for the HTSE have been estimated based on data from the TANDEM project, which specifies them as an annual 2.5% of the corresponding CAPEX. These costs typically encompass expenses related to routine operations and maintenance, personnel, periodic replacement of components, consumables, and insurance, ensuring the continuous and reliable operation of the electrolyser units, and this corresponds to an annual OPEX of approximately 6.1425 million EUR.

As with the CAPEX projections, the OPEX for HTSE units is expected to decrease over time due to technological learning and efficiency gains. The same cost reduction dynamics assumed for CAPEX, namely a 30% reduction after the first 20 years and an additional 15% reduction in the following 20 years—have been applied to OPEX as well. However, as explained in the previous section, these reductions have been distributed annually over each period to reflect a gradual decrease rather than abrupt step changes, capturing the progressive nature of technological maturation and cost improvements.

5.3.3 Opex for Hydrogen Storage Buffer

Tandem in this case indicates annual OPEX equal to 1.5% of the CAPEX. These costs typically cover routine maintenance, safety monitoring, minor repairs, consumables, and insurance to ensure reliable operation, resulting in approximately 735,000 EUR per year. As with the electrolyzers, the OPEX for hydrogen storage is expected to decrease over time, following the same cost reduction trends applied to the CAPEX of hydrogen technologies.

5.3.4 Opex for Hydrogen Compressor

The TANDEM OPEX for the hydrogen compressor have been estimated equal to 1% of the CAPEX, resulting in 15,000 EUR a year. These costs typically include routine maintenance, periodic inspections, lubrication and cooling system upkeep, minor repairs, and insurance to ensure continuous and safe compressor operation. Similar to the HTSE units, the OPEX for the hydrogen compressor is expected to decrease over time, following the same cost reduction trajectory assumed for hydrogen technologies.

5.3.5 Opex for Gas Turbine

The operational expenditures (OPEX) for the LM6000 gas turbine have been estimated using data from Gas Turbine World (2024), which reports fixed O&M costs of 16.30 USD/kW installed. The designed system features a capacity of 47 MW, and this results in a total installed cost of approximately 45.19 million EUR and fixed O&M costs of about 6,965 EUR per MW annually, after conversion from USD and applying an exchange rate of 1.17 USD/EUR. Therefore, the total annual OPEX for the LM6000 gas turbine is approximately 327,355 EUR. Since the project already secures its fuel supply from other subsystems, we have conservatively assumed that fuel-related OPEX can be reduced by 50%, leading to this final estimate.

5.3.6 Opex for Methanation Reactor

The OPEX of a Methanation Reactor are significantly influenced by the costs of its input streams, particularly hydrogen and carbon dioxide (CO_2). While hydrogen is produced on-site, the required CO_2 must be sourced externally to enable the production of synthetic methane and to contribute to decarbonization objectives. It has been assumed that CO_2 is captured from industrial processes, where capture costs largely depend on the concentration of CO_2 in the flue gas stream. Higher CO_2 concentrations generally reduce capture costs due to lower energy and solvent consumption during separation.

Two primary references have been considered for estimating CO_2 capture costs. The first, the Global CCS Institute report (2017), indicates costs ranging from 30 to 70 $\frac{EUR}{ton-CO_2}$ depending on the industrial source, from coal-based to natural gas processes. The second study by Smith et al. (2024) reports an average cost of approximately 60 $\frac{EUR}{ton-CO_2}$, although without specifying the industrial source. Based on these data, a mean CO_2 capture cost of 55 $\frac{EUR}{ton-CO_2}$ has been assumed as a balanced compromise between the reported values.

Furthermore, future projections for CO_2 capture costs have been informed by findings from Gruber et al. (2022), who suggest that ongoing research and technological improvements are expected to reduce these costs of approximately 73.5% (from 95 USD/ton to 25 in the long term), leading the initial 55 $\frac{EUR}{ton-CO_2}$ to an estimated cost of roughly 14.5 $\frac{EUR}{ton-CO_2}$ by around 2085. This cost reduction has been implemented as a gradual decrease over time, consistent with anticipated technology learning curves and market developments.

5.4 Revenues

ricavi con fonti + ipotesi crescita/decrecita ricavi e calcolo PUN etc..

The revenue streams for the proposed integrated system originate from multiple products and market segments. Specifically, revenues are generated through the sale of electricity to the

local energy community (Comunità Energetica Rinnovabile, CER) and, when production exceeds local demand, through sales to the wholesale electricity market. Additionally, revenues are derived from hydrogen sales targeted primarily at the transport sector, as well as from synthetic gas (syngas) sales intended to meet the residual fossil fuel demand within the region and, in case of surplus production, to external markets beyond the project's geographical scope.

5.4.1 Electricity Revenues

For electricity, revenues have been computed as the sum of earnings from sales to the CER and revenues from surplus electricity dispatched to the wholesale market. Revenues from sales to the CER have been determined by considering the total annual electricity output delivered to the community, as calculated by the Modelica simulation outputs. The electricity price applied for these calculations has been derived from historical data of the zonal day-ahead electricity price (PUN zonale) for the Northern Italian market area, adjusted by a discount factor to promote public acceptance of the infrastructure.

Specifically, the reference electricity price has been established by analyzing the monthly PUN zonale data recorded from 2022 to the present. An initial estimation of the zonal price for the remaining months of 2025 was obtained by extrapolating the trend observed in 2023 and 2024 through linear interpolation. Subsequently, a weighted average monthly price over the past three years was calculated, assigning higher weights to more recent data to reflect current market dynamics. Finally, the average annual price was determined by computing a weighted mean of these monthly values, where the weighting was based on the quantity of electricity sold to the community in each month, since this parameter is strongly influenced by seasonal variations in the community's photovoltaic self-generation capacity. To enhance public acceptance and encourage regional engagement, a 10% discount was applied to the final price offered to the CER as a form of implicit subsidy (GSE, 2023).

For electricity sold to the wholesale market, the same methodology was adopted for price estimation, following identical steps in the analysis of historical and projected PUN zonale data. However, in this case, the 10% discount was not applied, as market sales are not subject to local incentives or community agreements.

5.4.2 Hydrogen Revenues

d

5.5 Economic Results: base case

D

5.5.1 Sensitivity Analysis

D

5.6 Economic Results: alternative scenarios

dato che buco finanziario, i primi 15 anni facciamo solo reattore (full electric) per mettere da parte un po' di profitto quando la possibilità di decarbonizzare il settore dei trasporti è più matura, dopo 15 anni si costruisce l'impianto secondario con HTSE, metanatore e turbina a gas. questo permette di guadagnare di più prima e investire più tardi sui componenti secondari.

risultato è uno scenario ibrido con NPV positivo, con 5 anni in meno di operation per ottimizzare il ricambio di HTSE.

6 RESULTS

6.1 Environmental Impact

6.1.1 GHG Emissions assessment

Regional Energy Mix




Figure 22: Local energy mix evolution over time.

Local Energy Mix

Residual Fossil Fuel Consumption

Transportation Sector mettere commento su miglioramento della qualità dell'aria

Overall GHG Emissions




Figure 23: GHG emissions over time.




Figure 24: Local Net Electricity and Fossil Demand evolution in time.

6.1.2 H₂O Usage

Citare il mancato impatto sulle risorse idriche perché trascurabile rispetto alla massa di acqua nel lago

6.1.3 Land Use

No impatto sul terreno perché sito già nuclearizzato

6.2 Conclusions

7 POSSIBLE IMPROVEMENTS

7.1 On the Data Collection

It is definitely possible and could give better results if the data for each class was obtained by a set of real building from the region instead of just one. Ideally one would use a statistically significant set of buildings and vary the utilization profile as well. Moreover, it would be beneficial to weight the simulation data on the real energy requirements of those same buildings, which is a much more complex task since it would require extensive data acquisition during the year. While this is feasible for electrical demand (most operators give to the customer a detailed bill with hourly consumption), it is much more difficult to get the same data for fossil fuel consumption. At last, the normalization has been done with the heated area and not with the volume (which is much more indicative of the energy requirement of a building) given the on-field knowledge that the volume is usually approximately obtained by a rule of thumb of multiplying the heated area by a factor of 2.7 or 3 in most cases. From the simulation we have

neglected humidification and dehumidification electricity needs since these plants are rarely installed today, a better evaluation would evaluate the possible future share of air treatment plants in the residential sector.

Photovoltaic: We have neglected any solar-thermal system installed since they are considered not very impactful and their impact is complex to evaluate.

Conversion thermal to primary: use time dependent efficiency for heat pumps that take into account the ambient temperature, this could be accomplished considering that our code uses hourly data.

Other Electricity Demand: This is without a doubt the most complex contribution to evaluate, especially considering that it is not easy to imagine how the electricity consumption will evolve in 25 years. It could be improved by collecting a statistically significant number of examples from the region on the type of appliances installed and their consumption.

Overall: the methodology of using class distribution as a way of evaluating the energy demand is considered a good approach, for the best results we shall gather consumption data for both electric and fossil fuels for a statistically significant number of buildings for each energy class.

7.2 On the Plant Modelling

7.3 On the Economic Study

8 CONCLUSION

REFERENCES

- [1] Terna SpA, *Dati Statistici sui Consumi di Energia Elettrica per Settore*, <https://dati.terna.it/fabbisogno/dati-statistici>, Accessed: 2025-06-26, 2025.
- [2] Regione Lombardia, *Database CENED+2 - Certificazione ENergetica degli EDifici*, <https://www.dati.lombardia.it/Energia/Database-CENED-2-Certificazione-ENergetica-degli-E/bbky-sde5>, Accessed: 2025-03-25, 2025.
- [3] Gestore dei Servizi Energetici (GSE), *Mappa Interattiva delle Cabine Primarie*, <https://www.gse.it/servizi-per-te/autoconsumo/mappa-interattiva-delle-cabine-primarie>, Accessed: 2025-04-14, 2025.
- [4] Istituto Nazionale di Statistica (ISTAT), *Censimento permanente della popolazione - Anno 2023 - Lombardia*, https://www.istat.it/wp-content/uploads/2025/04/Censimento-permanente-popolazione_Anno-2023_Lombardia.pdf, Accessed: 2025-06-26, 2025.
- [5] E. Fuentes, L. Arce, and J. Salom, "A review of domestic hot water consumption profiles for application in systems and buildings energy performance analysis," *Renewable and Sustainable Energy Reviews*, vol. 81, pp. 1530–1547, 2017. DOI: 10.1016/j.rser.2017.05.229.
- [6] OpenStreetMap Contributors, *Nominatim Search Tool*, <https://nominatim.openstreetmap.org/ui/search.html>, Accessed: 2025-04-16, 2025.
- [7] Joint Research Centre, *Photovoltaic Geographical Information System (PVGIS)*, https://re.jrc.ec.europa.eu/pvg_tools/en/, Accessed: 2025-04-16, 2025.
- [8] Acquirente Unico S.p.A., *Electricity residential demand*, <https://www.consumienergia.it/portaleConsumi/it/energia-elettrica-utenze-domestiche.page>, Accessed: 2025-04-14, 2025.
- [9] G. Simonini et al., "Integrating Small Modular Reactors into hybrid energy systems: the tandem Modelica library," in *International Conference on Small Modular Reactors and their Applications*, IAEA, Vienne, Austria, Oct. 2024. [Online]. Available: <https://hal.science/hal-04645663>.
- [10] Politecnico di Milano, *Modelica models description for the "TANDEM" library*, https://tandemproject.eu/wp-content/uploads/2024/07/D2_3_Modelica_models_description_for_the_tandem_library_V1-1.pdf, Accessed: 2025-04-16, 2024.
- [11] M. Götz et al., "Renewable power-to-gas: A technological and economic review," *Renewable and Sustainable Energy Reviews*, vol. 53, pp. 1472–1482, 2016, ISSN: 1364-0321. DOI: <https://doi.org/10.1016/j.rser.2015.09.042>. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0960148115301610>.
- [12] Dassault Systèmes, *Dymola, Dynamic Modeling Laboratory*, <https://www.3ds.com/products/catia/dymola>, Accessed: 2025-04-16, 2025.