EXAMPLE DATA — FICTIONAL TEST DOCUMENT FOR BATATIS USER TESTING — NOT A REAL PROJECT

MEHTA ARCHITECTURE (fictional) — PROJECT 2611 "BOWVIEW COMMONS" — CALGARY, AB

SHEET A-401 FEATURE STAIR & ATRIUM — GENERAL NOTES REV C 2026-10-16 ISSUED FOR: PERMIT (DRAFT)

1. Building: 4 storeys, mixed use (retail at grade, residential above). Sprinklered throughout (NFPA 13).
2. Feature stair S2: exposed cross-laminated timber (CLT) treads and stringers, 3-ply 105 mm, open to 3-storey atrium. Not a required exit stair (to be confirmed).
3. Atrium: connects levels 1–3; smoke control by mechanical consultant — **design TBD**.
4. CLT left exposed (no encapsulation) for architectural intent. Owner requirement.
5. Fire performance of exposed CLT: **fire test report TBD**. Char-rate calc by structural — not received.
6. Alternative solution basis: per STANDATA 19-BCB-012 and Div. B 9.10.9.9. *(per Raj — please verify)*
7. Flame-spread rating of finish: supplier says "Class B or better" — no documentation on file.
8. Owner: Bowview Commons Ltd. (fictional) Rep: R. Mehta, Architect Permit #: pending

NOTE TO FILE: Submission deadline Fri. Variance package needed for exposed CLT at atrium stair.