

Daily Evaluation Report

Campus Building Monitoring System

Report Period: February 12, 2026 - February 13, 2026

Generated: February 13, 2026

Executive Summary

Total Energy

23217.74

kWh

Total Wastage

5217.74

kWh

Total Alerts

0

alerts

Critical Issues

0

issues

Sustainability Score

47.0

/ 100

CO₂ Emissions

9439.20

kg

Key Highlights

- Limited historical data available for trend analysis

Building Performance

Building	Status	Energy (kWh)	Wastage (%)	Avg Temp (°C)	Occupancy (%)
Engineering Block	good	3686.67	28.00	22.30	64.60
Science Lab	good	4438.74	23.30	21.20	70.60
Library	good	2570.98	33.90	22.10	81.70
Dorm A	good	3151.30	31.30	22.80	53.30
Dorm B	good	3173.27	32.20	21.20	61.80
Admin Building	needs attention	2709.81	25.50	24.50	74.20
Sports Complex	good	3486.97	32.10	22.20	51.90

Alerts Summary

Total Alerts	Critical	Warning	Avg Response Time
0	0	0	0.00 minutes

Recommendations

[HIGH] Buildings with High Energy Wastage

7 building(s) showing wastage above 15%: Engineering Block, Science Lab, Library, Dorm A, Dorm B, Admin Building, Sports Complex. Consider scheduling energy audits.

Expected Impact: Energy audits typically identify 10-20% savings opportunities

Sustainability Metrics

CO₂ Emissions

9439.20

kg

Energy Intensity

0.59

kWh/m²

Renewable %

20.10

%

Cost Savings

226.54

₹

Net Zero Progress

44.10

%