


Date Period $\vee$	State,District,Site,Sec ∨	Customer Name	WTG Model	✓ Turbine Code	~
2022-23	Multiple selections	All	All	✓ All	$\vee$

#### **WTG Performance Assessment Report**

Site : [®] WTG No. : [®] WTG Model : [®]

ctoto	cito	OFNA	WITC Conneit	No of MIC-	Total MANA
state	site	OEM	WTG Capacity	No. of WIGS	lotal MW
GJ - Kutch	Amaliara	SUZLON	1.50	2	3.00
GJ - Kutch	Arikhana	SUZLON	1.50	2	3.00
GJ - Kutch	Changadai	SUZLON	1.25	1	1.25
GJ - Kutch	Kadoli	SUZLON	1.25	1	1.25
GJ - Kutch	Kadoli	SUZLON	1.50	7	10.50
GJ - Kutch	Kosa	SUZLON	2.10	2	4.20
GJ - Kutch	Nanisindhodi	SUZLON	1.25	1	1.25
GJ - Kutch	Nanisindhodi	SUZLON	1.50	3	4.50
GJ - Kutch	Rampar	SUZLON	2.10	1	2.10
GJ - Kutch	Shikarpur	SUZLON	1.50	5	7.50
GJ - Kutch	Suthari	SUZLON	0.60	1	0.60
GJ - Kutch	Suthari	SUZLON	1.25	1	1.25
GJ - Kutch	Suthari	SUZLON	1.50	10	15.00
GJ - Kutch	Ukheda	SUZLON	2.10	2	4.20
GJ - Kutch	Vayor	SUZLON	2.10	17	35.70
GJ - Saurashtra	Amaliara	SUZLON	1.50	1	1.50
GJ - Saurashtra	Bhanvad	SUZLON	2.10	5	10.50
GJ - Saurashtra	Jamjodhpur	SUZLON	2.10	3	6.30
GJ - Saurashtra	Jodiya	SUZLON	2.10	7	14.70
GJ - Saurashtra	Kuchhadi	SUZLON	1.25	1	1.25
GJ - Saurashtra	Kuchhadi	SUZLON	2.10	2	4.20
GJ - Saurashtra	Mahidad	SUZLON	2.10	2	4.20
GJ - Saurashtra	Maliya Miyana	Pioneer	1.50	1	1.50
GJ - Saurashtra	Maliya Miyana	SUZLON	1.50	6	9.00
GJ - Saurashtra	Maliya Miyana	SUZLON	2.10	5	10.50
GJ - Saurashtra	Modpar	SUZLON	2.10	15	31.50
GJ - Saurashtra	Modpar	SUZLON	2.60	4	10.40
GJ - Saurashtra	Motagunda	GAMESA	0.85	1	0.85
GJ - Saurashtra	Ratdi	SUZLON	2.10	5	10.50
GJ - Saurashtra	Sanodar	SUZLON	2.10	2	4.20
GJ - Saurashtra	Sardhar	SUZLON	2.10	1	2.10
GJ - Saurashtra	Suvarda	SUZLON	2.10	1	2.10
Karnataka	CHI12MW	GAMESA	2.00	1	2.00
Karnataka	Hassan	SUZLON	1.50	5	7.50



Date Period	~	Past Period	~	State,District,Site,Sec	~	Customer Name	~	WTG Model	~	Turbine Code	~
2023-24	~	Multiple selections	~	All	~	All	~	All	~	AK163	~

## **WTG Performance Assessment Report**

Site	: Shirwa	WTG No.		:	AK16	3	'	WTG M	lodel	:	S 66 I	Mark II		
	Past Performance	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Total
FY_2017-18_ Acti	ual gen. (LU)	1.72	1.96	2.50	1.97	2.08	0.77	0.37	0.32	0.71	0.32	0.39	0.63	13.74
FY_2018-19_ Act	ual gen. (LU)	1.29	1.35	2.54	2.16	2.11	1.45	0.42	0.24	0.44	0.48	0.61	0.74	13.81
FY_2019-20_ Act	ual gen. (LU)	1.04	1.55	1.78	3.83	1.43	0.79	0.38	0.82	0.63	0.67	0.72	0.86	14.49
FY_2020-21_ Act	ual gen. (LU)	1.10	1.73	2.24	2.13	1.34	0.61	0.46	0.46	0.75	0.59	0.39	0.97	12.75
FY_2021-22_ Act	ual gen. (LU)	0.93	1.74	2.83	2.66	2.45	0.62	0.76	0.38	0.44	0.31	0.49	0.86	14.47
	Performance in Glance FY_2023-24	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	YTD

FY_2019-20_ Actual gen. (LU)	1.04	1.55	1.78	3.83	1.43	0.79	0.38	0.82	0.63	0.67	0.72	0.86	14.49
FY_2020-21_ Actual gen. (LU)	1.10	1.73	2.24	2.13	1.34	0.61	0.46	0.46	0.75	0.59	0.39	0.97	12.75
FY_2021-22_ Actual gen. (LU)	0.93	1.74	2.83	2.66	2.45	0.62	0.76	0.38	0.44	0.31	0.49	0.86	14.47
Performance in Glance FY_2023-24	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Jan-24	Feb-24	Mar-24	YTD
Estimated gen. (LU)	0.98	1.97	2.30	1.43	3.01	0.95	1.01	0.42	0.00	0.00	0.00	0.00	12.06
Actual gen. (LU)	0.84	1.57	2.05	1.33	2.89	0.85	0.92	0.37	0.00	0.00	0.00	0.00	10.81
Estimated Vs. Actual (%)	-14.7%	-20.2%	-10.9%	-6.8%	-4.1%	-10.6%	-9.0%	-12.2%	-	-	-	-	-10.4%
Total Loss (%)	14.7%	20.2%	10.9%	6.8%	4.1%	10.6%	9.0%	12.2%	-	-	-	-	10.4%
1) Scheduled Outages (%)	2.3%	-	-	-	-	0.8%	-	5.2%	-	-	-	-	0.4%
1.1. WTG PM	2.3%	-	-	-	-	0.8%	-	3.8%	-	-	-	-	0.4%
1.2. Internal Grid PM	_	-	-	-	-	-	-	-	-	-	-	-	-
1.3. PSS PM	-	-	-	-	-	-	-	1.4%	-	-	-	-	0.0%
2) Un Scheduled Outages (%)	10.5%	14.5%	5.0%	2.5%	2.4%	6.4%	7.1%	7.3%	-	-	-	-	6.4%
2.1. Lubrication System	-	-	-	-	-	-	-	-	-	-	-	-	-
2.2. DFIG/ Converter/ Turbine Electrical System/ SFS System	_	-	-	0.8%	1.3%	-	0.1%	-	-	-	-	-	0.4%
2.3. Gear Box System	_	-	-	-	-	-	-	1.2%	-	-	-	-	0.0%
2.4. Generator System	_	-	-	-	-	-	-	-	-	-	-	-	-
2.5. Main Bearing	_	-	-	-	-	-	-	-	-	-	-	-	-
2.6. Pitch System	2.4%	9.2%	2.6%	-	-	-	4.8%	-	-	-	-	-	2.6%
2.7. Yaw System	_	-	-	-	-	-	-	-	-	-	-	-	-
2.8. Vibration & Oscillation	-	-	-	-	-	-	-	-	-	-	-	-	-
2.9. Turbine Rotor System	-	-	-	-	-	-	-	-	-	-	-	-	-
2.10. Panel Temperature Errors	_	-	-	_	-	-	-	-	-	-	-	-	_
2.11. PLC & Control System	0.1%	-	0.5%	-	-	0.8%	-	-	-	-	-	-	0.2%
2.12. Hydraulic Brake & Rotor Lock System	_	-	-	_	-	-	-	-	-	-	-	-	_
2.13. Wind Vane & Anemometer System	_	-	-	_	-	-	-	-	-	-	-	-	_
2.14. Data Logger Error	-	-	-	-	-	-	-	-	-	-	-	-	-
2.15. Blade Issue	7.8%	-	-	_	_	_	-	-	-	-	-	-	0.6%
2.16. VCB & Transformer System	-	2.0%	1.2%	0.8%	_	4.5%	1.2%	5.2%	-	-	-	-	1.3%
2.17. Manual Shutdown	_	-	-	_	1.1%	-	-	-	-	-	-	-	0.3%
2.18. Internal Grid Outages	0.2%	3.2%	0.8%	0.5%	_	0.5%	1.0%	1.0%	-	-	-	-	0.9%
2.19. PSS Outages	_	0.1%	-	0.5%	-	0.6%	-	-	-	-	-	-	0.1%
2.20. MBD	_	-	-	-	-	-	-	-	-	-	-	-	-
2.21. Others	_	-	-	-	-	-	-	-	-	-	-	-	-
3) Power Curtailment (%)	-	-	-	0.2%	-	-	-	-	-	-	-	-	0.0%
4) Power Curve Performance (%)	0.3%	-0.1%	0.0%	0.0%	-0.1%	-0.2%	0.1%	-0.3%	-	-	-	-	-0.0%
5) External Grid (%)	1.3%	2.5%	3.5%	1.2%	1.8%	3.5%	1.8%	-	-	-	-	-	2.2%
5.1. External Grid PM	-	-	-	-	-	-	-	-	-	-	-	-	-
5.2. External Grid Outages	1.3%	2.5%	3.5%	1.2%	1.8%	3.5%	1.8%	-	_	_	-	-	2.2%
6) Force Majeure (%)	0.2%	3.2%	2.3%	2.8%	-	-	-	-	-	-	-	-	1.3%




Date Period	~	State,District,Site,Sec	~	Customer Name	~	WTG Model	~	Turbine Code	~
Multiple selections	~	All	~	All	<b>~</b>	All	~	GP16	~

## **WTG Performance Assessment Report**

Site : Hassan South			WTG	No.		:	GP16	<u> </u>		WTG	Model			: S	82 V3
	Performance in Glance	2010-11	2011-12	2012-13	2013-14	2014-15	2015-16	2016-17	2017-18	2018-19	2019-20	2020-21	2021-22	2022-23	YTD
Estimated gen. (LU)		26.03	29.68	30.41	29.08	24.90	24.02	24.43	23.35	32.36	23.90	23.70	48.00	26.05	365.90
Actual gen. (LU)		25.24	27.00	27.82	27.12	24.04	22.25	22.83	21.99	22.79	21.74	16.44	21.57	24.57	305.39
Estimated Vs. Actual (9	%)	-3.0%	-9.1%	-8.5%	-6.7%	-3.5%	-7.4%	-6.5%	-5.8%	-29.6%	-9.0%	-30.7%	-55.1%	-5.7%	-16.5%
Total Loss (%)		3.0%	9.1%	8.5%	6.7%	3.5%	7.4%	5.5%	5.7%	6.1%	9.0%	26.4%	3.2%	5.7%	7.3%
1) Scheduled Outages	(%)	2.2%	0.9%	1.2%	1.9%	1.2%	1.9%	2.2%	1.3%	0.7%	0.4%	1.5%	1.3%	0.7%	1.3%
1.1. WTG PM		2.2%	0.9%	1.2%	1.2%	1.1%	1.5%	1.8%	1.2%	0.4%	0.4%	1.4%	0.6%	0.4%	1.1%
1.2. Internal Grid	I PM	-	-	-	0.6%	0.2%	0.4%	0.4%	0.1%	0.1%	-	-	-	0.3%	0.2%
1.3. PSS PM		-	-	-	-	-	-	-	-	0.2%	-	0.1%	0.7%	-	0.1%
2) Un Scheduled Outag	ges (%)	3.6%	10.2%	10.1%	8.7%	6.0%	7.9%	4.8%	7.4%	6.6%	11.3%	6.3%	3.1%	3.6%	6.7%
2.1. Lubrication	System	-	-	2.1%	-	-	-	-	-	-	-	0.0%	0.4%	0.1%	0.2%
2.2. DFIG/ Conve	erter/ Turbine Electrical System/ SFS System	-	1.5%	2.4%	0.9%	2.0%	2.7%	-	0.3%	1.0%	2.4%	0.8%	0.1%	0.5%	1.1%
2.3. Gear Box Sys	stem	-	-	0.2%	-	-	-	2.0%	0.4%	0.9%	-	1.7%	-	-	0.4%
2.4. Generator Sy	ystem	-	0.4%	0.9%	0.5%	-	-	-	-	0.1%	0.5%	1.0%	-	0.1%	0.3%
2.5. Main Bearin	g	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2.6. Pitch System	1	-	0.9%	1.7%	4.1%	1.7%	3.7%	-	0.3%	1.5%	4.5%	1.4%	0.3%	0.7%	1.5%
2.7. Yaw System		-	0.6%	-	0.8%	0.0%	0.1%	0.7%	0.2%	0.3%	2.4%	0.4%	0.1%	0.1%	0.4%
2.8. Vibration &	Oscillation	-	-	-	-	-	-	_	-	-	-	-	-	-	-
2.9. Turbine Roto	or System	-	-	-	-	-	-	_	0.0%	-	-	-	-	-	0.0%
2.10. Panel Temp	perature Errors	-	-	-	-	-	-	_	-	-	-	-	-	_	-
2.11. PLC & Cont	trol System	-	-	0.0%	0.6%	0.7%	-	0.2%	-	0.2%	0.4%	0.3%	0.7%	0.1%	0.3%
2.12. Hydraulic E	Brake & Rotor Lock System	-	-	-	-	-	-	_	-	-	-	-	-	_	-
2.13. Wind Vane	& Anemometer System	-	-	-	-	-	-	_	-	-	-	-	-	_	-
2.14. Data Logge	er Error	-	-	-	-	-	-	-	-	-	-	-	-	_	-
2.15. Blade Issue		-	-	2.1%	-	-	-	-	-	0.6%	-	-	-	_	0.2%
2.16. VCB & Trar	nsformer System	0.9%	-	-	-	0.5%	-	-	0.3%	0.4%	0.2%	-	-	0.2%	0.2%
2.17. Manual Sh	utdown	2.7%	6.7%	0.6%	1.7%	1.2%	1.5%	1.1%	4.4%	0.5%	0.3%	0.3%	0.7%	0.6%	1.7%
2.18. Internal Gr	id Outages	-	-	-	-	-	-	0.9%	1.5%	1.0%	0.6%	0.3%	0.7%	0.5%	0.4%
2.19. PSS Outage	es	-	-	-	-	-	-	-	-	-	-	-	-	0.7%	0.0%
3) Power Curtailment	(%)	-	-	0.0%	0.0%	-	0.0%	-	-	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
4) Power Curve Perfor	mance (%)	-2.7%	-2.0%	-2.7%	-3.8%	-4.0%	-3.2%	-3.4%	-3.5%	-2.6%	-4.5%	-3.2%	-1.3%	0.2%	-2.7%
5) External Grid (%)		-	-	-	-	-	-	0.8%	-	1.1%	1.3%	0.3%	0.1%	0.8%	0.3%
5.1. External Grid	d PM	-	-	-	-	-	-	_	-	-	_	_	_	_	_
5.2. External Grid	d Outages	-	-	-	-	-	-	0.8%	-	1.1%	1.3%	0.3%	0.1%	0.8%	0.3%
6) Force Majeure (%)		_	_	_	_	0.2%	0.7%	1.1%	0.5%	0.4%	0.6%	21.5%	_	0.3%	1.6%






#### **WTG Performance Assessment Report**

Site : Varsamedi WTG No. : VM04 WTG Model : S 82 V3





### WTG Performance Assessment - Losses



#### **WTG Performance Assessment Report**

