

Acknowledgments

Architectural Energy Corporation (AEC) prepared this manual under contract to the New Buildings Institute (NBI). Charles Eley served as the primary author and technical editor. Kimberly Goodrich wrote Chapter 4 and provided copy editing, formatting, and document production. John Arent, Kristen Salinas, Lisa Gartland, and Deborah Stanescu provided technical content in Chapter 6. AEC had four subcontractors. Energy and Environmental Economics (Snuller Price and his team) developed the default time-of-use energy tariffs and was primarily responsible for Chapter 5. Mangesh Basarkar of Florida Solar Energy Center (FSEC) developed the acceptance criteria for Standard 140-2007 and was primarily responsible for Chapter 3. Martyn Dodd of EnergySoft developed the advanced modeling recommendations and was primarily responsible for Chapter 7. Jon McHugh of McHugh Engineering contributed to Chapter 6 on lighting, daylighting, and refrigeration.

Mark Cherniack was the project manager for New Buildings Institute and managed the review process. Valuable input was received from Cliff Majersik and Sonal Kemkar of the Institute of Market Transformation; Martha Brook of the California Energy Commission; David Goldstein and Nick Zigelbaum of the Natural Resources Defense Council; Harry Misuriello of ACEEE; Jean Lupinacci of US EPA; Dan Macumber and Luigi Polese of the National Renewable Energy Laboratory; Krishnan Gowri, Ron Jarnigan, and Mike Rosenberg, of the Pacific Northwest National Laboratory; Tianzhen Hong and Philip Haves of Lawrence Berkeley National Laboratory; Kevin Madison of Madison Engineering; Fred Porter and Michael Holtz of AEC; Dan Nall of Flack+Kurtz; Joel Neymark of J. Neymark and Associates; Philip Fairey of FSEC; Jason Glazer of GARD Analytics; and several other members of the ASHRAE 90.1 Energy Cost Budget (ECB) Subcommittee.

New Buildings Institute, Architectural Energy Corporation, and other team members are grateful to John Wilson and the Energy Foundation, which provided funding to enable this work.

This publication benefited from considerable previous research which is documented in footnotes. However, the following documents were especially important resources:

- ASHRAE Standard 90.1-2001 and 90.1-2007, Energy Standards for Buildings Except Low-Rise Residential Buildings (especially the Performance Rating Method in Appendix G)
- California 2005 Nonresidential ACM manual, California Energy Commission
- ECB Compliance Supplement, Version 1.2, March 1996, Prepared by the 90.1 ECB Panel, but unpublished
- B. Griffith, et. al., Methodology for Modeling Building Energy Performance across the Commercial Sector, Technical Report NREL/TP-550-41956, March 2008

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/acknowledgments>

1 Overview

1.1 Purposes

The COMNET energy efficiency calculation process serves multiple purposes, including the following:

- Establishing eligibility for federal tax deductions per §179D of the Internal Revenue Service code (expired);
- Calculating percent savings for point eligibility related to green building rating systems; and
- Estimating annual energy use for a building in the design phase for the purpose of Design to Earn ENERGY STAR.

COMNET software may be accredited for one or more purposes. Depending on the purpose, the process is somewhat different. [Table 1.1-1](#) [1] summarizes the major differences in calculation procedures for the currently supported purposes. These differences are described in more detail in the sections that follow.

Table 1.1-1: "Differences in Calculation Procedures by Original Purposes"

| | Tax Deductions | LEED 2.2 | LEED 2012 | Design to Earn ENERGY STAR |
|----------------------------|---------------------------|---------------------------|---------------------------|----------------------------|
| Baseline Standard | ASHRAE Standard 90.1-2001 | ASHRAE Standard 90.1-2007 | ASHRAE Standard 90.1-2010 | CBECS Median Energy Use |
| Operating Assumptions | Prescribed | Neutral Dependent | Neutral Dependent | Default |
| Percent Savings Energy Use | Regulated Only | All Energy Use | All Energy Use | Not applicable |

1.1.1 Baseline Standards

Both tax deductions and green building rating systems are based on comparing the performance of the proposed design against a code-minimum baseline building; the baseline for federal tax deductions is ASHRAE Standard 90.1-2001 and the baseline for green building ratings is ASHRAE Standard 90.1-2007 or ASHRAE Standard 90.1-2010. The baseline for Design to Earn ENERGY STAR is the median or average energy use for a similar building, in a similar climate, operated in a similar manner. The median is based on energy consumption as reported in the CBECS¹ database. As COMNET is expanded to support additional purposes, additional baselines will be added as necessary.

This manual is consistent with ASHRAE Standard 90.1-2007 and 90.1-2010, but does not include addenda, approved or otherwise. ASHRAE Standard 90.1 is under continuous maintenance. This means that the committee regularly develops, approves and publishes addenda to the standard. At the time of this writing, a number of addenda to Standard 90.1 have been approved and an even greater number is pending. ASHRAE gathers these addenda includes them in the next official publication of the standard.

The modeling rules and procedures in this manual are consistent with the Performance Rating Method (PRM) in Appendix G of relevant version of ASHRAE Standard 90.1

When Standard 90.1 does not establish a baseline, the PRM often gives the rating authority the ability to establish a baseline. In some instances, this COMNET manual establishes a baseline where one does not exist in Standard 90.1, thereby assuming the responsibility of the rating authority. Examples include plug loads and commercial refrigeration. In other instances, the baseline building specification in the PRM was not specific enough and this manual expands on the definition to eliminate ambiguity.² The purpose of these elaborations and expansions is to reduce ambiguity and offer credits for energy efficiency measures not addressed by Standard 90.1. It is not the intent of this manual to change the baseline building defined by the PRM or the underlying standards. The COMNET manual is intended to work in series with, not in parallel with the PRM.

¹. CBECS is Commercial Building Energy Utilization Survey, which is conducted by the federal Energy Information Agency (EIA) approximately every four years.

². An example is the supply air temperature reset requirement for baseline building systems 5 through 8.

1.1.2 Modeling Assumptions

When calculating annual energy use, it is necessary to make assumptions about how the proposed building is operated. Operating assumptions

include thermostat settings, number of occupants, receptacle loads, process loads, hot water loads as well as schedules of operation for HVAC systems, lighting systems and other systems. Sometimes these data are known with some certainty and other times (for instance for speculative buildings), it is necessary to make estimates. COMNET provides guidance through defaults for these situations.

1.1.3 Percent Savings

There are differences in how percent savings are calculated, depending on the purpose. ASHRAE Standard 90.1 set a baseline for the energy used for heating, cooling, ventilation, interior lighting and hot water¹. Since they are regulated by the baseline standard, these components of energy use are referred to in COMNET as the *regulated energy*. There is a multitude of other equipment and systems in a building that use energy, including:

- All the things that are plugged into convenience outlets such as personal computers, printers, coffee machines, refrigerators and desk lamps;
- Commercial refrigeration equipment such as open or closed refrigerated casework, walk-in refrigerators, walk-in freezers, and other equipment common to restaurants, food stores, and convenience stores;
- Transportation systems such as elevators, escalators, and moving walkways;
- Special ventilation systems to remove carbon monoxide from parking garages or fumes from restaurants or laboratories;
- Grills, ovens, fryers, steam trays, and other cooking equipment in restaurants and cafeterias;
- Compressed air systems in manufacturing and warehouse facilities; and
- Other specialized equipment in laboratories, hospitals, and manufacturing plants.

These components of energy use are referred to in this manual as the *non-regulated energy*, because a baseline is not established by ASHRAE Standard 90.1. *Total energy* is the sum of the *regulated energy* and the *non-regulated energy*. When percent savings are calculated for tax deduction purposes, only the *regulated energy* is considered. When percent savings are calculated for green building ratings, the *total energy* is considered. Energy cost is the metric for comparison, per the PRM.

(1.1.3-1)

TeX Embedding failed!

(1.1.3-2)

TeX Embedding failed!

¹ Exterior lighting is also regulated by the Standard, but is typically not included in the performance calculations performed for code compliance purposes.

1.2 Scope

This manual is intended to be used for buildings that are in the planning, design or construction phases. It is also intended to apply to buildings that are within the scope of ASHRAE Standard 90.1.

The long-term goal of this manual is to define modeling rules and procedures for all conceivable design features that may be incorporated in buildings. The authors recognize, however, that this goal cannot be fully achieved due to limitations in the development energy simulation algorithms, and due to the natural lag time between the introduction of an advanced energy efficiency measure or device and the development of algorithms to simulate its performance.

The goal of the manual is to provide methods that are as flexible and accurate as possible. This goal can best be achieved if the manual is a ‘living document,’ changing and growing as increasing amounts of information and better modeling methods become available.

1.3 Audience

This document has been written with several different audiences in mind. These audiences are:

1.3.1 Software Developers

The majority of this document’s content consists of rules which are intended to be implemented by software developers. These requirements include rules for automatically creating the baseline building and for producing standard reports with correct percent savings and/or energy use estimates.

1.3.2 Rating Authorities

The term ‘rating authority’ is used in this manual to represent the organization that is issuing a green building rating or energy label. The term is

also extended to include government organizations that would review and approve claims for tax deductions.

1.3.3 Energy Analysts

When permitted by the rating authority, an energy analyst can manually apply the COMNET modeling rules and procedures to create the baseline buildings and the proposed design and to summarize information into a report for submission to the rating authority.

1.4 Organization

This document is organized in seven chapters and eight appendices, as described below:

| Chapter | Description |
|---|--|
| 1. Overview | The purpose, organization, content, and intent of the manual (this chapter). |
| 2. General Modeling Procedures | An overview of the COMNET modeling process, outlining the modeling rules and assumptions that are implemented in the same way for both the standard design and the proposed design, and procedures for determining system types and equipment's sizes. |
| 3. Software Requirements | Requirements for the simulation engines and software shells that are used to make calculations. |
| 4. Content and Format of Standard Reports | The content and organization of the standard reports that need to be produced by qualifying software. |
| 5. Energy Costs and Currency | Data on how energy savings are valued and compared. |
| 6. Building Descriptors Reference | The acceptable range of inputs for the proposed design and a specification for the baseline building. |
| 7. Modeling Tips for Advanced Design Features | Modeling rules and procedures for advanced design features. |
| Appendix A – Building Descriptors Table | Tabular summary and classification of building descriptors |
| Appendix B – Modeling Data | Modeling data and assumptions by building type and space use. |
| Appendix C – Schedules | Default and prescribed schedules of operation. |
| Appendix D – Construction Materials | Default construction materials library. |
| Appendix E – Software Tests | Spreadsheets and specifications for software tests. |
| Appendix F – Energy Costs | Documentation of the methodology used to develop the Chapter 5 energy costs. |
| Appendix G – XML Schema | The COMNET compliant XML schema specified in Chapter 4 and supported by the COMNET Portal. |
| Appendix H – Equipment Curves | Spreadsheet that summarizes and graphs the default equipment performance curves referenced in the Modeling Guidelines and Procedures. |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/overview>

Links:

[1] <http://www.comnet.org/mgp/content/11-purposes#differences-in-calculation-procedures-by-original-purposes>

2 General Modeling Procedures

2.1 General Requirements for Data from the User

2.1.1 General

Users must provide valid data for all descriptors that are designated as *compulsory* in Appendix A and that apply to parts of the building that must be modeled.

2.1.2 Requirement for Complete Building Description

Complete descriptions of the building envelope, mechanical, service water heating, and electrical systems for the project are required.

2.1.3 Building Envelope Descriptions

The user shall provide accurate descriptions for all building envelope assemblies including exterior walls, windows, doors, roofs, underground walls and floors. The user shall provide data for all of the required descriptors listed in Appendix A that correspond with these assemblies. However, the following exceptions apply:

- Any envelope assembly that covers less than 1% of the total area of that assembly type (e.g., exterior walls) need not be separately described. If not separately described, the area of an envelope assembly must be added to the area of the next most similar assembly of that type.
- Exterior surfaces whose azimuth orientation and tilt differ by no more than 45° and are otherwise the same may be described as a single surface or described using multipliers. This specification would permit a circular form to be described as an octagon.

2.1.4 Space Use Classification

The user must designate space use classifications that best match the uses for which the building or individual spaces within the building are being designed or used. Depending on purpose, space use classifications determine the default or prescribed occupant density, receptacle power, service water heating, minimum outdoor ventilation air, operating schedule, and lighting assumptions used in the rating analysis. They also determine the lighting power and other characteristics of the baseline building.

The user must specify the space use classifications using either the *building area* or *space-by-space* categories but may not combine the two types of classification within a single analysis. The building area method assigns assumptions based on average values that occur within typical buildings of the designated type. The building area method is recommended for use when detailed space planning information is unavailable. More than one building area category may be used in a building if it is a mixed-use facility.

The space-by-space method requires space-by-space entry of floor area and space use designations. The space-by-space method can be used whenever design information is available with the necessary detail.

Both the *building area* and *space-by-space* choices are consistent with the baseline standards supported in COMNET and are listed in Appendix B. COMNET provides a single list of *building area* and *space-by-space* classifications so that when a model is specified by a user, it can be analyzed for multiple purposes.

2.1.5 Treatment of Building Descriptors Not Fully Addressed By This Document

The goal for this document is to provide input and rating rules covering a full range of energy-related features encountered in commercial buildings. However, this goal is unlikely to ever be achieved due to the large number of features that must be covered and the continuous evolution of building materials and technologies. Where descriptors need to be used that are not addressed completely (or are not addressed at all) in this manual, users are expected to employ these inputs using their judgment consistent with accepted design and construction practice. Any uncertainty regarding appropriate modeling assumptions must be resolved so that the impact is conservatively assessed; for example, so as to

make it less likely rather than more likely that percent savings will be higher.

2.2 Thermal Blocks, HVAC Zones and Space Functions

2.2.1 Definitions

A *thermal block* is a space or collection of spaces within a building having sufficiently similar space conditioning requirements so that those conditions could be maintained with a single thermal control device. A thermal block is a thermal and not a geometric concept: spaces need not be contiguous to be combined within a single thermal block.

An *HVAC zone* is a physical space within the building that has its own thermostat and zonal system for maintaining thermal comfort. HVAC zones are identified on the HVAC plans. HVAC zones should not be split between thermal blocks, but a thermal block may include more than one HVAC zone.

A *space function* is a sub-component of a thermal zone that has specific baseline lighting requirements and for which there are associated defaults for outside air ventilation, occupancy, receptacle loads, and hot water consumption. An *HVAC zone* may contain more than one *space function*. Appendix B has a list of the space functions that may be used with the COMNET rating method.

[Figure 2.2.1-1](#) [1] shows the hierarchy of *space functions*, *HVAC zones* and *thermal blocks*.




Figure 2.2.1-1: "Hierarchy of Space Functions, HVAC Zones and Thermal Blocks"

2.2.2 General Guidance

Thermal blocks and the HVAC zones and space functions that they contain are user inputs; they are not automatically generated by COMNET accredited software. This section provides some general rules and guidance on how to effectively define the thermal blocks. Albert Einstein once said "everything should be made as simple as possible, but no simpler" and that is the challenge when creating thermal blocks¹. The energy simulation model should include as few thermal blocks as possible, but as many as are needed. Breaking a building into thermal blocks is a step of the energy modeling process that requires considerable judgment.

Because of differences in the capabilities and limitations of various simulation tools and the extreme variety in size and complexity of buildings to which the *rating method* may be applied, a rigid set of rules for defining thermal blocks is not possible. Some exercise of user judgment will be required in most cases to determine the most appropriate way to subdivide and model a building.

Defining appropriate thermal blocks will save time for the user and will help to ensure accurate results. However, regardless of how the user chooses to subdivide the rated building, for most purposes, identical subdivisions will be used in modeling the baseline building. It is difficult to predict what impact a faulty decision would have on percent savings, but there is little doubt that the impact on proposed design energy use could be significant.

¹ "On the Method of Theoretical Physics" The Herbert Spencer Lecture, delivered at Oxford (10 June 1933); also published in *Philosophy of Science*, Vol. 1, No. 2 (April 1934), pp. 163-169.

2.2.3 Number of Thermal Blocks

In general, the smaller the number of thermal blocks that are defined, the lower the user's effort will be to create the building description. However, if too few thermal blocks are defined, simulation results are likely to be less accurate. In order to simplify ratings, users should define as few thermal blocks as possible, consistent with the other guidance in this section. Normally, the number of thermal blocks in a building should not exceed the number of HVAC zones in the building.

2.2.4 Space Use Classification Considerations

Thermal blocks may contain up to ten different space use classifications, provided the spaces have similar space conditioning requirements. If the building area method is used, each thermal block must be assigned to one and only one building area category. For space classifications that are combined in a single thermal block, the spaces must meet all of the following conditions:

- Use the same operating schedule.
- Use the same space temperature schedule.
- Have similar internal load power densities. Combined lighting, receptacle, and process equipment power densities that differ by no more than 2.0 W/ft² or a factor of two may be considered similar.
- Have similar occupant densities. Occupant densities (i.e., densities represented in floor area per occupant [under peak design conditions]) that differ by no more than a factor of three may be considered similar.

2.2.5 Envelope Load Considerations

Thermal blocks shall consist of spaces having similar envelope loads; for example, thermal loads from solar heat gains and conductive heat losses from roofs. In general, spaces close to the perimeter of the building should be in separate thermal blocks from interior spaces. The following guidance shall be applied in combining HVAC zones into thermal blocks:

- Exterior and interior spaces shall not be combined in the same thermal block, except as permitted below.

Exception: Exterior spaces without fenestration or doors may be combined with interior spaces in the same thermal block.

- Exterior spaces having different glazed orientations shall not be combined in the same thermal block, except as permitted below.

Exception: Exterior spaces having different glazed orientations but small effective apertures for solar heat gain (i.e., solar heat gain coefficient times fenestration area divided by zone floor area less than 10%) may be combined in a single thermal block.

Exception: Exterior spaces having different glazed orientations but whose orientations differ by 45° or less may be combined in a single thermal block. This is not intended to prevent or discourage modeling of actual or anticipated corner zones or other actual HVAC zones which include fenestration of varying orientations in a single contiguous space.

- Spaces with envelope loads from floors and/or roofs shall only be combined within a single thermal block with spaces having similar loads from floors and/or roofs.
- Separate thermal blocks shall be created when fenestration area varies greatly. For example, a long perimeter corridor with small windows at one end, but all glass at the other should be split into two thermal blocks.

2.2.6 Conformance with HVAC Zones

Thermal blocks shall conform with the actual HVAC zoning as documented on the construction documents or the as-built drawings. "Conform with" as used here means that thermal blocks shall accurately reflect the actual floor areas of the HVAC zones (i.e., to within 5% of actual square footage), and thermal blocks and HVAC zones should share the same bounding surfaces.

2.2.7 Combining HVAC Zones

Under specific conditions, different HVAC zones may be combined into a single thermal block to reduce user input and to simplify the computer description of the building. Zone multipliers may also be used to achieve similar simplification, when this is a feature of the software. Provided all of the following conditions are met, different HVAC zones may be combined to create a single thermal block (or identical thermal blocks to which multipliers are applied):

- No more than ten different HVAC zones are included in any one thermal block.
- All the HVAC zones have similar space conditioning requirements.
- All of the zones are served by the same HVAC system or by the same kind of HVAC system. Perimeter baseboards, unit heaters or fan powered boxes (vs. straight boxes) should not be considered the "same kind" of HVAC system as zones without these features.
- All zones have similar minimum airflows (cfm/ft²) and if any have separate exhaust, this is met generally by transfer air from the HVAC zones in the thermal block.

2.2.8 Thermal Blocks in Multifamily Residential Buildings

Multifamily residential buildings, including hotel and motel occupancies, should be modeled using one thermal block per unit. Where units are thermally similar, dwelling units or hotel rooms may be combined. Corner units and units with roof or floor loads shall only be combined with units sharing these features.

2.2.9 Plenums

Plenums are spaces above the ceiling and below the floor above where lighting fixtures, pipes, ducts and other building services are often located. Plenums may or may not be used as return air plenums. Because of the leakage through the ceiling (typically suspended with lay-in panels), the temperature of the plenum tracks the temperature of the space, except that it is generally warmer because of heat stratification and heat produced by lighting fixtures located at the ceiling or in the plenum.

It is generally recommended that plenums be modeled as separate thermal blocks, but at the modeler's discretion, they may be combined with conditioned space below for modeling simplicity.

2.3 Unmet Load Hours

The Performance Rating Method and this manual use the term “unmet load hours” as a criterion for sizing equipment, for qualifying natural ventilation systems, and for other purposes. The concept of unmet load hours applies to individual thermal blocks but is summed for the building as a whole. For a thermal block, it represents the number of hours during a year when the HVAC system serving the thermal block is unable to maintain the set point temperatures for heating and/or cooling. During periods of unmet loads, the space temperature drifts above the cooling setpoint or below the heating setpoint. An unmet load hour occurs only during periods when the HVAC system is scheduled to operate. One hour with un-met loads General Modeling Procedures - Calculation Procedures Page 2-6 COMNET Manual August 2010 in one or more thermal block counts as a single un-met load hour for the building. If unmet load hours for more than one thermal block coincide (occur at the same hour), they count as only one unmet load hour for the building. Un-met load hours include periods when the space is either under cooled or under heated.


Unmet load hours can occur because fans, air flows, coils, furnaces, air conditioners or other equipment is undersized. Unmet load hours can also occur due to user errors including mismatches between the thermostat setpoint schedules and HVAC operating schedules or from other input errors, for instance, high internal gains or occupant loads. The term, as used in this manual, only addresses equipment undersizing. It is the responsibility of the user to address other causes of unmet load hours in the proposed design. There can be many reasons, but the following checklist is offered as a starting point:

- Make sure that thermostat schedules agree with schedules of HVAC system operation; occupant schedules; miscellaneous equipment schedules; outside air ventilation schedules and other schedules of operation that could affect the ability of the HVAC system to meet loads in the thermal block.
- Check to make sure that inputs for internal gains, occupants, outside air ventilation are reasonable and are consistent with the intended operation of the building.
- Examine the simulated operation of controls to determine if primary or secondary heating or cooling equipment (pumps, coils, boilers, etc.) is activated. Verify that the controls are not resetting in a way that reduces modeled capacity.

2.4 Calculation Procedures

Not applicable for Design to Earn ENERGY STAR.

The process for tax deductions and green building ratings is illustrated in [Figure 2.4-1](#) [2]. For both of these purposes, the proposed design is compared to a baseline building and the percent savings are calculated for the proposed design relative to the baseline building.






Figure 2.4-1: "Calculation Process for Tax Deductions and Green Building Ratings"

1. The process begins with a detailed description of the proposed design. Information is provided in enough detail to enable an estimate of annual energy use for a typical weather year. This information includes the building envelope, the lighting systems, the HVAC systems, the water heating systems and other important energy-using systems. This collection of information is referred to in this manual as *building descriptors*. A detailed presentation of the building descriptors are provided in Chapter 6.
2. Before the calculations are performed, some of the building descriptors are modified for the proposed design to incorporate *prescribed* (neutral independent) modeling assumptions. Prescribed modeling assumptions are different depending on purpose. For tax deductions, they include schedules of operation and plug loads. For green building ratings, there are few prescribed modeling assumptions.
3. The next step is to make a simulation of the *proposed* design to determine how well the heating and cooling loads are being satisfied. The indicator is *unmet load hours*, the number of hours during the year when the space temperature is below the heating set point temperature or greater than the cooling set point temperature. A large number of hours indicate that the equipment is undersized.
4. Test the number of unmet load hours and proceed only if the hours are less than 300 for the year of the simulation.
5. If the unmet load hours are greater than 300 for the year, then the baseline building simulation model is adjusted to reduce the unmet load hours to less than 300. If the problem is heating, then the size of the boiler or furnace may need to be increased. If the problem is cooling, then the size of the coils or chillers may need to be increased. These adjustments are not made automatically for the proposed building, but rather are specified by the modeler. See [Figure 2.5.2-1](#) [3].
6. If the unmet load hours are less than 300, then the final simulation is performed. If no changes are made in the model, this may be the same simulation in step 3. These calculations produce the results that are compared to the baseline building, which is calculated in steps 7 through 16.
7. Create the baseline building following the rules in this manual. The baseline building has the same floor area, number of floors and spatial configuration as the proposed design; however, systems and components are modified to be in minimum compliance with the *baseline standard*. The HVAC systems for the baseline building are established according to rules in this manual and depend on the primary building activity (residential or non-residential), the floor area, the number of stories and the fuel used for heating. See [Figure 6.1.2-1](#) [4].
8. Sizing calculations are performed for the baseline building and heating equipment is oversized by 25% and cooling equipment by 15%.
9. The next step is to make a simulation of the baseline building to determine how well the heating and cooling loads are being satisfied. This process is the same as performed for the proposed design in step 3.
10. The number of unmet load hours is then tested to see if they are greater than 300. This is not likely to occur since the heating and cooling equipment is oversized by 15% for cooling and 25% for heating in step 8.
11. If the unmet load hours are greater than 300, then equipment in the baseline building is increased so that the unmet hours are less than 300. See [Figure 2.5.2-1](#) [3].
12. Once both the baseline building and the proposed design have unmet load hours less than 300, they are compared to confirm that the unmet load hours for the proposed design are not greater than 50 more than the baseline building.
13. If the difference in unmet hours is greater than 50, then the equipment in the baseline building is reduced in size so that the difference is less than or equal to 50. See [Figure 2.5.2-1](#) [3].
14. Once the tests on unmet load hours are satisfied, then the energy performance of the baseline building is calculated. If the tests of unmet hours are satisfied the first time through, this step is the same as step 9.
15. The baseline building is rotated 90 degrees and modeled again. This is repeated for four orientations. Each time the building is rotated the equipment is resized.
16. The baseline energy use for the baseline building is calculated as the average of the energy use for the four orientations.
17. The next step is to make a simulation of the proposed design to determine how well the heating and cooling loads are being satisfied. Finally, the percent savings are calculated. For tax deductions, only regulated energy is considered, but for green building ratings, total energy is considered.

The COMNET calculation process described above is consistent with the ASHRAE Standard 90.1 Performance Rating Method (PRM) as contained in Appendix G of the Standard.

2.5 HVAC Capacity Requirements and Sizing

Not applicable for Design to Earn ENERGY STAR.

To ensure that the simulated space-conditioning loads are adequately met, adequate capacity must be available in each of the components of the HVAC system; e.g., supply-air flow rates, cooling coils, chillers, and cooling towers. If any component of the system is incapable of adequate performance, the simulation may understate the required energy inputs for space conditioning and report unmet load hours. Adequate capacities

are required in the simulations of both the proposed design and baseline building. The subsections below describe the procedures that shall be followed to ensure that both the baseline building and the rated building are simulated with adequate space-conditioning capacities.

2.5.1 Specifying HVAC Capacities for the Proposed Design

As shown in [Figure 2.4-1](#) [2], the proposed design shall have no more than 300 unmet load hours. If this requirement is violated, the software shall require the user to make changes to the proposed design building description to bring the unmet load hours below 300. This process is not automated by the software. There are two tests that must be met:

- Space loads must be satisfied: Space temperatures must be maintained within one half of the throttling range (e.g., 1°F with a 2°F throttling range) of the scheduled heating or cooling thermostat setpoints. This criterion may be exceeded for no more than 300 hours for a typical year.
- System loads must be satisfied: Plant equipment must have adequate capacity to satisfy the HVAC system loads. This criterion may be exceeded for no more than 300 hours for a typical year.

If either the space or system loads do not meet the above criteria, the equipment in the proposed design shall be resized by the user and appropriate changes shall be made to the construction documents such that the criteria are met. If the space conditioning criteria are not met because the HVAC equipment in the proposed design lacks the capability to provide either heating or cooling, equipment capable of providing the needed space conditioning must be added by the user. The type of equipment added will depend on the type of HVAC system in the proposed design and the judgment of the energy analyst.


Equipment sizes for the proposed design shall be entered into the model by the energy analyst and shall agree with the equipment sizes specified in the construction documents. When the simulations of these actual systems indicate that specified space conditions are not being adequately maintained in one or more thermal block(s), the user shall be prompted to make changes to equipment sizes and to make corresponding changes to the construction documents. This occurs when the unmet load hours exceed 300 for the year.


2.5.2 Sizing Equipment in the Baseline Building

Equipment in the baseline building is automatically oversized by the program (25% for heating and 15% for cooling). However, in cases when unmet load hours in the proposed design are greater than 50 hours compared to the baseline building, equipment in the baseline building may have to be downsized. The criterion is that the unmet load hours in the proposed design may be no greater than 50 hours more than the corresponding thermal block in the baseline building. [Figure 2.5.2-1](#) [3] shows the recommended procedure for downsizing equipment in the baseline building so that the 50 hour delta requirement is satisfied. Note that this procedure may result in the baseline building equipment not meeting the 25% oversizing requirement for heating and the 15% oversizing requirement for cooling. It is also possible that the downsizing will result in a reduction in the 20 F delta-T specified in § G3.1.2.8 of the PRM.

Unmet load hours are evaluated at the building level by looking at the unmet load hours for each of the thermal blocks being modeled. One hour with unmet loads in one or more thermal block counts as a single unmet load hour for the building. Therefore, the unmet load hours for the building will never be less than the worst thermal block.

[Figure 2.5.2-1](#) [3] shows the process of adjusting equipment sizes in the baseline building in order to meet the 50 hour delta requirement. Equipment in the baseline building is already oversized, so the process is to incrementally make adjustments to the thermal block with the most unmet load hours until the un-met load hours for the baseline building are within 50 of the proposed design. The process is explained in greater detail in the paragraphs that follow [Figure 2.5.2-1](#) [3].





[5]

Figure 2.5.2-1: "Procedure for Adjusting Equipment HVAC Sizes in the Baseline Building"

1. The process begins with simulation results for both the proposed design and the baseline building.
2. Simulate the baseline building and calculate the un-met load hours for the building (see definition above).
3. Compare the unmet load hours between the proposed design and the baseline building. If the proposed design is no more than 50 hours greater than the baseline building, then move no adjustments are necessary and the process is complete (step 18), otherwise move to 4.
4. When the difference between the proposed design and the baseline building is greater than 50 unmet load hours, then determine the thermal block with the greatest total un-met load hours for heating and/or cooling. Adjustments will be made to this thermal block.
5. Test to see which is greater: the difference in heating unmet load hours or cooling unmet load hours.
6. If the difference for the thermal block is mostly cooling, then look at the system type serving the thermal block. If the system is type 1 through 4 (single zone systems) then go to 8, otherwise go to 9.
8. For system types 1 through 4, test to see if it is possible to reduce air flow to the thermal block and still maintain the minimum outside air ventilation level. If so, go to 10; otherwise, go to 11.
10. Reduce the cooling capacity of the packaged equipment by 2% and let the air flow to the zone scale in order to meet a 20°F delta-T difference between the setpoint temperature in the space and the supply air. Maintain the same ratio of sensible to total cooling capacity.
11. Raise the supply air temperature to the thermal block by 1°F. This reduces the 20°F delta-T, but is necessary to maintain air flow to the space at a volume adequate to meet the outside air ventilation requirement.
9. For system types 5 through 8, test to see if it is possible to reduce air flow to the thermal block and still maintain the minimum outside air ventilation level. If so, go to 12; otherwise, go to 13.
12. Reduce the design air flow rate to the thermal block by 2%. Allow the upstream coil and cooling equipment to be auto-sized so that their capacity is also reduced.
13. Raise the supply air temperature to the thermal block by 1°F. This reduces the 20°F delta-T, but is necessary to maintain air flow to the space at a volume adequate to meet the outside air ventilation requirement.
7. If the difference for the thermal block is mostly heating, then look at the system type serving the thermal block. If the system type is 1 or 3, go to 14; if the system type is 2 or 4, go to 15; if the system type is 5 or 6, go to 16; or if the system type is 6 or 8, go to 17.
14. For system types 1 or 3, reduce the heating coil capacity or the size of the furnace by 2%
15. For system types 2 or 4, reduce the size of the heat pump compressor and the supplemental heater by 2%. Note that for modeling purposes the size of the heat pump compressor is changed without changing the size of the cooling capacity.
16. For system types 5 or 6, reduce the size of the reheat coil by 2%. Auto size the boiler accordingly.
17. For system types 6 or 8 reduce the size of the electric reheat coil by 2%.
3. Move back to step 2.
20. Finish.

2.6 Ventilation Requirements

Assumptions regarding outside air ventilation shall be based on applicable building codes or ASHRAE Standard 62.1-2007 if local codes do not apply. If information on ventilation rates is unavailable, values from Appendix B shall be used. For most purposes, the same assumptions on outside air ventilation are used in the baseline building and the rated building; therefore, no credit can be realized by reducing ventilation rates in the rated building.

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/2-general-modeling-procedures>

Links:

- [1] <http://www.comnet.org/mgp/content/221-definitions#hierarchy-of-space-functions-hvac-zones-and-thermal-blocks>
- [2] <http://www.comnet.org/mgp/content/24-calculation-procedures#calculation-process-for-tax-deductions-and-green-building-ratings>
- [3] <http://www.comnet.org/mgp/content/252-sizing-equipment-baseline-building#procedure-for-adjusting-equipment-hvac-sizes-in-the-baseline-building>
- [4] <http://www.comnet.org/mgp/content/hvac-system-map#hvac-mapping>
- [5] <http://www.comnet.org/mgp/content/14-facility-features#Energy-2.5.2-1-Procedure-0>

3 Software Requirements

This chapter contains the software requirements that must be implemented by COMNET accredited software. The tests fall into the following categories:

- Tests to verify that the software is evaluating thermal loads and the response of the HVAC systems to these loads in a manner that is acceptable. These tests reference *ASHRAE Standard 140-2007, Standard Method of Test for Evaluation of Building Energy Analysis Computer Programs*.
- Tests to verify that the candidate building or the proposed design is modeled with the correct fixed and restricted inputs, including schedules of operation, receptacle loads, process loads and other components.
- Tests to verify that the baseline building is created correctly, e.g. that the baseline HVAC system is properly specified and that other components of the baseline are correctly defined.

3.1 General Requirements

3.1.1 Scope

The *Rating Software* must satisfy the requirements contained in this section.

The *Rating Software* shall be capable of modeling at least 50 *thermal blocks*.

The *Rating Software* shall be capable of modeling at least 15 separate HVAC systems.

3.1.2 Calculation Methods

The *Rating Software* shall calculate the annual consumption of all end uses in buildings, including fuel and electricity for:

- HVAC (heating, cooling, fans, and ventilation);
- Lighting (both interior and exterior);
- Receptacles and miscellaneous electric;
- Service water heating;
- Process energy uses;
- Commercial refrigeration systems; and
- All other energy end uses that typically pass through the building meter.

The *Rating Software* shall perform a simulation on an hourly time interval (at a minimum) over a one year period (8760 hours) with the ability to model changes in weather parameters, schedules, and other parameters for each hour of the year. This is typically achieved by specifying a 24-hour schedule for each day of the week plus holidays.

Calculating Design Loads

The software shall be capable of performing design load calculations for determining required HVAC equipment capacities and air and water flow rates using accepted industry calculation methods for both the proposed design and baseline building design.

Checking Simulation Output for Unmet Loads

The software shall be capable of checking the output of the energy analysis module for the proposed design to ensure that space conditions are maintained within the tolerances specified (maximum of 300 unmet load hours per year).

Adjusting Capacities

For the baseline building (when applicable), the software shall be capable of modifying capacities, temperatures or flow rates for baseline building HVAC system components resulting in excessive unmet loads hours meeting the criteria, following the procedures in Chapter 2.

Error Handling

The software shall identify error conditions when unmet loads fail to meet the criteria, prevent completion of the rating analysis, and provide information to the user describing the error that has occurred and what steps the user should take to remedy the situation.

3.1.3 Climate Data

The *Rating Software* shall perform simulations using hourly values of climate data, such as temperature and humidity, derived from WYEC (Weather Year for Energy Calculation), TMY (Typical Meteorological Year) or CWEC (Canadian Weather for Energy Calculations) climate data.

The *Rating Software* shall calculate solar radiation on exterior surfaces on an hourly basis from the values of direct normal irradiance and diffuse horizontal irradiance contained in the climate data, taking ground reflectance into account.

3.1.4 Utility Rates

The *Rating Software* shall be capable of simulating time-of-use rates and apply both demand and energy charges for each time period of the rate schedule.

3.1.5 Thermal Mass

The calculation procedures used in the *Rating Software* shall account for the effect of thermal mass on: loads due to occupants, lights, solar radiation, and transmission through building envelope; amount of heating and cooling required to maintain the specified space temperature schedules; and variation in space temperature.

3.1.6 Modeling Space Temperature

The *Rating Software* shall contain a dynamic simulation of space temperature which accounts for:

- Dynamics in change in heating and cooling setpoint temperatures;
- Deadband between heating and cooling thermostat settings;
- Temperature drift in transition to setback or setup thermostat schedules;
- Temperature drift in periods when heating or cooling capability are scheduled off;
- Temperature drift when heating or cooling capability of the system is limited by heating or cooling capacity, air flow rate, or scheduled supply air temperature; and
- Indirectly conditioned *thermal blocks*, where the temperature is determined by internal loads, heat transfer through building envelope, and heat transfer between *thermal blocks*.

3.1.7 Heat Transfer between Thermal Blocks

The *Rating Software* shall be capable of modeling heat transfer between a *thermal block* and adjacent *thermal blocks*.

The *Rating Software* shall account for the effect of this heat transfer on the space temperature, space conditioning loads, and resulting energy use in the *thermal block* and in the adjacent *thermal blocks*.

3.1.8 Control and Operating Schedules

The *Rating Software* shall be capable of modeling control and operating schedules which can vary by:

- The hour of the day;
- The day of the week; and
- Holidays treated as a special day of the week.

The *Rating Software* shall be capable of explicitly modeling all of the schedules specified in Appendix C of this manual.

3.1.9 Loads Calculation

The loads calculations described in this section relate to the simulation engine and not to the procedure used the design engineer to size and select equipment.

Internal Loads

The *Rating Software* shall be capable of calculating the hourly cooling loads due to occupants, lights, receptacles, and process loads.

The calculation of internal loads shall account for the dynamic effects of thermal mass.

The *Rating Software* shall be capable of simulating schedules for internal loads in the form given in Appendix C.

The simulation of cooling load due to lights shall account for:

- The effect of the proportion radiant and convective heat, which depends on the type of light, on the dynamic response characteristic; and
- A portion of heat from lights going directly to return air, the amount depending on the type and location of fixture.

Building Envelope Loads

The *Rating Software* shall calculate heat transfer through walls, roofs and floors for each *thermal block*, accounting for the dynamic response due to thermal characteristics of the particular construction as defined in the *Building Descriptors* in Chapter 6.

The calculation of heat transfer through walls and roofs shall account for the effect of solar radiation absorbed on the exterior surface, which depends on orientation, reflectance and emittance of the surface.

The *Rating Software* shall calculate heat transfer through windows and skylights, accounting for both temperature difference and transmission of solar radiation through the glazing.

Calculation of cooling load due to transmission of solar radiation through windows and skylights shall account for:

- The angular incidence of the direct beam sunlight and the angular and spectral dependence of the solar properties.
- Orientation (azimuth and tilt of surface).
- The effect of shading from overhangs side fins, louvers or neighboring buildings or terrain.

Infiltration

The *Rating Software* shall be capable of simulating infiltration that varies by the time of day and day of the week.

3.1.10 Systems Simulation

General

The *Rating Software* shall be capable of modeling:

- The baseline building systems defined in Chapter 6,
- The lighting, water heating, HVAC and miscellaneous equipment detailed in Chapter 6
- All compulsory and required features as listed in Appendix A and detailed in Chapter 6
- The capability to model multiple zone systems serving at least 15 *thermal blocks*.

The *Rating Software* shall be capable of modeling plenum air return.

Terminal Characteristics

The *Rating Software* shall be capable of simulating the effect on space temperature and energy use of:

- Limited capacity of terminal heating devices;
- Limited capacity of terminal cooling devices; and
- Limited rate of air flow to *thermal blocks*.

HVAC Systems and Equipment

The *Rating Software* shall be capable of simulating the effect on energy use and space temperature in *thermal blocks* served by the HVAC system, including:

- Limited heating capacity of an HVAC system;
- Limited cooling capacity of an HVAC system;
- Temperature rise of supply air due to heat from supply fan, depending on the location of the fan;
- Temperature rise of return air due to heat from return fan;
- Temperature rise of return air due to heat from lights to return air stream; and
- Fan power as a function of supply air flow in variable air volume systems.

Central Plant Systems and Equipment

The *Rating Software* shall be capable of simulating the effect on energy use of limited heating or cooling capacity of the central plant system.

If the *Rating Software* is not capable of simulating the effect of limited heating or cooling capacity of the central plant system on space temperature in *thermal blocks* dependent on the central plant system for heating and cooling, then it shall issue a warning message when loads on the central plant system are not met.

Equipment Performance Curves

The *Rating Software* shall be capable of modeling the part load efficiency and variation in capacity of equipment as follows:

- Furnaces as a function of part load;
- Boilers as a function of part load, supply hot water temperature, and return hot water temperature;
- Water-cooled compressors including heat pumps and chillers as a function of part load, evaporator fluid, or air temperature and condensing fluid temperature;
- Air-cooled compressors including heat pumps, direct expansion cooling and chillers as a function of part load, ambient dry-bulb temperature, and wet-bulb temperature returning to the cooling coil;
- Evaporative cooling systems as a function of ambient wet-bulb temperature; and
- Cooling towers as a function of range, approach and ambient wet-bulb temperature.

Economizer Control

The *Rating Software* shall be capable of modeling integrated air- and water-side economizers.

The *Rating Software* shall be capable of modeling electronic enthalpy air-side economizer controls that vary the high limit as a function of both temperature and enthalpy.

Air Side Heat-Recovery

The *Rating Software* shall be capable of modeling heat recovery between the exhaust air stream and the outside air stream. The software shall account for auxiliary energy uses associated with heat recovery systems, including pumping energy, frost control, and system control.

Heat-Recovery Water Heating

The *Rating Software* shall be capable of modeling heat recovery water heating from the following sources:

- Double bundled chiller;
- Refrigerant desuperheater as part of a packaged HVAC unit;
- Heat exchanger on the condenser water loop; and
- Heat-recovery water-to-water heat pump operating off of the condenser or chilled water loop.

Heat-Pump Water Heaters

The *Rating Software* shall be capable of modeling heat-pump water heaters. The algorithm must allow the evaporator coil to be located in:

- Any thermal block;
- Any plenum; and
- Outside.

3.1.11 Managing User Input

This section addresses the processes of data entry and the validation of user input data that can be performed prior to and independent of the energy simulation.

Building Descriptor Inputs and Restrictions

Building descriptors are discussed in Chapter 6 and listed in tabular form in Appendix A. Building descriptors are classified in one of several ways:

- **Reference.** Information that does not affect the energy rating results, such as the name of the architect, the address of the building, or rating authority applications numbers.
- **Trigger.** A building descriptor that turns on or turns off the applicability of other building descriptors. An example is the daylight modeling method.
- **Asset.** Information about the rated building that does affect the results such as insulation levels, window construction or equipment efficiency.
- **Special Asset.** Information about the rated building that is considered an asset, but requires special documentation of performance. Examples include reduced infiltration or credit for natural ventilation.
- **Neutral Dependent.** Information that is the same for both the rated building and the baseline building. The baseline building assumes the same conditions specified for the rated buildings. Examples are schedules of operation, temperature settings, etc. For purposes that do not use a modeled baseline building, such as Design to Earn ENERGY STAR, the designation of “neutral dependent” means that the rating

use a modeled baseline building, such as Design to Earn ENERGY STAR, the designation of "neutral dependent" means that the rating process attempts to neutralize for this variable.

- **Use-or-Lose.** This is a special case of a neutral dependent classification except that baseline value has a floor or ceiling. An example is retail display lighting whereby the baseline building is equal to the rated building up to a maximum power limit. When the rated building value is within an acceptable range, the use-or-lose" variable is neutral dependent. When the value for the rated building is outside the acceptable range, the building descriptor is an asset.
- **Neutral Independent.** Information that is the same for both the rated building and the baseline building, but is prescribed. Examples are schedules of operation when the purpose is federal tax credits.
- **Defaults** are provided for many building descriptors. A common default is provided for convenience and may be overridden by the user with no special documentation. However, when a default is provided for a special asset, the value must be used unless special documentation is provided.

Building descriptors may also be classified by the **level of software support** that is required: compulsory, required, optional, and unsanctioned. Compulsory inputs must always be supported by the software and specified by the user. Required inputs shall be supported by the rating software but they may not be applicable for all ratings. Optional inputs are addressed in this manual and restrictions may apply, but it is up to the software vendor as to whether the inputs are supported. Unsanctioned inputs are inputs that are not addressed in this manual; these are not listed in Appendix A or discussed in Chapter 6.

Restrictions may apply to all compulsory and required inputs. Appendix A specifies the compulsory building descriptors. Examples of compulsory inputs are climate zone, floor area, and space-by-space classification. If the software provides a means for the user to input building descriptors listed as optional in Appendix A, all input conditions and restrictions shall apply.

The software user interface shall: 1) clearly indicate when a building descriptor has an associated default, 2) indicate what the default value is, and 3) provide a convenient means for the user to over-ride the default. When default values for special assets are overridden, the software interface shall notify the user that documentation is required.

For neutral independent building descriptors, the software is not required to provide a means for users to enter data since the software will automatically assign the prescribed value. However, if the user is permitted to input values for prescribed inputs, the software must inform the user that a prescribed value and not the value input by the user will be used in calculating the rating.

No restrictions are specified for unsanctioned inputs. If the software uses unsanctioned inputs, the software documentation or help system shall specify the applicability of the building descriptors, its definition, the units in which it is expressed, restrictions on input for the proposed design, and, if applicable, how the building descriptor is defined for the baseline building.

The software may assist the user in describing the proposed design by displaying typical values for building descriptors, provided deliberate action by the user is necessary before a displayed value is used.

Data Validation

Compulsory Input Checks

The software shall check to ensure that valid entries have been made for all compulsory building descriptors before the user is permitted to proceed with the next step in the rating process.

Handling of Missing Inputs

If a required input is missing or invalid, the software shall: 1) notify the user that the input is missing or invalid, 2) identify the input field(s) with missing or invalid data, and 3) prevent the user from moving to the next step of the rating process. The software may provide additional information designed to help the user correct the deficiency.

Validity Checks

The software shall check all user inputs to ensure that the following conditions are met:

- *Simulation Tool Limits.* Inputs do not exceed the minimums or maximums for the parameters permitted by the simulation engine.
- *Rating Rule Limits.* Inputs do not exceed minimums or maximums for the descriptors specified in Chapter 6 of this document.
- *Simulation Tool Discrete Options.* Inputs correspond with valid discrete or list options for parameters available in the simulation engine.
- *Rating Rule Discrete Options.* Inputs correspond with valid discrete options provided for in Chapter 6.

Handling Invalid Input

When invalid data is entered, the software shall: 1) notify the user of the invalid input, 2) identify the nonconforming input field, and 3) prevent execution of the next step of the rating process; i.e., generating the input description for the proposed design. The software may provide additional information designed to help the user correct the deficiency.

Consistency Checks

The consistency checks described above are intended to identify errors and oversights in user input and thereby help ensure that the building description is complete and interpretable by the energy analysis program. Examples of consistency checks include making sure that total window

description is complete and interpretable by the energy analysis program. Examples of consistency checks include making sure that total window area does not exceed the wall area in which they are contained and that the necessary plant equipment has actually been connected to the secondary HVAC systems. The software may include additional consistency checks provided these are clearly documented in the user documentation or on-line help system.

Handling Inconsistent Input

If the proposed design fails a consistency check, the software shall: 1) notify the user that an inconsistency exists, 2) identify the specific consistency check that has been failed, 3) identify the inconsistent input fields, if feasible, and 4) prevent execution of the next step of the rating process; i.e., generating the input description for the proposed design. The software may provide additional information designed to help the user correct the deficiency.

3.2 ASHRAE Standard 140-2007 Tests

This method of testing is provided for analyzing and diagnosing building energy simulation software using software-to-software and software-to-quasi-analytical-solution comparisons. The methodology allows different building energy simulation programs, representing different degrees of modeling complexity, to be tested by comparing the predictions from other building energy programs to the simulation results provided by the Rating Software in question.

The specifications for determining input values, the weather data required and an overview for all the test cases containing information on those building parameters that change from case to case is provided in the Standard 140-2007 documentation. The cases are grouped as:

- Building Thermal Envelope and Fabric Load Base Case
- Building Thermal Envelope and Fabric Load Basic Tests
 - Low mass
 - High mass
 - Free float
- Building Thermal Envelope and Fabric Load In-Depth Tests
- Space-Cooling Equipment Performance Analytical Verification Base Case
- Space-Cooling Equipment Performance Parameter Variation Analytical Verification Tests
- Space-Cooling Equipment Performance Comparative Test Base Case
- Space-Cooling Equipment Performance Comparative Tests
- Space-Heating Equipment Performance Analytical Verification Base Case
- Space-Heating Equipment Performance Analytical Verification Tests
- Space-Heating Equipment Performance Comparative Tests

COMNET software is required to perform the ASHRAE Standard 140-2007 suite of software tests and the results of these tests shall conform to the COMNET acceptance requirements. All tests shall be completed in accord with the requirements of ASHRAE Standard 140-2007. The resulting estimates of energy consumption shall fall between the minimum and maximum values established by COMNET, unless a valid explanation is provided. The portfolio folder for Appendix E contains spreadsheets wherein the software vendor enters the results of the Standard 140 simulations for comparison against the criteria. When results from candidate software fall outside the COMNET acceptance range or when candidate software is unable to perform one of the tests, the vendor shall provide an explanation of the reason as per ASHRAE Standard 140-2007 requirements. The portfolio folder for Appendix E also contains a methodology paper that describes how the acceptance criteria were developed.

3.2.1 Using the Spreadsheets

Four spreadsheets are provided in Appendix E for documenting results from candidate software and comparing to the COMNET acceptance ranges. These parallel the spreadsheets provided with ASHRAE Standard 140-2007. For each of the spreadsheets, the fields where data is entered are shaded pale yellow. The tabs where data is entered and where results are reviewed are shown in [Table 3.2.1-1](#) [1].

Table 3.2.1-1: "Spreadsheets for Verifying Standard 140 Tests"

| Spreadsheet | Enter Data on Tab | Check Results on Tab |
|--|-------------------|----------------------|
| COMNET Acceptance Range Results 5-2.xls | A | A |
| COMNET Acceptance Range Results 5-3A.xls | YD | A |
| COMNET Acceptance Range Results 5-3B.xls | YD | Q |
| COMNET Acceptance Range Results 5-4.xls | YD | Q |

3.3 Modeling Assumptions and Baseline Building Tests

The previous suite of tests, based on ASHRAE Standard 140-2007, verifies that the simulation engine produces results that are reasonable. Each test requires a simulation to be run. The tests in this section are intended to verify that the software correctly constructs the proposed design and baseline buildings and correctly applies the proposed design input restrictions specified in Chapter 6 and Appendix A.

The simulations described in this section use five prototype buildings. Prototypes A1, A3 and A20 are all the same five-zone, 150 ft x 150 ft, floor plate, but with one, three and 20 stories. Prototypes B1 and C1 are five-zone, one-story, square prototype buildings measuring 200 ft x 200 ft and 400 ft x 400 ft respectively. Prototype D is a more complex, mixed use building with a below-grade garage, retail on the first level, office space on levels two and three, and four stories of multi-family housing over the office. [Figure 3.3-1](#) [2] is an image of all of the prototype buildings, positioned next to each other. Appendix E has a Google Sketchup file with the detailed geometry for each of the prototypes. Appendix E also has a spreadsheet with tabular detail on each of the prototype buildings along with forms for the software vendor to complete.




Figure 3.3-1: "Prototype Buildings for Modeling Assumptions and Baseline Building Tests"

Evaluation of the modeling assumptions and baseline building tests is **qualitative**. The software developer shall use the candidate software and make the simulations described in this section for the proposed design and the baseline building. The input and output files for each of these cases shall then be evaluated by the software developer to verify that:

- Default schedules of operation are applied for both the baseline building and the proposed design.
- The baseline building use the correct system types as prescribed in Chapter 6.
- An economizer (of the right type) is included in the baseline building if required.
- The primary and secondary baseline building systems are properly specified and sized.
- Fan brake horsepower is correctly specified for the baseline building.
- The baseline building is correctly rotated and the equipment is re-sized for each rotation.
- The baseline building envelope constructions are correctly substituted for exterior opaque surfaces, partitions and fenestration.
- Fenestration area in the baseline building is reduced, when the proposed design fenestration area is greater than the limit.
- The baseline building lighting system is correctly specified and that exterior lighting is modeled.
- Receptacle loads, refrigeration equipment and other equipment is modeled according to the rules in this manual.
- Prescribed modeling assumptions are applied for both the baseline building and the proposed design.
- Elevators in Prototypes A20 and D are included.
- Overhangs are modeled in the proposed design for Prototype D but not the baseline building.
- The models make a reasonable estimate of unmet load hours.
- Unconditioned spaces are modeled.
- Other baseline building specifications and/or modeling assumptions are correctly applied.

As the software developer verifies the above and other conditions, the input and output files should be annotated with comments (or by some other means) to demonstrate that the modeling rules specified in Chapter 6 and Appendix A are correctly applied. Software developers should use the output format spreadsheets, included in Appendix E, to report the results of these tests. These annotated files are then submitted to COMNET for further evaluation. Any errors discovered shall be corrected by making modifications to the software; the simulations shall be repeated; and the new results shall be annotated for submittal to COMNET.

3.3.1 Summary of Required Simulations

Separate rating analyses are required for each purpose. Runs 1 through 20 are required when software is accredited for green building ratings that use ASHRAE Standard 90.1-2007 as the baseline. Runs 21 through 29 are required for tax credits that use ASHRAE Standard 90.1-2001 as the baseline. See [Table 3.3.1-1](#) [3]. Runs 30 through 49 are required when software is accredited for green building ratings that use ASHRAE Standard 90.1-2010 as the baseline.

Table 3.3.1-1: "Summary of Analyses for Modeling Assumptions and Baseline Building Tests"

| Run | Purpose | Prototype | Climate | Occupancy Option | Lighting Power Density (W/ft²) | Equipment Power Density (W/ft²) | HVAC System | Default Schedules |
|-----|----------|-----------|---------|------------------|--------------------------------|---------------------------------|-------------|-------------------|
| 1 | Points07 | A1 | Chicago | Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 2 | Points07 | A1 | Chicago | Office | 1.20 | 1.50 | PSZ-HP | No |
| 3 | Points07 | A1 | Chicago | Office | 1.40 | 2.00 | PVAV | No |

| Prototype | City | Use | Area (sq ft) | Volume (cu ft) | Energy (kWh) | Cost (\$) |
|-----------|--------------|---------------------|--------------|----------------|--------------|-----------|
| 4 | Points07 A1 | Denver Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 5 | Points07 A1 | Miami Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 6 | Points07 A3 | Chicago Office | 1.00 | 1.00 | PVAV | Yes |
| 7 | Points07 A3 | Denver Office | 1.00 | 1.00 | PVAV | Yes |
| 8 | Points07 A3 | Miami Office | 1.00 | 1.00 | PVAV | Yes |
| 9 | Points07 A20 | Chicago Office | 1.00 | 1.00 | VAV | Yes |
| 10 | Points07 A20 | Denver Office | 1.00 | 1.00 | VAV | Yes |
| 11 | Points07 A20 | Miami Office | 1.00 | 1.00 | VAV | Yes |
| 12 | Points07 B1 | Chicago Supermarket | 2.10 | 0.20 | PSZ-AC | Yes |
| 13 | Points07 B1 | Denver Retail | 1.90 | 0.90 | PSZ-AC | Yes |
| 14 | Points07 B1 | Miami Manufacturing | 1.30 | 1.00 | PSZ-HP | Yes |
| 15 | Points07 C1 | Chicago Retail | 1.50 | 0.90 | PSZ-AC | Yes |
| 16 | Points07 C1 | Denver Warehouse | 0.80 | 0.40 | PSZ-AC | Yes |
| 17 | Points07 C1 | Miami Manufacturing | 1.30 | 1.00 | PSZ-HP | Yes |
| 18 | Points07 D | Chicago See detail | See detail | See detail | See detail | Yes |
| 19 | Points07 D | Denver See detail | See detail | See detail | See detail | Yes |
| 20 | Points07 D | Miami See detail | See detail | See detail | See detail | Yes |
| 21 | Tax A1 | Chicago Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 22 | Tax A1 | Denver Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 23 | Tax A1 | Miami Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 24 | Tax B1 | Chicago Supermarket | 2.10 | 0.20 | PSZ-AC | Yes |
| 25 | Tax B1 | Denver Retail | 1.90 | 0.90 | PSZ-AC | Yes |
| 26 | Tax B1 | Miami Manufacturing | 1.30 | 1.00 | PSZ-HP | Yes |
| 27 | Tax D | Chicago See detail | See detail | See detail | See detail | Yes |
| 28 | Tax D | Denver See detail | See detail | See detail | See detail | Yes |
| 29 | Tax D | Miami See detail | See detail | See detail | See detail | Yes |
| 30 | Points10 A1 | Chicago Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 31 | Points10 A1 | Chicago Office | 1.20 | 1.50 | PSZ-HP | No |
| 32 | Points10 A1 | Chicago Office | 1.40 | 2.00 | PVAV | No |
| 33 | Points10 A1 | Denver Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 34 | Points10 A1 | Miami Office | 1.00 | 1.00 | PSZ-AC | Yes |
| 35 | Points10 A3 | Chicago Office | 1.00 | 1.00 | PVAV | Yes |
| 36 | Points10 A3 | Denver Office | 1.00 | 1.00 | PVAV | Yes |
| 37 | Points10 A3 | Miami Office | 1.00 | 1.00 | PVAV | Yes |
| 38 | Points10 A20 | Chicago Office | 1.00 | 1.00 | VAV | Yes |
| 39 | Points10 A20 | Denver Office | 1.00 | 1.00 | VAV | Yes |
| 40 | Points10 A20 | Miami Office | 1.00 | 1.00 | VAV | Yes |
| 41 | Points10 B1 | Chicago Supermarket | 2.10 | 0.20 | PSZ-AC | Yes |
| 42 | Points10 B1 | Denver Retail | 1.90 | 0.90 | PSZ-AC | Yes |
| 43 | Points10 B1 | Miami Manufacturing | 1.30 | 1.00 | PSZ-HP | Yes |
| 44 | Points10 C1 | Chicago Retail | 1.50 | 0.90 | PSZ-AC | Yes |
| 45 | Points10 C1 | Denver Warehouse | 0.80 | 0.40 | PSZ-AC | Yes |
| 46 | Points10 C1 | Miami Manufacturing | 1.30 | 1.00 | PSZ-HP | Yes |
| 47 | Points10 D | Chicago See detail | See detail | See detail | See detail | Yes |
| 48 | Points10 D | Denver See detail | See detail | See detail | See detail | Yes |
| 49 | Points10 D | Miami See detail | See detail | See detail | See detail | Yes |

3.3.2 Prototypes A1, A3 and A20

Prototypes A1, A3 and A20 are all office buildings. They have the same 150 ft by 150 ft floor plate with a simple 15 ft perimeter zone. The main difference between the prototypes is the number of stores. A1 is a single story, A3 has three stories and A20 has twenty stories.

All three prototypes have a 12 floor-to-floor height and a plenum with a height of 3 ft 6 in. Ceiling height is 8 ft 6 in. Prototypes A1 and A3 have a window wall ratio of 31%; fenestration consists of 10 ft by 5 ft 6 in. windows spaced around the perimeter at 15 ft. Prototype A20 has a window-wall-ratio of 71% with floor-to-ceiling glass on all sides. [Figure 3.3.2-1](#) [4] is a visual image of the three prototype buildings.

Prototype A1 is a wood framed building while prototypes A3 and A20 are steel framed.

Detailed specifications for each of the prototype building models are presented in spreadsheets included in Portfolio Appendix E.




Figure 3.3.2-1: "Prototypes A1, A3 and A20"

3.3.3 Prototypes B1 and C1

Prototypes B1 and C1 are both single story, large floor plate buildings. Prototype B1 measures 200 ft x 200 ft with an 18 ft height and a 4 ft plenum. Prototype C1 measures 400 ft x 400 ft with a 24 ft height and no plenum. [Figure 3.3.3-1](#) [5] is a visual image of the two prototypes. Prototypes B1 and C1 each have fenestration on just one side. Prototype B1 has a store front glazing system that is 8 ft high by 80 ft wide. Prototype C1 has a store front glazing system that is 8 ft high by 160 ft wide. Both curtain wall systems have an horizontal overhang located at the top of the glazing that extends a distance of 8 ft. Both prototypes have mass walls (8 inch solid grouted CMU blocks, interior insulation and gypsum board). Detailed specifications for each of the prototype building models are presented in spreadsheets included in Appendix E.




Figure 3.3.3-1: "Prototypes B1 and C1"

3.3.4 Prototype D

Prototype D is a mixed use building with a clear specification. Prototype D is the case study building used in the User's Manual for ASHRAE Standard 90.1-2007 to demonstrate the use of the Performance Rating Method (PRM). The building has seven above-ground stories and an underground garage. The building's footprint is 150 ft x 90 ft with the long axis oriented due east-west. The first floor contains retail spaces with large display windows that have overhangs projecting 10 ft on the south, east, and west exposures. The second and third floors contain offices that have similarly oriented overhangs, although the overhangs project only 5 ft. Above the offices are apartments on floors four through seven. To provide more daylight and fresh air, the four floors of apartments have two 20 ft x 30 ft notches taken out of the floor plan; therefore, these levels have 1,200 ft² less floor area than floors one, two, and three. The building also has an unconditioned stairwell.




Figure 3.3.4-1: "Prototype D Floor Plans"






Figure 3.3.4-2: "Prototype D Exterior View"

Prototype D is a steel-framed building with steel stud walls with R-7 insulation in the cavities and $\frac{5}{8}$ in. sheetrock. The windows are single glazed with clear glass in all areas except the offices, which have single-pane windows with gray glass. All windows have thermally broken metal frames. Only the windows on the residential levels are operable.

A fluorescent electric lighting system is used throughout the commercial sections of the building. Lighting power density is 1.38 W/ft² in retail areas, 1.16 W/ft² in office areas, 0.25 W/ft² in the underground parking, and 0.5 W/ft² in stairwells. The perimeter zones of the office have automatic daylight dimming controls.

Retail spaces are served by a four-pipe fan coil system so that they can be independently shut down if the stores' operating hours differ significantly. A variable air volume (VAV) air-handling system served by the same centrifugal chiller and a boiler provides space conditioning in the office levels. The apartments are heated and cooled by four-pipe fan coil systems, which are also served by the chiller and boiler. The underground parking is ventilated during retail business hours.

A 160-ton, chiller with a rating of 0.6 kW/ton and a 2,250,000 Btu/h boiler serve all of the heating and cooling loads in the building.

Table 3.3.4-1: "Prototype D Surface Areas"

| Space Category | Orientation | Wall Area | Window Area | Window-Wall-Ratio | Proposed U-Value/SHGC |
|----------------------|-------------|-----------|-------------|-------------------|-----------------------|
| Residential | North | 6,600 | 1,202 | 18% | 1.22/0.82 |
| | Non-North | 30,360 | 5,389 | | |
| | | 36,960 | 6,591 | | |
| Residential total | | | | | |
| | | | | | |
| Nonresidential | | | | | |
| Retail | North | 1,600 | 534 | 37% | 1.22/0.82 |
| Office | North | 3,200 | 1,000 | | |
| Retail | Non | 4,293 | 2,920 | | 1.22/0.43 |
| Office | | 8,587 | 2,054 | | 1.22/0.82 |
| Nonresidential total | | 17,680 | 6,508 | | 1.22/0.43 |

Table 3.3.4-2: "Prototype D Lighting and Equipment Power"

| Area Description | Area | Lighting Power | | Equipment Power | |
|----------------------|---------|----------------|-------------------|-----------------|-------------------|
| | | Watts | W/ft ² | Watts | W/ft ² |
| Parking | 15,700 | 3,925 | 0.25 | 4,710 | 0.30 |
| Retail | 11,300 | 15,594 | 1.38 | 16,950 | 1.50 |
| Office | 27,000 | 31,320 | 1.16 | 27,000 | 1.00 |
| Apartment Units | 43,600 | 71,940 | 1.65 | 71,940 | 1.65 |
| Multi-family hallway | 5,600 | 4,480 | 0.80 | 3,920 | 0.70 |
| Totals | 103,200 | 127,258 | 1.23 | 124,520 | 1.21 |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/3-software-requirements>

Links:

- [1] <http://www.comnet.org/mgp/content/321-using-spreadsheets#spreadsheets-for-verifying-standard-140-tests>
- [2] <http://www.comnet.org/mgp/content/33-modeling-assumptions-and-baseline-building-tests#prototype-buildings-for-modeling-assumptions-and-baseline-building-tests>
- [3] <http://www.comnet.org/mgp/content/331-summary-required-simulations#summary-of-analyses-for-modeling-assumptions-and-baseline-building-tests>
- [4] <http://www.comnet.org/mgp/content/332-prototypes-a1-a3-and-a20#prototypes-a1-a3-and-a20>
- [5] <http://www.comnet.org/mgp/content/333-prototypes-b1-and-c1#prototypes-b1-and-c1>

4 Content and Format of Standard Reports

4.1 Overview

This chapter provides a summary of the requisite content and format of the COMNET standard reports. The establishment of these reports will standardize the way energy modeling output data is presented to various rating authorities. By standardizing the reports, all rating authorities will be able to view the same building information and evaluate the project for certification, labeling, or tax credit.

4.1.1 Content

Building information is organized into four standard reports:

- Building Summary
- Energy Measures
- Energy Results
- Representations

The Building Summary contains basic building information such as project title, location, and size (see [Figure 4.3.1-1](#) [1]). This brief report provides essential building data at a glance. The Energy Measures report will list the design features that are different between the proposed design and the standard design (see [Figure 4.3.2-1](#) [2]). Credit is offered based on these measures. The Energy Results report will contain a summary of fuel types and end uses (see [Figure 4.3.3-1](#) [3] and [Figure 4.3.3-2](#) [4]). The Representations report will have all relevant building titles and claims (see [Figure 4.3.4-1](#) [5]).

The COMNET reports also include the data necessary to automatically populate the forms required for LEED Online credit EAc1. This includes energy use by orientation, fuel costs and other factors.

4.1.2 Format

There are two COMNET required formats for building information reports: electronic and hard copy. The electronic standard reports will be generated in XML (eXtensible Markup Language). The hard copy standard reports will be in PDF (Portable Document File). Both report formats will be automatically generated by COMNET approved software. Each page of the report will have a header with the project name and date.

4.2 Electronic Format: XML

4.2.1 Background

The electronic format of the COMNET standard reports will be XML. XML is a broadly used mechanism for describing, storing, and exchanging data. The primary function of XML is to effectively organize data and allow for it to be distributed in a platform independent format. Designating XML as the electronic format for COMNET is not intended to create more work for the user. Rather, XML supplies consistency as well as flexibility to the reporting process. XML facilitates straightforward data transfer from users to rating authorities.

The flow of information from the user (e.g. energy analyst) to the rating authority is summarized in [Figure 4.2.1-1](#) [6]. First, the user inputs the necessary building data into the interface and runs the simulation engine as usual. When the user makes a successful simulation, the COMNET software will generate an XML file and produce the standard reports. This XML file will contain all of the data relevant to a building project for the purposes of rating and tax evaluation. Finally, the XML file can be sent to a rating authority and uploaded into their database for use in certification, labeling or determining tax deductions.






Figure 4.2.1-1: "Information Flow"

4.2.2 XML File Structure

The XML data structures are simple, yet comprehensive enough for the user to ensure full transfer of all relevant building information. The four output reports (Building Summary, Energy Measures, Energy Results, and Representations) will be generated from the XML file.

The data structure is a 'many-to-one' relationship. The first structure (Project Data) is the primary or parent object. All successive structures will point back to this parent object. These successive structures have infinite input capability: the same structure can be used as many times as needed to represent the data. [Figure 4.2.1-1](#) [6] outlines the XML structures proposed for the COMNET standard. The XML format would allow for the addition of future structures to adapt to advances and innovation in energy modeling process. The sections below provide more detailed outlines of the elements within the proposed XML data structures.

The COMNET report organization is shown in the pictorial representation of the schema below. The schema contains the following reports:

- The Building Summary Report contains the project data, the stakeholder list, the list of subspaces and LEED EPA data.
- Energy Efficiency Measure Report contains a list of energy efficiency measures.
- Energy Results report contains the energy results, including a breakdown by end use. This report also includes advisory messages and override summary when defaults are overridden.
- Representation Report contains signatory information from qualified parties.

The "E" designates XML data elements, "CT" designates complex data types, and the "A" designates attributes that apply to the data element. The attribute Units is used where needed to designate units.




Figure 4.2.2-1: "COMNET High Level Report Structure"




Figure 4.2.2-2: "Building Summary Report Structure"

This contains Project Data, a list of Stakeholders and a list of Sub-Spaces.




Figure 4.2.2-3: "Energy Efficiency Measure Report Structure"






Figure 4.2.2-4: "Energy Results Report Structure"

Note that the Energy Results report contains an "Other" element to accommodate a user-defined number of other end uses not included in the list above.




Figure 4.2.2-5: "Sample end use in Energy Results Report Structure"

View of one element in the Energy Results Report – includes energy use by orientation for baseline and end use breakdown by time period.





Figure 4.2.2-6: "Representation Report Structure"

The XML Reports defined as part of the schema utilize the following data structures:






Figure 4.2.2-7: "Project Data data type"




Figure 4.2.2-8: "LEED Project Data data type"





Figure 4.2.2-9: "EPA Rating Type data type"






Figure 4.2.2-10: "Address Type and Contact Type - used in the Building Summary report"




Figure 4.2.2-11: "Stakeholder Type – used in the Building Summary and Representation report"




Figure 4.2.2-12: "Sub-Space Type – used in the Building Summary report"




Figure 4.2.2-13: "Virtual RateType – used in with LEED Online reporting"




Figure 4.2.2-14: "Energy Efficiency Measure Type"




Figure 4.2.2-15: "Energy Use And Demand – used in Energy Results Report"




Figure 4.2.2-16: "Energy Results Type – used in Energy Results Report"




Figure 4.2.2-17: "Energy Results Breakdown Type – used in Energy Results Report"




Figure 4.2.2-18: "Energy Cost Summary – in Energy Results report, used in LEED Online Reporting"




Figure 4.2.2-19: "Exceptional Calculation Type and Onsite Renewable Type – used in LEED Online Reporting"




Figure 4.2.2-20: "Rep Type and Representation Type – used in Representations Report"




Figure 4.2.2-21: "Advisory Messages Type and Override Explanation Type"

4.3 Hard Copy Format: PDF

The COMNET approved software will produce an XML file and PDF reports. The following section provides examples of the automatically generated PDF standard reports: Building Summary, Energy Measures, Energy Results, and Representations. These examples are representative of a typical report output; however, they are not exhaustive.

4.3.1 Building Summary

| | | | | | |
|-----------------------------|-------------------------|------------------------|--------------|------------|-------------|
| Trenton Office Building | | Date | Jun 25, 2009 | | Page 1 of 2 |
| Project Data Summary | | | | | |
| | | | | | |
| Project Title | Trenton Office Building | | | | |
| Address | 5467 Sunset Drive | | | | |
| City | Trenton | State | CA | Zip | 94007 |
| Stories | 2 | | | | |
| Conditioned Area | 51,889 | Unconditioned Area | 0 | Total Area | 51,889 |
| Window to Wall Ratio | 29.2 % | Skylight to Roof Ratio | 0.5 % | | |
| Principal Building Activity | Office | | | | |
| Simulation Program | VisualDOE 4.1 | | | | |
| Energy Code Used | IECC 2006 | | | | |
| Weather File | TRENTON.bin | | | | |

| | |
|-----------------|----------------|
| Currency | Site Energy |
| Utility Rate | N/A |
| Baseline Design | IECC Compliant |

Figure 4.3.1-1: "Sample of First Building Summary Page, Generated by Software"

| | | | |
|-------------------------|--|-------------------|-------------|
| Trenton Office Building | | Date Jun 25, 2009 | Page 2 of 2 |
|-------------------------|--|-------------------|-------------|

Stakeholders

Role Owner

Last Name Pramtell

First Name Michelle

Address 897 Whirlwind Road

City Brackfield State CA Zip 93652

Role Architect

Last Name Havisham

First Name William

Address 4359 Creekside Avenue

City Fenton State CA Zip 91142

Role Mechanical Engineer

Last Name Evans

First Name Katherine

Address 228 Overland Trail

City Cicely State CA Zip 98865

Figure 4.3.1-2: "Sample of Second Building Summary Page, Generated by Software"

4.3.2 Energy Measures Report

| | | | |
|-------------------------|--|------|-------------|
| Trenton Office Building | | Date | Page 1 of 1 |
|-------------------------|--|------|-------------|

Energy Measures Report

| Energy Measure Category | (User Defined) | Energy Measure Description (User Defined) | |
|-------------------------|-----------------|---|---|
| | | Baseline | Proposed |
| Envelope | Fenestration | U-value = 0.57 SHGC = 0.49 | U-value = 0.29 SHGC = 0.28 Blue tinted, low-e, insulated glazing on all orientations. |
| | Roof Insulation | R-15 | R-25 |
| | Wall Insulation | R-13 | R-13 + R-7.5 in i |

| | | | |
|----------|----------------------------|--------------------------------|---|
| | | | |
| Lighting | Lighting Power Densities | none | majority of spaces fall below the minimum requirements |
| | Occupancy Sensors | none | occupancy sensors used |
| HVAC | VFD on Chilled Water Pumps | none | variable frequency drives placed on chilled water pumps |
| | High Efficiency Chillers | 0.64 kW/ton efficiency chiller | 0.51 kW/ton high efficiency chiller |
| | High Efficiency Fan Motors | none | high efficiency fan motors used |

Figure 4.3.2-1: "Sample of First Energy Measures Page, Generated by Software"

4.3.3 Energy Results Report

| | | | |
|--|------------------|-------------------|-------------------|
| Trenton Office Building | | Date Jun 25, 2009 | Page 1 of 1 |
| Energy Results | | | |
| End Use Summary | | | |
| Currency: Source kBtu Time Period: Annual | | | |
| | Baseline (kBtu) | Proposed (kBtu) | Difference (kBtu) |
| Interior Lighting | 1,714,287 | 1,542,935 | 171,352 |
| Space Heating | 2,631,089 | 2,083,102 | 547,987 |
| Space Cooling | 1,791,255 | 1,711,089 | 80,166 |
| Pumps | 867,338 | 744,899 | 122,439 |
| Fans | 1,349,966 | 1,286,433 | 63,533 |
| Service Water Heating | 67,500 | 67,500 | 0 |
| Office Equipment | 1,285,651 | 1,285,651 | 0 |
| Total Building Consumption | 9,707,086 | 8,721,609 | 985,477 |
| Percent Savings | 10.15% | | |

Figure 4.3.3-1: "Sample First Page, Energy Results, Generated by Software"

Trenton Office Building

Date Jun 25, 2009

Page 2 of 2

Energy Results

Monthly End Use Summary, By Fuel Type

| | Electricity (kBtu) | | | | | | Gas (kBtu) | |
|-------|--------------------|---------------|---------------|---------|-----------|------------------|-----------------------|-----------|
| | Interior Lighting | Space Heating | Space Cooling | Pumps | Fans | Office Equipment | Service Water Heating | Total |
| Jan | 143,418 | 404,101 | 100,232 | 72,396 | 112,681 | 107,555 | 5,891 | 946,274 |
| Feb | 130,100 | 259,339 | 125,982 | 65,737 | 102,316 | 97,564 | 5,492 | 786,530 |
| Mar | 154,566 | 302,842 | 148,603 | 77,256 | 120,244 | 115,923 | 6,391 | 925,825 |
| Apr | 138,096 | 218,637 | 150,132 | 70,859 | 110,288 | 103,563 | 5,791 | 797,367 |
| May | 148,998 | 178,740 | 166,404 | 74,451 | 115,879 | 111,745 | 5,991 | 802,208 |
| Jun | 148,263 | 143,490 | 169,660 | 74,369 | 115,751 | 111,196 | 5,692 | 768,420 |
| Jul | 138,820 | 105,577 | 163,170 | 71,286 | 110,954 | 104,112 | 5,292 | 699,211 |
| Aug | 154,566 | 123,600 | 178,753 | 77,428 | 120,513 | 115,923 | 5,592 | 776,375 |
| Sep | 138,096 | 109,733 | 169,520 | 71,391 | 111,117 | 103,563 | 5,092 | 708,513 |
| Oct | 143,418 | 159,271 | 163,976 | 72,081 | 112,191 | 107,555 | 5,392 | 763,884 |
| Nov | 137,127 | 246,266 | 145,428 | 68,812 | 107,102 | 102,839 | 5,292 | 812,866 |
| Dec | 138,820 | 379,495 | 109,395 | 71,271 | 110,930 | 104,112 | 5,592 | 919,615 |
| Total | 1,714,287 | 2,631,089 | 1,791,255 | 867,338 | 1,349,966 | 1,285,651 | 67,500 | 9,707,086 |

Figure 4.3.3-2: "Sample of Second Page, Energy Results, Generated by Software"

4.3.4 Representations Report

**Representations
Lighting**

An installation certificate is required to be posted at the building site or made available for all appropriate inspections. (The information provided on this form is required). After completion of final inspection, a copy must be provided to the building department (upon request) and the building owner at occupancy.

Outdoor Lighting

- ☒ High Efficacy Outdoor HID luminaires contain only high efficacy lamps, luminaire has factory installed HID ballast.
- ☒ Luminaires providing outdoor lighting and permanently mounted to a building or to other buildings on the same lot shall be high efficacy luminaires OR are controlled by occupant sensors with integral photo control.
- ☒ Lighting for parking lots for 8 or more vehicles shall have compliant lighting. Lighting for parking garages for 8 or more vehicles shall also have compliant lighting.

Declaration

- ☒ I hereby certify that compliant product(s) were installed in the building at the above location.

| | | |
|----------------------------|--|--|
| Item #s (if applicable) | Name: Michelle Pramtell  | Owner Pramtell & Associates |
| | Signature Date Jun 22, 2009 | |
| Item #s (if applicable) | Name: Justin Matisse  | General Contractor Evergreen Construction |
| | Signature Date Jun 24, 2009 | |
| Item #s (if applicable) | Name: Christine Kelly  | Installing Subcontractor Kelly Lighting Co. |
| | Signature Date Jun 21, 2009 | |

Figure 4.3.4-1: "Sample Second Page, Representations, Generated by Software"

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/4-content-and-format-standard-reports>

Links:

- [1] <http://www.comnet.org/mgp/content/431-building-summary#sample-of-first-building-summary-page-generated-by-software>
- [2] <http://www.comnet.org/mgp/content/432-energy-measures-report#sample-of-first-energy-measures-page-generated-by-software>
- [3] <http://www.comnet.org/mgp/content/433-energy-results-report#sample-first-page-energy-results-generated-by-software>
- [4] <http://www.comnet.org/mgp/content/433-energy-results-report#sample-of-second-page-energy-results-generated-by-software>
- [5] <http://www.comnet.org/mgp/content/434-representations-report#sample-second-page-representations-generations-by-software>
- [6] <http://www.comnet.org/mgp/content/421-background#information-flow>

5 Energy Costs and Currency Specification

5.1 Overview

This chapter provides default time-of-use tariffs that may be used for COMNET purposes that use cost as the metric. The COMNET valuation methodology provides default time-of-use rate schedules for electricity, gas, steam and chilled water. COMNET software shall incorporate these rates into the calculation procedure so that the default rate schedules are easily available to the user. The default rates simplify the process and provide a means to take credit for measures that have large savings during peak periods. Local utility rates may be used instead of the defaults when desired. The software shall have the capability to assign energy charges for different seasons, day types, and periods within the day. A procedure is provided at the end of this chapter to convert TOU energy costs to EPA source energy, for purposes that use EPA source energy as the metric. Appendix F describes the methodology used to create the TOU energy costs presented in this chapter.

5.2 Geographic Regions

Default TOU energy costs are provided for 16 regions. These are consistent with the DOE/ASHRAE climate zones. [Figure 5.2-1](#) [1] below provides a map of the climate zones in the continental United States. Climate zone 1 is the tropical zone which includes Hawaii and the tip of Florida moving up to climate zone 8 which includes the northern arctic region of Alaska. Every county is in one unique climate zone.

There are 15 combinations of the 8 thermal zones and the 3 humidity zones. However, zone 3B is divided into two parts. Most of climate zone 3B is characterized by hot and dry summers; however, Los Angeles' climate is influenced by its coastal location. There are only five counties assumed to be in climate zone 3B (LA), Santa Barbara, Ventura, Los Angeles, Orange County, and San Diego. For each of the climate zones, the default TOU energy costs are shown in [Table 5.2-1](#) [2] through [Table 5.2-16](#) [3].




Figure 5.2-1: "United States Climate Zones"

Table 5.2-1: "Energy Cost Specification by Season and TOU Period – Climate Zone 1A"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|----------------------|----------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 12-21 | \$2.85 |
| | | | Mid-Peak | 9-11, 22-24 | \$0.91 |
| | | | Off-Peak | 1-8 | \$0.85 |
| | Fall (September-November) | Weekends/Holidays | Off-Peak | 1-24 | \$0.85 |
| | | Weekdays | Peak | 12-21 | \$1.13 |
| | | | Mid-Peak | 8-11, 22-24 | \$0.81 |
| | | | Off-Peak | 1-7 | \$0.77 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.77 |
| | Winter (December-February) | Weekdays | Peak | NA | NA |

| | | | | | |
|---------------------------|-------------------------------------|----------|-------------|--------|----------|
| February) | | | Mid-Peak | 8-23 | \$0.78 |
| | | | Off-Peak | 24-7 | \$0.71 |
| Weekends/Holidays | | | Off-Peak | 1-24 | \$0.71 |
| | | | | | |
| Spring (March-May) | Weekdays | Peak | 13-21 | \$0.96 | |
| | | Mid-Peak | 9-12, 22-23 | \$0.84 | |
| | | Off-Peak | 24-8 | \$0.77 | |
| | Weekends/Holidays | Off-Peak | 1-24 | \$0.77 | |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$9.33 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.42 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$133.74 |
| | High Demand Season (November-March) | All | All | 1-24 | \$163.80 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.15 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.41 |

Table 5.2-2: "Energy Cost Specification by Season and TOU Period – Climate Zone 2A"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|---------------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-September) | Weekdays | Peak | 14-21 | \$2.51 |
| | | | Mid-Peak | 22-1, 11-13 | \$0.85 |
| | | | Off-Peak | 2-10 | \$0.81 |
| | Fall (October-November) | Weekdays | Off-Peak | 1-24 | \$0.81 |
| | | | Peak | 13-23 | \$0.99 |
| | | | Mid-Peak | 9-12 | \$0.78 |
| | | Weekends/Holidays | Off-Peak | 24-8 | \$0.75 |
| | | | Off-Peak | 1-24 | \$0.75 |
| | | | Off-Peak | 1-24 | \$0.75 |
| | Winter (December-February) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 8-22 | \$0.85 |
| | | | Off-Peak | 23-7 | \$0.77 |
| | Spring (March-May) | Weekdays | Off-Peak | 1-24 | \$0.77 |
| | | | Peak | 13-22 | \$1.06 |
| | | | Mid-Peak | 10-12, 23-24 | \$0.87 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | Off-Peak | 1-9 | \$0.82 |
| | | | Off-Peak | 1-24 | \$0.82 |
| | High Demand Season (November-March) | All | Off-Peak | 1-24 | \$0.82 |
| | | | Off-Peak | 1-24 | \$0.82 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$123.31 |
| | High Demand Season (November-March) | All | All | 1-24 | \$169.94 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.06 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.46 |

Table 5.2-3: "Energy Cost Specification by Season and TOU Period – Climate Zone 2B"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|----------------------|----------------------|-----------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 9-21 | \$2.47 |
| | | | Mid-Peak | NA | NA |

| | | | | | |
|----------------------------|-------------------------------------|-------------------|----------|--------------|----------|
| Fall (September-November) | Weekdays | Weekdays | Off-Peak | 22-8 | \$0.74 |
| | | | Off-Peak | 1-24 | \$0.74 |
| | | | Peak | 13-21 | \$0.94 |
| | Weekends/Holidays | Weekends/Holidays | Mid-Peak | 11-12 | \$0.86 |
| | | | Off-Peak | 22-10 | \$0.79 |
| | | | Off-Peak | 1-24 | \$0.79 |
| | Weekdays | Weekdays | Off-Peak | 1-24 | \$0.79 |
| | | | Peak | 7-9, 18-22 | \$0.92 |
| | | | Mid-Peak | 10-13 | \$0.88 |
| | Weekends/Holidays | Weekends/Holidays | Off-Peak | 23-6, 14-17 | \$0.82 |
| | | | Off-Peak | 1-24 | \$0.82 |
| | | | Off-Peak | 1-24 | \$0.82 |
| Winter (December-February) | Weekdays | Weekdays | Peak | 13-21 | \$0.89 |
| | | | Mid-Peak | 10-12, 22-23 | \$0.80 |
| | | | Off-Peak | 24-9 | \$0.74 |
| | Weekends/Holidays | Weekends/Holidays | Off-Peak | 1-24 | \$0.74 |
| | | | Off-Peak | 1-24 | \$0.74 |
| | | | Off-Peak | 1-24 | \$0.74 |
| | Weekdays | Weekdays | Peak | 13-21 | \$0.89 |
| | | | Mid-Peak | 10-12, 22-23 | \$0.80 |
| | | | Off-Peak | 24-9 | \$0.74 |
| | Weekends/Holidays | Weekends/Holidays | Off-Peak | 1-24 | \$0.74 |
| | | | Off-Peak | 1-24 | \$0.74 |
| | | | Off-Peak | 1-24 | \$0.74 |
| | | | Off-Peak | 1-24 | \$0.74 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.37 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.78 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$120.05 |
| | High Demand Season (November-March) | All | All | 1-24 | \$168.88 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.03 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.45 |

Table 5.2-4: "Energy Cost Specification by Season and TOU Period – Climate Zone 3A"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|---------------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 12-19 | \$3.48 |
| | | | Mid-Peak | 8-11, 20-23 | \$0.89 |
| | | | Off-Peak | 24-7 | \$0.82 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.82 |
| | | | Off-Peak | 1-24 | \$0.82 |
| | | | Off-Peak | 1-24 | \$0.82 |
| | Fall (September-October) | Weekdays | Peak | 12-20 | \$0.91 |
| | | | Mid-Peak | 7-11, 21-22 | \$0.79 |
| | | | Off-Peak | 23-6 | \$0.76 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.76 |
| | | | Off-Peak | 1-24 | \$0.76 |
| | | | Off-Peak | 1-24 | \$0.76 |
| Gas (\$/therm) | Winter (November-February) | Weekdays | Peak | 6-11, 18-21 | \$0.84 |
| | | | Mid-Peak | 12-17 | \$0.79 |
| | | | Off-Peak | 22-5 | \$0.75 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.75 |
| | | | Off-Peak | 1-24 | \$0.75 |
| | | | Off-Peak | 1-24 | \$0.75 |
| | Spring (March-May) | Weekdays | Peak | 12-21 | \$0.97 |
| | | | Mid-Peak | 7-11 | \$0.88 |
| | | | Off-Peak | 22-6 | \$0.77 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.77 |
| | | | Off-Peak | 1-24 | \$0.77 |
| | | | Off-Peak | 1-24 | \$0.77 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$127.61 |
| | High Demand Season (November-March) | All | All | 1-24 | \$171.38 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.10 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.47 |

Table 5.2-5: "Energy Cost Specification by Season and TOU Period – Climate Zone 3B (LA)"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|---------------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 13-19 | \$3.59 |
| | | | Mid-Peak | 9-12, 20-23 | \$0.94 |
| | | | Off-Peak | 24-8 | \$0.59 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.59 |
| | Fall (September-November) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 9-22 | \$1.40 |
| | | | Off-Peak | 23-8 | \$0.71 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.71 |
| | Winter (December-March) | Weekdays | Peak | 11-15, 18-22 | \$1.04 |
| | | | Mid-Peak | 8-10, 16-17 | \$0.96 |
| | | | Off-Peak | 23-7 | \$0.72 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.72 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.77 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.22 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$125.72 |
| | High Demand Season (November-March) | All | All | 1-24 | \$160.95 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.08 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.38 |

Table 5.2-6: "Energy Cost Specification by Season and TOU Period – Climate Zone 3B"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|----------------------|-----------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-September) | Weekdays | Peak | 14-20 | \$3.60 |
| | | | Mid-Peak | 9-13, 21-22 | \$0.83 |
| | | | Off-Peak | 23-8 | \$0.71 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.71 |
| | Fall (October-November) | Weekdays | Peak | 17-21 | \$1.00 |
| | | | Mid-Peak | 7-16 | \$0.95 |
| | | | Off-Peak | 22-6 | \$0.83 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.83 |
| | Winter (December-February) | Weekdays | Peak | 17-21 | \$0.91 |
| | | | Mid-Peak | 7-16 | \$0.79 |
| | | | Off-Peak | 22-6 | \$0.75 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.75 |
| Gas (\$/therm) | Spring (March-May) | Weekdays | Peak | 12-21 | \$0.87 |
| | | | Mid-Peak | 7-11 | \$0.81 |
| | | | Off-Peak | 22-6 | \$0.73 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.73 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.90 |
| | High Demand Season | All | All | 1-24 | \$11.83 |

| | | | | | |
|------------------------------|--|-----|-----|------|----------|
| | (November-March) | | | | |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$127.68 |
| | High Demand Season (November-March) | All | All | 1-24 | \$169.57 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.10 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.46 |

Table 5.2-7: "Energy Cost Specification by Season and TOU Period – Climate Zone 3C"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|------------------------------|--|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (July-September) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 8-11, 17-18 | \$1.53 |
| | | | Off-Peak | 19-7, 12-16 | \$1.11 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$1.11 |
| | Fall (October-November) | Weekdays | Peak | 9-20 | \$0.95 |
| | | | Mid-Peak | 6-8, 21-23 | \$0.79 |
| | | | Off-Peak | 24-5 | \$0.74 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.74 |
| | Winter (December-April) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 8-22 | \$1.29 |
| | | | Off-Peak | 23-7 | \$0.77 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.77 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$9.36 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.18 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$134.26 |
| | High Demand Season (November-March) | All | All | 1-24 | \$160.36 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.15 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.38 |

Table 5.2-8: "Energy Cost Specification by Season and TOU Period – Climate Zone 4A"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|-------------------------|----------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 12-20 | \$3.41 |
| | | | Mid-Peak | 8-11, 21-23 | \$1.02 |
| | | | Off-Peak | 24-7 | \$0.83 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.83 |
| | Fall (September-November) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 7-24 | \$0.88 |
| | | | Off-Peak | 1-6 | \$0.72 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.72 |
| | Winter (December-February) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 7-20 | \$0.96 |
| | | | Off-Peak | 21-6 | \$0.83 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.83 |

| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.85 |
|---------------------------|-------------------------------------|-------------------|----------|------|----------|
| | Spring (March-May) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 8-22 | \$0.95 |
| | | | Off-Peak | 23-7 | \$0.77 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.77 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$9.07 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.99 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$130.05 |
| | High Demand Season (November-March) | All | All | 1-24 | \$171.95 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.12 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.48 |

Table 5.2-9: "Energy Cost Specification by Season and TOU Period – Climate Zone 4B"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|----------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 11-20 | \$3.04 |
| | | | Mid-Peak | 8-10, 21-22 | \$0.86 |
| | | | Off-Peak | 23-7 | \$0.85 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.85 |
| | Fall (September-October) | Weekdays | Peak | 12-20 | \$0.91 |
| | | | Mid-Peak | 7-11, 21-22 | \$0.80 |
| | | | Off-Peak | 23-6 | \$0.76 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.76 |
| | Winter (November-February) | Weekdays | Peak | 18-22 | \$0.84 |
| | | | Mid-Peak | 7-17 | \$0.81 |
| | | | Off-Peak | 23-6 | \$0.75 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.75 |
| Gas (\$/therm) | Spring (March-May) | Weekdays | Peak | 11-16, 19-21 | \$0.96 |
| | | | Mid-Peak | 7-10, 17-18 | \$0.91 |
| | | | Off-Peak | 22-6 | \$0.77 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.77 |
| | Low Demand Season (April-October) | All | All | 1-24 | \$8.33 |
| | | All | All | 1-24 | \$11.15 |
| | High Demand Season (November-March) | All | All | 1-24 | \$119.46 |
| | | All | All | 1-24 | \$159.81 |
| | Low Demand Season (April-October) | All | All | 1-24 | \$1.03 |
| | | All | All | 1-24 | \$1.37 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.03 |
| | | All | All | 1-24 | \$1.37 |

Table 5.2-10: "Energy Cost Specification by Season and TOU Period – Climate Zone 4C"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|----------------------|--------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 10-18 | \$2.25 |
| | | | Mid-Peak | 7-9, 19-23 | \$0.96 |
| | | | Off-Peak | 24-6 | \$0.64 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.64 |
| | Fall (September-October) | Weekdays | Peak | NA | NA |

| | | | | | |
|---------------------------|-------------------------------------|-------------------|----------|--------------|----------|
| | Fall (September-October) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 8-23 | \$0.91 |
| | | | Off-Peak | 24-7 | \$0.76 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.76 |
| Winter (November-March) | Weekdays | | Peak | 8-12, 17-21 | \$1.52 |
| | | | Mid-Peak | 13-16, 22-23 | \$0.95 |
| | | | Off-Peak | 24-7 | \$0.76 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.76 |
| Spring (April-May) | Weekdays | | Peak | NA | NA |
| | | | Mid-Peak | 8-23 | \$0.76 |
| | | | Off-Peak | 24-7 | \$0.60 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.60 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$9.01 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.10 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$129.13 |
| | High Demand Season (November-March) | All | All | 1-24 | \$159.20 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.11 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.37 |

Table 5.2-11: "Energy Cost Specification by Season and TOU Period – Climate Zone 5A"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|---------------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 13-21 | \$3.08 |
| | | | Mid-Peak | 10-12, 22-24 | \$1.05 |
| | | | Off-Peak | 1-9 | \$0.76 |
| | Fall (September-October) | Weekends/Holidays | Off-Peak | 1-24 | \$0.76 |
| | | Weekdays | Peak | 13-22 | \$1.07 |
| | | | Mid-Peak | 9-12 | \$0.91 |
| | | | Off-Peak | 23-8 | \$0.72 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.72 |
| | Winter (November-March) | Weekdays | Peak | 18-22 | \$1.21 |
| | | | Mid-Peak | 8-17, 23-24 | \$0.99 |
| | | | Off-Peak | 1-7 | \$0.80 |
| | Spring (April-May) | Weekdays | Off-Peak | 1-24 | \$0.80 |
| | | | Peak | 12-20 | \$1.20 |
| | | | Mid-Peak | 9-11, 21-24 | \$1.01 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.97 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.78 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$128.57 |
| | High Demand Season (November-March) | All | All | 1-24 | \$168.85 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.10 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.45 |

Table 5.2-12: "Energy Cost Specification by Season and TOU Period – Climate Zone 5B"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|---------------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 11-20 | \$2.69 |
| | | | Mid-Peak | 8-10, 21-22 | \$0.81 |
| | | | Off-Peak | 23-7 | \$0.76 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.76 |
| | Fall (September-October) | Weekdays | Peak | 13-20 | \$0.71 |
| | | | Mid-Peak | 6-12, 21-22 | \$0.61 |
| | | | Off-Peak | 23-5 | \$0.54 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.54 |
| | Winter (November-March) | Weekdays | Peak | 9-17 | \$1.10 |
| | | | Mid-Peak | 7-8, 18-23 | \$1.07 |
| | | | Off-Peak | 24-6 | \$0.93 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.93 |
| | Spring (April-May) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 7-22 | \$0.96 |
| | | | Off-Peak | 23-6 | \$0.80 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.80 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.28 |
| | High Demand Season (November-March) | All | All | 1-24 | \$10.71 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$118.69 |
| | High Demand Season (November-March) | All | All | 1-24 | \$153.51 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.02 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.32 |

Table 5.2-13: "Energy Cost Specification by Season and TOU Period – Climate Zone 6A"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|----------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 12-20 | \$3.32 |
| | | | Mid-Peak | 9-11, 21-24 | \$0.97 |
| | | | Off-Peak | 1-8 | \$0.78 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.78 |
| | Fall (September-October) | Weekdays | Peak | 12-21 | \$1.11 |
| | | | Mid-Peak | 8-11, 22-23 | \$0.84 |
| | | | Off-Peak | 24-7 | \$0.80 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.80 |
| | Winter (November-March) | Weekdays | Peak | 9-13, 18-22 | \$1.16 |
| | | | Mid-Peak | 14-17 | \$1.00 |
| | | | Off-Peak | 23-8 | \$0.83 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.83 |
| | Spring (April-May) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 8-23 | \$0.89 |
| | | | Off-Peak | 24-7 | \$0.71 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.71 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.86 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.53 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$127.02 |

| | | | | | |
|------------------------------|--|-----|-----|------|----------|
| | High Demand Season (November-March) | All | All | 1-24 | \$165.38 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.09 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.42 |

Table 5.2-14: "Energy Cost Specification by Season and TOU Period – Climate Zone 6B"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|------------------------------|--|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 12-21 | \$2.27 |
| | | | Mid-Peak | 8-11, 22-23 | \$0.79 |
| | | | Off-Peak | 24-7 | \$0.76 |
| | Fall (September-October) | Weekends/Holidays | Off-Peak | 1-24 | \$0.76 |
| | | | Peak | NA | NA |
| | | | Mid-Peak | 8-18 | \$0.84 |
| | | Weekends/Holidays | Off-Peak | 19-7 | \$0.81 |
| | | | Off-Peak | 1-24 | \$0.81 |
| | | | Off-Peak | 1-24 | \$0.81 |
| | Winter (November-March) | Weekdays | Peak | 8-11, 18-21 | \$1.44 |
| | | | Mid-Peak | 12-17 | \$0.87 |
| | | | Off-Peak | 22-7 | \$0.79 |
| | Spring (April-May) | Weekends/Holidays | Off-Peak | 1-24 | \$0.79 |
| | | | Off-Peak | 1-24 | \$0.80 |
| | | | Off-Peak | 1-24 | \$0.80 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.32 |
| | High Demand Season (November-March) | All | All | 1-24 | \$10.63 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$119.26 |
| | High Demand Season (November-March) | All | All | 1-24 | \$152.40 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.02 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.31 |

Table 5.2-15: "Energy Cost Specification by Season and TOU Period – Climate Zone 7"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|-------------------------|----------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 10-21 | \$2.48 |
| | | | Mid-Peak | 7-9, 22-23 | \$0.77 |
| | | | Off-Peak | 24-6 | \$0.62 |
| | Fall (September-September) | Weekends/Holidays | Off-Peak | 1-24 | \$0.62 |
| | | | Peak | NA | NA |
| | | | Mid-Peak | 8-21 | \$0.90 |
| | | Weekends/Holidays | Off-Peak | 22-7 | \$0.58 |
| | | | Off-Peak | 1-24 | \$0.58 |
| | | | Off-Peak | 1-24 | \$0.58 |
| | Winter (October-March) | Weekdays | Peak | 8-13, 17-22 | \$1.28 |
| | | | Mid-Peak | 14-16 | \$1.00 |
| | | | Off-Peak | 23-7 | \$0.86 |
| | Spring (April-May) | Weekends/Holidays | Off-Peak | 1-24 | \$0.86 |
| | | | Off-Peak | 1-24 | \$0.86 |
| | Spring (April-May) | Weekdays | Peak | NA | NA |
| | | | Mid-Peak | 7-21 | \$1.13 |

| | | | | | |
|---------------------------|-------------------------------------|-------------------|----------|------|----------|
| | | | Off-Peak | 22-6 | \$0.82 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.82 |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$8.95 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.41 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$128.26 |
| | High Demand Season (November-March) | All | All | 1-24 | \$163.63 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.10 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.40 |

Table 5.2-16: "Energy Cost Specification by Season and TOU Period – Climate Zone 8"

| Fuel | Seasons | Day Types | Time Periods | Hours in TOU Period (1-24) | Present Value of Energy Cost |
|---------------------------|-------------------------------------|-------------------|--------------|----------------------------|------------------------------|
| Electricity (\$/kWh) | Summer (June-August) | Weekdays | Peak | 9-23 | \$0.78 |
| | | | Mid-Peak | NA | NA |
| | | | Off-Peak | 24-8 | \$0.65 |
| | Fall (September-September) | Weekends/Holidays | Off-Peak | 1-24 | \$0.65 |
| | | Weekdays | Peak | 8-23 | \$0.79 |
| | | | Mid-Peak | NA | NA |
| | | | Off-Peak | 24-7 | \$0.68 |
| | | Weekends/Holidays | Off-Peak | 1-24 | \$0.68 |
| | Winter (October-April) | Weekdays | Peak | 8-23 | \$1.61 |
| | | | Mid-Peak | NA | NA |
| | | | Off-Peak | 24-7 | \$0.81 |
| | Spring (May-May) | Weekdays | Off-Peak | 1-24 | \$0.81 |
| | | | Peak | 9-23 | \$0.77 |
| | | | Mid-Peak | NA | NA |
| Gas (\$/therm) | Low Demand Season (April-October) | All | All | 1-24 | \$9.20 |
| | High Demand Season (November-March) | All | All | 1-24 | \$11.56 |
| Steam (\$/Mlb) | Low Demand Season (April-October) | All | All | 1-24 | \$131.93 |
| | High Demand Season (November-March) | All | All | 1-24 | \$165.76 |
| Chilled Water (\$/ton-hr) | Low Demand Season (April-October) | All | All | 1-24 | \$1.13 |
| | High Demand Season (November-March) | All | All | 1-24 | \$1.42 |

5.3 Calculating Zero Energy Performance Index (zEPI)

The zero energy performance index (zEPI) is the ratio of energy performance of the rated building to the average energy consumption of a similar building at the turn of the millennium that is operated in a similar climate, for similar hours of and similar operating conditions. zEPI is used by some rating programs and COMNET purposes. The COMNET modeling rules and procedures produce an estimate of the energy performance of the proposed design. The energy performance of the baseline building can be determined in a variety of ways. For comparison, the rated building energy performance and baseline building energy performance need to be compared in consistent units; the units are specified for each purpose. This section provides a method for converting EPA source energy to energy costs, consistent with the COMNET default tariffs.

The process, using the COMNET tariffs, is similar except that the zEPI energy efficiency ratio is calculated as the ratio of energy cost instead of source energy. The following procedure enables the energy performance of the baseline building to be converted to COMNET energy costs:

- A. Estimate the energy cost of the rated building through simulations and using the default tariffs provided in this chapter.
- B. Estimate the electricity, gas, steam and/or other fuels of the baseline building or comparator building for a similar climate and for similar operating conditions.
- C. Use the EPA source energy multipliers to convert the baseline building estimates to EPA source energy. The source-site ratio for electricity is 3.34; natural gas is 1.047; fuel oil and propane are 1.01; steam is 1.45; hot water is 1.35; chilled water is 1.05; wood, coal, coke and other fuels are 1.00. The EPA source energy multipliers are static and do not vary with season, day, or hour. ¹
- D. Convert the EPA source energy to COMNET TOU costs using the conversion factors in [Table 5.3-1](#) [4].
- E. Calculate the zEPI as the ratio of the proposed design energy costs divided by the baseline building energy costs, as determined in the previous step.

A benefit of using the COMNET tariffs for zEPI is that building features such as daylighting or thermal storage that reduce energy demand in periods when the utility grid is stressed and when more expensive generating sources are on-line are given more credit. The procedure in this section enables proper credit for thermal storage, daylighting, photovoltaic production and other measures that reduce energy consumption during peak periods.

Note that if the energy performance of the baseline building is determined through simulations, the COMNET default tariffs may be directly applied and this procedure is not applicable. Note also that some rating programs may require that the ratio of the rated building and the baseline building be compared using source energy. In this case, this procedure is also not applicable.

Table 5.3-1: "Source Energy Conversion Factors (\$/kBtu)"

²

| Climate Zone | Vacant | Office | Laboratory | Refrigerated Warehouse | Food Sales | Public Order and Safety | Outpatient Health Care | Refrigerated Warehouse | Religious Worship | Public Assembly |
|--------------|-----------|--------------|-----------------------|------------------------|------------|-------------------------|------------------------|------------------------|-------------------|-----------------|
| 1A | \$0.0944 | \$0.0929 | \$0.0928 | \$0.0956 | \$0.0892 | \$0.0932 | \$0.0937 | \$0.0939 | \$0.0911 | \$0.0921 |
| 2A | \$0.0915 | \$0.0908 | \$0.0900 | \$0.0929 | \$0.0880 | \$0.0902 | \$0.0898 | \$0.0904 | \$0.0909 | \$0.0874 |
| 2B | \$0.0936 | \$0.1020 | \$0.1022 | \$0.0935 | \$0.0895 | \$0.1025 | \$0.1024 | \$0.0922 | \$0.1015 | \$0.1016 |
| 3A | \$0.0974 | \$0.0942 | \$0.0950 | \$0.0983 | \$0.0893 | \$0.0960 | \$0.0961 | \$0.0954 | \$0.0954 | \$0.0957 |
| 3B (LA) | \$0.0967 | \$0.0981 | \$0.0980 | \$0.0980 | \$0.0916 | \$0.0981 | \$0.0981 | \$0.0978 | \$0.1003 | \$0.1003 |
| 3B | \$0.0959 | \$0.1010 | \$0.1005 | \$0.0955 | \$0.0945 | \$0.1008 | \$0.1011 | \$0.0949 | \$0.0967 | \$0.0953 |
| 3C | \$0.0919 | \$0.0922 | \$0.0926 | \$0.0916 | \$0.0878 | \$0.0922 | \$0.0921 | \$0.0901 | \$0.0947 | \$0.0948 |
| 4A | \$0.0973 | \$0.0984 | \$0.0984 | \$0.1010 | \$0.0947 | \$0.0980 | \$0.0973 | \$0.0984 | \$0.1040 | \$0.1008 |
| 4B | \$0.0928 | \$0.0932 | \$0.0938 | \$0.0958 | \$0.0906 | \$0.0930 | \$0.0930 | \$0.0959 | \$0.0986 | \$0.0956 |
| 4C | \$0.0924 | \$0.0955 | \$0.0950 | \$0.0928 | \$0.0876 | \$0.0948 | \$0.0949 | \$0.0910 | \$0.0962 | \$0.0945 |
| 5A | \$0.1007 | \$0.1029 | \$0.1031 | \$0.0951 | \$0.0964 | \$0.1056 | \$0.1021 | \$0.0942 | \$0.1010 | \$0.0987 |
| 5B | \$0.0943 | \$0.0984 | \$0.0993 | \$0.0875 | \$0.0915 | \$0.0984 | \$0.0984 | \$0.0866 | \$0.0948 | \$0.0948 |
| 6A | \$0.0998 | \$0.1014 | \$0.1016 | \$0.1030 | \$0.0961 | \$0.1012 | \$0.1024 | \$0.1019 | \$0.1018 | \$0.1022 |
| 6B | \$0.0901 | \$0.0915 | \$0.0923 | \$0.0937 | \$0.0879 | \$0.0914 | \$0.0915 | \$0.0917 | \$0.0929 | \$0.0928 |
| 7 | \$0.0994 | \$0.1013 | \$0.1015 | \$0.1027 | \$0.0957 | \$0.1011 | \$0.1024 | \$0.1020 | \$0.1032 | \$0.1041 |
| 8 | \$0.0949 | \$0.0933 | \$0.0959 | \$0.0977 | \$0.0883 | \$0.0938 | \$0.0943 | \$0.0918 | \$0.0998 | \$0.0984 |
| Climate Zone | Education | Food Service | Inpatient Health Care | Nursing | Lodging | Strip Shopping Mall | Enclosed Mall | Retail Other than Mall | Service | Other |
| 1A | \$0.0952 | \$0.0930 | \$0.0923 | \$0.0909 | \$0.0916 | \$0.0939 | \$0.0940 | \$0.0940 | \$0.0957 | \$0.0942 |
| 2A | \$0.0874 | \$0.0913 | \$0.0897 | \$0.0888 | \$0.0900 | \$0.0914 | \$0.0911 | \$0.0917 | \$0.0926 | \$0.0912 |
| 2B | \$0.1021 | \$0.0926 | \$0.0917 | \$0.0911 | \$0.0901 | \$0.0975 | \$0.0961 | \$0.0973 | \$0.0972 | \$0.0934 |
| 3A | \$0.0957 | \$0.0930 | \$0.0926 | \$0.0914 | \$0.0917 | \$0.0952 | \$0.0945 | \$0.0960 | \$0.0967 | \$0.0956 |
| 3B (LA) | \$0.1004 | \$0.0954 | \$0.0938 | \$0.0939 | \$0.0936 | \$0.0986 | \$0.0987 | \$0.0986 | \$0.0975 | \$0.0966 |
| 3B | \$0.0966 | \$0.0978 | \$0.0963 | \$0.0948 | \$0.0987 | \$0.1012 | \$0.1011 | \$0.1019 | \$0.1018 | \$0.0956 |
| 3C | \$0.0948 | \$0.0919 | \$0.0914 | \$0.0917 | \$0.0903 | \$0.0908 | \$0.0905 | \$0.0910 | \$0.0948 | \$0.0922 |
| 4A | \$0.1005 | \$0.1009 | \$0.0972 | \$0.0966 | \$0.0937 | \$0.1029 | \$0.1021 | \$0.1046 | \$0.1040 | \$0.0984 |
| 4B | \$0.0991 | \$0.0956 | \$0.0917 | \$0.0916 | \$0.0905 | \$0.0989 | \$0.0981 | \$0.0990 | \$0.0996 | \$0.0922 |
| 4C | \$0.0954 | \$0.0918 | \$0.0914 | \$0.0911 | \$0.0894 | \$0.0937 | \$0.0923 | \$0.0937 | \$0.0949 | \$0.0935 |
| 5A | \$0.1001 | \$0.1014 | \$0.1036 | \$0.1042 | \$0.0936 | \$0.1040 | \$0.1037 | \$0.1047 | \$0.1053 | \$0.1001 |
| 5B | \$0.0947 | \$0.0925 | \$0.0985 | \$0.0985 | \$0.0882 | \$0.0973 | \$0.0978 | \$0.0981 | \$0.0984 | \$0.0948 |
| 6A | \$0.1030 | \$0.0981 | \$0.0979 | \$0.0976 | \$0.0995 | \$0.1023 | \$0.1024 | \$0.1022 | \$0.1020 | \$0.0997 |
| 6B | \$0.0928 | \$0.0893 | \$0.0891 | \$0.0892 | \$0.0900 | \$0.0917 | \$0.0921 | \$0.0922 | \$0.0924 | \$0.0903 |
| 7 | \$0.1046 | \$0.0977 | \$0.0975 | \$0.0972 | \$0.0982 | \$0.1012 | \$0.1012 | \$0.1012 | \$0.1011 | \$0.0993 |
| 8 | \$0.0996 | \$0.0911 | \$0.0920 | \$0.0917 | \$0.0892 | \$0.0919 | \$0.0915 | \$0.0918 | \$0.0919 | \$0.0943 |

¹. ENERGY STAR Performance Ratings Methodology for Incorporating Source Energy use, U. S. Environmental Protection Agency.

². Source energy conversions from "ENERGY STAR Performance Ratings Methodology for Incorporating Source Energy Use", December 2007, were used to generate this table.

Links:

[1] <http://www.comnet.org/mgp/content/52-geographic-regions#united-states-climate-zones>

[2] <http://www.comnet.org/mgp/content/52-geographic-regions#energy-cost-specification-by-season-and-TOU-period---climate-zone-1A>

[3] <http://www.comnet.org/mgp/content/52-geographic-regions#energy-cost-specification-by-season-and-TOU-period---climate-zone-8>

[4] [http://www.comnet.org/mgp/content/53-calculating-zero-energy-performance-index-zepi#source-energy-conversion-factors-\(\\$/kBtu\)](http://www.comnet.org/mgp/content/53-calculating-zero-energy-performance-index-zepi#source-energy-conversion-factors-($/kBtu))

6.10 On-Site Power Generation

Building projects may incorporate other on-site electricity generation equipment, such as cogeneration plants or fuel cells that make electricity and produce heat. Projects may also include wind turbines. These systems may be modeled in various ways and the building descriptors described below should be considered an example of one set. In all cases, the baseline building will be modeled without on-site generation equipment. If there is no thermal link between the power generation equipment and building equipment (such as heat recovery from CHP), on-site power generation can be modeled in a separate process, otherwise, it needs to be linked to the building simulation.

6.10.1 Photovoltaic Systems

Candidate buildings may have photovoltaic (PV) systems and the energy generated by these systems may offset the power used by HVAC, lighting, and other building systems. Since most PV systems work under a net metering arrangement whereby the utility grid is used as a storage battery, accepting excess energy when it is available and providing power back to the building at night and other times when the PV system is not generating, the simulation of PV systems need to be on an hourly time step so that it can be aligned with the building loads and the utility rate structure.

This section describes one set of building descriptors for specifying a PV system. This set of building descriptors is based on the five-parameter model¹. Other models may be used for PV systems. The inputs apply only to the proposed design, as the baseline building is modeled without a PV system.

Configuration

This set of building descriptors addresses the overall layout and design of the PV system, including the orientation and slope of the collectors, how they are wired together, and how they are linked to an inverter that converts DC power to AC and synchronizes it with the grid.

PV System Name

| | |
|---------------------------|--|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | A unique identifier that can be used to reference the PV system and associate it with the construction documents |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | The name should provide a link to the construction documents. |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Number of Modules in a String

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | This is the number of modules in a series string. Modules in series increase voltage which is often needed in order to match output voltage with the inverter requirements; modules in parallel increase current. |
| <i>Units</i> | Numeric: integer |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Number of Strings

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | This is the number of strings of modules in parallel. Modules in series increase voltage; modules in parallel increase current. |
| <i>Units</i> | Numeric: integer |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Collector Area

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | The area of the collector module. |
| <i>Units</i> | Square feet (ft ²) |
| <i>Input Restrictions</i> | From manufacturer's specification |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Slope

| | |
|----------------------|--|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | The slope of the collector modules relative to the horizontal. |
| <i>Units</i> | Degrees (°) |

| | |
|---------------------------|---|
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Azimuth

| | |
|---------------------------|--|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | The orientation of the collector modules relative to due North. An azimuth of 180° faces due south; 90° faces east, etc. |
| <i>Units</i> | Degrees (°) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

PV Mounting Height

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | The height of the collectors above the ground. |
| <i>Units</i> | Feet (ft) |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Shading

Shading of PV systems results in significant reduction of production and must be accounted for in an acceptable manner. A method is implied in the following building descriptors that is consistent with the NSHP Calculator². With this method, the area around the solar system is divided into 22.5° cones and the height and distance to shading objects is entered for each quadrant. Other methods may be used, including use of the building shade inputs (see *building site characteristics* under *project data*)

Shading Azimuth

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | A quadrant where the height and distance of shading objects is specified. |
| <i>Units</i> | List: ENE, E, ESE, SE, SSE, S, SSW, SW, WSW, W, WNW |
| <i>Input Restrictions</i> | As estimated from existing surrounding buildings and shading structures |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Shading Object Height

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | The height of the building or shading object in the 22.5° cone |
| <i>Units</i> | Feet (ft) |
| <i>Input Restrictions</i> | As estimated from existing surrounding buildings and shading structures |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Shading Object Distance

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | The horizontal distance from the shading object to the collectors |
| <i>Units</i> | Feet (ft) |
| <i>Input Restrictions</i> | As estimated from existing surrounding buildings and shading structures |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Collector Performance

The collector performance can be characterized by the following five variables that are available from PV array manufacturers: the open-circuit voltage, the short-circuit current, the voltage and current at the maximum power-point, and the temperature coefficient of the open-circuit voltage. These are described below.

Short-circuit Current

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | I_{sc} - current measured with zero voltage |
| <i>Units</i> | Amps |
| <i>Input Restrictions</i> | From manufacturer's specification |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Open-circuit Voltage

| | |
|---------------------------|--|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | V_{oc} - voltage measured with an open circuit |
| <i>Units</i> | Volts |
| <i>Input Restrictions</i> | From manufacturer's specification |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Maximum Power-Point Voltage and Current

| | |
|----------------------|----------------|
| <i>Applicability</i> | All PV systems |
|----------------------|----------------|

| | |
|---------------------------|--|
| <i>Definition</i> | I_{mp} , V_{mp} - current and voltage at the maximum power-point condition. These parameters are typically reported at Standard Test Conditions of 1000 W/m ² and a cell temperature of 25°C. |
| <i>Units</i> | Amps and Volts |
| <i>Input Restrictions</i> | From manufacturer's specification |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Open-circuit Temperature Coefficient

| | |
|---------------------------|--|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | V_{oc} - temperature coefficient at open-circuit voltage |
| <i>Units</i> | I/C |
| <i>Input Restrictions</i> | From manufacturer's specification |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Short-circuit Temperature Coefficient

| | |
|---------------------------|---|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | V_{oc} - temperature coefficient at short-circuit current. This is supplied the manufacturer. |
| <i>Units</i> | V/C |
| <i>Input Restrictions</i> | From manufacturer's specification |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

Normal Operating Cell Temperature (NOCT)

| | |
|---------------------------|--|
| <i>Applicability</i> | All PV systems |
| <i>Definition</i> | The normal operating cell temperature, typically between 45°C and 55°C |
| <i>Units</i> | Degrees Celsius (°C) |
| <i>Input Restrictions</i> | From manufacturer's specification |
| <i>Baseline Rules</i> | None (PV not modeled for the baseline building) |

1. De Soto, W., S.A. Klein, and W.A. Beckman, "Improvement and validation of a model for photovoltaic array performance", Solar Energy, Volume 80, Issue 1, January 2006, Pages 78-88
2. More information is available at <http://www.gosolarcalifornia.ca.gov/nshp/> [1].

6.10.2 Wind Systems

Wind systems produce electricity and their output depends on the availability of wind at the project site. Wind speed and direction is contained on the climate file used for the building simulation. The building descriptors below assume that the wind turbine is free to pivot to face the wind.

System Name

| | |
|---------------------------|---|
| <i>Applicability</i> | All wind systems |
| <i>Definition</i> | A unique identifier that makes a link to the construction documents |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | None (Wind not modeled for the baseline building) |

Rated Output

| | |
|---------------------------|---|
| <i>Applicability</i> | All wind systems |
| <i>Definition</i> | The rated output of the wind turbine at a given design condition, e.g. wind speed |
| <i>Units</i> | Kilowatts (kW) |
| <i>Input Restrictions</i> | As specified by the manufacturer |
| <i>Baseline Rules</i> | None (Wind not modeled for the baseline building) |

Rate Wind Speed

| | |
|---------------------------|--|
| <i>Applicability</i> | All wind systems |
| <i>Definition</i> | The wind speed at which the rated output is measured |
| <i>Units</i> | Miles per hour (mph) |
| <i>Input Restrictions</i> | As specified by the manufacturer |
| <i>Baseline Rules</i> | None (Wind not modeled for the baseline building) |

Cut-in Wind Speed

| | |
|---------------------------|---|
| <i>Applicability</i> | All wind systems |
| <i>Definition</i> | The wind speed above which the system will produce useful power |
| <i>Units</i> | Miles per hour (mph) |
| <i>Input Restrictions</i> | As specified by the manufacturer |
| <i>Baseline Rules</i> | None (Wind not modeled for the baseline building) |

Part Load Performance

| | |
|---------------------------|---|
| <i>Applicability</i> | All wind systems |
| <i>Definition</i> | The rated capacity gives the power production at one wind speed. The part load performance will generally be a curve that gives the output for wind speeds that are greater or lower than the rated wind speed. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | As specified by the manufacturer |
| <i>Baseline Rules</i> | None (Wind not modeled for the baseline building) |

6.10.3 Cogeneration and Fuel Cells

| System Name | |
|---------------------------|---|
| <i>Applicability</i> | All cogeneration systems |
| <i>Definition</i> | A unique identifier that makes a link to the construction documents |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

| Rated Output | |
|---------------------------|---|
| <i>Applicability</i> | All cogeneration systems |
| <i>Definition</i> | The rated electric power that the cogenerator can produce |
| <i>Units</i> | Kilowatts (kW) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

| Rated Efficiency | |
|---------------------------|--|
| <i>Applicability</i> | All cogeneration systems |
| <i>Definition</i> | The efficiency of converting a fuel to electricity |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

| Heat Production Rate | |
|---------------------------|---|
| <i>Applicability</i> | All cogeneration systems |
| <i>Definition</i> | The rate of heat production at the rated output |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

| Heat Temperature | |
|---------------------------|---------------------------------------|
| <i>Applicability</i> | All cogeneration systems |
| <i>Definition</i> | The temperature of the water produced |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

| Modulation | |
|---------------------------|---|
| <i>Applicability</i> | All cogeneration systems |
| <i>Definition</i> | The capability of the cogeneration system to modulate output with corresponding modulation of input energy and waste heat |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

| Schedule | |
|---------------------------|---|
| <i>Applicability</i> | All cogeneration systems |
| <i>Definition</i> | A schedule that indicates when the cogeneration system will operate and perhaps at what capacity (if there is a means for modulation) |
| <i>Units</i> | Data structure: schedule, on/off or fractional |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/610-site-power-generation>

Links:

[1] <http://www.gosolarcalifornia.ca.gov/nshp/>

6.11 Common Data Structures

This section describes common data structures referenced in this chapter and in Appendix A. The data structures presented here define objects and example parameters needed to define them. The parameters described are the most common for energy simulation engines. However, other parameters or data constructs are acceptable. It is not the intent of COMNET to impose a single format for a data structure when alternative structures could be equally acceptable.

6.11.1 Schedule

This data structure provides information on how equipment, people, lights, or other items are operated on an hourly basis. The ultimate construct of a schedule is an hourly time series for the simulation period, typically 8,760 hours (365 days time 24 hours/day). However, software has often built up the hourly schedule from 24-hour schedules for different day types: weekdays, Saturdays, Sundays, holidays, etc.

There are several types of schedules:

- **Temperature** schedules specify a temperature to be maintained in a space, a temperature to be delivered from an air handler, or the leaving temperature from a chiller or other equipment.
- **Fraction** schedules specify the fraction of lights that are on, the fraction of people that are in the space, the fraction of maximum infiltration, or other factors.
- **On/off** schedules specify when equipment is operating or when infiltration is occurring.
- **Time period** schedules define periods of time for equipment sequencing, utility tariffs, etc. A time period schedule typically breaks the year in to two or more seasons. For each season, day types are identified such as weekday, Saturday, Sunday and holidays. Each day type in each season is then divided into time periods.

Software may accommodate any appropriate user specification of the schedule as long as the schedules listed in Appendix C are supported.

6.11.2 Holidays

A series of dates defining holidays for the simulation period. Dates identified are operated for the schedule specified for holidays.

6.11.3 Surface Geometry

This data structure represents the location, size, and position of a surface. Surfaces include roofs, walls, floors, and partitions. Surfaces are typically planar and can be represented in various manners, including the following:

- Rectangular surfaces may be represented by a height and width along with the X, Y, and Z of surface origin and the tilt and azimuth
- Surfaces may also be represented by a series of vertices (X, Y, and Z coordinates defining the perimeter of a surface). More complex polygons may be represented in this manner.

6.11.4 Opening Geometry

This data structure represents the location and size of an opening within a surface. The most common method of specifying the geometry of an opening is to identify the parent surface, the height and width of the opening, and the horizontal and vertical offset (X and Y coordinates relative to the origin of the parent surface). An opening can also include a recess into the parent surface, which provides shading. However, other geometric constructs are acceptable.

6.11.5 Opening Shade

This data structure describes the dimensions and position of external shading devices such as overhangs, side fins, or louvers that shade the opening. Overhangs are commonly specified in terms of the projection distance, height above the opening, and extension distance on each side of the opening. Side fins may be described in a similar manner. Any geometric construct is acceptable as long as it accounts for the physical and geometric relationship between the opening and the objects around it that provide shading.

6.11.6 Construction Assembly

This data structure describes the layers that make up the construction of a wall, roof, floor, or partition. Typically, a construction consists of a sequence of materials, described from the outside surface to the inside surface. A construction assembly may also be defined in terms of its U-factor and the time pattern of heat transmission related to the thermal mass.

6.11.7 Fenestration Construction

This data structure describes the frame, glass, and other features of a window or skylight. Information may be defined in multiple ways, but the criteria themselves are published as a combination of U-factor, solar heat gain coefficient (SHGC), and visible light transmission (VT). Some simulation programs use more detailed methods of describing the performance of fenestration that take into account the angle of incidence of sun striking the fenestration and other factors.

6.11.8 Material

This data structure describes a material that is used to build up a construction assembly. Typical material properties include specific heat, density, conductivity, and thickness. Materials can also be described in terms of their thermal resistance. The latter approach is sometimes used to approximate construction layers that are not homogeneous, such as framing members in combination with cavity insulation.

6.11.9 Slab Construction

This data structure describes the composition of a slab-on-grade. There are many acceptable ways to represent slabs in energy simulation models. Some models have building descriptors for the perimeter length and the F-factor, which represents the heat loss per lineal foot. Other models require that the slab surface area within two feet of the building perimeter be specified along with the interior slab area. In the latter case, coefficients of heat loss either to the air temperature, the ground temperature, or both are linked to insulation configurations.

6.11.10 Exterior Surface Properties

This data structure describes the characteristics of exterior surfaces. Exterior surface properties may include emissivity, reflectivity, and roughness. The first two govern radiation exchange from the surface, while the latter governs the magnitude of the exterior air film resistance.

6.11.11 Building Shade

This data structure describes trees, adjacent buildings, terrain, and other objects near the proposed building that would shade the building for a significant portion of the year. Exterior shading objects typically have the same properties as surfaces, e.g. the coordinates of the origin, height, width, azimuth, and tilt. They may also have transparency in terms of both SHGC and VT, and the transparency may be varied according to a schedule or algorithm.

6.11.12 Utility Rate

This data structure describes how energy costs are calculated for the consumption of a particular fuel such as electricity, gas, chilled water, or steam. A utility rate typically references a Time Period Schedule (see above). For each period, an energy cost, a peak demand charge, or other costs may be assigned.

6.11.13 Occupant Heat Rate

This data structure represents the rate of heat and moisture generated by building occupants. This is typically specified in terms of a sensible heat rate and a latent heat rate. Both are typically specified in Btu/h.

6.11.14 Furniture and Contents

This data structure represents the thermal mass effect of furniture and other building contents. This is sometimes expressed in terms of lb/ft² for the space in question.

6.11.15 Reference Position in a Space

This data structure locates a reference point in a space, typically for the purposes of daylighting control. The typical construct for the reference

This data structure locates a reference point in a space, typically for the purposes of daylighting simulation. The typical constructor for the reference point is a set of coordinates (X, Y, and Z) relative to the space coordinate system.

6.11.16 Two Dimensional Curve

This data structure explains one parameter in terms of another. An example is a curve that modifies the efficiency of an air conditioner relative to the fraction of time that the equipment operates within the period of an hour, for example. The relationship can be expressed in terms of the X and Y coordinates of points on the curve or it can be expressed as an equation.

6.11.17 Three Dimensional Curve

This data structure explains one parameter in terms of two others. An example is a curve that modifies the efficiency of an air conditioner relative to the outside air dry-bulb temperature and the wet-bulb temperature of air returning to the coil. The relationship is a three-dimensional surface and can be expressed in terms of the X and Y coordinates of points on the curve or it can be expressed as an equation.

6.11.18 Temperature Reset Schedule

This data structure describes the relationship between one temperature and another. For example, the independent variable might be outside air temperature and the dependent variable is supply air temperature. In this case, a common schedule would be to set the supply air temperature at 55°F when the outside air temperature is 80°F or warmer and at 62°F when the outside air temperature is 58°F or cooler with the supply air temperature scaling between 55°F and 62°F when the outside air temperature is between 80°F and 58°F. Temperature reset schedules can be specified in various ways.

6.11.19 Photovoltaic (PV) Panel

This data structure describes the power produced by a PV panel as a function of the solar insolation, incident angle, temperature, and other parameters.

6.11.20 Contact

This data structure describes a contact which is used to identify a stakeholder in the process, such as the architect, engineer, or owner. Information includes the name, address, email, telephone and other relevant information. See the COMNET schema for more information.

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/611-common-data-structures>

6.1 Overview

This chapter methodically goes through the building descriptors for the proposed design and the baseline building, when applicable. The baseline building must be specified for most COMNET purposes. The building descriptors discussed in this chapter are also summarized in Appendix A in a more brief and tabular form.

6.1.1 Definition of Building Descriptors

Building descriptors provide information about the proposed design and the baseline building. In this chapter, the building descriptors are discussed in the generic terms of engineering drawings and specifications. By using generic building descriptors, this manual avoids bias toward one particular energy simulation engine. The building descriptors in this chapter are consistent with commonly used simulation software. Other building descriptors may be substituted as long as the input restrictions and definition of the baseline building conditions are consistent.

Each energy simulation program has its own way of accepting building information. EnergyPlus, for instance, uses a comma delimited data file called an IDF file. DOE-2 uses BDL (building design language) to accept information. It is the responsibility of the COMNET software developer to translate the generic terms used in this chapter into the “native language” of the simulation program used by the software. [Figure 6.1.1-1](#) [1] illustrates the flow of information.




Figure 6.1.1-1: "Information Flow"

6.1.2 HVAC System Map

A baseline building is not used when COMNET is used for Design to Earn ENERGY STAR.

The HVAC system in the baseline building depends on the primary building activity, the size of the building and the energy source used for heating in the proposed design. [Figure 6.1.2-1](#) [2] shows the HVAC system types that apply in each case. Details about these systems are provided in subsequent sections.

Many of the building descriptors have a one-to-one relationship between the proposed design and the baseline building, for example, every wall in the proposed design has a corresponding wall in the baseline building. For HVAC systems, this one-to-one relationship generally does not hold. The HVAC system serving the proposed design and the baseline building may be completely different, each with different components, etc.




Figure 6.1.2-1: "HVAC Mapping"

For systems 1 through 4, each thermal block shall be served by a separate system. For systems 5 through 8, a single system serves the whole building with a separate air handler for each floor. Systems 5 and 6 are packaged equipment with DX cooling and fans combined in the same box. For these systems, each floor will have its own system.

There are several important exceptions to the HVAC mapping rules that apply to spaces with unusual internal heat gains, different schedules, special pressurization requirements, or unique outside air needs. These exceptions will typically apply to laboratories, data centers, and many spaces in healthcare facilities. See Chapter 7 for the special requirements for these building types. The exceptions are described below:

- Separate occupancies in mixed use buildings are served by separate baseline building systems. Examples include residential spaces located over retail and other similar conditions. (See the PRM, G3.1.1, Exception a.)
- A separate baseline building system shall serve laboratories or group of laboratories with an exhaust system designed for 5,000 cfm or more of air movement. The baseline building system serving the laboratory spaces shall be either system 5 (PVAV with hot water reheat) or system 6 (PVAV with parallel fan-powered boxes and electric reheat), depending on the heating source in the building. The PVAV system must be capable of reducing the exhaust and makeup air volume to 50% of design values during unoccupied periods. This exception essentially requires VAV for both the supply fan and the exhaust system. (See the PRM, G3.1.1, Exception c.)
- Spaces that do not trigger the laboratory exception above may still have a separate baseline building system. Either system 3 (PSZ-AC) or system 4 (PSZ-HP) shall serve spaces in the baseline building (depending on the heating source for the building) when one of the following conditions apply:
 - Spaces on a floor have significantly different schedules or internal heat loads. Heat gain differences of more than 10 Btu/h or operation schedule differences of more than 40 hours/week trigger this exception. (See the PRM, G3.1.1, Exception b.)
 - Spaces on a floor have "special pressurization relationships, cross-contamination requirements, or code-required minimum circulation rates". Many laboratory spaces with fume hoods would likely trigger this exception. (See the PRM, G3.1.1, Exception c.)

These special systems serve just the spaces that trigger the exceptions. The rest of the building/floor is served by the baseline building HVAC system and air handlers shown in [Figure 6.1.2-1](#) [2].

6.1.3 Organization of Information

Building descriptors are grouped under objects or building components. A wall or exterior surface (an object) would have multiple building descriptors dealing with its geometry, thermal performance, etc. Each building descriptor contains the following pieces of information.

Building Descriptor Title

| | |
|---------------------------|---|
| <i>Applicability</i> | Information on when the building descriptor applies to the proposed design |
| <i>Definition</i> | A definition for the building descriptor |
| <i>Units</i> | The units that are used to prescribe the building descriptor |
| <i>Input Restrictions</i> | Any restrictions on information that may be entered for the proposed design |
| <i>Baseline Rules</i> | How the building descriptor applies to the baseline building |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/611-overview>

Links:

- [1] <http://www.comnet.org/mgp/content/611-definition-building-descriptors#chapter-6-information-flow>
- [2] <http://www.comnet.org/mgp/content/hvac-system-map#hvac-mapping>

6.2 Project Data

6.2.1 General Information

| Project Name | |
|-----------------------------------|---|
| <i>Applicability</i> | All Projects |
| <i>Definition</i> | Name used for the project, if one is applicable |
| <i>Units</i> | Text |
| <i>Input Restrictions</i> | Input is optional for the proposed design |
| <i>Baseline Rules</i> | Not applicable |
| Project Address | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Street address, city, state, and zip code |
| <i>Units</i> | Text |
| <i>Input Restrictions</i> | Input is mandatory for the proposed design |
| <i>Baseline Rules</i> | Not applicable |
| Project Owner | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Owner(s) of the project or individual or organization for whom the building permit is sought. Information should include name, title, organization, email, and phone number |
| <i>Units</i> | Data structure: Contact |
| <i>Input Restrictions</i> | Input is optional for the proposed design |
| <i>Baseline Rules</i> | Not applicable |
| Architect | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Architect responsible for the building design. Information should include name, title, organization, email, and phone number |
| <i>Units</i> | Data structure: Contact |
| <i>Input Restrictions</i> | Input is mandatory for the proposed design |
| <i>Baseline Rules</i> | Not applicable |
| HVAC Engineer | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | HVAC Engineer responsible for the building design. Information should include name, title, organization, email, and phone number |
| <i>Units</i> | Data structure: Contact |
| <i>Input Restrictions</i> | Input is mandatory for the proposed design. Information should include name, title, organization, email, and phone number |
| <i>Baseline Rules</i> | Not applicable |
| Lighting Engineer/Designer | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Lighting Engineer/Designer responsible for the building design. Information should include name, title, organization, email, and phone number |
| <i>Units</i> | Data structure: Contact |
| <i>Input Restrictions</i> | Input is mandatory for the proposed design |
| <i>Baseline Rules</i> | Not applicable |
| Energy Modeler | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Individual responsible for performing the rating analysis. Information should include name, title, organization, email, and phone number |
| <i>Units</i> | Data structure: Contact |
| <i>Input Restrictions</i> | Input is mandatory for the proposed design |
| <i>Baseline Rules</i> | Not applicable |
| Date | |

| | |
|---------------------------|---|
| Applicability | All projects |
| Definition | Date of completion of the rating analysis or the date of its most-recent revision |
| Units | Date format |
| Input Restrictions | Input is mandatory for the proposed design |
| Baseline Rules | Not applicable |

6.2.2 Baseline Standard

| | |
|---------------------------|--|
| Purpose | |
| Applicability | All Projects |
| Definition | The purpose for which the COMNET software is used: The modeling rules and procedures for most of the building descriptors are triggered by this choice. |
| Units | List of COMNET supported purposes |
| Input Restrictions | Compulsory input |
| Baseline Rules | The definition of the baseline building is derived from this input, when applicable. |

| | |
|--------------------------------|--|
| Building Classification | |
| Applicability | When the whole building method is used instead of the space-by-space method of classifying activity in the building |
| Definition | The building type or principle activity. One of two available classification methods for identifying the function of the building or the functions of spaces within the building, which in turn determine energy-related requirements for the baseline building design. Appendix B lists the building classifications that are available under the building area method. |
| Units | List: Choose a building activity from Appendix B or select "Space-by-Space" if the space-by-space method is used. |
| Input Restrictions | For multi-use buildings, the building may be divided and a different building classification may be assigned to each part. Either the building classification method or the space-by-space classification method must be used, but the two classification methods may not be mixed within a single rating. |
| Baseline Rules | The proposed design designations apply to the baseline building. |

| | |
|---------------------------|---|
| Baseline Standard | |
| Applicability | All projects |
| Definition | The baseline standard that defines the baseline building. ASHRAE Standard 90.1-2001 is the baseline standard for tax deduction calculations. ASHRAE Standard 90.1-2007 is the baseline standard for green building ratings. This is determined from the Purpose (see above) and it may not be necessary to enter it explicitly. |
| Units | List: Either ASHRAE Standard 90.1-2001, 2007 or 2010, depending on Purpose (see above). |
| Input Restrictions | None |
| Baseline Rules | Not applicable |

| | |
|-------------------------------|--|
| Percent Savings Method | |
| Applicability | Tax deduction calculations and green building ratings |
| Definition | The method used to calculate percent savings. For tax deductions, only regulated energy is addressed in the numerator and denominator of the percent savings calculation, while with green building ratings, all energy uses in the building are accounted for. Regulated energy includes interior lighting, heating, cooling, fans and hot water. Non-regulated energy is everything else. The same equation is used with both methods (see Equation Figure 6.2.2-1 [1]), however, the Q term only includes regulated energy for tax deductions, but total energy for green building ratings. |

TeX Embedding failed!

Figure 6.2.2-1: "Percent Savings Method Equation"

| | |
|---------------------------|---|
| Units | List |
| Input Restrictions | This building descriptor is determined from the purpose and is not generally input directly by the software user. |
| Baseline Rules | Not applicable |

6.2.3 Geographic and Climate Data

The following data needs to be specified or derived in some manner. Software developers may use any acceptable method to determine the data. For instance, zip code could be entered and every thing else could be derived from this. Alternatively, state, county and city could be entered and the other variables could be derived from those. If the software allows for the parameters to be individually specified, then data validation should be employed to verify that the inputs are consistent with each other.

| | |
|----------------------|--|
| Zip Code | |
| Applicability | All projects |
| Definition | One of approximately 44,000 postal designations in the United States |

| | |
|-----------------------------------|---|
| Definition | One of approximately 1,500 postal designations in the United States |
| Units | List |
| Input Restrictions | None |
| Baseline Rules | Not applicable |
| Latitude | |
| Applicability | All projects |
| Definition | The latitude of the project site |
| Units | Degrees (°) |
| Input Restrictions | None |
| Baseline Rules | Not applicable |
| Longitude | |
| Applicability | All projects |
| Definition | The longitude of the project site |
| Units | Degrees (°) |
| Input Restrictions | None |
| Baseline Rules | Not applicable |
| Elevation | |
| Applicability | All projects |
| Definition | The height of the building site above sea level |
| Units | Feet (ft) |
| Input Restrictions | None |
| Baseline Rules | Not applicable |
| Thermal Zone | |
| Applicability | All projects |
| Definition | One of eight thermal zones defined in ASHRAE 90.1-2004 and later |
| Units | List |
| Input Restrictions | None |
| Baseline Rules | Used to determine building envelope and other criteria |
| Moisture Zone | |
| Applicability | All projects |
| Definition | One of three moisture zones defined in ASHRAE 90.1-2004 and later |
| Units | List: Moist (A), Dry (B), or Marine (C) |
| Input Restrictions | None |
| Baseline Rules | Used to determine building envelope and other criteria |
| Time Zone | |
| Applicability | All projects |
| Definition | The time zone measured from GMT |
| Units | List |
| Input Restrictions | Typically derived from other inputs such as zip code or state |
| Baseline Rules | Same time zone as the proposed design |
| Daylight Savings Time Observed | |
| Applicability | All projects |
| Definition | An indication that daylight savings time is observed. The schedules of operation are shifted by an hour twice a year and this affects the time occurrence of solar gains, temperature and other factors |
| Units | Boolean (True/False) |
| Input Restrictions | Typically derived from other inputs such as zip code or state |
| Baseline Rules | Same as the proposed design |
| State | |
| Applicability | All projects |
| Definition | The state where the project is located |
| Units | List |
| Input Restrictions | None |
| Baseline Rules | Not applicable |
| County | |

| | |
|---------------------------|---|
| Applicability | All projects |
| Definition | The county where the project is located |
| Units | List |
| Input Restrictions | None |
| Baseline Rules | Not applicable |

City

| | |
|---------------------------|---------------------------------------|
| Applicability | All projects |
| Definition | The city where the project is located |
| Units | List |
| Input Restrictions | None |
| Baseline Rules | Not applicable |

Weather Data for Simulation

| | |
|---------------------------|--|
| Applicability | All projects |
| Definition | The hourly (i.e., 8,760 hour per year) weather data to be used in performing the building energy simulations. Weather data must include outside dry-bulb temperature, outside wet-bulb temperature, atmospheric pressure, wind speed, wind direction, cloud amount, cloud type (or total horizontal solar and total direct normal solar), clearness number, ground temperature, humidity ratio, density of air, and specific enthalpy. |
| Units | Various |
| Input Restrictions | Weather data should be representative of the long term conditions at the site |
| Baseline Rules | Weather data shall be the same for both the proposed design and baseline building |

Ground Reflectance

| | |
|---------------------------|---|
| Applicability | All projects |
| Definition | Ground reflectance affects daylighting calculations and solar gain. The reflectance can be specified as a constant for the entire period of the energy simulation or it may be scheduled, which might be appropriate to account for snow cover in the winter. |
| Units | Data structure: schedule, fraction |
| Input Restrictions | Default of 0.30 |
| Baseline Rules | Ground reflectance shall be the same for both the proposed design and the baseline building when it is specified to capture snow cover. When specific design features are incorporated to increase or reduce reflectance for the purpose of enhancing daylighting, there can be variation between the proposed design and the standard design, when appropriately documented. |

6.2.4 Building Site Characteristics

Shading of Building Site

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Shading of building fenestration, roofs, or walls by other structures, surrounding terrain, vegetation, and the building itself |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | The default is for the site to be unshaded. The user may input the necessary information to model shading of the building site by any permanent object or feature likely to significantly reduce incident solar loads on the building site. Permanent here means likely to remain for the life of the building or likely to be replaced by objects that will produce similar shading over the life of the building. |
| <i>Baseline Rules</i> | The proposed and baseline building designs are modeled with identical assumptions regarding shading of the building site. |

6.2.5 Calendar

Year for Analysis

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The calendar year to be used for the annual energy simulations. This input determines the correspondence between days of the week and the days on which weather events on the weather tape occur and has no other impact. |
| <i>Units</i> | List: choose a year (other than a leap year). |
| <i>Input Restrictions</i> | Any calendar year that does not include a leap year. |
| <i>Baseline Rules</i> | Same calendar year as the proposed design |

Schedule of Holidays

| | |
|----------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | A list of dates on which holidays are observed and on which holiday schedules are used in the simulations. |

| | | |
|---------------------------|---|-----------------------------|
| <i>Definition</i> | A list of dates on which holidays are observed and on which holiday schedules are used in the simulations | |
| <i>Units</i> | Data structure | |
| <i>Input Restrictions</i> | The following ten holidays represent the default set. When a holiday falls on a Saturday, the holiday is observed on the Friday proceeding the Saturday. If the holiday falls on a Sunday, the holiday is observed on the following Monday. | |
| | New Years Day | January 1 |
| | Martin Luther King Day | Third Monday in January |
| | Presidents Day | Third Monday in February |
| | Memorial Day | Last Monday in May |
| | Independence Day | July 4 |
| | Labor Day | First Monday in September |
| | Columbus Day | Second Monday in October |
| | Veterans Day | November 11 |
| | Thanksgiving Day | Fourth Thursday in November |
| | Christmas Day | December 25 |
| | Other holiday sets may be observed when input by the user. | |
| <i>Baseline Rules</i> | The baseline building model shall observe the same holidays specified for the proposed design | |

6.2.6 Energy Price Data

Not applicable for Design to Earn ENERGY STAR.

The default energy rates for electricity and gas are shown in Chapter 5. Tables are provided for each of the thermal and moisture zones that include time-of-use rates for electricity and seasonal rates for gas, steam and chilled water.

| Currency | |
|------------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The currency used to compare the proposed design and the baseline building |
| <i>Units</i> | List: local energy costs, default time-of-use energy costs, EPA source energy, or site energy. |
| <i>Input Restrictions</i> | The default is time-of-use energy costs specified in Chapter 5. |
| <i>Baseline Rules</i> | Same as the proposed design |
| Local Electric Utility Rates | |
| <i>Applicability</i> | When Currency (see above) is "local energy costs" |
| <i>Definition</i> | The local utility rate for electricity delivered to the building. The utility rate data entered under this descriptor may include a variety of rate features, such as demand charges, time of day rates, service charges, and taxes. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | The baseline building shall use the same utility rate as the proposed design. |
| Local Gas Utility Rates | |
| <i>Applicability</i> | When Currency (see above) is "local energy costs" |
| <i>Definition</i> | The utility rates for natural gas delivered to the building. The utility rate data entered under this descriptor may include seasonal variations, service charges, and taxes. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | The baseline building shall use the same utility rate as the proposed design. |
| Local Other Utility Rates | |
| <i>Applicability</i> | When Currency (see above) is "local energy costs" |
| <i>Definition</i> | The utility rates for chilled water, steam or other energy sources delivered to the building. The utility rate data entered under this descriptor may include seasonal variations, service charges, taxes, and other factors. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | The baseline building shall use the same utility rate as the proposed design. |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/62-project-data>

Links:

[1] <http://www.comnet.org/mgp/content/622-baseline-standard#percent-savings-method-equation>

6.3 Thermal Blocks

A thermal block is a space or collection of spaces having similar space-conditioning requirements and is the basic thermal unit used in modeling the building. A thermal block can include more than one HVAC zone, but HVAC zones are not split between thermal blocks.

6.3.1 General Information

Thermal Block Name

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | A unique identifies for the thermal block |
| <i>Units</i> | Text |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

Thermal Block Description

| | |
|---------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | A brief description of the thermal block that identifies the spaces and/or zones that are included or other descriptive information. The description should tie the thermal block to the building plans. |
| <i>Units</i> | Text |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

Thermal Block Type

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Designation of the thermal block as directly conditioned space, indirectly conditioned space (i.e., conditioned only by borrowed heating or cooling from an adjacent thermal block), or plenum (i.e., unoccupied but partially conditioned as a consequence of its role as a path for returning air). |
| <i>Units</i> | List: directly conditioned, indirectly conditioned, unconditioned or plenum |
| <i>Input Restrictions</i> | The default thermal block type is “directly conditioned.” |
| <i>Baseline Rules</i> | The descriptor is identical for proposed and baseline building designs. |

System Name

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The HVAC system name of the system that serves this thermal block. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | The baseline may have a different system mapping if the baseline building has a different HVAC type than the proposed design. |

Occupancy Type

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | One of three occupancy categories used in determining the baseline building envelope requirements. The three categories are residential, nonresidential, and semi-heated. |
| <i>Units</i> | List: residential, nonresidential, or semi-heated |
| <i>Input Restrictions</i> | The input is derived from the building classification or from the classification of the spaces that make up the thermal block. |
| <i>Baseline Rules</i> | Same as the proposed design |

Floor Area

| | |
|---------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The gross floor area of a thermal block including walls and minor spaces for mechanical or electrical services, such as chases, that are not assigned to other thermal blocks; larger mechanical spaces and electrical rooms should not be combined. User input of floor areas of individual thermal blocks should be accurate to within 5% of actual, while user inputs of gross building areas should be accurate to within 2% of actual when measured to the outside surface of exterior walls. |
| <i>Units</i> | Square feet (ft ²) |
| <i>Input Restrictions</i> | The floor area of the thermal block is derived from the floor area of the individual spaces that make up the thermal block. |
| <i>Baseline Rules</i> | Identical to the proposed design |

6.3.2 Interior Lighting

Inputs for interior lighting are specified at the space level (see specification below). In those instances when thermal blocks contain just one space, the inputs here will be identical to the inputs for the single space that is contained within the thermal block.

For those instances when a thermal block contains more than one space, the software shall either model the lighting separate for each space and sum energy consumption and heat gain for each time step of the analysis or it must incorporate some procedure to sum inputs or calculate weighted averages such that the lighting data used at the thermal block level is equal to the combination of lighting data for each of the spaces contained in the thermal block.

In some cases, combining lighting data at the space level into lighting data for the thermal block may be challenging and would have to be done at the level of each time step in the simulation. These cases include:

- A thermal block that contains some spaces that have daylighting and others that do not.
- A thermal block that contains spaces with different schedules of operation.
- A thermal block that contains some spaces that have a schedule adjusted in some way for lighting controls and other spaces that do not.
- Combinations of the above.

6.3.3 Receptacle and Process Loads

Inputs for receptacle and process loads are specified at the space level (see specification below). In those instances when thermal blocks contain just one space, the inputs here will be identical to the inputs for the single space that is contained within the thermal block.

For those instances when a thermal block contains more than one space, the software shall either model the receptacle and process loads separate for each space and sum energy consumption and heat gain for each time step of the analysis or it must incorporate some procedure to sum inputs or calculate weighted averages such that the receptacle and process loads used at the thermal block level are equal to the combination of receptacle and process loads for each of the spaces contained in the thermal block.

When the spaces contained in a thermal block have different schedules, combining receptacle and process loads from the space level may be challenging and would have to be done at the level of each time step in the simulation. See discussion above on lighting.

6.3.4 Occupants

Inputs for occupant loads are specified at the space level (see specification below). In those instances when thermal blocks contain just one space, the inputs here will be identical to the inputs for the single space that is contained within the thermal block.

For those instances when a thermal block contains more than one space, the software shall either model the occupant loads separate for each space and the heat gain for each time step of the analysis or it must incorporate some procedure to sum inputs or calculate weighted averages such that the occupant loads used at the thermal block level are equal to the combination of occupant loads for each of the spaces contained in the thermal block.

When the spaces contained in a thermal block have different occupant schedules, rolling up occupant loads from the space level may be challenging and would have to be done at the level of each time step in the simulation. See discussion above on lighting.

6.3.5 Infiltration

| Infiltration Method | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Energy simulation programs have a variety of methods for modeling uncontrolled air leakage or infiltration. Some procedures use the effective leakage area which is generally applicable for small residential scale buildings. The component leakage method requires the user to specify the average leakage through the building envelope per unit area (ft ²). Other methods require the specification of a maximum rate, which is modified by a schedule. |
| <i>Units</i> | List: effective leakage area, component leakage, air changes per hour, or other method supported by the energy analysis software. |
| <i>Input Restrictions</i> | <p>For the purpose of federal tax credits, a fixed infiltration rate shall be specified and calculated as a leakage per area of exterior envelope, including the gross area of exterior walls, roofs, and exposed floors, but excluding slabs on grade and interior partitions.</p> <p>For green building ratings and Design to Earn ENERGY STAR, the default method is the component leakage method, however, there are no restrictions on other reasonable methods.</p> |
| <i>Baseline Rules</i> | The infiltration method used for the proposed design shall be used for the baseline building. |
| Infiltration Data | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Information needed to characterize the infiltration rate in buildings. The required information will depend on the infiltration |

method selected above. For the effective leakage area method, typical inputs are leakage area in ft² or other suitable units and information to indicate the height of the building and how shielded the site is from wind pressures. The air-changes per hour (ACH) method requires an estimate of the ACH and a schedule which modifies the ACH for various periods during the year. Similar data would be specified for the leakage per component area method. Only zones with exterior wall area are assumed to be subject to infiltration.

| | |
|---------------------------|--|
| <i>Units</i> | A data structure is required to define the effective leakage area model, while a single numeric value can define the ACH or the leakage per area of exterior envelope method. |
| <i>Input Restrictions</i> | For the purpose of federal tax credits, infiltration shall be equal to 0.038 times the gross wall area exposed to ambient outdoor air. For green building ratings and Design to Earn ENERGY STAR, any reasonable inputs may be specified, consistent with the chosen infiltration modeling method. Acceptable ranges for inputs should be defined for each method supported by rating software. |
| <i>Baseline Rules</i> | The infiltration data for the baseline building shall be the same as the proposed design unless the proposed design employs specific measures that go beyond the mandatory measures specified by the baseline standard. When credit is taken for reductions in infiltration (see above), test results or research reports shall be provided that document and support the inputs used for the baseline building and the proposed design. |

Infiltration Schedule

| | |
|---------------------------|--|
| <i>Applicability</i> | When an infiltration method is used that requires the specification of a schedule |
| <i>Definition</i> | With the ACH method and other methods (see above), it may be necessary to specify a schedule that modifies the infiltration rate for each hour or time step of the simulation. Typically the schedule is either on or off, but can also be fractional. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | For the purpose of federal tax credits, the infiltration schedules from Appendix C, Tables 12 through 16 shall be used. The infiltration method and rate (see above) are also specified. For green building ratings and Design to Earn ENERGY STAR, the default infiltration schedule is 1.0 (100% of specified infiltration rate for periods of time when the fans serving the thermal block are not operating and a zero [no infiltration] for periods of time when the fans are operating). This is based on the assumption that the fans pressurize the space and that the impact of introducing outside air into the thermal block is accounted for in the operation of the HVAC system. |
| <i>Baseline Rules</i> | The infiltration schedule for the baseline building shall be the same as the proposed design. |

6.3.6 Natural Ventilation

Natural ventilation may be modeled for a thermal block in the proposed design when the following conditions are met:

- The thermal block does not have an air conditioning system.
- The temperature of the thermal block does not exceed the cooling setpoint temperature for more than 300 hours for the year of the simulation with just the natural ventilation system operating.

Under these circumstances, the thermal block in the proposed design is modeled with no air conditioning when the natural ventilation system maintains temperature. For periods when the space temperature is greater than the cooling setpoint, an air conditioner like the one for the baseline building is assumed to operate to maintain temperature. The fans in this simulated system cycle with loads. The corresponding thermal block in the baseline building is modeled with air conditioning and the fans operate continuously.

Natural Ventilation Method

| | |
|---------------------------|--|
| <i>Applicability</i> | All thermal blocks with natural ventilation |
| <i>Definition</i> | The method used to model natural ventilation. The choices will depend to some extent on the capabilities of the energy simulation program. One procedure that could be used with most energy simulation programs would be to approximate the effect of natural ventilation by scheduling a high rate of infiltration when conditions are right. The schedule would typically be developed through computational fluid dynamic software or with other software that is capable of estimating the cooling benefit of natural ventilation and relating it to climate so that the schedule can be developed. |
| <i>Units</i> | List: choices depend on the capabilities of the energy simulation program. |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Baseline building is not modeled with natural ventilation. |

Air Flow Rate

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects with natural ventilation that use a method that require the specification of an air flow rate |
| <i>Definition</i> | The rate of air flow through the thermal block when the natural ventilation system is operating |
| <i>Units</i> | Air changes per hour or cfm |
| <i>Input Restrictions</i> | The air flow rate for the proposed design shall be determined using sound engineering methods and supporting documentation shall be provided. |
| <i>Baseline Rules</i> | Baseline building is not modeled with natural ventilation. |

Natural Ventilation Schedule

| | |
|----------------------|---|
| <i>Applicability</i> | All projects with natural ventilation that use a method that requires a schedule |
| <i>Definition</i> | A schedule that modifies the airflow rate through the thermal block dictates when windows can be opened to provide natural ventilation. |

| | |
|---------------------------|---|
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | The schedule for the proposed design shall be determined using sound engineering methods and keyed to outdoor temperature and perhaps other conditions on the weather file used for the simulation. |
| <i>Baseline Rules</i> | The baseline building is not modeled with natural ventilation. |

6.3.7 Thermal Mass

This set of building descriptors characterize the thermal mass that is not explicitly captured by the definition of exterior surfaces and/or interior partitions.

Thermal Response Characteristics

| | |
|---------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | <p>This building descriptor only addresses the building contents. The thermal mass associated with floors, interior walls, and other building envelope components is derived from the thermal properties and materials that make up these components. However, if interior partitions are not explicitly entered (see below) their effect may be captured with this input.</p> <p>The thermal capacitance of the building contents are typically specified in terms of the composite weight of the building contents in lb/ft² or absolute weight in lb. In this instance, the software assumes an average specific heat for the contents. This input can also be specified as the mass of the contents multiplied times the specific heat of the contents. The latter method would be a summation, since each item may have a different specific heat.</p> |
| <i>Units</i> | lb/ft ² or lb |
| <i>Input Restrictions</i> | Any reasonable inputs, consistent with the proposed design and the method used by the simulation program to model interior thermal mass |
| <i>Baseline Rules</i> | The interior thermal mass in the baseline building shall be the same as the proposed design. |

Furniture and Contents

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | A specification of the mass and heat capacity of furniture and other elements in the interior of the building. This includes information about the coverage and weight of furniture in the space as well as how much of the floor is covered by furniture. The latter affects how much of the solar gains that enters the space is directed to the floor with delayed heat gain and how much becomes a more instantaneous load. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | Any reasonable inputs, consistent with the proposed design and the method used by the simulation program to model interior thermal mass. |
| <i>Baseline Rules</i> | The interior thermal mass and modeling assumptions in the baseline building shall be the same as the proposed design. |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/63-thermal-blocks>

6.4 Space Uses

Each thermal block discussed above may be subdivided into HVAC zones and the HVAC zones may be further subdivided into space uses. This section presents the building descriptors that relate to the space uses. Space uses and the defaults associated with them are listed in Appendix B. Every thermal block shall have at least one space, as defined in this section, when the space-by-space method is used. The spaces and space uses in the baseline building shall generally be the same as the rated building, except that when daylighting is modeled in the baseline building but not the rated building, the space in the baseline building shall be divided into a daylighted portion (50%) and a non-daylighted portion (50%).

6.4.1 General Information

| Classification | |
|---------------------------|--|
| <i>Applicability</i> | When building space type uses are known and can be delineated within the building area |
| <i>Definition</i> | Space-by-space classification is one of two available classification methods for identifying the function of the building, which for most purposes determines certain energy-related requirements for the baseline and create defaults for the proposed building design. See Appendix B for a list of the building types and space types that may be selected. |
| <i>Units</i> | List: See the tables in Appendix B. If the building activity is specified by the whole building method, then this input is not applicable. |
| <i>Input Restrictions</i> | The space-by-space method is restricted to the common space types defined in Section 9 of ASHRAE 90.1 and listed in Appendix B. Detailed information about each space must be known in order for the space-by-space method to be used over the whole building method. Either method may be used, but the two may not be mixed within a single rating. |
| <i>Baseline Rules</i> | The baseline building shall have a corresponding space type for each one in the proposed design and the classifications shall be the same. |
| Floor Area | |
| <i>Applicability</i> | All projects that use the space-by-space classification method (see above) |
| <i>Definition</i> | The floor area of the space. The area of the spaces that make up a thermal block shall sum to the floor area of the thermal block. |
| <i>Units</i> | Square Feet (ft ²) |
| <i>Input Restrictions</i> | Area shall be measured to the outside of exterior walls and to the center line of partitions. |
| <i>Baseline Rules</i> | Area shall be identical to the proposed design. |

6.4.2 Occupants

| Number of Occupants | |
|---------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The number of persons in a space. The number of persons is modified by an hourly schedule (see below), which approaches but does not exceed 1.0. Therefore, the number of persons specified by the building descriptor is similar to design conditions as opposed to average occupancy. |
| <i>Units</i> | The number of persons may be specified in an absolute number, ft ² /person, or persons/1000 ft ² . |
| <i>Input Restrictions</i> | The number of occupants is prescribed for tax deductions. The number of occupants is a default for green building ratings and Design to Earn ENERGY STAR. For tax deductions, the values in Appendix B from the California 2005 ACM shall be used. Other defaults are also shown in Appendix B. |
| <i>Baseline Rules</i> | The number of occupants must be identical for both the proposed and baseline design cases. |
| Occupant Heat Rate | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The sensible and latent heat produced by each occupant in an hour. This depends on the activity level of the occupants and other factors. Heat produced by occupants must be removed by the air conditioning system as well as the outside air ventilation rate and can have a significant impact on energy consumption. |
| <i>Units</i> | Btu/h specified separately for sensible and latent gains |
| <i>Input Restrictions</i> | The occupant heat rate is prescribed for tax deductions. The occupant heat rate is a default for green building ratings and Design to Earn ENERGY STAR. For tax deductions, the values in California 2005 ACM Appendix B from the shall be used. |
| <i>Baseline Rules</i> | The occupant heat rate for the baseline building shall be the same as the proposed design. |
| Occupancy Schedule | |
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The occupancy schedule modifies the number of occupants to account for expected operational patterns in the building. The schedule adjusts the heat contribution from occupants to the space on an hourly basis to reflect time-dependent usage |

| | |
|---------------------------|---|
| | patterns. The occupancy schedule can also affect other factors such as outside air ventilation, depending on the control mechanisms specified. |
| <i>Units</i> | Data structure: schedule, fractional. |
| <i>Input Restrictions</i> | The occupant schedule is prescribed for tax deductions. The occupant schedule is a default for green building ratings and Design to Earn ENERGY STAR. For tax deductions, an appropriate schedule from Appendix C Tables 12-16 (California 2005 ACM) shall be used. |
| <i>Baseline Rules</i> | Occupancy schedules are identical for proposed and baseline building designs |

6.4.3 Interior Lighting

The building descriptors in this section are provided for each lighting system. Typically a space will have only one lighting system, but in some cases, it could have two or more. Examples include a general and task lighting system in offices or hotel multi-purpose rooms that have lighting systems for different functions.

Regulated Interior Lighting Power

| | |
|---------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Total connected lighting power for all regulated interior lighting power. This includes the loads for lamps and ballasts. |
| <i>Units</i> | W/ft ² |
| <i>Input Restrictions</i> | As designed. The connected power should be cross-referenced to a space type and to the construction documents |
| <i>Baseline Rules</i> | <p>With the building classification method, use the product of the lighting power density for the building classification from Appendix B and the floor area of the space.</p> <p>With the space-by-space method, use the product of the lighting power densities for the space-by-space from Appendix B and the floor areas for the corresponding spaces.</p> |

Non-Regulated Interior Lighting Power

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | <p>Power for the following lighting equipment and applications are exempt from the baseline standards, provided they are controlled by an independent control device:</p> <ol style="list-style-type: none"> Display or accent lighting that is an essential element for the function performed in galleries, museums, and monuments. Lighting that is integral to equipment or instrumentation and is installed by its manufacturer. Lighting specifically designed for medical or dental procedures and lighting integral to medical equipment. Lighting integral to both open and glass enclosed refrigerator and freezer cases. Lighting integral to food warming and food preparation equipment. Lighting for plant growth or maintenance. Lighting in spaces specifically designed for use by the visually impaired. Lighting in retail display windows, provided the display area is enclosed by ceiling-height partitions. Lighting in interior spaces that have been specifically designated as registered historic landmark interiors. Lighting that is an integral part of advertising or directional signage. Exit signs Lighting that is for sale or lighting educational demonstration systems. Lighting for theatrical purposes including performance, stage, motion picture or television production. Lighting for television broadcasting in sporting activity areas. Casino gaming areas. Furniture mounted supplemental task lighting that is controlled by automatic shut-off and local control (added in ASHRAE 90.1-2007). <p>In addition, lighting is exempt that is specifically designated as required by a health or life safety statute, ordinance, or regulation for reasons of safety or security.</p> <p>Emergency lighting that is automatically off during normal building operation is not considered.</p> |
| <i>Units</i> | W/ft ² |
| <i>Input Restrictions</i> | As designed. The non-regulated lighting power should be cross-referenced to the type of exception and to the construction documents. The default for non-regulated lighting power is zero. |
| <i>Baseline Rules</i> | The non-regulated interior lighting in the baseline building shall be the same as the proposed design. |

Lighting Schedules

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Schedule of operation for interior lighting power used to adjust the energy use of lighting systems on an hourly basis to reflect time-dependent patterns of lighting usage. Different schedules may be defined for different lighting circuits, depending on the capabilities of the software. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | The lighting schedule is prescribed for tax deductions. The lighting schedule is a default for green building ratings and Design to Earn ENERGY STAR. For tax deductions, an appropriate schedule from Appendix C Tables 12-16 for the California 2005 ACM shall be used. For green building ratings and Design to Earn ENERGY STAR, the default schedule |

California 2005 ASHRAE shall be used. For green building ratings and Design to Earn ENERGY STAR, the default schedules are presented in Appendix C.

Baseline Rules

The baseline building shall use the same lighting schedules as the proposed design. The only exception to this rule is when the proposed design has a task/ambient lighting system. In this case the proposed design task lighting system may be controlled on a different schedule and the proposed design schedule proposed for the ambient lighting system is used for all the lighting in the baseline building.

Retail Display Lighting Power

Applicability

Display lighting in retail display and other space-by-space classifications

Definition

Display lighting is special lighting to highlight merchandise. Its purpose is to enhance the visual appearance of the merchandise and not to provide lighting for a visual task. Display lighting is treated as use-it-or-lose-it in ASHRAE Standard 90.1. To qualify for display lighting, the lighting must be separately controlled from the general lighting.

ASHRAE Standard 90.1-2007 defines four categories of display lighting:

- Retail Area 1 (all other)
- Retail Area 2 (vehicles, sporting goods)
- Retail area 3 (furniture clothing cosmetics)
- Retail area 4 (jewelry, crystal, china).

Units

W or W/ft²

Input Restrictions

As designed. The default for lighting power for retail display wattage is 0.0 watts. When display lighting is entered in the software, its purpose shall be defined (see the categories above in the definitions section).

Baseline Rules

Baseline building lighting power is the lesser of proposed design power or the allowed power. The allowed lighting power is defined as the floor area of the retail display times the allowances in [Table 6.4.3-1](#) [1].

Table 6.4.3-1: "Lighting Power Allowances for Retail Display Lighting"

| ASHRAE Standard 90.1-2007 | | |
|---------------------------|---------------|------------------------------------|
| | Category | Allowed Power (W/ft ²) |
| | Retail Area 1 | 1.0 |
| | Retail Area 2 | 1.7 |
| | Retail Area 3 | 2.6 |
| | Retail Area 4 | 4.2 |

Decorative Lighting Power

Applicability

All projects that have decorative lighting and are rated using the space-by-space method

Definition

Decorative lighting includes wall sconces, chandeliers and other decorative lighting that is provided for purposes other than illuminating visual tasks. The baseline standards treat this lighting as use-it-or-lose-it.

Units

W or W/ft²

Input Restrictions

As designed. The default for decorative lighting power is 0.0 watts/ft². When using the space-by-space method, the user may input the power for qualifying decorative lighting using the decorative lighting power descriptor and cross-referencing the construction documents.

Baseline Rules

For the space-by-space method, decorative lighting power in the baseline building is equal to the lesser of the actual wattage of decorative lighting specified for the proposed design or 1.0 W/ft².

Lighting Power for VDT Viewing

Applicability

Tax deductions only (ASHRAE Standard 90.1-2001 baseline)

Definition

ASHRAE Standard 90.1-2001 provided additional lighting in spaces that are intended for use with video display terminals (VDT). This special allowance was eliminated with ASHRAE Standard 90.1-2007 and only applies for the purpose of calculating tax deductions.

In order for a space to qualify for the special allowance, the specified luminaires must have special optical characteristics that direct most of the light down and minimize light cast to the sides. Specifically, a qualifying luminaire must serve a VDT viewing task and provide a maximum luminance measured from the vertical of 80 candelas/ft² at 65 degrees, 33 candelas/ft² 75 degrees and 17 candelas/ft² at 85 degrees or greater.

Units

W/ft²

Input Restrictions

As designed. The default for lighting power for VDT viewing is 0.0 watts/ft². The user may input qualifying lighting power for qualifying areas with cross-references to lighting schedules and spaces on the construction documents. A cut-sheet tabulating the candela distribution of the luminaires shall be provided.

Baseline Rules

The allowed lighting power for qualifying spaces is increased by 0.35 W/ft² from the allowed values in Appendix B.

Light Heat Gain Distribution

Applicability

All projects

Definition

The distribution of the heat generated by the lighting system that is directed to the space, the plenum, the HVAC return air, or to other locations. This input is a function of the luminaire type and location. Luminaires recessed into a return air plenum contribute more of their heat to the plenum or the return air stream if the plenum is used for return air; while pendant mounted fixtures hanging in the space contribute more of their heat to the space. Common luminaire type/space configurations are listed in Table 3, Chapter 18, 2009 ASHRAE Handbook – Fundamentals, summarized in [Table 6.4.3-2](#) [2] below. Typically the data will be linked to list of common luminaire configurations similar to [Table 6.4.3-2](#) [2] so that the user chooses a luminaire type category and heat gain is automatically distributed to the appropriate locations.

This input may also be used to approximate the benefit of displacement ventilation (see Chapter 7).

| | |
|---------------------------|--|
| Units | List (of luminaire types) or data structure consisting of a series of decimal fractions that assign heat gain to various locations. |
| Input Restrictions | Default values listed in Table 6.4.3-2 [2] shall be used as a default when the luminaire categories apply. Values within the ranges of Table 6.4.3-2 [2] may be used when following the rules in the 2009 HOF. Other values may be used when manufacturers' literature and/or testing data is available, and adequate documentation is provided to the rating authority. Where lighting fixtures having different heat venting characteristics are used within a single space, the wattage weighted average heat-to-return-air fraction shall be used. |
| Baseline Rules | The baseline building shall use the above referenced defaults. |

Table 6.4.3-2: "Light Heat Gain Parameters for Typical Operating Conditions"

Source: 3, Table 3, Chapter 18, 2009 ASHRAE Handbook – Fundamentals

| Luminaire Category | Space Fraction | Radiative Fraction |
|---|-----------------------------|-----------------------------|
| Recessed fluorescent luminaire without lens | 0.64 to 0.74 (default 0.69) | 0.48 to 0.68 (default 0.58) |
| Recessed fluorescent luminaire with lens | 0.40 to 0.50 (default 0.45) | 0.61 to 0.73 (default 0.67) |
| Downlight compact fluorescent luminaire | 0.12 to 0.24 (default 0.18) | 0.95 to 1.00 (default 0.97) |
| Downlight incandescent luminaire | 0.70 to 0.80 (default 0.75) | 0.95 to 1.00 (default 0.97) |
| Non-in-ceiling fluorescent luminaire | 1.0 (default 1.0) | 0.50 to 0.57 (default 0.53) |

Power Adjustment Factors (PAF)

| | |
|---------------------------|---|
| Applicability | All projects |
| Definition | Automatic controls that are not already required by the baseline standard and which reduce lighting power more or less uniformly over the day can be modeled as power adjustment factors. Power adjustment factors represent the percent reduction in lighting power that will approximate the effect of the control. Models account for such controls by adjusting the installed power by $(1 - \text{PAF})$. The types of controls that are recognized for credit are listed in ASHRAE Standard 90.1-2007, Appendix G, Table G3.2 and shown below in Table 6.4.3-3 [3]. |
| Units | List: control types (see above) linked to PAFs |
| Input Restrictions | As designed |
| Baseline Rules | PAF is zero |

Table 6.4.3-3: "Power Adjustment Factors"

| Automatic Control Device | Non-24-hour occupied buildings that are less than 5,000 ft² | Other buildings |
|--|---|-----------------|
| Programmable timing control | 10% | 0% |
| Occupant sensor | 15% | 10% |
| Occupant sensor and programmable timing controls | 15% | 10% |
| Bi-level parking garage controls ¹ | 30% | 30% |
| Bi-level controls in hotel corridors | 20% | 20% |
| Scene controller with timeclock | 20% | 20% |

¹ Bi-level Smart LED Parking Garage Lighting, Public Interest Energy Research Program IOU Partnership Draft-Case Study
http://cltc.ucdavis.edu/images/_projects/demonstration/bi_level_smart_led_parking_garage_lighting/pier_demo_uc_csu_bi_level_smart_led_parking_garage_lighting.pdf

6.4.4 Daylighting Control

This group of building descriptors is applicable for spaces that have daylighting controls.

Daylight Modeling Method

| | |
|----------------------|--|
| Applicability | All spaces with daylighting controls |
| Definition | The method used to model daylighting. Daylighting credits must be calculated based on the local climate and daylight models of the space. Building descriptors are provided in this section for an internal daylighting model and two variations of an external daylighting model: |

1. **Internal daylighting model.** With this method, the simulation model has the capability to model the daylighting contribution for each hour of the simulation and make an adjustment to the lighting power for each hour, taking into account factors such as daylighting availability, geometry of the space, daylighting aperture, control type and the lighting system. The assumption is that the geometry of the space, the reflectance of surfaces, the size and configuration of the daylight apertures, and the light transmission of the glazing are taken from other building descriptors.
2. **External daylighting model.** An external daylighting model may be used in combination with an hourly simulation program to calculate daylighting savings as long as it produces consistent results and makes use of the key assumptions described below for internal daylighting models. Exterior daylight models include, but are not limited to, the following types of methods:
 - A. **Schedule adjustments.** With this method, a space is modeled in a stand alone daylighting program to determine the amount of interior daylight available different times of the year and for different times of the day. In addition this program has an electric lighting model that calculates the electricity savings by hour based on interior illuminance and the daylighting control type (switching, dimming etc.). These savings values are converted into a schedule of electric lighting power reduction multipliers. This lighting power reduction schedule is applied to the proposed design energy simulation model and results in reduced electric lighting energy consumption and reduced internal heat gain, both of which are reflected in the proposed design energy consumption.
 - B. **Daylight ratio.** With this method, an outside program pre-calculates a relationship between outdoor daylight conditions (illuminances or luminances) and interior illuminance. Within the rating software, interior illuminance is calculated from the daylighting ratios and the daylight conditions derived from data on the local weather file. The remainder of the calculations are the same as for an internally calculated daylight model where the interior illuminances are compared to an illuminance setpoint and electric lighting power is calculated based on control type. The two most widely used methods of pre-calculating daylighting ratios are the modified daylight factor method and the daylight coefficients method.
 - a. The modified daylight factor method uses pre-calculated diffuse and direct illuminance daylight factors and multiplies these by diffuse and direct beam outdoor illuminance from the weather file to calculate interior illuminance.¹ Daylight factors are calculated from a simulation of the space that relies on user entered information about the space modeled such as orientation, geometry, material properties (transmittances and reflectances) etc. For any given hour, the interior illuminance at the reference point is calculated by the direct beam angle specific daylight factor multiplied by the outdoor direct beam and clear sky illuminance and this is added to the overcast daylight factor multiplied by the overcast sky illuminance. Outdoor direct beam, clear sky and overcast sky illuminances are calculated from the weather data used in the proposed building energy simulation.
 - b. The daylight coefficients method is essentially a similar but more accurate method that relates internal illuminance to the luminance of patches of the sky.² The sky is divided up into patches as defined by altitude and azimuth. The daylight coefficients are ratios of interior illuminance to luminance for patches or areas on the sky dome. An outside daylight simulation program uses information about the space modeled: its orientation, geometry, material properties (transmittances and reflectances) etc, and calculates daylight coefficients for each sky patch. The precalculated daylight coefficients are then used to calculate interior illuminances for each hour. The illuminance for a location with the space at any point in time is the product of the luminance for each sky patch multiplied by the specific daylight coefficient for each sky patch integrated over the entire sky dome. The luminance for each sky patch is calculated from the weather data used in the proposed building energy simulation.

Other methods may be used by software developers as long as they produce consistent results. Regardless of the method used, it is desirable that all methods have the same key assumptions.

| | |
|---------------------------|------------------|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Lighting Schedules for Daylighting

| | |
|---------------------------|---|
| <i>Applicability</i> | Daylighted spaces that use the schedule adjustment method |
| <i>Definition</i> | A schedule that indicates the reduction in electric lighting for the lighting system that is being controlled. This schedule is applied to the lighting schedule (see above) to produce a schedule for lighting with daylighting controls. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | The schedule of adjustments should account for seasonal variations in the time of day. Since the schedule will apply for both sunny days and overcast days, the adjustments should represent the conservative condition, e.g. the smallest savings. |
| <i>Baseline Rules</i> | Baseline does not have daylighting |

Daylight Ratios

| | |
|---------------------------|---|
| <i>Applicability</i> | Daylighted spaces that use the daylight ratio method |
| <i>Definition</i> | A matrix of daylight factors for the space that represent the ratio on illumination at the daylighting reference point to the exterior illumination. The simulation engine calculates the daylighting illumination at the reference point based on this information and the exterior illumination and uses the daylighting control building descriptors to determine for each hour how the lighting power is reduced. |
| <i>Units</i> | Data structure: matrix |
| <i>Input Restrictions</i> | The special daylighting program used to calculate the daylight factors should use inputs consistent with those described below for the internal daylight model method. |

Baseline Rules The baseline building does not have daylighting

Daylighted Area

Applicability All daylighted spaces

Definition The floor area that is daylighted. Two types of daylighted areas are recognized. The primary daylighted area is the portion that is closest to the daylighting source and receives the most illumination. The secondary daylighted area is an area farther from the daylighting source, but still receives useful daylight.

Units Data structure

Input Restrictions

The default primary daylight area for sidelighting is a band near the window with a depth equal to the distance from the floor to the top of the window. The default secondary daylight area for sidelighting is a band beyond the primary daylighted area that extends a distance double the distance from the floor to the top of the window. Other daylight areas may be defined with appropriate documentation.

The default primary daylight area for toplighting is a band around the skylight well that has a depth equal to the 70% of the ceiling height. The default secondary daylight area for toplighting is a band beyond the primary daylighted area that extends 140% of the ceiling height.

Daylighted areas may not overlap or extend beyond partitions higher than 5 ft.

Error checking includes ensuring that the following is true:

Sidelit depth is less than or equal to ceiling height.

Total daylit area is no greater than space area.

Baseline Rules The baseline building does not have daylighting

Reference Position for Illuminance Calculations

Applicability Daylighted spaces that use the internal daylight model method

Definition The position of the daylight reference point within the daylighted space. Lighting controls are simulated so that the illuminance at the reference position is always above the illuminance setpoint. Thus for step switching controls, the combined daylight illuminance plus uncontrolled electric light illuminance at the reference position must be greater than the setpoint illuminance before the controlled stage of lighting can be tuned off. Similarly, dimming controls will be dimmed so that the combination of the daylight illuminance plus the controlled lighting illuminance is equal to the setpoint illuminance.

Units Data structure

Input Restrictions The reference location shall be as far away from daylight apertures as possible (but still within the daylighted area) so that all occupants have sufficient amounts of total illuminance (combined daylight and electric light) under all daylighting conditions.

Baseline Rules The baseline building does not have daylighting.

Illuminance Setpoint

Applicability Daylighted spaces that use the internal daylight model method

Definition The design illuminance for the daylighted space. The daylighting control adjusts the controlled lighting to maintain this level of illuminance at the reference point.

Units Footcandles

Input Restrictions As designed, but should be consistent with the visual tasks in the space and the recommendations of the IESNA.

Baseline Rules Baseline does not have a daylighting control.

Fraction of Controlled Lighting

Applicability Daylighted spaces that use the internal daylight model method or the daylight ratio method

Definition The fraction of the lighting power in the daylighted space that is controlled by daylight. This is applicable when some of the luminaires in the space are controlled by daylighting and others are not. This input can be eliminated if multiple lighting systems are modeled for each space and the system that is controlled by daylight is separately specified.

Units Numeric: fraction

Input Restrictions As designed

Baseline Rules Baseline does not have a daylighting control.

Daylighting Control Type

Applicability Daylighted spaces that use the internal daylight model method or the daylight ratio method

Definition

The type of control that is used to control the electric lighting in response to daylight available at the reference point. The options are:

- Step Switching controls have discrete steps of light output, where the fraction of rated power matches the fraction of light output. See [Figure 6.4.4-1](#) [4].
- Step Dimming controls also have discrete steps of light output but typically the intermediate steps of light output are associated with higher levels of fraction of rated power. When the lights are fully off or fully on, the fraction of rated power matches the fraction of light output. See [Figure 6.4.4-1](#) [4].
- Continuous Dimming controls have a fraction to rated power to fraction of rated output that is a linear interpolation of the minimum power fraction at the minimum dimming light fraction to rated power (power fraction = 1.0) at full light output. See [Figure 6.4.4-2](#) [5].
- Continuous Dimming + Off controls are the same as continuous dimming controls except that these controls can turn all the way off when none of the controlled light output is needed. See [Figure 6.4.4-2](#) [5].

all the way on when none of the controlled light output is needed. See [Figure 6.4.4-2](#) [5].




Figure 6.4.4-1: "Example Stepped Daylighting Control"




Figure 6.4.4-2: "Example Dimming Daylight Control"

| | |
|---------------------------|---|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Baseline does not have a daylighting control. |

Minimum Dimming Power Fraction

| | |
|---------------------------|---|
| <i>Applicability</i> | Daylighted spaces that use the internal daylight model method or the daylight ratio method and dimming controls |
| <i>Definition</i> | The minimum power fraction when controlled lighting is fully dimmed. Minimum power fraction = (Minimum power) / (Full rated power). See Figure 6.4.4-2 [5]. |
| <i>Units</i> | Numeric: fraction |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Baseline does not have a daylighting control. |

Minimum Dimming Light Fraction

| | |
|---------------------------|--|
| <i>Applicability</i> | Daylighted spaces that use the internal daylight model method or the daylight ratio method and dimming controls |
| <i>Definition</i> | Minimum light output of controlled lighting when fully dimmed. Minimum light fraction = (Minimum light output) / (Rated light output). See Figure 6.4.4-2 [5]. |
| <i>Units</i> | Numeric: fraction |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Baseline does not have a daylighting control. |

Number of Control Steps

| | |
|---------------------------|---|
| <i>Applicability</i> | Daylighted spaces that use the internal daylight model method or the daylight ratio method and stepped controls |
| <i>Definition</i> | Number of control steps. For step switching, this term defines even steps of light output and even steps of rated power fractions. For step dimming, identifies number of steps that require fraction of rated light output and rated power fraction. |
| <i>Units</i> | Numeric: integer |
| <i>Input Restrictions</i> | Integer less than 10. |
| <i>Baseline Rules</i> | Baseline does not have a daylighting control. |

Step Dimming Control Points

| | |
|---------------------------|---|
| <i>Applicability</i> | Daylighted spaces that use the internal daylight model method or the daylight ratio method and stepped dimming controls |
| <i>Definition</i> | Number of control steps. For step switching, this term defines even steps of light output and even steps of rated power fractions. For step dimming, identifies number of steps that require fraction of rated light output and rated power fraction. |
| <i>Units</i> | Data structure. Matched pairs of data (light output and fraction of rated power) for the defined number of control steps |
| <i>Input Restrictions</i> | Integer less than 10. More than 10 steps approximate with continuous dimming. |
| <i>Baseline Rules</i> | Baseline does not have a daylighting control. |

1. F. Winkelmann & S. Selkowitz. "Daylighting Simulation in DOE-2: Theory, Application, Validation and Applications." LBL-19829. <http://simulationresearch.lbl.gov/dirpubs/19829.pdf>
2. Tregenza P., Waters I, "Daylight coefficients", Lighting Research and Technology, 15(2), pp. 65- 71, 1983

6.4.5 Receptacle and Process Loads

Receptacle and process loads contribute to heat gains in spaces and directly use energy.

| Receptacle and Process Power | |
|--|--|
| <i>Applicability</i> | All building projects |
| <i>Definition</i> | <p>Receptacle power is power for typical general service loads in the building. Receptacle power includes equipment loads normally served through electrical receptacles, such as office equipment and printers, but does not include either task lighting or equipment used for HVAC purposes. Receptacle power values are slightly higher than the largest hourly receptacle load that is actually modeled because the receptacle power values are modified by the receptacle schedule, which approaches but does not exceed 1.0.</p> <p>Receptacle power is considered an unregulated load; no credit has been offered in the past for savings; identical conditions have been required for both the baseline building and the proposed design. Offering credit for receptacle loads is difficult due to their temporal nature and because information is not always available on what equipment will go in the building. Tenants also have the ability to plug and unplug devices leisure or switch them out for different equipment, adding to the difficulty of assigning credit for promised energy efficiency.</p> |
| <i>Units</i> | Total power (W) for the space or power density (W/ft ²) |
| <i>Input Restrictions</i> | <p>For federal tax deductions, values from the California 2005 ACM column from Appendix B shall be used as a prescribed value. For this purpose, there is no credit for reductions in receptacle loads.</p> <p>For green building ratings and Design to Earn ENERGY STAR, receptacle loads in the proposed design may be calculated in one of three ways:</p> <ol style="list-style-type: none"> 1. The COMNET recommended defaults from Appendix B may be used, in which case the same values are used for the baseline building and there is no credit for reductions. 2. If detailed information is known, the receptacle power can be calculated using Equations (6.4.5-1) and (6.4.5-2). In this instance, the energy analyst must be able to estimate the number of personal computers, the number of printers and the number of other equipment in the space. If this detail is not available, then Method 1 above must be used. With Method 2, the multipliers in Equation (6.4.5-2) shall be equal to 1.0, e.g. no credit for reductions. 3. If detailed information is known and the owner is willing to make a long term commitment to purchase ENERGY STAR equipment, then Method 3 may be used. Method 3 is the same as Method 2, except that credit may be taken in the proposed design for reductions in receptacle power. The magnitude of the reduction depends on the length of the commitment, as determined from Table 6.4.5-3 [6]. |
| <i>Baseline Rules</i> | With Methods 1 and 2, the receptacle power in the baseline building shall be the same as the proposed design. When Method 3 is used for the proposed design, the baseline building receptacle power is established using Method 2, thereby providing a credit. |
| <i>Requirements for Long Term Commitment</i> | One of the largest hurdles is establishing accountability; savings must be verified and credible. A commitment to good behavior will have to be documented appropriately, either in leasing language, within corporate (or organizational) resolutions, or in tenant manuals to ensure that energy efficient equipment will be used not only initially but also for future replacements. The inability to make long term commitments has prevented credits from being offered, since the equipment that makes up receptacle loads is short lived and replaced frequently. It is unfortunate that buildings have been restricted in this dimension since there is significant room for saving energy, especially as state and local regulations become more stringent and some strive for zero net-energy. |
| <i>Equations for Estimating Receptacle Loads</i> | <p>This section describes the COMNET procedure for estimating receptacle and process power when detailed information is known. The procedure provides a means for taking credit for energy reductions when the owner is willing to make a long term commitment to purchase ENERGY STAR equipment. COMNET Methods 2 and 3 are based on procedures developed by NREL¹ which estimate receptacle and process power density based on a count of computers, printers and other equipment in the space. The procedure is shown in Equations (6.4.5-1) and (6.4.5-2).</p> |

(6.4.5-1)

TeX Embedding failed!

where

-
- P** is the estimated power density for the space in W/ft².
- PD_{sd}** is an estimate of receptacle power from personal computers, monitors, servers, printers and other equipment determined from Equation (6.4.5-2). Units are W/ft².
- PD_{misc}** is an estimate of miscellaneous receptacle power for equipment not specifically accounted for in PD_{sd}.

- C_{sd} is an adjustment coefficient from Appendix B, Table 2 based on the occupancy of the space. This coefficient along with PDMisc accounts for unreported equipment. Csd scales with the estimated equipment power, while PDMisc is a constant.
- d is a diversity factor from Appendix B, Table 2 based on the occupancy of the space.

(6.4.5-2)

TeX Embedding failed!

where

M_{xx} is the energy efficiency multiplier from Table 6.4.5-3 [6] for the “xx” device in question. For Method 2, M_{xx} is always unity (1.0), e.g. no credit.

N_{xx} is the number of devices in the proposed design for the “xx” device in question.

P_{xx} is the nominal mean power from Table 6.4.5-1 [7] for the “xx” device in question.

Area is the area of the space in ft².

Credit is limited to equipment where the ENERGY STAR program applies, including PCs, monitors, copiers, laser and inkjet printers, vending machines, and refrigerators. No credit is offered for equipment for which the program does not apply.

Table 6.4.5-1: "Nominal Mean Power for Surveyed Devices"

| Subscript | Mean Nominal Peak Power Levels of Surveyed Devices | CBECS Variable | Data Source | Nominal Mean Power (W) |
|-----------|--|----------------|---------------------------|------------------------|
| PC | Personal computers | PCNUM8 | Roth et al. 2002 | 55 |
| CRT | CRT personal computer monitors | PCNUM8 | Roth et al. 2002 | 90 |
| LCD | Flat personal computer monitors | PCNUM8 | Roth et al. 2002 | 25 |
| Server | Servers | SRVNUM8 | Roth et al. 2002 | 650 |
| POS | Point of sale (cash registers) | RGSTRN8 | Roth et al. 2002 | 50 |
| Las | Laser Printers | PRNTRN8 | Roth et al. 2002 | 263 |
| Ink | Ink Jet Printers | PRNTRN8 | Roth et al. 2002 | 42.5 |
| Copy | Copy machines | COPRN8 | Roth et al. 2002 | 660 |
| Refrig | Residential refrigerators | RFGRSN8 | Assumption | 350 |
| Vend | Vending machines | RFGVNN8 | Assumption; see ADL 1993) | 450 |

Table 6.4.5-2: "Credits for Energy Efficient Equipment"

The credits are based on a 4% discount rate, which is consistent with the ENERGY STAR program.

| | | Credit for Energy STAR Equipment | | | | | | | |
|-----------|---------------------------|----------------------------------|---------|---------|---------|----------|----------|----------|----------|
| Subscript | Equipment | 1 Year | 2 Years | 4 Years | 5 Years | 10 Years | 15 Years | 20 Years | 30 Years |
| PC | PC | 0.014 | 0.028 | 0.054 | 0.067 | 0.121 | 0.165 | 0.201 | 0.254 |
| CRT | CRT Monitors | 0.031 | 0.060 | 0.115 | 0.141 | 0.256 | 0.349 | 0.425 | 0.538 |
| LCD | LCD Monitors | 0.019 | 0.037 | 0.071 | 0.087 | 0.158 | 0.216 | 0.263 | 0.333 |
| Server | Servers | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| POS | POS | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| Las | Laser Printers | 0.015 | 0.029 | 0.056 | 0.069 | 0.125 | 0.171 | 0.209 | 0.264 |
| Ink | Inkjet Printers | 0.027 | 0.052 | 0.100 | 0.123 | 0.223 | 0.304 | 0.370 | 0.469 |
| Copy | Copiers | 0.004 | 0.007 | 0.014 | 0.018 | 0.032 | 0.044 | 0.053 | 0.067 |
| Refrig | Residential Refrigerators | 0.011 | 0.022 | 0.043 | 0.052 | 0.095 | 0.130 | 0.159 | 0.201 |
| Vend | Vending Machines | 0.020 | 0.039 | 0.075 | 0.092 | 0.168 | 0.229 | 0.279 | 0.353 |

Table 6.4.5-3: "Multipliers for Energy Efficient Equipment (1 – Credit)"

The credits are based on a 4% discount rate, which is consistent with the ENERGY STAR program.

| | | Multipliers for Energy Efficient Equipment (1 – Credit) | | | | | | | |
|-----------|--------------|---|---------|---------|---------|----------|----------|----------|----------|
| Subscript | Equipment | 1 Year | 2 Years | 4 Years | 5 Years | 10 Years | 15 Years | 20 Years | 30 Years |
| PC | PC | 0.014 | 0.028 | 0.054 | 0.067 | 0.121 | 0.165 | 0.201 | 0.254 |
| CRT | CRT Monitors | 0.031 | 0.060 | 0.115 | 0.141 | 0.256 | 0.349 | 0.425 | 0.538 |
| LCD | LCD Monitors | 0.019 | 0.037 | 0.071 | 0.087 | 0.158 | 0.216 | 0.263 | 0.333 |

| | | | | | | | | | |
|--------|---------------------------|-------|-------|-------|-------|-------|-------|-------|-------|
| Server | Servers | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| POS | POS | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| Las | Laser Printers | 0.015 | 0.029 | 0.056 | 0.069 | 0.125 | 0.171 | 0.209 | 0.264 |
| Ink | Inkjet Printers | 0.027 | 0.052 | 0.100 | 0.123 | 0.223 | 0.304 | 0.370 | 0.469 |
| Copy | Copiers | 0.004 | 0.007 | 0.014 | 0.018 | 0.032 | 0.044 | 0.053 | 0.067 |
| Refrig | Residential Refrigerators | 0.011 | 0.022 | 0.043 | 0.052 | 0.095 | 0.130 | 0.159 | 0.201 |
| Vend | Vending Machines | 0.020 | 0.039 | 0.075 | 0.092 | 0.168 | 0.229 | 0.279 | 0.353 |

Receptable Schedule

| | |
|---------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | Schedule for receptacle power loads used to adjust the intensity on an hourly basis to reflect time-dependent patterns of usage. |
| <i>Units</i> | Data structure: schedule, fraction |
| <i>Input Restrictions</i> | For green building ratings and Design to Earn ENERGY STAR the schedule is a default. The default schedule for green building ratings and Design to Earn ENERGY STAR is taken from Tables 1 through 11 of Appendix C. |
| <i>Baseline Rules</i> | Schedules for the baseline building shall be identical to the proposed design. |

1. Griffith, B, et. al., Methodology for Modeling Building Energy Performance across the Commercial Sector, Technical Report, (NREL/TP-550-41956, March 2008, Appendix C, Section C.14. Note that elevators and escalators have been removed from the NREL equation, since they are treated separately.

6.4.6 Commercial Refrigeration Equipment

Commercial refrigeration does not need to be modeled for calculation of tax deductions.

Commercial refrigeration equipment includes the following:

- Walk-in refrigerators
- Walk-in freezers
- Refrigerated casework

The 2008 California energy efficiency standards include refrigerated warehouses for the first time and there are plans to include walk-in refrigerators and freezers in the next update for 2011. ASHRAE has expanded the scope for Standard 90.1 to include more process energy, including commercial refrigeration. The building energy efficiency standards generally do not address commercial refrigeration, however, a recent USDOE standard scheduled to become effective in 2012 does address some of the equipment.

Walk-in refrigerators and freezers typically have remote condensers. Some refrigerated casework has remote condensers, while some have a self-contained condenser built into the unit. Refrigerated casework with built-in condensers reject heat directly to the space while remote condensers reject heat in the remote location, typically on the roof or behind the building.

Refrigerated casework can be further classified by the purpose, the type of doors and, when there are no doors, the configuration: horizontal, vertical or semi-vertical. USDOE has developed standards for refrigerated casework. [Table 6.4.6-1](#) [8] shows these classifications along with the standard level of performance, expressed in kWh/d, which depends on the class of equipment, the total display area, and the volume of the casework.

Table 6.4.6-1: "USDOE Requirements for Refrigerated Casework (kWh/d)"

Table I-1- Standard Levels For Commercial Refrigeration Equipment

| Equipment class ² | Standard level * ** (kWh/day)*** | Equipment class | Standard level * ** (kWh/day) |
|------------------------------|-------------------------------------|-----------------|----------------------------------|
| VOP.RC.M | 0.82 x TDA + 4.07 | VCT.RC.I | 0.66 x TDA + 3.05 |
| SVO.RC.M | 0.83 x TDA + 3.18 | HCT.RC.M | 0.16 x TDA + 0.13 |
| HZO.RC.M | 0.35 x TDA + 2.88 | HCT.RC.L | 0.34 x TDA + 0.26 |
| VOP.RC.L | 2.27 x TDA + 6.85 | HCT.RC.I | 0.4 x TDA + 0.31 |
| HZO.RC.L | 0.57 x TDA + 6.88 | VCS.RC.M | 0.11 x V + 0.26 |
| VCT.RC.M | 0.22 x TDA + 1.95 | VCS.RC.L | 0.23 x V + 0.54 |
| VCT.RC.L | 0.56 x TDA + 2.61 | VCS.RC.I | 0.27 x V + 0.63 |
| SOC.RC.M | 0.51 x TDA + 0.11 | HCS.RC.M | 0.11 x V + 0.26 |
| VOP.SC.M | 1.74 x TDA + 4.71 | HCS.RC.L | 0.23 x V + 0.54 |
| SVO.SC.M | 1.73 x TDA + 4.59 | HCS.RC.I | 0.27 x V + 0.63 |
| HZO.SC.M | 0.77 x TDA + 5.55 | SOC.RC.L | 1.08 x TDA + 0.22 |
| HZO.SC.L | 1.92 x TDA + 7.08 | SOC.RC.I | 1.26 x TDA + 0.26 |
| VCT.SC.I | 0.67 x TDA + 3.29 | VOP.SC.L | 4.37 x TDA + 11.82 |
| VCS.SC.I | 0.38 x V + 0.88 | VOP.SC.I | 5.55 x TDA + 15.02 |

| | | | |
|----------|-------------------|----------|--------------------|
| HCT.SC.I | 0.56 x TDA + 0.43 | SVO.SC.L | 4.34 x TDA + 11.51 |
| SVO.RC.L | 2.27 x TDA + 6.85 | SVO.SC.I | 5.52 x TDA + 14.63 |
| VOP.RC.I | 2.89 x TDA + 8.7 | HZO.SC.I | 2.44 x TDA + 9. |
| SVO.RC.I | 2.89 x TDA + 8.7 | SOC.SC.I | 1.76 x TDA + 0.36 |
| HZO.RC.I | 0.72 x TDA + 8.74 | HCS.SC.I | 0.38 x V + 0.88 |

* TDA is the total display area of the case, as measured in the Air-Conditioning and Refrigeration Institute (ARI) Standard 1200-2006, Appendix D.

** V is the volume of the case, as measured in ARI Standard 1200-2006, Appendix C.

*** Kilowatt hours per day.

² For this rulemaking, equipment class designations consist of a combination (in sequential order separated by periods) of: (1) An equipment family code (VOP=vertical open, SVO=semivertical open, HZO=horizontal open, VCT=vertical transparent doors, VCS=vertical solid doors, HCT=horizontal transparent doors, HCS=horizontal solid doors, or SOC=service over counter); (2) an operating mode code (RC=remote condensing or SC=self contained); and (3) a rating temperature code (M=medium temperature (38° F), L=low temperature (0°F), or I=ice-cream temperature (-15°F)). For example, "VOP.RC.M" refers to the "vertical open, remote condensing, medium temperature" equipment class. See discussion in section V.A.2 and chapter 3 of the TSD, market and technology assessment, for a more detailed explanation of the equipment class terminology. See table IV-2 for a list of the equipment classes by category.

Walk-in refrigerators and freezers are not covered by the USDOE standards and test procedures. COMNET default values for these are given in [Table 6.4.6-2](#) [9]. These values are expressed in W/ft² of refrigerator or freezer area. This power is assumed to occur continuously. Some walk-ins have glass display doors on one side so that products can be loaded from the back. Glass display doors increase the power requirements of walk-ins. Additional power is added when glass display doors are present. The total power for walk-in refrigerators and freezers is given in Equation (6.4.6-1).

(6.4.6-1)

TeX Embedding failed!

Where

P_{Walk-in} is the estimated power density for the walk-in refrigerator or freezer in (W)

A_{xxx} the area of the walk-in refrigerator or freezer (ft²)

N_{xxx} the number of glass display doors (unitless)

PD_{xxx} the power density of the walk-in refrigerator or freezer taken from [Table 6.4.6-2](#) [9] (W/ft²)

D_{xxx} the power associated with a glass display door for a walk-in refrigerator or freezer (W/door)

xxx subscript indicating a walk-in freezer or refrigerator (Ref or Frz)

Table 6.4.6-2: "Default Power for Walk-In Refrigerators and Freezers (W/ft²)"

Source: These values are determined using the procedures of the Heatcraft Engineering Manual, Commercial Refrigeration Cooling and Freezing Load Calculations and Reference Guide, August 2006. The EER is assumed to be 12.39 for refrigerators and 6.33 for Freezers. The specific efficiency is assumed to be 70 for refrigerators and 50 for freezers. Operating temperature is assumed to be 35 F for refrigerators and -10 F for freezers.

| Floor Area | Refrigerator | Freezer |
|--|--------------|---------|
| 100 ft ² or less | 8.0 | 16.0 |
| 101 ft ² to 250 ft ² | 6.0 | 12.0 |
| 251 ft ² to 450 ft ² | 5.0 | 9.5 |
| 451 ft ² to 650 ft ² | 4.5 | 8.0 |
| 651 ft ² to 800 ft ² | 4.0 | 7.0 |
| 801 ft ² to 1,000 ft ² | 3.5 | 6.5 |
| More than 1,000 ft ² | 3.0 | 6.0 |
| Additional Power for each Glass Display Door | 105 | 325 |

Note:

Refrigeration Modeling Method

Applicability All buildings that have commercial refrigeration for cold storage or display

Definition

The method used to estimate refrigeration energy and to model the thermal interaction with the space where casework is located. Three methods are included in this manual:

- **COMNET defaults.** With this method, the power density values provided in Appendix B, Table 6-1 are used; schedules are assumed to be continuous operation.
- **USDOE performance ratings.** With this method, the energy modeler takes inventory of the refrigerated casework in

the rated building and sums the rated energy use (typically in kWh/day). Walk-in refrigerators and freezers shall use the defaults from Equation (6.4.6-1) and the values from [Table 6.4.6-2](#) [9]. All refrigeration equipment is then assumed to operate continuously.

- **Explicit refrigeration model.** With this method, all components of the refrigeration system are explicitly modeled in DOE-2.2R or other hourly simulation program with this capability.²

The remaining building descriptors in this section apply to buildings that use either the COMNET defaults or the USDOE performance ratings.

| | |
|---------------------------|--|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Method used to model the proposed design shall be used for the baseline building. Note that credit is offered only when the <i>USDOE performance ratings</i> method is used. |

Refrigeration Power

| | |
|---------------------------|---|
| <i>Applicability</i> | All buildings that have commercial refrigeration for cold storage or display and do not use the explicit refrigeration model |
| <i>Definition</i> | Commercial refrigeration power is the average power for all commercial refrigeration equipment, assuming constant year-round operation. Equipment includes walk-in refrigerators and freezers, open refrigerated casework, and closed refrigerated casework. It does not include residential type refrigerators used in kitchenettes or refrigerated vending machines. These are covered under <i>receptacle power</i> . |
| <i>Units</i> | Kilowatts (kW) |
| <i>Input Restrictions</i> | With the <i>COMNET defaults</i> method, the values in Appendix B, Table 6 are prescribed. These values are multiplied times the floor area of the rated building to estimate the refrigeration power. With the <i>USDOE performance ratings</i> method, refrigeration power is estimated by summing the kWh/day for all the refrigeration equipment in the space and dividing by 24 hours. The refrigeration power for walk-in refrigerators and freezers is added to this value. |
| <i>Baseline Rules</i> | Refrigeration power is the same as the proposed design when the COMNET defaults are used. When the <i>USDOE performance ratings</i> method is used, refrigeration power for casework shall be determined from Table 6.4.6-1 [8]; the power for walk-in refrigerators and freezers shall be the same as the proposed design. |

Remote Condenser Fraction

| | |
|----------------------|--|
| <i>Applicability</i> | All buildings that have commercial refrigeration for cold storage or display and use the <i>COMNET defaults</i> or <i>USDOE performance ratings</i> methods |
| <i>Definition</i> | <p>The fraction of condenser heat that is rejected to the outdoors. For self-contained refrigeration casework, this value will be zero. For remote condenser systems, this value is 1.0. For combination systems, the value should be weighted according to refrigeration capacity.</p> <p>For refrigeration with self contained condensers and compressors, the heat that is removed from the space is equal to the heat that is rejected to the space, since the evaporator and condenser are both located in the same space. There may be some latent cooling associated with operation of the equipment, but this may be ignored with the <i>COMNET defaults</i> or <i>USDOE performance ratings</i> methods. The operation of self-contained refrigeration units may be approximated by adding a continuously operating electric load to the space that is equal to the energy consumption of the refrigeration units. Self-contained refrigeration units add heat to the space that must be removed by the HVAC system.</p> <p>When the condenser is remotely located, heat is removed from the space but rejected outdoors. In this case, the refrigeration equipment functions in a manner similar to a continuously running split system air conditioner. Some heat is added to the space for the evaporator fan, the anti-fog heaters and other auxiliary energy uses, but refrigeration systems with remote condensers remove more heat from the space where they are located than they add. The HVAC system must compensate for this imbalance.</p> <p>For remotely located condensers using the COMNET defaults or USDOE performance ratings methods, the heat that is removed from the space is determined as follows:</p> |

(6.4.6-2)

TeX Embedding failed!

Where

- Q** The rate of heat removal from the space due to the continuous operation of the refrigeration system (kBtu/h). A negative number means that heat is being removed from the space; a positive number means that heat is being added.
- kW** The power of the refrigeration system determined by using the COMNET defaults or the USDOE performance ratings method (kW)
- F** The remote condenser fraction (see building descriptor below) (unitless)
- COP** The coefficient of performance of the refrigeration system (unitless)

The simple approach outlined above assumes that there is no latent cooling associated with the refrigeration system. The heat addition or removal resulting from the above equation can be modeled in a number of ways, to accommodate the variety of calculation engines available. It can be scheduled if the engine can accommodate a heat removal schedule. It can be modeled as a separate, constantly running air conditioner, if the engine can accommodate two cooling systems serving the same thermal block. Other modeling techniques are acceptable as long as they are thermodynamically equivalent.

| | |
|--------------|----------|
| <i>Units</i> | Fraction |
|--------------|----------|

| | |
|---------------------------|-----------------------------|
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |

Refrigeration COP

| | |
|---------------------------|--|
| <i>Applicability</i> | All buildings that have commercial refrigeration for cold storage or display and use the <i>COMNET defaults</i> or <i>USDOE performance ratings</i> methods |
| <i>Definition</i> | The coefficient of performance of the refrigeration system. This is used only to determine the heat removed or added to the space, not to determine the refrigeration power or energy. |
| <i>Units</i> | Fraction |
| <i>Input Restrictions</i> | This value is prescribed to be 3.6 for refrigerators and 1.8 for freezers. ³ |
| <i>Baseline Rules</i> | Same as the proposed design |

Refrigeration Schedule

| | |
|---------------------------|--|
| <i>Applicability</i> | All buildings that have commercial refrigeration for cold storage or display |
| <i>Definition</i> | The schedule of operation for commercial refrigeration equipment. This is used to convert refrigeration power to energy use. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | Continuous operation is prescribed. |
| <i>Baseline Rules</i> | Same as the proposed design |

1. See Table C-43, p. 146 of NREL/TP-550-41956, Methodology for Modeling Building Energy Performance across the Commercial Sector, Technical Report, Appendix C, March 2008. The values in this report were taken from Table 8-3 of the California Commercial End-Use Survey, Consultants Report, March 2006, CEC-400-2006-005
2. Direct modeling of refrigeration equipment in buildings is not broadly supported by energy simulation programs. The simulation program that is used in most energy analysis of refrigeration equipment is DOE-2.2R, which is a proprietary and limited release version of the DOE-2.2 simulation engine used by EQuest. EnergyPlus also has refrigeration modeling capabilities. These software applications allow the user to define the configuration of equipment and to specify the performance characteristics of each piece of equipment. These applications can also account for the interaction of the equipment with the temperature and humidity of the space where it is located. The complexity and variation of input for these models makes it very difficult to specify baseline conditions. For this reason, credit for efficient refrigeration systems is not offered in COMNET Phase I when explicit refrigeration models are used.
3. These values are consistent with the assumptions for the default values for walk-ins, which assume an EER of 12.39 for refrigerators and 6.33 for freezers.

6.4.7 Elevators, Escalators and Moving Walkways

Elevators, escalators and moving walkways do not need to be modeled for calculation of tax deductions.

Elevators, escalators and moving walkways account for 3% to 5% of electric energy use in buildings.¹ Buildings up to about five to seven stories typically use hydraulic elevators because of their lower initial cost. Mid-rise buildings commonly use traction elevators with geared motors, while high-rise buildings typically use gearless systems where the motor directly drives the sheave. The energy using components include the motors and controls as well as the lighting and ventilation systems for the cabs.

Elevators are custom designed for each building. In this respect they are less like products than they are engineered systems, e.g. they are more akin to chilled water plants where the engineer chooses a chiller, a tower, pumping and other components which are field engineered into a system. The main design criteria are safety and service. Some manufacturers have focused on energy efficiency of late and introduced technologies such as advanced controls that optimize the position of cars for minimum travel and regeneration motors that become generators when a loaded car descends or an empty car rises. These technologies can result in 35% to 40% savings.²

The motors and energy using equipment is typically located within the building envelope so it produces heat that must be removed by ventilation or by air conditioning systems. In energy models, a dedicated thermal zone (elevator shaft) will typically be created and this space can be indirectly cooled (from adjacent spaces) or positively cooled.

Little information is known on how to model elevators. As engineered systems, the model would need information on the number of starts per day, the number of floors, motor and drive characteristics, and other factors. Some work has been done to develop and categorize energy models for elevators³ however for Phase I of this rules and procedures manual, a simple procedure is recommended based on a count of the number of elevators, escalators and moving walkways in the building. This data is shown in [Table 6.4.7-1](#) [10].⁴

Table 6.4.7-1: "Unit Energy Consumption Data for Elevators, Escalators and Moving Walkways"

⁵

| Mode | Elevators | | Escalators and Moving Walkways | |
|---------------------------|-------------|--------------|--------------------------------|--------------|
| | Power (W) | Annual Hours | Power (W) | Annual Hours |
| Active | 10,000 | 300 | 4,671 | 4,380 |
| Ready | 500 | 7,365 | n.a. | 0 |
| Standby | 250 | 1,095 | n.a. | 0 |
| Off | 0 | 0 | 0 | 4,380 |
| Typical Annual Energy Use | 7,000 kWh/y | | 20,500 kWh/y | |

Elevator/Escalator Power

| | |
|----------------------|--|
| <i>Applicability</i> | All buildings that have commercial elevators, escalator, or moving walkways |
| <i>Definition</i> | The power for elevators, escalators and moving walkways for different modes of operation. Elevators typically operate in |

three modes: active (when the car is moving passengers), ready (when the lighting and ventilation systems are active but the car is not moving), and standby (when the lights and ventilation systems are off). Escalators and moving walkways are either active or turned off.

| | |
|---------------------------|---|
| <i>Units</i> | W/unit |
| <i>Input Restrictions</i> | The power values from Table 6.4.7-1 [10] for different modes of operation are prescribed for the proposed design. |
| <i>Baseline Rules</i> | Same as the proposed design |

Elevator/Escalator Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All buildings that have commercial elevators, escalator, or moving walkways |
| <i>Definition</i> | The schedule of operation for elevators, escalators, and moving walkways. This is used to convert elevator/escalator power to energy use. |
| <i>Units</i> | Data structure: schedule, state |
| <i>Input Restrictions</i> | The schedule specified for the building should match the operation patterns of the building. The total number of hours for each mode of operation should match the values in Table 6.4.7-1 [10] (the default) unless documentation is provided to demonstrate that other schedules are appropriate. |
| <i>Baseline Rules</i> | Same as the proposed design |

1. Sachs, Harvey M., Opportunities for Elevator Energy Efficiency Improvements, American Council for an Energy Efficiency Economy, April 2005
2. Ibid.
3. Al-Sharif, Lutfi, Richard Peters and Rory Smith, Elevator Energy Simulation Model, Elevator World, November 2005, Volume LII, No 11
4. TIAx, Commercial and Residential Sector Miscellaneous Electricity consumption: Y20005 and Projections to 2030, Final Report to the U.S. Department of Energy's Energy Information Administration (EIA) and Decision Analysis Corporation (DAC), September 22, 2006, Reference Number D0366.
5. The TIAx report does not give energy consumption data for moving walkways. For the purposes of this manual, it is assumed to be equal to escalators.

6.4.8 Process, Gas

Commercial gas equipment does not need to be modeled for determination of tax deductions.

Commercial gas equipment includes the following:

- Ovens
- Fryers
- Grills
- Other equipment

The majority of gas equipment is located in the space and may contribute both sensible and latent heat. Gas equipment is typically modeled by specifying the rate of peak gas consumption and modifying this with a fractional schedule. Energy consumption data for gas equipment is only beginning to emerge.

Because of these limits, the COMNET procedure for commercial gas is limited in this first release of the rules and procedures. The procedure consists of prescribed power and energy values for use with both the proposed design and the baseline building. No credit for commercial gas energy efficiency features is offered.

The prescribed values are provided in Appendix B, Table 6¹. Schedules are defaulted to be continuous operation.

Gas Equipment Power

| | |
|---------------------------|---|
| <i>Applicability</i> | All buildings that have commercial gas equipment |
| <i>Definition</i> | Commercial gas power is the average power for all commercial gas equipment, assuming constant year-round operation. |
| <i>Units</i> | Btu/h-ft ² |
| <i>Input Restrictions</i> | The values in Appendix B, Table 6 are prescribed. |
| <i>Baseline Rules</i> | Same as the proposed design |

Gas Equipment Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All buildings that have commercial gas equipment |
| <i>Definition</i> | The schedule of operation for commercial gas equipment. This is used to convert gas power to energy use. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | Continuous operation is prescribed. The default values for power are based on continuous operation, although this is not realistic. |
| <i>Baseline Rules</i> | Same as the proposed design |

Gas Equipment Location

| | |
|---------------------------|--|
| <i>Applicability</i> | All buildings that have commercial gas equipment |
| <i>Definition</i> | The assumed location of the gas equipment for modeling purposes. Choices are in the space or external. |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | Same as the proposed design |

Radiation Factor

| | |
|----------------------|-------------------------------------|
| <i>Applicability</i> | Gas appliances located in the space |
|----------------------|-------------------------------------|

| | |
|---------------------------|--|
| <i>Definition</i> | The fraction of heat gain to appliance energy use |
| <i>Units</i> | Fraction |
| <i>Input Restrictions</i> | Default value is 0.15. Other values can be used when a detailed inventory of equipment is known. The override value shall be based on data in Table 5C, Chapter 18, ASHRAE HOF, 2009, or similar tested information from the manufacturer. |
| <i>Baseline Rules</i> | Same as the proposed design |

1. See Table C-43, p. 146 of NREL/TP-550-41956, Methodology for Modeling Building Energy Performance across the Commercial Sector, Technical Report, Appendix C, March 2008. The values in this report were taken from Table 8-3 of the California Commercial End-Use Survey, Consultants Report, March 2006, CEC-400-2006-005

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/64-space-uses>

Links:

- [1] <http://www.comnet.org/mgp/content/643-interior-lighting#lighting-power-allowances-for-retail-display-lighting>
- [2] <http://www.comnet.org/mgp/content/643-interior-lighting#light-heat-gain-parameters-for-typical-operating-conditions>
- [3] <http://www.comnet.org/mgp/content/643-interior-lighting#power-adjustment-factors>
- [4] <http://www.comnet.org/mgp/content/644-daylighting-control#example-stepped-daylighting-control>
- [5] <http://www.comnet.org/mgp/content/644-daylighting-control#example-dimming-daylight-control>
- [6] [http://www.comnet.org/mgp/content/receptacle-and-process-loads#multipliers-for-energy-efficient-equipment-\(1—Credit\)](http://www.comnet.org/mgp/content/receptacle-and-process-loads#multipliers-for-energy-efficient-equipment-(1—Credit))
- [7] <http://www.comnet.org/mgp/content/receptacle-and-process-loads#nominal-mean-power-for-surveyed-devices>
- [8] [http://www.comnet.org/mgp/content/commercial-refrigeration-equipment#USDOE-requirements-for-refrigerated-casework-\(kWh/d\)](http://www.comnet.org/mgp/content/commercial-refrigeration-equipment#USDOE-requirements-for-refrigerated-casework-(kWh/d))
- [9] [http://www.comnet.org/mgp/content/commercial-refrigeration-equipment#default-power-for-walk-in-refrigerators-and-freezers-\(W/ft²\)](http://www.comnet.org/mgp/content/commercial-refrigeration-equipment#default-power-for-walk-in-refrigerators-and-freezers-(W/ft²))
- [10] <http://www.comnet.org/mgp/content/elevators-escalators-and-moving-walkways#unit-energy-consumption-data-for-elevators-,escalators-and-moving-walkways>

6.5 Building Envelope Data

6.5.1 Materials

Energy simulation programs commonly define construction assemblies by listing a sequence of materials that make up that construction assembly. Appendix D has a list of standard materials that may be referenced by construction assemblies. Additional materials not listed in Appendix D may be defined as described below. Alternate methods may be used to define construction assemblies such as specifying the U-factor and optionally, a metric describing thermal mass such as *heat capacity* (HC). These alternate methods may not require identification of materials. When a material is defined, all of the properties listed below must be defined. Some materials listed in Appendix D are non-homogeneous, for instance, framing members with insulation in the cavity.

Material Name

| | |
|---------------------------|---|
| <i>Applicability</i> | When construction assemblies reference materials that are not standard |
| <i>Definition</i> | The name of a construction material used in the exterior envelope of the building |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | Material name is a required input for materials not available from the standard list. The user may not modify entries for predefined materials. |
| <i>Baseline Rules</i> | Not applicable |

Density

| | |
|---------------------------|---|
| <i>Applicability</i> | All non-standard materials |
| <i>Definition</i> | The density (or mass per unit of volume) of the construction material as documented in an ASHRAE handbook, a comparably reliable reference, or manufacturers' literature. |
| <i>Units</i> | Numeric input: lb/ft ³ |
| <i>Input Restrictions</i> | Density is a required input when non-standard materials are specified. |
| <i>Baseline Rules</i> | Not applicable |

Specific Heat

| | |
|---------------------------|--|
| <i>Applicability</i> | All non-standard materials |
| <i>Definition</i> | The specific heat capacity of a material is numerically equal to the quantity of heat that must be supplied to a unit mass of the material to increase its temperature by 1 degree F. |
| <i>Units</i> | Btu/lb•°F |
| <i>Input Restrictions</i> | Specific heat is a required input when non-standard materials are specified. The specific heat capacity of the construction material as documented in an ASHRAE handbook, a comparably reliable reference, or manufacturers' literature. |
| <i>Baseline Rules</i> | Not applicable |

Thermal Conductivity

| | |
|---------------------------|--|
| <i>Applicability</i> | All non-standard materials |
| <i>Definition</i> | The thermal conductivity of a material of unit thickness is numerically equal to the quantity of heat that will flow through a unit area of the material when the temperature difference through the material is 1 degree F. |
| <i>Units</i> | Btu/h•ft•°F |
| <i>Input Restrictions</i> | Thermal conductivity is a required input for non-standard materials. |
| <i>Baseline Rules</i> | Not applicable |

Thickness

| | |
|---------------------------|---|
| <i>Applicability</i> | All non-standard materials |
| <i>Definition</i> | The thickness of a material |
| <i>Units</i> | ft or in. (cm) |
| <i>Input Restrictions</i> | Thickness is a required input for non-standard materials. The user shall document the data source for thermal conductivity used for additional materials under the <i>material name</i> descriptor. |
| <i>Baseline Rules</i> | Not applicable |

6.5.2 Construction Assemblies

Assembly Name

| | |
|----------------------|--------------|
| <i>Applicability</i> | All projects |
|----------------------|--------------|

| | |
|---------------------------|--|
| <i>Definition</i> | The name of a construction assembly that describes a roof, wall, or floor assembly. The name generally needs to be unique so it can be referenced precisely by surfaces. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | Construction name is a required input. |
| <i>Baseline Rules</i> | Not applicable |

Specification Method

| | |
|---------------------------|--|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | The method of describing a construction assembly. The more simple method is to describe the U-factor of the construction assembly which can account for thermal bridging and other factors. However with this method, the time delay of heat transfer through the construction assembly is not accounted for. Generally, with the U-factor method, heat transfer is assumed to occur instantly. The more complex method is to describe the construction assembly as a series of layers, each layer representing a material. With this method, heat transfer is delayed in accord with the thermal mass and other properties of the assembly. |
| <i>Units</i> | List: choices are U-factor or Layers |
| <i>Input Restrictions</i> | The layers method shall be used for all constructions except for metal building or similar constructions with negligible thermal mass. |
| <i>Baseline Rules</i> | For each construction, the proposed design specification method shall be used. |

U-factor

| | |
|---------------------------|--|
| <i>Applicability</i> | All construction assemblies that are specified by a U-factor |
| <i>Definition</i> | The steady state rate of heat transfer through a construction assembly |
| <i>Units</i> | Btu/h-ft ² -°F |
| <i>Input Restrictions</i> | U-factors should be consistent with values in Appendix A of ASHRAE Standard 90.1-2007. |
| <i>Baseline Rules</i> | Not applicable |

Layers

| | |
|---------------------------|---|
| <i>Applicability</i> | All construction assemblies that use the layers method of specification |
| <i>Definition</i> | A structured list of pairs of material names that describe a construction assembly, beginning with exterior finish and progressing through to the interior finish. Material names must be from the standard list (Appendix E) or defined (see above). |
| <i>Units</i> | Data structure: construction assembly |
| <i>Input Restrictions</i> | The user is required to describe all layers in the actual roof assembly and the proposed design will be modeled as input by the user. |
| <i>Baseline Rules</i> | See building descriptors for roofs, walls, and floors. |

U-factor Derating Factor

| | |
|---------------------------|--|
| <i>Applicability</i> | All construction assemblies that use the layers method of specification |
| <i>Definition</i> | A derating factor to account for thermal bridges and other non-homogeneous construction features. The factor is a multiplier on the U-factor such that a value greater than one increases heat losses and gains. The layers method assumes that all layers are completely homogeneous and that there are no thermal bridges or other features that would increase heat gain or loss. |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | Default is 1.2 (120%). Minimum value is 1.0 and maximum value is 3.0. |
| <i>Baseline Rules</i> | The baseline building shall use a derating factor of 1.0, e.g. no derating. |

6.5.3 Roofs

Roof Name

| | |
|---------------------------|---|
| <i>Applicability</i> | All roof surfaces |
| <i>Definition</i> | A unique name or code that identifies the roof and ties it to the construction documents submitted for energy code review. It is not mandatory to name roofs. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | None |

Roof Type

| | |
|---------------------------|--|
| <i>Applicability</i> | All roof surfaces |
| <i>Definition</i> | One of three classifications of roofs defined in the baseline standard. These classifications are defined in ASHRAE Standard 90.1-2001 and ASHRAE Standard 90.1-2007 along with the associated User's Manuals. The prescriptive U-factor requirements for roofs depend on the type. For green building ratings and tax credits, it is not necessary to specify this information, as the PRM fixes the type for the baseline building to "insulation entirely above the deck." This descriptor can be derived from other building descriptors and it may not be necessary for the software user to specify it directly. |
| <i>Units</i> | List: attic and other roofs; metal building roofs; and roofs with insulation entirely above deck. |
| <i>Input Restrictions</i> | This input is optional for the purposes covered by this manual. |
| <i>Baseline Rules</i> | All roofs in the baseline building are modeled as "insulation entirely above deck." |

Roof Geometry

| | |
|---------------------------|--|
| <i>Applicability</i> | All roofs, required input |
| <i>Definition</i> | Roof geometry defines the position, orientation, azimuth, tilt, and dimensions of the roof surface. The details of how the coordinate system is implemented may vary between software programs. The data structure for surfaces is described in the reference section of this chapter. |
| <i>Units</i> | Data structure: surface |
| <i>Input Restrictions</i> | There are no restrictions other than that the surfaces defined must agree with the building being modeled, as represented on the construction drawings or as-built drawings. |
| <i>Baseline Rules</i> | Roof geometry will be identical in the proposed and baseline building designs. |

Roof Construction

| | |
|---------------------------|---|
| <i>Applicability</i> | All roofs, required input |
| <i>Definition</i> | A reference to a construction assembly for the proposed design. See the building descriptors above for construction assemblies. |
| <i>Units</i> | Dimensionless reference |
| <i>Input Restrictions</i> | All roof surfaces must reference a construction assembly. |
| <i>Baseline Rules</i> | Roofs in the baseline building are of the type “insulation entirely above deck.” The insulation requirement is determined by climate zone and is given in Table 6.5.3-1 [1]. The baseline building roof construction shall be modeled as layers as defined in Table 6.5.3-2 [2]. These tables reflect a construction that is available in the standard list of constructions. |

Table 6.5.3-1: "Baseline Building R-value and U-factor Criteria for Roofs"

| Applicable Standard | Space Category | Climate Zone | Standard Design | |
|-----------------------------|----------------|---------------|--------------------|------------------|
| | | | Minimum Insulation | Maximum Assembly |
| 90.1 – 2001 | Nonresidential | 1-7 | R-15 c.i. | U-0.063 |
| | | 8 | R-20 c.i. | U-0.048 |
| | Residential | 1,2,3,4,5,6,7 | R-15 c.i. | U-0.063 |
| | | 8 | R-20 c.i. | U-0.048 |
| | Semi-Heated | 1 | NR | U-1.282 |
| | | 2,3,4 | R-3.8 c.i. | U-0.218 |
| | | 5,6,7 | R-5.0 c.i. | U-0.173 |
| | | 8 | R-10.0 c.i. | U-0.093 |
| 90.1 – 2007 and 90.1 – 2010 | Nonresidential | 1 | R-15 c.i. | U-0.063 |
| | | 2-8 | R-20 c.i. | U-0.048 |
| | Residential | 1-8 | R-20 c.i. | U-0.048 |
| | | 1, 2 | R-3.8 c.i. | U-0.218 |
| | Semi-Heated | 3, 4 | R-5.0 c.i. | U-0.173 |
| | | 5 | R-7.6 c.i. | U-0.119 |
| | | 6,7 | R-10.0 c.i. | U-0.093 |
| | | 8 | R-15.0 c.i. | U-0.063 |

Table 6.5.3-2: "Baseline Building Roof Construction Assemblies"

| Construction | Layer | Thickness (inch) | Conductivity (Btu/h ft F) | Density (lb/ft ³) | Specific Heat (Btu/lb F) | R-value (ft ² ·°F·h/Btu) | U-factor (Btu/h·ft ² ·F) |
|----------------|----------------------------|------------------|---------------------------|-------------------------------|--------------------------|-------------------------------------|-------------------------------------|
| Roof R-20 c.i. | Exterior air film | | | | | 0.17 | |
| | Roofing membrane | | | | | 0.00 | |
| | R-20 continuous insulation | 4.8 | 0.02 | 1.8 | 0.29 | 20.00 | |
| | Steel deck | 0.06 | 26 | 480 | 0.10 | 0.00 | |
| | Interior air film | | | | | 0.61 | |
| | Total for assembly | | | | | 20.78 | 0.048 |
| Roof R-15 c.i. | Exterior air film | | | | | 0.17 | |
| | Roofing membrane | | | | | 0.00 | |
| | R-15 continuous insulation | 3.6 | 0.02 | 1.8 | 0.29 | 15.00 | |
| | Steel deck | 0.06 | 26 | 480 | 0.10 | 0.00 | |
| | Interior air film | | | | | 0.61 | |
| | Total for assembly | | | | | 15.78 | 0.063 |
| Roof R-10 c.i. | Exterior air film | | | | | 0.17 | |
| | Roofing membrane | | | | | 0.00 | |
| | R-10 continuous insulation | 2.4 | 0.02 | 1.8 | 0.29 | 10.00 | |

| | | | | | | | |
|-----------------|-----------------------------|------|------|-----|------|-------|-------|
| | Steel deck | 0.06 | 26 | 480 | 0.10 | 0.00 | |
| | Interior air film | | | | | 0.61 | |
| | Total for assembly | | | | | 10.78 | 0.093 |
| Roof R-7.6 c.i. | Exterior air film | | | | | 0.17 | |
| | Roofing membrane | | | | | 0.00 | |
| | R-7.6 continuous insulation | 1.8 | 0.02 | 1.8 | 0.29 | 7.6 | |
| | Steel deck | 0.06 | 26 | 480 | 0.10 | 0.00 | |
| | Interior air film | | | | | 0.61 | |
| | Total for assembly | | | | | 8.38 | 0.119 |
| Roof R-5 c.i. | Exterior air film | | | | | 0.17 | |
| | Roofing membrane | | | | | 0.00 | |
| | R-5 continuous insulation | 1.2 | 0.02 | 1.8 | 0.29 | 5.00 | |
| | Steel deck | 0.06 | 26 | 480 | 0.10 | 0.00 | |
| | Interior air film | | | | | 0.61 | |
| | Total for assembly | | | | | 5.78 | 0.173 |
| Roof R-3.8 c.i. | Exterior air film | | | | | 0.17 | |
| | Roofing membrane | | | | | 0.00 | |
| | R-3.8 continuous insulation | 0.9 | 0.02 | 1.8 | 0.29 | 3.80 | |
| | Steel deck | 0.06 | 26 | 480 | 0.10 | 0.00 | |
| | Interior air film | | | | | 0.61 | |
| | Total for assembly | | | | | 4.58 | 0.218 |
| NR. | Exterior air film | | | | | 0.17 | |
| | Roofing membrane | | | | | 0.00 | |
| | Steel deck | 0.06 | 26 | 480 | 0.10 | 0.00 | |
| | Interior air film | | | | | 0.61 | |
| | Total for assembly | | | | | 5.78 | 1.282 |

Exterior Roof Surface Properties

| | |
|---------------------------|---|
| <i>Applicability</i> | All roofs |
| <i>Definition</i> | The exterior roof surface properties descriptor defines the characteristics of exterior surfaces. Exterior surface properties include emissivity, reflectivity and roughness. The first two govern radiation exchange from the surface, while the latter governs the magnitude of the exterior air film resistance. |
| <i>Units</i> | Data structure: exterior surface properties |
| <i>Input Restrictions</i> | The default value is a reflectance of 0.30 and an emittance of 0.75. The default value may be overridden when roof materials are used that have been tested by the Cool Roof Rating Council (CRRC) and are called for in the construction documents. In cases where the default value is overridden, the user is required to submit documentation identifying the test procedure that was used to establish the non-default values. |
| <i>Baseline Rules</i> | The default values (see Input Restrictions above) shall be used for roofs for the baseline building. |

6.5.4 Exterior Walls

Wall Name

| | |
|---------------------------|--|
| <i>Applicability</i> | All walls, optional input |
| <i>Definition</i> | A unique name or code that relates the exterior wall to the design documents. This is an optional input since there are other acceptable ways to key surfaces to the construction documents. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | None |

Wall Type

| | |
|---------------------------|---|
| <i>Applicability</i> | All wall surfaces, optional |
| <i>Definition</i> | One of four categories of above-grade wall assemblies used to determine minimum insulation requirements for walls. The four wall type categories are as follows: a) mass walls, b) metal building walls, c) metal framing walls, and d) wood framing and other walls. These wall types are defined in the baseline standards and the associated User's Manuals. The prescriptive criteria of the baseline standards depend on the wall type, but for green building ratings and tax deduction calculations, the PRM specifies that all baseline walls shall be "metal framed" so the input is not used for the purposes of this manual. |
| <i>Units</i> | List: mass walls, metal building walls, metal framing walls, and wood framing and other walls |
| <i>Input Restrictions</i> | This input is optional for the purposes covered by this manual. This input can often be derived from other inputs and may not need to be explicitly specified. |

Baseline Rules All walls in the baseline building are modeled as “metal framed.”

Wall Geometry

Applicability All walls, required input

Definition Wall geometry defines the position, orientation, azimuth, and tilt of the wall surface. The details of how the coordinate system is implemented may vary between simulation engines. The data structure for surfaces is described in the reference section of this chapter.

Units Data structure: surface

Input Restrictions There are no restrictions other than that the surfaces defined must agree with the building being modeled, as represented on the construction drawings or as-built drawings.

Baseline Rules Wall geometry in the baseline building is identical to the proposed design.

Wall Construction

Applicability All walls, required input

Definition A reference to a construction assembly for the proposed design. See the building descriptors above for construction assemblies.

Units Dimensionless reference

Input Restrictions All wall surfaces must reference a construction assembly that meets the mandatory requirements of the appropriate baseline standard.

Baseline Rules Walls in the baseline building are all of the type “metal framed”. The insulation requirement is determined by the baseline standard and climate zone and is given in [Table 6.5.4-1](#) [3]. The baseline building construction shall be modeled as layers as defined in [Table 6.5.4-2](#) [4].

Table 6.5.4-1: "Baseline Building R-value and U-factor Criteria for Walls"

| Applicable Standard | Space Category | Climate Zone | Standard Design | |
|---------------------|----------------|--------------|--------------------|------------------|
| | | | Minimum Insulation | Maximum Assembly |
| 90.1 - 2001 | Nonresidential | 1-4 | R-13 | U-0.124 |
| | | 5,6 | R-13 + R-3.8 c.i. | U-0.084 |
| | | 7,8 | R-13 + R-7.5 c.i. | U-0.064 |
| | Residential | 1,2 | R-13 | U-0.124 |
| | | 3 | R-13 + R-3.8 c.i. | U-0.084 |
| | | 4- 7 | R-13 + R-7.5 c.i. | U-0.064 |
| | | 8 | R-13 + 10.0 c.i. | U-0.055 |
| | Semi-Heated | 1- 3 | NR | U-0.352 |
| | | 4 - 8 | R-13 | U-0.124 |
| 90.1 - 2007 | Nonresidential | 1,2 | R-13 | U-0.124 |
| | | 3 | R-13 + R-3.8 c.i. | U-0.084 |
| | | 4-8 | R-13 + R-7.5 c.i. | U-0.064 |
| | Residential | 1 | R-13 | U-0.124 |
| | | 2-6 | R-13 + R-7.5 c.i. | U-0.064 |
| | | 7 | R-13 +15.6 c.i. | U-0.042 |
| | | 8 | R-13 + R-18.8 c.i. | U-0.037 |
| | Semi-Heated | 1 | NR | U-0.352 |
| | | 2-7 | R-13 | U-0.124 |
| | | 8 | R-13 + R-3.8 c.i. | U-0.084 |

Table 6.5.4-2: "Baseline Building Wall Construction Assemblies"

| Construction | Layer | Thickness (inch) | Conductivity (Btu/h ft F) | Density (lb/ft³) | Specific Heat (Btu/lb F) | R-value (ft²·°F·h/Btu) | U-factor (Btu/ft²·°F·h) |
|--------------------|-------------------------------|------------------|---------------------------|------------------|--------------------------|------------------------|-------------------------|
| Wall R-13 + R-18.8 | Air film | | | | | 0.17 | |
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |
| | R-18.8 continuous insulation | 1.800 | 0.0200 | 1.8 | 0.29 | 18.8 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | R-13 insulation/steel framing | | | | | 6.00 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | Interior air film | | | | | 0.68 | |
| | Total for assembly | | | | | 26.85 | 0.037 |
| Wall R-13 + R-15.6 | Air film | | | | | 0.17 | |
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |

| | | | | | | | |
|--------------------|-------------------------------|-------|--------|-----|------|--------|-------|
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |
| | R-15.6 continuous insulation | 1.800 | 0.0200 | 1.8 | 0.29 | 15.6 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | R-13 insulation/steel framing | | | | | 6.00 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | Interior air film | | | | | 0.68 | |
| | Total for assembly | | | | | 23.65 | 0.042 |
| Wall R-13 + R-10.0 | Air film | | | | | 0.17 | |
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |
| | R-10.0 continuous insulation | 1.800 | 0.0200 | 1.8 | 0.29 | 10.0 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | R-13 insulation/steel framing | | | | | 6.00 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | Interior air film | | | | | 0.68 | |
| Wall R-13 + R-7.5 | Total for assembly | | | | | 18.05 | .055 |
| | Air film | | | | | 0.17 | |
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |
| | R-7.5 continuous insulation | 1.800 | 0.0200 | 1.8 | 0.29 | 7.50 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | R-13 insulation/steel framing | | | | | 6.00 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| Wall R-13 + R-3.8 | Interior air film | | | | | 0.68 | |
| | Total for assembly | | | | | 15.55 | 0.64 |
| | Air film | | | | | 0.17 | |
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |
| | R-3.8 continuous insulation | 0.912 | 0.0200 | 1.8 | 0.29 | 3.80 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | R-13 insulation/steel framing | | | | | 6.00 | |
| Wall R-13 | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | Interior air film | | | | | 0.68 | |
| | Total for assembly | | | | | 11.85 | 0.84 |
| | Air film | | | | | 0.17 | |
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | R-13 insulation/steel framing | | | | | 6.00 | |
| Wall R-13 | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | Interior air film | | | | | 0.68 | |
| | Total for assembly | | | | | 199.95 | 0.124 |
| | Air film | | | | | 0.17 | |
| | Stucco | 0.400 | 0.4167 | 116 | 0.2 | 0.08 | |
| | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | Cavity/steel framing | | | | | 0.79 | |
| Wall R-13 | Gypsum board | 0.625 | 0.0930 | 50 | 0.2 | 0.56 | |
| | Interior air film | | | | | 0.68 | |
| | Total for assembly | | | | | 2.84 | 3.52 |

Exterior Wall Surface Properties

Applicability All walls

Definition

The exterior wall surface properties descriptor describes the characteristics of exterior wall surfaces. Exterior surface properties may include emissivity, reflectivity and roughness. The first two govern radiation exchange from the surface, while the latter governs the magnitude of the exterior air film resistance.

The descriptor is a critical default structure input, applicable to all models. Critical defaults require documentation to change. Data structures are outlined in the reference data structures section of this chapter.

Units Data structure: exterior surface properties

Input Restrictions The default value for emittance is 0.90. The default value for reflectance is 0.30. There is no default for roughness. The

default values may be overridden only in cases when the lower reflectance can be documented by manufacturers' literature or tests.

Baseline Rules

The baseline building shall use default values for emittance and reflectance. The roughness of the baseline building walls shall be identical to the proposed design.

6.5.5 Exterior Floors

| Floor Name | |
|---------------------------|--|
| <i>Applicability</i> | All floor surfaces |
| <i>Definition</i> | A unique name or code that relates the exposed floor to the design documents. Exposed floors include floors exposed to the outdoors and floors over unconditioned spaces, but do not include slab-on-grade floors, below grade floors, or interior floors. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | None |
| Floor Type | |
| <i>Applicability</i> | All exterior floor surfaces, optional |
| <i>Definition</i> | One of three categories of exposed floor assemblies used to determine minimum prescriptive insulation requirements. The three floor type categories are: a) mass floor, b) steel joist floor, and c) wood and other floors. Definitions of these three exterior floor types are contained in Section 3.2, <i>Definitions</i> , of the baseline standard and associated User's Manuals. This building descriptor is not used for the purposes of this manual, since the type for the baseline building is fixed at "steel joist". This building descriptor can often be derived from other information in the model and may not be required as an explicit input. |
| <i>Units</i> | List: mass floor, metal joist floor, and wood and other floors |
| <i>Input Restrictions</i> | This building descriptor input is optional for the purposes of this manual. |
| <i>Baseline Rules</i> | The baseline building floors shall be of type "steel joist." |
| Floor Geometry | |
| <i>Applicability</i> | All exterior floors, required input |
| <i>Definition</i> | Floor geometry defines the position, orientation, azimuth, and tilt of the floor surface. The details of how the coordinate system is implemented may vary between software programs. The data structure for surfaces is described in the reference section of this chapter. |
| <i>Units</i> | Data structure: surface |
| <i>Input Restrictions</i> | There are no restrictions other than that the surfaces defined must agree with the building being modeled, as represented on the construction documents or as-built drawings. |
| <i>Baseline Rules</i> | Baseline building floor geometry is identical to the proposed design. |
| Floor Construction | |
| <i>Applicability</i> | All floors, required input |
| <i>Definition</i> | A reference to a construction assembly for the proposed design |
| <i>Units</i> | Dimensionless reference |
| <i>Input Restrictions</i> | All floor surfaces must reference a construction assembly that meets the mandatory measures of the baseline standards. |
| <i>Baseline Rules</i> | Exterior floors in the baseline building are of type "steel joist." The insulation requirements depend on the baseline standard and the climate zone and are given in Table 6.5.5-1 [5]. The baseline building constructions shall be modeled as layers, which are defined in Table 6.5.5-2 [6]. |

Table 6.5.5-1: "Baseline Building R-value and U-factor Criteria for Exposed Floors"

| Applicable Standard | Space Category | Climate Zone | Standard Design | |
|---------------------|----------------|--------------|--------------------|------------------|
| | | | Minimum Insulation | Maximum Assembly |
| 90.1 - 2001 | Nonresidential | 1 | NR | U-0.350 |
| | | 2-5 | R-19 | U-0.052 |
| | | 6-8 | R-30 | U-0.038 |
| | Residential | 1 | NR | U-0.350 |
| | | 2, 3 | R-19 | U-0.052 |
| | | 4- 7 | R-30 | U-0.038 |
| | | 8 | R-38 | U-0.032 |
| | Semi-Heated | 1, 2 | NR | U-0.350 |
| | | 3- 6 | R-13 | U-0.069 |
| | | 7, 8 | R-19 | U-0.052 |
| 90.1 - 2007 | Nonresidential | 1 | NR | U-0.350 |
| | | 2,3 | R-19 | U-0.052 |

| | | | |
|-------------|-----|------|---------|
| | 4-7 | R-30 | U-0.038 |
| | 8 | R-38 | U-0.032 |
| Residential | 1 | NR | U-0.350 |
| | 2,3 | R-19 | U-0.052 |
| | 4,5 | R-30 | U-0.038 |
| | 6-8 | R-38 | U-0.032 |
| | 1 | NR | U-0.350 |
| Semi-Heated | 2-4 | R-13 | U-0.069 |
| | 5-8 | R-19 | U-0.052 |

Table 6.5.5-2: "Baseline Building Exposed Floor Construction Assemblies"

| Construction | Layer | Thickness (inch) | Conductivity (Btu/h ft F) | Density (lb/ft ³) | Specific Heat (Btu/lb F) | R-value (ft ² ·°F·h/Btu) | U-factor (Btu/ft ² ·°F·h) |
|----------------------|--------------------------------|---------------------|------------------------------|----------------------------------|-----------------------------|--|---|
| Floor R-38 | Interior air film (flow down) | - | - | - | - | 0.92 | - |
| | carpet and pad | - | - | - | - | 1.23 | - |
| | 4" concrete | 4 | 1.3333 | 140 | 0.2 | 0.25 | - |
| | R-38 insulation between joists | - | - | - | - | 28 | - |
| | metal deck | 0.06 | 26 | 480 | 0.1 | 0.00 | - |
| | Semi-exterior air film | - | - | - | - | 0.46 | - |
| | Total for assembly | | | | | 30.86 | 0.032 |
| Floor R-30 | Interior air film (flow down) | - | - | - | - | 0.92 | - |
| | carpet and pad | - | - | - | - | 1.23 | - |
| | 4" concrete | 4 | 1.3333 | 140 | 0.2 | 0.25 | - |
| | R-30 insulation between joists | - | - | - | - | 23.5 | - |
| | metal deck | 0.06 | 26 | 480 | 0.1 | 0.00 | - |
| | Semi-exterior air film | - | - | - | - | 0.46 | - |
| | Total for assembly | | | | | 26.36 | 0.038 |
| Floor R-19 | Interior air film (flow down) | - | - | - | - | 0.92 | - |
| | carpet and pad | - | - | - | - | 1.23 | - |
| | 4" concrete | 4 | 1.3333 | 140 | 0.2 | 0.25 | - |
| | R-19 insulation between joists | - | - | - | - | 16.37 | - |
| | metal deck | 0.06 | 26 | 480 | 0.1 | 0.00 | - |
| | Semi-exterior air film | - | - | - | - | 0.46 | - |
| | Total for assembly | | | | | 19.23 | 0.052 |
| Floor R-13 | Interior air film (flow down) | - | - | - | - | 0.92 | - |
| | carpet and pad | - | - | - | - | 1.23 | - |
| | 4" concrete | 4 | 1.3333 | 140 | 0.2 | 0.25 | - |
| | R-13 insulation between joists | - | - | - | - | 11.63 | - |
| | metal deck | 0.06 | 26 | 480 | 0.1 | 0.00 | - |
| | Semi-exterior air film | - | - | - | - | 0.46 | - |
| | Total for assembly | | | | | 14.49 | 0.069 |
| Floor -no insulation | Interior air film (flow down) | - | - | - | - | 0.92 | - |
| | Carpet and pad | - | - | - | - | 1.23 | - |
| | 4" concrete | 4 | 1.3333 | 140 | 0.2 | 0.25 | - |
| | Metal deck | 0.06 | 26 | 480 | 0.1 | 0.00 | - |
| | Semi-exterior air film | - | - | - | - | 0.46 | - |
| | Total for assembly | | | | | 2.86 | 0.350 |

6.5.6 Doors

Door Name

Applicability All doors, optional input

Definition A unique name or code that relates the door to the design documents submitted. Doors that are more than 50% glass are treated as windows and must be entered by the user using the windows building descriptors.

Units Text unique

| | |
|---------------------------|---|
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | None |
| Door Type | |
| <i>Applicability</i> | All doors, required input |
| <i>Definition</i> | The baseline standards classify doors as either: swinging or non-swinging. Non-swinging are generally roll-up doors. The prescriptive U-factor requirements depend on the door type so this input affects the baseline building criteria. The door types are described in greater detail in the baseline standards and the associated User's Manuals. This building descriptor may be derived from other building descriptors, in which case a specific input is not necessary. |
| <i>Units</i> | List: swinging or non-swinging |
| <i>Input Restrictions</i> | The door type shall be consistent with the type of door represented on the construction documents or as-built drawings. |
| <i>Baseline Rules</i> | The baseline building door type shall be the same as the proposed design. |

| | |
|---------------------------|--|
| Door Geometry | |
| <i>Applicability</i> | All doors |
| <i>Definition</i> | Door geometry defines the position and dimensions of the door surface relative to its parent wall surface. The azimuth and tilt (if any) of the door is inherited from the parent surface. The position of the door within the parent surface is specified through X,Y coordinates. The size is specified as a height and width (all doors are generally assumed to be rectangular in shape). The details of how the geometry of doors is specified may vary for each energy simulation program. |
| <i>Units</i> | Data structure: opening |
| <i>Input Restrictions</i> | No restrictions, other than that the inputs shall agree with the construction documents or as-built drawings. |
| <i>Baseline Rules</i> | Door geometry in the baseline building is identical to the proposed design. |

| | |
|---------------------------|---|
| Door U-factor | |
| <i>Applicability</i> | All doors |
| <i>Definition</i> | The thermal transmittance of the door, including the frame. |
| <i>Units</i> | Btu/h•ft ² •°F |
| <i>Input Restrictions</i> | Door U-factors shall be taken from the default values in Appendix A of ASHRAE Standard 90.1-2001 or ASHRAE Standard 90.1-2007, or shall be obtained from NFRC test procedures. |
| <i>Baseline Rules</i> | The door U-factor in the baseline building depends on the baseline standard, the climate zone and the type of door (swinging or non-swinging). Use values from Table 6.5.6-1 [7]. |

Table 6.5.6-1: "Baseline Building U-factor Criteria for Doors"

| Applicable Standard | Swinging or Non-swinging | Climate Zone | Space Category | | |
|-----------------------------|--------------------------|--------------|----------------|-------------|-------------|
| | | | Nonresidential | Residential | Semi-Heated |
| ASHRAE Standard 90.1 - 2001 | Swinging | 1- 5 | 0.700 | 0.700 | 0.700 |
| | | 6, 7 | 0.700 | 0.500 | 0.700 |
| | | 8 | 0.500 | 0.500 | 0.700 |
| | Non-swinging | 1, 2 | 1.450 | 1.450 | 1.450 |
| | | 3- 5 | 1.450 | 0.500 | 1.450 |
| | | 6- 8 | 0.500 | 0.500 | 1.450 |
| ASHRAE Standard 90.1 - 2007 | Swinging | 1- 4 | 0.700 | 0.700 | 0.700 |
| | | 5, 6 | 0.700 | 0.500 | 0.700 |
| | | 7, 8 | 0.500 | 0.500 | 0.700 |
| | Non-swinging | 1 | 1.450 | 1.450 | 1.450 |
| | | 2, 3 | 1.450 | 0.500 | 1.450 |
| | | 4 | 1.500 | 0.500 | 1.450 |
| | | 5- 7 | 0.500 | 0.500 | 1.450 |

6.5.7 Fenestration

Note that fenestration includes windows, doors that have more than 50% glazed area, and skylights. A skylight is fenestration that has a tilt of less than 60° from horizontal.

| | |
|---------------------------|---|
| Fenestration Name | |
| <i>Applicability</i> | All fenestration, optional input |
| <i>Definition</i> | A unique name or code that relates the fenestration to the design documents and a parent surface. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | No restrictions |
| <i>Baseline Rules</i> | Not applicable |

Fenestration Type (Vertical Fenestration)

| | |
|---------------------------|--|
| <i>Applicability</i> | All vertical fenestration |
| <i>Definition</i> | This is a classification of vertical fenestration that determines the thermal performance and solar performance requirement for vertical fenestration. |
| <i>Units</i> | List (ASHRAE Standard 90.1-2007): Nonmetal framing (all); metal framing (curtainwall/storefront); metal framing (entrance door); or metal framing (all other) List (ASHRAE Standard 90.1-2001): Fixed or Operable |
| <i>Input Restrictions</i> | No restrictions, other than that the vertical fenestration type must agree with the type specified on the construction documents or the as-built drawings. |
| <i>Baseline Rules</i> | Same as the proposed design |

Fenestration Type (Skylights)

| | |
|---------------------------|--|
| <i>Applicability</i> | All skylights |
| <i>Definition</i> | This is a classification of skylights that determines the thermal performance and solar performance requirement for vertical fenestration. |
| <i>Units</i> | List: Glass skylight with curb; plastic skylight with curb; or skylights with no curb |
| <i>Input Restrictions</i> | No restrictions, other than the skylight types specified must agree with the construction documents or the as-built drawings. |
| <i>Baseline Rules</i> | Same as the proposed design |

Fenestration Geometry

| | |
|---------------------------|---|
| <i>Applicability</i> | All fenestration |
| <i>Definition</i> | Fenestration geometry defines the position and dimensions of the fenestration surface within its parent surface and the identification of the parent surface. The orientation and tilt is inherited from the parent surface. The details of how the coordinate system is implemented may vary between rating software programs. |
| <i>Units</i> | Data structure: opening |
| <i>Input Restrictions</i> | There are no restrictions, other than a match with the construction drawings or as-built drawings. Specification of the fenestration position within its parent surface is required for the following conditions: 1) exterior shading is modeled from buildings, vegetation, other objects; or 2) if daylighting is modeled within the adjacent space. |
| <i>Baseline Rules</i> | The geometry of the fenestration shall be identical to the proposed design with the following exceptions: <ul style="list-style-type: none"> • If the gross area of all windows in the building exceeds 40% of the gross above-grade exterior wall area in the building, the dimensions of each window in the baseline building shall be reduced in size such that the window area in the baseline building is equal to 40% of the above-grade exterior wall area. • If the gross area of skylights in the building exceeds 5% of the gross roof area, the dimensions of each skylight shall be reduced in size such that the skylight area in the proposed design is equal to 5% of the gross roof area. |

Fenestration Construction

| | |
|---------------------------|---|
| <i>Applicability</i> | All fenestration |
| <i>Definition</i> | A collection of values that together describe the performance of a fenestration system. The values that are used to specify the criteria are U-factor, SHGC and VT . Data may be specified in other ways, however, as long as the data are supported by appropriate tests. |
| <i>Units</i> | Data structure: fenestration construction |
| <i>Input Restrictions</i> | Performance information for fenestration shall be developed from NFRC test procedures or shall be taken from the default values in Appendix A of the baseline standard. Values entered shall be consistent with the specifications and the construction documents. |
| <i>Baseline Rules</i> | The requirements for vertical fenestration U factor, Solar Heat Gain Coefficient, and Visible light transmission by climate zone and framing type are found in Table 6.5.7-1 [8] and for skylight inputs in Table 6.5.7-2 [9]. In cases where there is no requirement (NR) for SHGC or VT, the baseline building shall be equal to the proposed design. |

Table 6.5.7-1: "Baseline Building Criteria for Vertical Glazing for 90.1 2001"

| Building type | Climate Zone | Window to Wall Ratio | Standard Design | | | | | |
|----------------|--------------|----------------------|-------------------|----------|---------------|-------|-------------|-------|
| | | | Assembly U-factor | | Assembly SHGC | | Assembly VT | |
| | | | Fixed | Operable | All | North | All | North |
| Nonresidential | 1 | 0-30.0% | 1.22 | 1.27 | 0.25 | 0.61 | 0.25 | 0.61 |
| | | 30.1-40.0% | 1.22 | 1.27 | 0.25 | 0.44 | 0.25 | 0.44 |
| | 2 | 0-40.0% | 1.22 | 1.27 | 0.25 | 0.61 | 0.25 | 0.61 |
| | | 3(A,B) | 0-10.0% | 0.57 | 0.67 | 0.39 | 0.49 | 0.39 |
| | 3(A,B) | 10.1-20.0% | 0.57 | 0.67 | 0.25 | 0.49 | 0.25 | 0.49 |
| | | 20.1-40.0% | 0.57 | 0.67 | 0.25 | 0.39 | 0.25 | 0.39 |
| | 3(C) | 0-10.0% | 1.22 | 1.27 | 0.61 | 0.82 | 0.61 | 0.82 |
| | | 10.1-40.0% | 1.22 | 1.27 | 0.39 | 0.61 | 0.39 | 0.61 |

| | | | | | | | | |
|-------------|--------|------------|------|------|------|------|------|------|
| Residential | 4 | 0-40.0% | 0.57 | 0.67 | 0.39 | 0.49 | 0.50 | 0.62 |
| | 5 | 0-10.0% | 0.57 | 0.67 | 0.49 | 0.49 | 0.62 | 0.62 |
| | | 10.1-40.0% | 0.57 | 0.67 | 0.39 | 0.49 | 0.50 | 0.62 |
| | 6 | 0-10.0% | 0.57 | 0.67 | 0.49 | 0.49 | 0.62 | 0.62 |
| | | 10.1-40.0% | 0.57 | 0.67 | 0.39 | 0.49 | 0.50 | 0.62 |
| | 7 | 0-40.0% | 0.57 | 0.67 | 0.49 | 0.64 | 0.49 | 0.64 |
| | 8 | 0-40.0% | 0.46 | 0.47 | NR | NR | NR | NR |
| | 1 | 0-30.0% | 1.22 | 1.27 | 0.25 | 0.61 | 0.25 | 0.61 |
| | | 30.1-40.0% | 1.22 | 1.27 | 0.25 | 0.44 | 0.25 | 0.44 |
| | 2 | 0-10.0% | 1.22 | 1.27 | 0.39 | 0.61 | 0.39 | 0.61 |
| | | 10.1-40.0% | 1.22 | 1.27 | 0.25 | 0.61 | 0.25 | 0.61 |
| | 3(A,B) | 0-10.0% | 0.57 | 0.67 | 0.39 | 0.49 | 0.39 | 0.49 |
| | | 10.1-20.0% | 0.57 | 0.67 | 0.25 | 0.49 | 0.25 | 0.49 |
| | | 20.1-40.0% | 0.57 | 0.67 | 0.25 | 0.39 | 0.25 | 0.39 |
| | 3(C) | 0-10.0% | 1.22 | 1.27 | 0.61 | 0.82 | 0.61 | 0.82 |
| | | 10.1-20.0% | 1.22 | 1.27 | 0.61 | 0.61 | 0.61 | 0.61 |
| | | 20.1-30.0% | 1.22 | 1.27 | 0.39 | 0.61 | 0.39 | 0.61 |
| | | 30.1-40.0% | 1.22 | 1.27 | 0.34 | 0.61 | 0.34 | 0.61 |
| | 4 | 0-40.0% | 0.57 | 0.67 | 0.39 | 0.49 | 0.50 | 0.62 |
| | 5 | 0-10.0% | 0.57 | 0.67 | 0.49 | 0.49 | 0.62 | 0.62 |
| | | 10.1-40.0% | 0.57 | 0.67 | 0.39 | 0.39 | 0.50 | 0.50 |
| | 6 | 0-10.0% | 0.57 | 0.67 | 0.49 | 0.64 | 0.62 | 0.81 |
| | | 10.1-40.0% | 0.57 | 0.67 | 0.39 | 0.49 | 0.50 | 0.62 |
| | 7 | 0-40.0% | 0.57 | 0.67 | 0.49 | 0.64 | 0.62 | 0.81 |
| | 8 | 0-40.0% | 0.46 | 0.47 | NR | NR | NR | NR |
| Semiheated | 1-8 | 0-40.0% | 1.22 | 1.27 | NR | NR | NR | NR |

Table 6.5.7-2: "Baseline Building Criteria for Vertical Glazing for 90.1 2007 and 90.1-2010"

| Building type | Fenestration Type | Climate Zone | Standard Design | | |
|-------------------------------|--|--------------|-----------------|------|------|
| | | | U-factor | SHGC | VT |
| Nonresidential | Non-Metal Framing | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 0.75 | 0.25 | 0.32 |
| | | 3 | 0.65 | 0.25 | 0.32 |
| | | 4 | 0.40 | 0.40 | 0.51 |
| | | 5,6 | 0.35 | 0.40 | 0.51 |
| | | 7,8 | 0.35 | 0.45 | 0.57 |
| | Metal Framing Curtainwall/ Storefront | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 0.70 | 0.25 | 0.32 |
| | | 3 | 0.60 | 0.25 | 0.32 |
| | | 4 | 0.50 | 0.40 | 0.51 |
| | | 5,6 | 0.45 | 0.40 | 0.51 |
| | | 7,8 | 0.40 | 0.45 | 0.57 |
| | Metal Framing Entrance Door | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 1.10 | 0.25 | 0.32 |
| | | 3 | 0.90 | 0.25 | 0.32 |
| | | 4 | 0.85 | 0.40 | 0.51 |
| | | 5,6 | 0.80 | 0.40 | 0.51 |
| | | 7,8 | 0.80 | 0.45 | 0.57 |
| Nonresidential (Continued) | Metal Framing All Other | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 0.75 | 0.25 | 0.32 |
| | | 3 | 0.65 | 0.25 | 0.32 |
| | | 4 | 0.55 | 0.40 | 0.51 |
| | | 5,6 | 0.55 | 0.40 | 0.51 |
| | | 7,8 | 0.45 | 0.45 | 0.57 |

| | | | | | |
|----------------------------|--|------|------|------|------|
| Residential | Non-Metal Framing | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 0.75 | 0.25 | 0.32 |
| | | 3 | 0.65 | 0.25 | 0.32 |
| | | 4 | 0.40 | 0.40 | 0.51 |
| | | 5,6 | 0.35 | 0.40 | 0.51 |
| | | 7,8 | 0.35 | NR | NR |
| | Metal Framing Curtainwall/ Storefront | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 0.70 | 0.25 | 0.32 |
| | | 3 | 0.60 | 0.25 | 0.32 |
| | | 4 | 0.50 | 0.40 | 0.51 |
| | | 5,6 | 0.45 | 0.40 | 0.51 |
| | | 7,8 | 0.40 | NR | NR |
| | Metal Framing Entrance Door | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 1.10 | 0.25 | 0.32 |
| | | 3 | 0.90 | 0.25 | 0.32 |
| | | 4 | 0.85 | 0.40 | 0.51 |
| | | 5,6 | 0.80 | 0.40 | 0.51 |
| | | 7,8 | 0.80 | NR | NR |
| | Metal Framing All Other | 1 | 1.20 | 0.25 | 0.32 |
| | | 2 | 0.75 | 0.25 | 0.32 |
| | | 3 | 0.65 | 0.25 | 0.32 |
| | | 4 | 0.55 | 0.40 | 0.51 |
| | | 5,6 | 0.55 | 0.40 | 0.51 |
| | | 7,8 | 0.45 | NR | NR |
| Residential | Non-Metal Framing | 1- 5 | 1.20 | NR | NR |
| | | 6- 8 | 0.65 | NR | NR |
| | Metal Framing Curtainwall/ Storefront | 1- 5 | 1.20 | NR | NR |
| | | 6- 8 | 0.60 | NR | NR |
| | Metal Framing Entrance Door | 1- 5 | 1.20 | NR | NR |
| | | 6- 8 | 0.90 | NR | NR |
| Residential (Continued) | Metal Framing All Other | 1- 5 | 1.20 | NR | NR |
| | | 6- 8 | 0.65 | NR | NR |

Table 6.5.7-3: "Baseline Building Criteria for Skylights"

| Proposed Design | Applicable Standard | Climate Zone | % of Roof | Standard Design | | |
|-------------------------------|---------------------------------|---|-----------|-----------------|------|------|
| | | | | U-factor | SHGC | VT |
| Glass Skylight with Curb | 90.1 – 2001 & 90.1 - 2007 | 1,2 | 0-2.0% | 1.98 | 0.36 | 0.46 |
| | | | 2.1-5.0% | 1.98 | 0.19 | 0.24 |
| | | 3 (A,B) - (all climate zone 3 for 2007) | 0-2.0% | 1.17 | 0.39 | 0.50 |
| | | | 2.1-5.0% | 1.17 | 0.19 | 0.24 |
| | | 3 (C) (2001 only) | 0-2.0% | 1.98 | 0.61 | 0.77 |
| | | | 2.1-5.0% | 1.98 | 0.39 | 0.50 |
| | | 4,5 | 0-2.0% | 1.17 | 0.49 | 0.62 |
| | | | 2.1-5.0% | 1.17 | 0.39 | 0.50 |
| | | 6 | 0-5.0% | 1.17 | 0.49 | 0.62 |
| | | 7 | 0-2.0% | 1.17 | 0.68 | 0.68 |
| | | | 2.1-5.0% | 1.17 | 0.64 | 0.64 |
| | | 8 | 0-2.0% | 0.98 | 0.55 | 0.63 |
| Plastic Skylight with Curb | 90.1 - 2001 & 90.1 - 2007 | 1 | 0-2.0% | 1.90 | 0.34 | 0.41 |
| | | | 2.1-5.0% | 1.90 | 0.27 | 0.32 |
| | | 2 | 0-2.0% | 1.90 | 0.39 | 0.47 |
| | | | 2.1-5.0% | 1.90 | 0.34 | 0.41 |
| | | 3,4 | 0-2.0% | 1.30 | 0.65 | 0.78 |
| | | | 2.1-5.0% | 1.30 | 0.34 | 0.41 |

| | | | | | | |
|-----------------------|---------------------------|---|----------|------|------|------|
| Skylight without Curb | 90.1 – 2001 & 90.1 – 2007 | 5 | 0-2.0% | 1.10 | 0.77 | 0.92 |
| | | | 2.1-5.0% | 1.10 | 0.62 | 0.74 |
| | | 6 | 0-2.0% | 0.87 | 0.71 | 0.85 |
| | | | 2.1-5.0% | 0.87 | 0.58 | 0.70 |
| | | 7 | 0-2.0% | 0.87 | 0.77 | 0.92 |
| | | | 2.1-5.0% | 0.87 | 0.71 | 0.85 |
| | | 8 | 0-2.0% | 0.61 | 0.59 | 0.64 |
| | | 1,2 | 0-2.0% | 1.36 | 0.36 | 0.46 |
| | | | 2.1-5.0% | 1.36 | 0.19 | 0.24 |
| | | 3 (A,B) - (all climate zone 3 for 2007) | 0-2.0% | 0.69 | 0.39 | 0.50 |
| | | | 2.1-5.0% | 0.69 | 0.19 | 0.24 |
| | | 3 (C) (2001 only) | 0-2.0% | 1.36 | 0.61 | 0.77 |
| | | | 2.1-5.0% | 1.36 | 0.39 | 0.50 |
| | | 4,5 | 0-2.0% | 0.69 | 0.49 | 0.62 |
| | | | 2.1-5.0% | 0.69 | 0.39 | 0.50 |
| | | 6 | 0-5.0% | 0.69 | 0.49 | 0.62 |
| | | 7 | 0-2.0% | 0.69 | 0.68 | 0.68 |
| | | | 2.1-5.0% | 0.69 | 0.64 | 0.64 |
| | | 8 | 0-5.0% | 0.58 | 0.55 | 0.63 |

External Shading Devices

| | |
|---------------------------|--|
| <i>Applicability</i> | All fenestration |
| <i>Definition</i> | Devices or building features, such as overhangs, fins, shading screens, and setbacks of windows from the exterior face of the wall, that are documented on the construction documents and shade the glazing. Objects that shade the building but that are not part of the building and parts of the building that cause the building to shade itself are also modeled, but are not a part of this building descriptor. See <i>Shading of the Building Site</i> . |
| <i>Units</i> | Data structure: opening shade |
| <i>Input Restrictions</i> | No restrictions other than that the inputs must match the construction documents |
| <i>Baseline Rules</i> | The baseline building is modeled without external shading devices. |

Internal Shading Devices

| | |
|---------------------------|--|
| <i>Applicability</i> | All fenestration |
| <i>Definition</i> | Curtains, blinds, louvers, or other devices that are applied on the room side of the glazing material. Glazing systems that use blinds between the glazing layers are also considered internal shading devices. Glass coatings or components or treatments of the glazing materials are addressed through the Fenestration Construction building descriptor. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | Internal shading shall not be modeled in the proposed design, unless it is automatically controlled, based on input from an astronomical timeclock, an exterior pyronometer, or other sensors. The control algorithm shall be documented on the construction documents. Interior shades without automatic controls shall not be modeled. |
| <i>Baseline Rules</i> | The baseline building shall be modeled without interior shades. |

6.5.8 Below Grade Walls

Below Grade Wall Name

| | |
|---------------------------|--|
| <i>Applicability</i> | All projects, optional input |
| <i>Definition</i> | A unique name that keys the below grade wall to the construction documents |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable |

Below Grade Wall Geometry

| | |
|---------------------------|---|
| <i>Applicability</i> | All projects |
| <i>Definition</i> | A geometric construct that describes the dimensions and placement of walls located below grade. Below grade walls have soil or crushed rock on one side and interior space on the other side. Some simulation models take the depth below grade into account when estimating heat transfer, so the geometry may include height and width. |
| <i>Units</i> | Data structure: below grade wall geometry |
| <i>Input Restrictions</i> | There are no restrictions other than that the inputs shall be in agreement with the construction documents. |
| <i>Baseline Rules</i> | The geometry of below grade walls in the baseline building is identical to the below grade walls in the proposed design. |

Below Grade Wall Construction

| | |
|----------------------|------------------------------|
| <i>Applicability</i> | All projects, required input |
|----------------------|------------------------------|

| | |
|---------------------------|---|
| Definition | A description of the manner in which a below grade wall is constructed or a representation of the thermal performance of the below grade wall that can be used by the energy simulation software to estimate heat transfer. The construction can be described as a C-factor which is similar to a U-factor, except that the outside air film is excluded or the construction can be represented as a series of layers, like exterior constructions. |
| Units | Data structure: construction assembly |
| Input Restrictions | No restrictions other than that the inputs shall be in agreement with the construction documents. |
| Baseline Rules | See Table 6.5.8-1 [10] and Table 6.5.8-2 [11]. |

Table 6.5.8-1: "Baseline Building C-factor Criteria for Below-Grade Walls"

| Applicable Standard | Space Category | Climate Zone | Standard Design | |
|---------------------|----------------|--------------|--------------------|----------|
| | | | Minimum Insulation | C-Factor |
| 90.1 - 2001 | Nonresidential | 1- 6 | NR | 1.140 |
| | | 7, 8 | R-7.5 c.i. | 0.119 |
| | Residential | 1-5 | NR | 1.140 |
| | | 6- 8 | R-7.5 c.i. | 0.119 |
| | Semi-Heated | 1-8 | NR | 1.140 |
| 90.1 - 2007 | Nonresidential | 1- 4 | NR | 1.140 |
| | | 5/6/7/8 | R-7.5 c.i. | 0.119 |
| | Residential | 1-3 | NR | 1.140 |
| | | 4/5/6 | R-7.5 c.i. | 0.119 |
| | | 7 | R-10 c.i. | 0.092 |
| | | 8 | R-12.5 c.i. | 0.075 |
| | Semi-Heated | 1- 8 | NR | 1.140 |
| | | | | |

Table 6.5.8-2: "Baseline Building Below-Grade Wall Construction Assemblies"

| Construction | Layer | Thickness (inch) | Conductivity (Btu/h ft F) | Density (lb/ft ³) | Specific Heat (Btu/lb F) | R-value (ft ² ·°F·h/Btu) | C-factor (Btu/ft ² ·°F·h) |
|--------------|---|------------------|---------------------------|-------------------------------|--------------------------|-------------------------------------|--------------------------------------|
| NR | 115 lb/ft ³ CMU, solid grout | 8 | 0.45 | 115 | 0.20 | 0.87 | 1.140 |
| R-7.5 c.i. | 115 lb/ft ³ CMU, solid grout | 8 | 0.45 | 115 | 0.20 | 0.87 | |
| | R-10 continuous insulation | 1.8 | 0.02 | 1.8 | 0.29 | 7.50 | |
| | Total assembly | | | | | 8.37 | 0.119 |
| R-10 c.i. | 115 lb/ft ³ CMU, solid grout | 8 | 0.45 | 115 | 0.20 | 0.87 | |
| | R-10 continuous insulation | 2.4 | 0.02 | 1.8 | 0.29 | 10.00 | |
| | Total assembly | | | | | 10.87 | 0.092 |
| R-12.5 c.i. | 115 lb/ft ³ CMU, solid grout | 8 | 0.45 | 115 | 0.20 | 0.87 | |
| | R-10 continuous insulation | 3.0 | 0.02 | 1.8 | 0.29 | 12.50 | |
| | Total assembly | | | | | 13.37 | 0.075 |

6.5.9 Slab Floors in Contact with Ground

These building descriptors apply to slab-on-grade floors that are in direct contact with the ground.

Slab Floor Name

| | |
|---------------------------|---|
| Applicability | All slab floors, optional |
| Definition | A unique name or code that relates the exposed floor to the construction documents. |
| Units | Text, unique |
| Input Restrictions | None |
| Baseline Rules | Not applicable |

Slab Floor Type

| | |
|---------------------------|--|
| Applicability | All slab floors, required |
| Definition | One of two classes for floors in contact with ground. The classes are: 1) heated slab-on-grade floors and 2) unheated slab-on-grade floors. Heated slab-on-grade floors include all floors that are heated directly in order to provide heating to the space. Unheated slab-on-grade floors are all other floors in contact with ground. See the baseline standards and the associated User's Manuals for additional definition. |
| Units | List: heated or unheated |
| Input Restrictions | None |
| Baseline Rules | Unheated |

Slab Floor Geometry

| | |
|---------------------------|---|
| <i>Applicability</i> | All slab floors, required |
| <i>Definition</i> | A geometric construct representing a slab floor in contact with the earth. The geometric representation can vary depending on how the energy simulation software models slabs-on-grade. Some models require that only the perimeter of the slab be entered. Other models divide the slab into a perimeter band within 2 ft of the edge and the interior portion or core area, such that the perimeter area and the core area sum to the total area of the slab. |
| <i>Units</i> | Data structure: as appropriate for the simulation tool |
| <i>Input Restrictions</i> | No restrictions |
| <i>Baseline Rules</i> | Same as baseline building |

Slab Floor Construction

| | |
|---------------------------|---|
| <i>Applicability</i> | All slab floors, required input |
| <i>Definition</i> | <p>A description of how the slab is insulated (or not). How the construction is described will depend on the energy simulation model. Simple models may include just an F-factor, representing an instantaneous heat loss/gain to outside air. The F-factor could be related to the configuration of insulation in the proposed design. Other slab loss models may require that the surface area of the slab floor be divided between the perimeter and the interior. The insulation conditions then define heat transfer between both outside air and ground temperature.</p> <p>The insulation condition for slabs includes the R-value of the insulation and the distance it extends into the earth at the slab edge and how far it extends underneath the slab.</p> |
| <i>Units</i> | Data structure: depends on the model that is used |
| <i>Input Restrictions</i> | If the perimeter method is used to model the slab, F-factors shall be taken from Appendix A of ASHRAE Standard 90.1-2001 or ASHRAE Standard 90.1-2007. For all methods, inputs shall be consistent with the construction documents. |
| <i>Baseline Rules</i> | <p>Slab loss shall be modeled in the same manner in the baseline building as in the proposed design, e.g. if the perimeter method is used for the proposed design, the same method shall be used for the baseline building.</p> <p>The configuration of insulation and the F-factors for the baseline building are shown in Table 6.5.9-1 [12]. If the perimeter method is not used, then the F-factors from the table shall be used in the baseline building. If an alternative modeling method is used, then inputs to the method for the baseline building shall be consistent with the insulation configuration described in Table 6.5.9-1 [12].</p> |

Table 6.5.9-1: "Baseline Building F-factor Criteria for Slab-on-Grade Floors"

| Applicable Standard | Condition | Space Category | Climate Zone | Baseline Building | |
|---------------------|-----------|----------------|--------------|---------------------------|----------|
| | | | | Insulation Configuration | F-Factor |
| 90.1 – 2001 | Unheated | Nonresidential | 1-7 | NR | 0.730 |
| | | | 8 | R-10 for 24 in. vertical | 0.540 |
| | | Residential | 1-6 | NR | 0.730 |
| | | | 7 | R-10 for 24 in. vertical | 0.540 |
| | | | 8 | R-15 for 24 in. vertical | 0.520 |
| | | Semi-Heated | 1- 8 | NR | 0.730 |
| | Heated | Nonresidential | 1- 4 | R-7.5 for 12 in. vertical | 1.020 |
| | | | 5- 7 | R-10 for 36 in. vertical | 0.840 |
| | | | 8 | R-10 for 48 in. vertical | 0.780 |
| | | Residential | 1- 3 | R-7.5 for 12 in. vertical | 1.020 |
| | | | 4, 5 | R-10 for 36 in. vertical | 0.840 |
| | | | 6- 8 | R-10 for 48 in. vertical | 0.780 |
| | | Semi-Heated | 1- 7 | R-7.5 for 12 in. vertical | 1.020 |
| | | | 8 | R-7.5 for 24 in. vertical | .0950 |
| 90.1 – 2007 | Unheated | Nonresidential | 1-5 | NR | 0.730 |
| | | | 6 | R-10 for 24 in. vertical | 0.540 |
| | | | 7,8 | R-15 for 24 in. vertical | 0.520 |
| | | Residential | 1- 3 | NR | 0.730 |
| | | | 4, 5 | R-10 for 24 in. vertical | 0.540 |
| | | | 6, 7 | R-15 for 24 in. vertical | 0.520 |
| | | | 8 | R-20 for 24 in. vertical | 0.510 |
| | | | | | |
| | | Semi-Heated | 1- 8 | NR | 0.730 |
| | Heated | Nonresidential | 1, 2 | R-7.5 for 12 in. vertical | 1.020 |
| | | | 3 | R-10 for 24 in. vertical | 0.900 |
| | | | 4- 6 | R-15 for 24 in. vertical | 0.860 |
| | | | 7 | R-20 for 24 in. vertical | 0.843 |

| | | | |
|-------------|------|---------------------------|-------|
| Residential | 8 | R-20 for 48 in. vertical | 0.688 |
| | 1, 2 | R-7.5 for 12 in. vertical | 1.020 |
| | 3 | R-10 for 24 in. vertical | 0.900 |
| | 4, 5 | R-15 for 24 in. vertical | 0.860 |
| | 6- 8 | R-20 for 48 in. vertical | 0.688 |
| Semi-Heated | 1- 6 | R-7.5 for 12 in. vertical | 1.020 |
| | 7, 8 | R-10 for 24 in. vertical | 0.900 |

6.5.10 Heat Transfer between Thermal Blocks

| Partition Name | |
|---------------------------|--|
| <i>Applicability</i> | All partitions, optional |
| <i>Definition</i> | A unique name or code that relates the partition to the construction documents. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | The text should provide a key to the construction documents. |
| <i>Baseline Rules</i> | Not applicable |
| Partition Geometry | |
| <i>Applicability</i> | All partitions |
| <i>Definition</i> | A geometric construct that defines the position and size of partitions that separate one thermal block from another. The construct shall identify the thermal blocks on each side of the partition. Since solar gains are not generally significant for interior partitions, the geometry of partitions is sometimes specified as just an area along with identification of the thermal blocks on each side. |
| <i>Units</i> | Data structure: surface with additional information identifying the two thermal blocks that the partition separates. |
| <i>Input Restrictions</i> | No restrictions other than agreement with the construction documents |
| <i>Baseline Rules</i> | The geometry of partitions in the baseline building shall be identical to the proposed design. |
| Partition Construction | |
| <i>Applicability</i> | All partitions |
| <i>Definition</i> | A description of the construction assembly for the partition |
| <i>Units</i> | Data structure: construction assembly |
| <i>Input Restrictions</i> | No restrictions other than the need for agreement with the construction documents |
| <i>Baseline Rules</i> | Partitions in the baseline building shall be steel framed walls with 5/8 in. gypsum board on each side. |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/65-building-envelope-data>

Links:

- [1] <http://www.comnet.org/mgp/content/653-roofs#baseline-building-r-value-and-u-factor-criteria-for-roofs>
- [2] <http://www.comnet.org/mgp/content/653-roofs#baseline-building-roof-construction-assemblies>
- [3] <http://www.comnet.org/mgp/content/exterior-walls#baseline-building-r-value-and-u-factor-criteria-for-walls>
- [4] <http://www.comnet.org/mgp/content/exterior-walls#baseline-building-wall-construction-assemblies>
- [5] <http://www.comnet.org/mgp/content/exterior-floors#baseline-building-r-value-and-u-factor-criteria-for-exposed-floors>
- [6] <http://www.comnet.org/mgp/content/exterior-floors#baseline-building-exposed-floor-construction-assemblies>
- [7] <http://www.comnet.org/mgp/content/doors#baseline-building-u-factor-criteria-for-doors>
- [8] <http://www.comnet.org/mgp/content/fenestration#baseline-building-criteria-for-vertical-glazing-for-90.1-2001>
- [9] <http://www.comnet.org/mgp/content/fenestration#baseline-building-criteria-for-skylights>
- [10] <http://www.comnet.org/mgp/content/below-grade-walls#baseline-building-c-factor-criteria-for-below-grade-walls>
- [11] <http://www.comnet.org/mgp/content/below-grade-walls#baseline-building-below-grade-wall-construction-assemblies>
- [12] <http://www.comnet.org/mgp/content/slab-floors-contact-ground#baseline-building-f-factor-criteria-for-slab-on-grade-floors>

6.6 HVAC Zone Level Systems

This group of building descriptors relate to HVAC systems at the zone level. For purposes that have a baseline building there is not a one-to-one relationship between HVAC components in the proposed design and the baseline building since the baseline building system is determined from building type, size, and heating source. Appendix A shows the applicability of each building descriptor for eight baseline building systems.

6.6.1 Space Temperature Control

Space Thermostat Throttling Range

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | The number of degrees that the room temperature must change to cause the HVAC system to go from no heating or cooling (i.e., space temperatures floating) to full heating or cooling. |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | The prescribed value is 2°F. No input is needed and the prescribed value may not be overridden. |
| <i>Baseline Rules</i> | Same as the proposed design |

Space Temperature Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | An hourly space thermostat schedule |
| <i>Units</i> | Data structure: temperature schedule |
| <i>Input Restrictions</i> | The schedules specified in Appendix B, Table 7 and detailed in Appendix C shall be used as a default. When the default temperature schedule is overridden, the user must provide justification for use of nonstandard space temperature schedule assumptions. |
| <i>Baseline Rules</i> | Schedules in the baseline building shall be identical to the proposed design. |

6.6.2 Terminal Device Data

Terminal Type

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | <p>A terminal unit includes any device serving a zone (or group of zones collected in a thermal block) that has the ability to reheat or recool in response to the zone thermostat. This includes:</p> <ul style="list-style-type: none"> • None (the case for single zone units) • VAV box • Series Fan-Powered VAV box • Parallel Fan-Powered VAV box • Induction-type VAV box • Dual-duct mixing box (constant volume and VAV) • Two and three duct mixing dampers (multi-zone systems) • Reheat coil (constant volume systems) • Perimeter induction units |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Table 6.6.2-1 [1] specifies the HVAC terminal device for each of the baseline building systems. See Figure 6.1.2-1 [2] for a summary of the HVAC mapping. |

Table 6.6.2-1: "Baseline Building HVAC Terminal Devices"

| Baseline building System | Terminal Type |
|--------------------------|---------------|
| System 1 – PTAC | None |
| System 2 – PTHP | None |
| System 3 – PSZ-AC | None |
| System 4 – PSZ-HP | None |

| | |
|--|------------------------------|
| System 5 – Packaged VAV with Reheat | VAV Box |
| System 6 – Packaged VAV with PFP boxes | Parallel Fan-Powered VAV Box |
| System 7 – VAV with Reheat | VAV Box |
| System 8 – VAV with PFP boxes | Parallel Fan-Powered VAV Box |

6.6.3 Terminal Heating

This group of building descriptors applies to proposed design systems that have reheat coils at the zone level. The building descriptors are applicable for baseline building systems 5 through 8.

Terminal Heat Type

| | |
|--------------------|--|
| Applicability | Systems that have reheat coils at the zone level |
| Definition | The heating source for the terminal unit. This includes: <ul style="list-style-type: none">• Electric resistance• Gas furnace• Oil furnace• Hot water• Steam |
| Units | List (see above) |
| Input Restrictions | As designed. |
| Baseline Rules | Table 6.6.3-1 [3] shows the terminal heat type for each baseline building system. |

Table 6.6.3-1: "Baseline Building Terminal Heat Type"

| Baseline building System | Terminal Heat Type |
|--|---------------------|
| System 1 – PTAC | None |
| System 2 – PTHP | None |
| System 3 – PSZ-AC | None |
| System 4 – PSZ-HP | None |
| System 5 – Packaged VAV with Reheat | Hot Water |
| System 6 – Packaged VAV with PFP boxes | Electric Resistance |
| System 7 – VAV with Reheat | Hot Water |
| System 8 – VAV with PFP boxes | Electric Resistance |

Terminal Heat Capacity

| | |
|--------------------|---|
| Applicability | Systems that have reheat coils at the zone level |
| Definition | The heating capacity of the terminal heating source |
| Units | Btu/h |
| Input Restrictions | As designed. However, if the unmet load hours exceed 300, the energy analyst and design team may have to increase the size of the equipment so that the unmet load hours are less than 300. See Figure 6.1.2-1 [2] and Figure 6.7.2-1 [4]. |
| Baseline Rules | The software shall automatically size the terminal heating capacity to be 25% greater than the design loads. However, the equipment may need to be reduced in size such that the unmet load hours of the proposed design does not exceed the baseline building by more than 50. See Figure 6.7.2-1 [4]. |

Reheat Delta T

| | |
|---------------|---|
| Applicability | Systems that have reheat coils at the zone level |
| Definition | This is an alternate method to enter the terminal heat capacity. It can be calculated as follows: |

(6.6.3-1)

TeX Embedding failed!

TeX Embedding failed!

where

| | |
|--|--|
| <i>TeX Embedding failed!</i> T_{reheat} | heat rise across the terminal unit heating coil (°F) |
| T_{reheat} | heating air temperature at design (°F) |
| $T_{\text{cool_supply}}$ | supply air temperature at the heating coil (°F) |
| Q_{coil} | heating coil load (Btu/h) |

| | | |
|---------------------------|--|---------------|
| | CFM | airflow (cfm) |
| <i>Units</i> | Degrees Fahrenheit (°F) | |
| <i>Input Restrictions</i> | As designed, but may need to be increased if unmet load hours are greater than 300 | |
| <i>Baseline Rules</i> | Method not used for baseline building. See Heat Capacity above. | |

6.6.4 Baseboard Heat

Baseboard Capacity

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | The total heating capacity of the baseboard unit(s) |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable to the baseline building |

Baseboard Heat Control

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | Defines the control scheme of base board heating as either: Reset by outdoor air temperature; or Controlled by a space thermostat |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable for the baseline building. |

6.6.5 Zone Level Air Flow

VAV Air Flow

This group of building descriptors applies to proposed design systems that vary the volume of air at the zone level. The building descriptors are applicable for baseline building systems 5 through 8.

Design Airflow

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems that vary the volume of air at the zone level |
| <i>Definition</i> | The air delivery rate at design conditions |
| <i>Units</i> | cfm |
| <i>Input Restrictions</i> | As designed. If the unmet load hours in the proposed design are greater than 300, the building descriptor may need to be modified to meet the criterion. |
| <i>Baseline Rules</i> | For systems 5 through 8, the software shall automatically size the airflow to meet the baseline building loads based on a supply-air-to-room-air temperature difference of 20°F or the required ventilation air or makeup air, whichever is greater |

Terminal Minimum Stop

| | |
|---------------------------|--|
| <i>Applicability</i> | Systems that vary the volume of air at the zone level |
| <i>Definition</i> | The minimum airflow that will be delivered by a terminal unit before reheating occurs |
| <i>Units</i> | Unitless fraction airflow (cfm) or specific airflow (cfm/ft²) |
| <i>Input Restrictions</i> | This input must be greater than or equal to the outside air ventilation rate. |
| <i>Baseline Rules</i> | For systems 5 through 8, set the minimum airflow to be the greater of 0.4 cfm/ft² of conditioned floor area or the outside air ventilation rate. |

Fan Powered Boxes

Fan Powered Box Type

| | |
|---------------------------|---|
| <i>Applicability</i> | HVAC zones that have fan powered boxes |
| <i>Definition</i> | Defines the type of fan-powered induction box. This is either: <ul style="list-style-type: none"> • Series; or • Parallel |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |

Baseline Rules Applicable for baseline building systems 6 and 8 and the fan powered box type is parallel.

Fan Power

Applicability HVAC zones that have fan powered boxes

Definition The rated power input of the fan in a fan-powered box.

Units W or W/cfm

Input Restrictions As designed

Baseline Rules For baseline building systems 6 and 8, power is prescribed at 0.35 W/cfm.

Fan Power Box Induced Air Zone

Applicability HVAC zones that have fan powered boxes

Definition Zone from which a series or parallel fan-powered box draws its air

Units List (of zones)

Input Restrictions As designed

Baseline Rules If the proposed design has a plenum, then induced air will be drawn from that plenum. If the proposed design does not have a plenum, then induced air will be drawn from the space.

Parallel PIU Induction Ratio

Applicability HVAC zones that have fan powered boxes

Definition The ratio of induction-side airflow of a fan-powered box at design heating conditions to the primary airflow

Units Ratio

Input Restrictions As designed

Baseline Rules 50%

Parallel Fan Box Thermostat Setpoint

Applicability HVAC zones that have parallel fan powered boxes

Definition The temperature difference above the heating setpoint at which the parallel fan is turned on

Units Degrees Fahrenheit (°F)

Input Restrictions 2°F above the heating setpoint schedule

Baseline Rules 2°F above the heating setpoint schedule

Zone Exhaust

This group of building descriptors describes the rate of exhaust and the schedule or control for this exhaust. An exhaust system can serve one thermal block or multiple thermal blocks. Energy is summed for the exhaust system level, not the thermal block level.

Exhaust Fan Name

Applicability All HVAC zones

Definition A reference to an exhaust fan system that serves the thermal block

Units Text or other unique reference to an exhaust fan system defined in the secondary systems section.

Input Restrictions As designed

Baseline Rules Same as the proposed design

Exhaust Air Flow Rate

Applicability All HVAC zones

Definition Rate of exhaust from a thermal block

Units cfm

Input Restrictions As designed

Baseline Rules Same as the proposed design

Exhaust Fan Schedule

Applicability All HVAC zones

Definition Schedule indicating the pattern of use for exhaust air from the thermal block. This input should consider the position of fume hood sash opening. For toilets and other exhaust applications, the schedule may coincide with the operation of the exhaust fan system.

Units Data structure: schedule, fraction

Input Restrictions As designed

Baseline Rules Same as the proposed design

Outdoor Air Ventilation

Ventilation Source

Applicability All HVAC zones

Definition The source of ventilation for an HVAC system. The choices are:

- Natural (by operable openings)

- Natural (by operable openings)
- Mechanical (by fan)

| | |
|---------------------------|--|
| <i>Units</i> | List: natural or mechanical |
| <i>Input Restrictions</i> | For residential units and hotel/motel guest rooms, as designed. For all other occupancies, set to mechanical. |
| <i>Baseline Rules</i> | For residential units, set to natural, for all other occupancies, set equal to the value for the proposed design (mechanical). |

Design Ventilation Rate

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | The quantity of ventilation air that is provided to the space for the specified thermal block at maximum occupancy |
| <i>Units</i> | cfm or cfm/occupant |
| <i>Input Restrictions</i> | For the purpose of tax deduction calculations, the California ACM values from Table 4 of Appendix B shall be used. For green building ratings and Design to Earn ENERGY STAR, the COMNET values from Table 4 of Appendix B shall be used as a default. Other values may be used with appropriate documentation. |
| <i>Baseline Rules</i> | Same as the proposed design |

Minimum Ventilation Rate

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | The minimum quantity of ventilation air that must provided to the space when the HVAC system is operating |
| <i>Units</i> | cfm or cfm/ft ² |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as the proposed design |

Ventilation Control Method

| | |
|---------------------------|---|
| <i>Applicability</i> | All HVAC zones |
| <i>Definition</i> | <p>The method used to determine outside air ventilation needed for each hour in the simulation. This information is reported to the system serving the zone. The method of controlling outside air at the system level in response to this information is discussed under secondary systems. Options at the zone level are:</p> <ul style="list-style-type: none"> • Occupant sensors: When the space is occupied, the outside air requirement is equal to the <i>design ventilation rate</i>, otherwise, the outside air requirement is the <i>minimum ventilation rate</i>. • CO₂ sensors in the space: The outside air is determined to maintain a maximum CO₂ concentration in the space. This may be approximated by multiplying the ventilation rate per occupant times the number of occupants for that hour. • Turnstiles to determine the number of occupants in the space (appropriate for theatres, etc.): The outside air requirement is modulated based on the number of occupants in the space, based on the turnstile counts. • Fixed ventilation rate. Outside air is delivered to the zone at a constant rate and is equal to the design ventilation rate (see above). |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | <p>For the federal tax credit, if the design occupancy is greater than 100 persons per 1,000 ft² and the system design outside air flow rate is greater than 3,000 cfm, set control method to <i>CO₂ sensors in the space</i>, otherwise set to <i>fixed ventilation rate</i>.</p> <p>For green building incentive programs, set to <i>CO₂ sensors in the space</i> if the design occupancy is greater than 40 people per 1,000 ft² and the system design outdoor air flow rate is greater than 1,200 cfm, otherwise set to <i>fixed ventilation rate</i>.</p> |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/66-hvac-zone-level-systems>

Links:

- [1] <http://www.comnet.org/mgp/content/662-terminal-device-data#baseline-building-HVAC-terminal-devices>
- [2] <http://www.comnet.org/mgp/content/hvac-system-map#hvac-mapping>
- [3] <http://www.comnet.org/mgp/content/663-terminal-heating#baseline-building-terminal-heat-type>
- [4] <http://www.comnet.org/mgp/content/system-controls#sat-cooling-setpoint-reset-based-on-outdoor-air-temperature-oat-for-dry-b-and-marine-climates>

6.7 HVAC Secondary Systems

This group of building descriptors relate to the secondary HVAC systems. There is not a one-to-one relationship between secondary HVAC system components in the proposed design and the baseline building system since the baseline building system is determined from building type, size and heating source. Appendix A shows the applicability of each building descriptor for the eight baseline building systems. Depending on the nature of the proposed design, any of the building descriptors could apply.

6.7.1 Basic System Information

HVAC System Name

Applicability

All system types
A unique descriptor for each HVAC System

Units Text, unique

Input Restrictions When applicable, this input should match the tags that are used on the plans.

Baseline Rules None

System Type

Applicability All system types

Definition A unique descriptor which identifies the following attributes of an HVAC System:

- Number of air decks (one to three);
- Constant or variable air flow;
- Type of terminal device; and
- Fan configuration for multiple deck systems.

Units None

Input Restrictions As designed

Baseline Rules Based on the prescribed system type (see [Figure 6.1.2-1](#) [1]). The baseline system types are shown in the table below.

Table 6.7.1-1: "Baseline Building System Type"

| Baseline Building System | System Type |
|--|---------------------------------|
| System 1 – PTAC | Single Zone Heating and Cooling |
| System 2 – PTHP | Single Zone Heating and Cooling |
| System 3 – PSZ-AC | Single Zone Heating and Cooling |
| System 4 – PSZ-HP | Single Zone Heating and Cooling |
| System 5 – Packaged VAV with Reheat | Single Duct VAV |
| System 6 – Packaged VAV with PFP boxes | Single Duct VAV |
| System 7 – VAV with Reheat | Single Duct VAV |
| System 8 – VAV with PFP boxes | Single Duct VAV |

Total Cooling Capacity

Applicability

All system types

Definition

The installed cooling capacity of the project. This includes all:

- Chillers;
- Built-up DX; and,
- Packaged cooling units.

Units Cooling tons (12,000 Btu/h per ton)

Input Restrictions As designed. This could be calculated by the program from the proposed design building description or a separate load calculation may be used. Unmet load hours for the simulation shall not exceed 300 annually. Weather conditions used in sizing runs shall be based on 1% dry-bulb and 1% wet-bulb cooling design temperatures.

| | |
|-----------------------|---|
| <i>Baseline Rules</i> | Autosize. The cooling capacity shall be oversized by 15%. If the number of unmet load hours of the proposed design exceeds the number of unmet load hours of the baseline by more than 50, decrease the cooling capacity as indicated in Figure 2.4-1 [2] and Figure 2.5.2-1 [3]. |
|-----------------------|---|

6.7.2 System Controls

Schedules

| Cooling Schedule | |
|---------------------------|---|
| <i>Applicability</i> | All cooling systems |
| <i>Definition</i> | A schedule that represents the availability of cooling |
| <i>Units</i> | Data structure: schedule, on/off |
| <i>Input Restrictions</i> | For tax deduction calculations, the fan schedules from Tables 12 through 16 of Appendix C shall be used for cooling availability. For green building ratings and Design to Earn ENERGY STAR, the schedules in Appendix C shall be used as a default. The cooling availability schedule shall be consistent with the supply fan schedule and thermostat schedules to reduce the likelihood of unmet load hours. |
| <i>Baseline Rules</i> | Same as the proposed design |
| Heating Schedule | |
| <i>Applicability</i> | All systems |
| <i>Definition</i> | A schedule that represents the availability of heating |
| <i>Units</i> | Data structure: schedule, on/off |
| <i>Input Restrictions</i> | For tax deduction calculations, the schedules from Tables 12 through 16 of Appendix C shall be used. For green building ratings and Design to Earn ENERGY STAR, the schedules in Appendix C shall be used as a default. The heating availability schedule shall be consistent with the supply fan schedule. |
| <i>Baseline Rules</i> | Same as the proposed design |
| Air-Handler Schedule | |
| <i>Applicability</i> | All systems that do not cycle with loads |
| <i>Definition</i> | A schedule that indicates when the air handler operates continuously |
| <i>Units</i> | Data structure: schedule, on/off |
| <i>Input Restrictions</i> | For the purpose of tax deduction calculations, the fan schedule is prescribed. One of the schedules from Appendix C, Tables 12-16 shall be used. |
| | For green building ratings and Design to Earn ENERGY STAR, the schedules in Appendix C are defaults, but other schedules may be used when detailed information is known about the proposed design. |
| | When a fan system serves several occupancies, the fan schedule must remain ON to serve the operating hours of each occupancy. |
| <i>Baseline Rules</i> | Same as the proposed design |
| Air Handler Fan Cycling | |
| <i>Applicability</i> | All fan systems |
| <i>Definition</i> | This building descriptor indicates whether the system supply fan operates continuously or cycles with building loads. The fan systems in most commercial buildings operate continuously. |
| <i>Units</i> | List: continuous or cycles with loads |
| <i>Input Restrictions</i> | Continuous fan operation during occupied periods is a prescribed input, except for hotel guest rooms and high-rise residential. For these building types, continuous operation is the default, however, the option to let the fan cycle with loads may be used when the following conditions are met and documented: <ul style="list-style-type: none"> • The spaces served by the system are located within 25 ft of an operable window. • The openable window area is at least 4% of the floor space. • Other requirements for natural ventilation specified in ASHRAE Standard 62.1-2007, Section 5.1 are satisfied. For natural ventilation systems, an air conditioner is modeled in the proposed design even though one is not specified for the proposed design. This fan in the simulated air conditioner is allowed to cycle with loads since the simulated air conditioner is assumed to operate only when natural ventilation is unable to satisfy thermal comfort. |
| <i>Baseline Rules</i> | Same as proposed design, except for natural ventilation, in which case the fans in the baseline building are assumed to operate continuously |
| Optimum Start Control | |
| <i>Applicability</i> | Systems with the control capability for flexible scheduling of system start time based on building loads. |
| <i>Definition</i> | Optimum start control adjusts the start time of the HVAC unit such that the space is brought to setpoint just prior to occupancy. This control strategy modifies the heating, cooling, and fan schedules. |
| <i>Units</i> | Boolean (Yes/No) |
| <i>Input Restrictions</i> | As designed |

| | |
|---------------------------|--|
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The baseline building shall have optimum start controls when the baseline building design supply airflow is greater than 10,000 cfm. |

Night-Cycle HVAC Fan Control

| | |
|---------------------------|---|
| <i>Applicability</i> | All systems |
| <i>Definition</i> | <p>The control of an HVAC system that is triggered by the heating or cooling temperature setpoint for thermal blocks during periods when the heating, cooling and fan systems are scheduled to be off. The choices are:</p> <ul style="list-style-type: none"> • Cycle on call from any zone • Cycle on call from the primary control zone • Stay off • Cycle zone fans only (for systems with fan-powered boxes) Restart fans below given ambient temperature. |
| <i>Units</i> | None |
| <i>Input Restrictions</i> | As designed. However, night-cycle control shall be cycled on call from any zone for heating in climate zones 2 through 8, and for cooling in climate zones 1b, 2b, and 3b. |
| <i>Baseline Rules</i> | Cycle on call from any zone |

Cooling Control

Cooling Supply Air Temperature

| | |
|---------------------------|--|
| <i>Applicability</i> | Applicable to all systems |
| <i>Definition</i> | The supply air temperature setpoint at design cooling conditions |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | 20°F lower than the design room air temperature |

Cooling Supply Air Temperature Control

| | |
|---------------------------|--|
| <i>Applicability</i> | Any system with multiple cooling stages or unloading |
| <i>Definition</i> | <p>The method of controlling the supply air temperature. Choices are:</p> <ul style="list-style-type: none"> • Fixed (constant) • Reset by warmest zone • Reset by outside air dry-bulb temperature • Scheduled setpoint |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | For baseline building systems 1 through 4, the SAT control is not applicable. For systems 5 through 8, the SAT control shall be reset by outside dry-bulb temperature. |

Cooling Reset Schedule by OSA

| | |
|----------------------|--|
| <i>Applicability</i> | When the proposed design resets SAT by outside air dry-bulb temperature |
| <i>Definition</i> | <p>A linear reset schedule that represents the SAT setpoint as a function of outdoor air dry-bulb temperature. This schedule is defined by the following data points (see Figure 6.7.2-1 [4]):</p> <ul style="list-style-type: none"> • The coldest cooling supply air temperature • The corresponding (hot) outdoor air dry-bulb setpoint • The warmest cooling supply air temperature • The corresponding (cool) outdoor air dry-bulb setpoint |




Figure 6.7.2-1: "SAT Cooling Setpoint Reset based on Outdoor Air Temperature (OAT) for Dry (B) and Marine (C) Climates"




Figure 6.7.2-2: "SAT cooling setpoint reset based on outdoor air temperature for humid 'A' climates"

| | |
|--------------------|---|
| Units | Data structure (two matched pairs of SAT and OAT, see above) |
| Input Restrictions | As designed |
| Baseline Rules | Applicable for baseline building systems 5 through 8. For these systems, the minimum SAT shall be equal to the design conditions SAT when OAT is equal to or greater than 80 F. The maximum SAT shall be 5 F greater than the minimum when the OAT is 60 F or less. |

Heating Control

| | |
|--|--|
| Preheat Setpoint | |
| Applicability | Systems with a preheat coil located in the outside air stream |
| Definition | The control temperature leaving the preheat coil |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed |
| Baseline Rules | Same as the proposed design |
| Heating Supply Air Temperature | |
| Applicability | All systems |
| Definition | The supply air temperature leaving the air handler when the system is in a heating mode (not the air temperature leaving the reheat coils in VAV boxes) |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed |
| Baseline Rules | 110°F for system types 1-4; 70°F for system types 5-8 |
| Heating Supply Air Temperature Control | |
| Applicability | Systems with the capability to vary heating SAT |
| Definition | The method of controlling heating SAT. Choices are: <ul style="list-style-type: none">• Fixed (constant)• Reset by coldest zone• Reset by outside air dry-bulb temperature• Scheduled setpoint |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed |
| Baseline Rules | Fixed (constant) |
| Heating Reset Schedule by OSA | |
| Applicability | Systems that reset the heating SAT by outside dry-bulb temperature (this typically applies to dual-duct systems or to single zone systems with hydronic heating coils) |
| Definition | A linear reset schedule that represents the heating supply air temperature or hot deck supply air temperature (for dual duct systems) as a function of outdoor air dry-bulb temperature. This schedule is defined by the following data points (see Figure 6.7.2-3 [5]): <ul style="list-style-type: none">• The hottest heating supply air temperature• The corresponding (cold) outdoor air dry-bulb threshold• The coolest heating supply air temperature• The corresponding (mild) outdoor air dry-bulb threshold |




Figure 6.7.2-3: "Example of SAT heating setpoint reset based on outdoor air temperature (OAT)."

| | |
|---------------------------|---------------------|
| <i>Units</i> | Data structure (°F) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Night Purge

The baseline building does not have night purge controls. If the software supports it and the proposed design has the features, the following keywords may be used to model night purge. Note that night purge is coupled with thermal mass in the building, which is specified by other building descriptors.

Night Purge Availability Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems that operate the fans for nighttime purge of heat gains |
| <i>Definition</i> | A schedule which represents the availability of night purge controls. |
| <i>Units</i> | Data structure: schedule, on/off |
| <i>Input Restrictions</i> | As designed. The default is no night purge control. |
| <i>Baseline Rules</i> | Not applicable |

Night Purge Control

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems that operate the fans for nighttime purge of heat gains |
| <i>Definition</i> | The control strategy for operation of nighttime purge. The control strategy may take account of indoor temperature, season, indoor temperature and other factors. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Night Purge Fan Ratio

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems that operate the fans for nighttime purge of heat gains |
| <i>Definition</i> | The ratio of fan speed for a night purge cycle. |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed. The default is 100% (or fans available at full speed). |
| <i>Baseline Rules</i> | Not applicable |

6.7.3 Fan Systems

Baseline Building Fan System Summary

The baseline building fan system is summarized in this section. See [Figure 6.1.2-1](#) [1] for the HVAC baseline building system mapping.

Total baseline building fan system power for the baseline building fan systems is given in [Table 6.7.3-1](#) [6] for ASHRAE Standard 90.1-2007 and [Table 6.7.3-1](#) [7] for ASHRAE Standard 90.1-2001. In these tables, "cfms" is the supply fan air flow at peak design conditions. This is calculated for the baseline building with the sizing procedure described in [Figure 2.4-1](#) [2] and [Figure 2.5.2-1](#) [3]. This brake horsepower includes the supply fan, the return fan, and exhaust fans. Exhaust fans include kitchen hoods, toilets, fume hoods, and other miscellaneous fans that operate at design conditions.

Table 6.7.3-1: "Baseline Building Fan System – ASHRAE Standard 90.1-2007"

| | System Types 1-2 | System Types 3-4 | System Types 5-8 |
|--|---------------------------|---|---|
| Brake Horsepower (bhp) | Not applicable | $0.00094 \times \text{cfm}_s + A$ | $0.0013 \times \text{cfm}_s + A$ |
| Fan Motor Efficiency (hm) | Not applicable | ASHRAE Standard 90.1-2007, Table 10.8 | ASHRAE Standard 90.1-2007, Table 10.8 |
| Fan Power (W) | $0.3 \times \text{cfm}_s$ | $(\text{bhp} \times 746) / \text{TeX Embedding failed!m}$ | $(\text{bhp} \times 746) / \text{TeX Embedding failed!m}$ |
| The term “A” for system types 3-8, is calculated based on equipment in the proposed design using the procedure in Table 6.5.3.1.1B of ASHRAE Standard 90.1-2007. This accounts for various additional fan pressure drops associated with special conditions. | | | |

Table 6.7.3-2: "Baseline Building Fan System – ASHRAE Standard 90.1-2001"

| | Fan Size | System Types 1-4 | System Types 5-8 |
|----------------------------|---------------|---|---|
| Nameplate Horsepower (nhp) | < 20,000 cfm | $0.0012 \times \text{cfm}_s + P_{\text{filter}} + P_{\text{process}} + P_{\text{relief}}$ | $0.0017 \times \text{cfm}_s + P_{\text{filter}} + P_{\text{process}} + P_{\text{relief}}$ |
| | => 20,000 cfm | $0.0011 \times \text{cfm}_s + P_{\text{filter}} + P_{\text{process}} + P_{\text{relief}}$ | $0.0015 \times \text{cfm}_s + P_{\text{filter}} + P_{\text{process}} + P_{\text{relief}}$ |
| Fan Motor Efficiency (hm) | | ASHRAE Standard 90.1-2001, Table 10.2 | ASHRAE Standard 90.1-2001, Table 10.2 |
| Brake Horsepower (bhp) | | $\text{nhp} \times \text{TeX Embedding failed!m}$ | $\text{nhp} \times \text{TeX Embedding failed!m}$ |
| Fan Power (W) | | $(\text{bhp} \times 746) / \text{TeX Embedding failed!m}$ | $(\text{bhp} \times 746) / \text{TeX Embedding failed!m}$ |

The terms Pfilter, Pprocess, and Prelief account for additional pressure drop. These are based on features in the proposed design such as special filtration, process fans, and relief or return fans. See Section 6.3.3.1 of ASHRAE Standard 90.1-2001 and the associated User's Manual for details on how to calculate these adders.

When the proposed design has exhaust fans (toilets or kitchens), return fans, or fume hood exhaust systems, the baseline building has the same systems. The brake horsepower determined from [Table 6.7.3-1](#) [6] and [Table 6.7.3-1](#) [7] is allocated to these baseline building fan systems proportionally to the allocation in the proposed design. The allocation of brake horsepower to the supply fan, the return and any exhaust or fume hood fans is based on the ratios described below.

Supply Fan Ratio

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems that serve thermal blocks that have exhaust, fume hoods, kitchen exhaust or return fans |
| <i>Definition</i> | The ratio of supply fan brake horsepower in the proposed design to total fan system brake horsepower for the proposed design at design conditions |
| <i>Units</i> | Unitless ratio |
| <i>Input Restrictions</i> | Derived from other building descriptors |
| <i>Baseline Rules</i> | Same as proposed design |

Return Fan Ratio

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems that serve thermal blocks that have exhaust, fume hoods, kitchen exhaust or return fans |
| <i>Definition</i> | The ratio of return fan brake horsepower in the proposed design to total fan system brake horsepower for the proposed design at design conditions |
| <i>Units</i> | Unitless ratio |
| <i>Input Restrictions</i> | Derived from other building descriptors |
| <i>Baseline Rules</i> | Same as proposed design |

Exhaust Fan Ratio

| | |
|---------------------------|--|
| <i>Applicability</i> | Systems that serve thermal blocks that have exhaust, fume hoods, kitchen exhaust or return fans |
| <i>Definition</i> | The ratio of exhaust fan brake horsepower in the proposed design to total fan system brake hp for the proposed design at design conditions. Exhaust fans include toilet exhaust, kitchen hoods and other miscellaneous exhaust. Fume hood exhaust is treated separately. |
| <i>Units</i> | Unitless ratio |
| <i>Input Restrictions</i> | Derived from other building descriptors. In the event that a common exhaust system serves thermal blocks that are served by different HVAC systems, the brake horsepower shall be divided in proportion to design cfm. |
| <i>Baseline Rules</i> | Same as proposed design |

Supply Fans

Fan System Modeling Method

| | |
|----------------------|--|
| <i>Applicability</i> | All fan systems |
| <i>Definition</i> | Software commonly models fans in three ways. |

- Power-per-unit-flow. The simple method is for the user to enter the electric power per unit of flow (W/cfm). This method is commonly used for unitary equipment and other small fan systems.

- Static pressure. A more detailed method is to model the fan as a system whereby the static pressure, fan efficiency, part-load curve, and motor efficiency are specified at design conditions.
- Break horsepower. A third method is to specify brake horsepower at design conditions instead of fan efficiency and static pressure. This is a variation of the second method whereby brake horsepower is specified in lieu of static pressure and fan efficiency. The latter two methods are commonly used for VAV and other larger fan systems.

| | |
|---------------------------|--|
| <i>Units</i> | List: power-per-unit-flow, static pressure or brake horsepower |
| <i>Input Restrictions</i> | As designed. The power-per-unit-flow method shall be used when no fan performance data is available for the proposed design cooling system, e.g. only EER or SEER are available. |
| <i>Baseline Rules</i> | If the proposed design uses the power-per-unit-flow method, the baseline building shall also use this method, otherwise the baseline building shall use the brake horsepower method. |

Supply Fan Design Air Rated Capacity

| | |
|---------------------------|---|
| <i>Applicability</i> | All fan systems |
| <i>Definition</i> | The design air flow rate of the supply fan(s) at design conditions. This building descriptor sets the 100% point for the fan part-load curve. |
| <i>Units</i> | cfm |
| <i>Input Restrictions</i> | As designed. This input should be at least as great as the sum of the design air flow specified for each of the thermal blocks that are served by the fan system. For multiple deck systems, a separate entry should be made for each deck. |
| <i>Baseline Rules</i> | The program shall automatically size the air flow at each thermal block to meet the loads. The design air flow rate calculation shall be based on a 20 degree temperature differential between supply air and the room air. The supply fan design air flow rate shall be the sum of the calculated design air flow for the thermal blocks served by the fan system. |

Fan Control Method

| | |
|---------------------------|--|
| <i>Applicability</i> | All fan systems |
| <i>Definition</i> | A description of how the supply (and return/relief) fan(s) are controlled. The options include: <ul style="list-style-type: none"> • Constant volume • Variable-flow, inlet or discharge dampers • Variable-flow, inlet guide vanes • Variable-flow, variable speed drive (VSD) • Variable-flow, variable pitch blades • Variable-flow, other • Two-speed • Constant volume, cycling (fan cycles with heating and cooling) |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Applicable to variable air volume systems Based on the prescribed system type. Refer to the HVAC System Map in Figure 6.1.2-1 [1]. |

Table 6.7.3-3: "Baseline Building Fan Control Method"

| Baseline building System | Fan Control Method |
|--|---|
| System 1 – PTAC | Constant volume |
| System 2 – PTHP | Constant volume |
| System 3 – PSZ-AC | Constant volume |
| System 4 – PSZ-HP | Constant volume |
| System 5 – Packaged VAV with Reheat | Variable-flow, variable speed drive (VSD) |
| System 6 – Packaged VAV with PFP boxes | Variable-flow, variable speed drive (VSD) |
| System 7 – VAV with Reheat | Variable-flow, variable speed drive (VSD) |
| System 8 – VAV with PFP boxes | Variable-flow, variable speed drive (VSD) |

Supply Fan Brake Horsepower

| | |
|---------------------------|---|
| <i>Applicability</i> | All fan systems, except those specified using the power-per-unit-flow method |
| <i>Definition</i> | The design shaft brake horsepower of the supply fan(s). This input does not need to be supplied if the Supply Fan kW is supplied. |
| <i>Units</i> | Horsepower (hp) |
| <i>Input Restrictions</i> | As designed. If this building descriptor is specified for the proposed design, then the <i>Static Pressure</i> and <i>Fan Efficiency</i> are not. |
| <i>Baseline Rules</i> | See Table 6.7.3-1 [6] for ASHRAE Standard 90.1-2007 and Table 6.7.3-1 [7] for ASHRAE Standard 90.1-2001. These tables give the baseline building fan system brake horsepower. The brake horsepower for the supply fan is this value times the Supply Fan Ratio (see above). |

Supply Fan Static Pressure

| | |
|----------------------|--|
| <i>Applicability</i> | All fan systems, except those specified using the power-per-unit-flow method |
| <i>Definition</i> | The design static pressure for the supply fan. This is important for both fan electric energy usage and duct heat gain |

| | |
|---------------------------|--|
| | calculations. |
| <i>Units</i> | Inches of water column (in. H ₂ O) |
| <i>Input Restrictions</i> | As designed. The design static pressure for the supply fan does not need to be specified if the supply fan brake horsepower (bhp) is specified. |
| <i>Baseline Rules</i> | Not applicable. When <i>Static Pressure</i> and <i>Fan Efficiency</i> are entered for the proposed design, the baseline building shall use <i>Brake Horsepower</i> . |

| Supply Fan Efficiency | |
|---------------------------|--|
| <i>Applicability</i> | All fan systems, except those specified using the power-per-unit-flow method |
| <i>Definition</i> | The efficiency of the fan at design conditions |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | As designed. The supply fan efficiency does not need to be specified if the supply fan brake horsepower (bhp) is specified. |
| <i>Baseline Rules</i> | Not applicable. When <i>Static Pressure</i> and <i>Fan Efficiency</i> are entered for the proposed design, the baseline building shall use <i>Brake Horsepower</i> . |

| Supply Motor Efficiency | |
|---------------------------|---|
| <i>Applicability</i> | All supply fans, except those specified using the power-per-unit-flow method |
| <i>Definition</i> | The full-load efficiency of the motor serving the supply fan |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | As designed. Not applicable when the power-per-unit-flow method is used. |
| <i>Baseline Rules</i> | From Table 10.8 of ASHRAE Standard 90.1-2007 or Table 10.2 of ASHRAE Standard 90.1-2001 |

| Fan Position | |
|---------------------------|--|
| <i>Applicability</i> | All supply fans |
| <i>Definition</i> | The position of the supply fan relative to the cooling coil. The configuration is either draw through (fan is downstream of the coil) or blow through (fan is upstream of the coil). |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | Draw through |

| Motor Position | |
|---------------------------|---|
| <i>Applicability</i> | All supply fans |
| <i>Definition</i> | The position of the supply fan motor relative to the cooling air stream. The choices are: in the air stream or out of the air stream. |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | In the air stream |

| Fan Part-Flow Power Curve | |
|---------------------------|--|
| <i>Applicability</i> | All variable flow fan systems |
| <i>Definition</i> | A part-load power curve which represents the percentage full-load power draw of the supply fan as a function of the percentage full-load air flow. The curve is typically represented as a quadratic equation with an absolute minimum power draw specified. |
| <i>Units</i> | Unitless ratio |
| <i>Input Restrictions</i> | As designed. The default fan curve shall be selected from Equation (6.7.3-1) and Table 6.7.3-4 [8] for the type of fan specified in the proposed design. |

(6.7.3-1)

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

where

| | |
|---------------|---|
| PLR | Ratio of fan power at part load conditions to full load fan power |
| PowerMin | Minimum fan power |
| FanRatio | Ratio of cfm at part-load to full-load cfm |
| a, b, c and d | Constants from Table 6.7.3-4 [8] below |

Table 6.7.3-4: "Fan Curve Default Values"

| Fan Type - Control Type | a | b | c | d | %Power _{Min} |
|--|--------|--------|---------|--------|-----------------------|
| AF or BI riding the curve ^a | 0.1631 | 1.5901 | -0.8817 | 0.1281 | 70% |

| | | | | | |
|---|---------------|---------------|---------------|----------------|------------|
| AF or BI with inlet vanesa | 0.9977 | -0.659 | 0.9547 | -0.2936 | 50% |
| FC riding the curvea | 0.1224 | 0.612 | 0.5983 | -0.3334 | 30% |
| FC with inlet vanesa | 0.3038 | -0.7608 | 2.2729 | -0.8169 | 30% |
| Vane-axial with variable pitch bladesa | 0.1639 | -0.4016 | 1.9909 | -0.7541 | 20% |
| Any fan with VSD (use for baseline building)^b | 0.0013 | 0.1470 | 0.9506 | -0.0998 | 20% |
| VSD with static pressure reset ^c | -0.0031 | 0.0991 | 1.0268 | -0.1128 | 20% |

Data Sources:

- ECB Compliance Supplement, public review draft, Version 1.2, March 1996, but adjusted to be relatively consistent with the curve specified in the PRM.
- The fan curve for VSD is specified in Table G3.1.3.15
- Advanced VAV System Design Guide, California Energy Commission, CEC Publication 500,-03-082 A-11, April 2005, but adjusted to be relatively consistent with the curve specified in the PRM.

Baseline Rules

Not applicable for baseline building systems 1-4. The curve for VSD fans shall be used for baseline building systems 5-8 with no adjustment for static pressure setpoint reset.

Supply Fan kW

Applicability Fan systems that use the power-per-unit-flow method

Definition The supply fan power per unit of flow.

Units kW/cfm

Input Restrictions

As designed or specified in the manufacturers' literature. For units with rated total cooling capacities less than 120,000 Btu/h, the user may default to a value calculated as follows:

(6.7.3-2)

TeX Embedding failed!

where

Fan_{kW} The supply fan power (kW)

Q_{rated} The rated total cooling capacity (Btu/h)

Baseline Rules

Applicable when the baseline building uses the power-per-unit-flow method. Fan power is determined using [Table 6.7.3-1 \[6\]](#) for ASHRAE Standard 90.1-2007 and [Table 6.7.3-1 \[7\]](#) for ASHRAE Standard 90.1-2001. This power is then multiplied by the supply fan ratio.

Relief Fans

The baseline building has a return fan when the baseline building system is type 3 through 8 and the proposed design has a return fan.

Plenum Zone

Applicability Any system with return ducts or return air plenum

Definition A reference to the thermal block that serves as return plenum or where the return ducts are located

Units Text, unique

Input Restrictions As designed

Baseline Rules Applicable when the baseline building has a return fan. Same as the proposed design when the proposed design has a plenum, otherwise, the return air ducts are assumed to be located in the space.

Return Air Path

Applicability Any system with return ducts or return air plenum

Definition Describes the return path for air. This can be one of the following: ducted return; plenum return; or direct-to-unit.

Units List (see above)

Input Restrictions As designed

Baseline Rules Applicable when the baseline building has a return fan. For baseline building systems 1 and 2, the return air path shall be direct-to-unit. For baseline building systems 3 through 8 and when the proposed design is direct-to-unit, the baseline building shall be ducted return, otherwise the baseline building return air path shall be same as proposed design.

Return/Relief Air Rated Capacity

Applicability All systems with a return or relief fan

Definition The design air flow fan capacity of the return or relief fan(s). This sets the 100% fan flow point for the part-load curve (see below).

Units cfm

Input Restrictions As designed

Baseline Rules Applicable when the baseline building has a return fan. The return fan air *Rated Capacity* shall be equal to the baseline

building supply fan capacity less exhaust air flow.

Return/Relief Fan Brake Horsepower

| | |
|---------------------------|--|
| <i>Applicability</i> | Any system with return or relief fans that uses the brake horsepower method |
| <i>Definition</i> | The design shaft brake horsepower of the return/relief fan(s) |
| <i>Units</i> | Brake horsepower (bhp) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Applicable when the baseline building has a return fan. The bhp of the return fan shall be the fan system brake horsepower (see Table 6.7.3-1 [6] and Table 6.7.3-1 [7]) times the return fan ratio. In other words, brake horsepower is allocated in proportion to the proposed design. |

Return/Relief Design Static Pressure

| | |
|---------------------------|--|
| <i>Applicability</i> | Any system with return or relief fans that uses the static pressure method |
| <i>Definition</i> | The design static pressure for return fan system. This is important for both fan electric energy usage and duct heat gain calculations. |
| <i>Units</i> | Inches of water column (in. H ₂ O) |
| <i>Input Restrictions</i> | As designed. The design static pressure for the return fan does not need to be specified if the return fan brake horsepower (bhp) is specified. |
| <i>Baseline Rules</i> | Not applicable. When <i>Static Pressure</i> and <i>Fan Efficiency</i> are entered for the proposed design, the baseline building shall use <i>Brake Horsepower</i> . |

Return/Relief Fan Efficiency

| | |
|---------------------------|--|
| <i>Applicability</i> | Any system with return or relief fans that uses the static pressure method |
| <i>Definition</i> | The efficiency of the fan at design conditions |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | As designed. The return/relief fan efficiency does not need to be specified if the return fan brake horsepower (bhp) is specified. |
| <i>Baseline Rules</i> | Not applicable. When <i>Static Pressure</i> and <i>Fan Efficiency</i> are entered for the proposed design, the baseline building shall use <i>Brake Horsepower</i> . |

Return/Relief Motor Efficiency

| | |
|---------------------------|---|
| <i>Applicability</i> | All return fans, except those specified using the power-per-unit-flow method |
| <i>Definition</i> | The full-load efficiency of the motor serving the supply fan |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | As designed. Not applicable when the power-per-unit-flow method is used. |
| <i>Baseline Rules</i> | From Table 10.8 of ASHRAE Standard 90.1-2007 or Table 10.2 of ASHRAE Standard 90.1-2001 |

Motor Position

| | |
|---------------------------|---|
| <i>Applicability</i> | All return fans |
| <i>Definition</i> | The position of the supply fan motor relative to the cooling air stream. The choices are: in the air stream or out of the air stream. |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | In the air stream |

Fan Part-Flow Power Curve

| | |
|---------------------------|--|
| <i>Applicability</i> | All return fans for variable flow fan systems. |
| <i>Definition</i> | A part-load power curve which represents the percentage full-load power draw of the supply fan as a function of the percentage full-load air flow. |
| <i>Units</i> | Unitless ratio |
| <i>Input Restrictions</i> | As designed. The default fan curve shall be selected from Equation (6.7.3-1) and Table 6.7.3-4 [8] for the type of fan specified in the proposed design. |
| <i>Baseline Rules</i> | Not applicable for baseline building systems 1-4. The curve for VSD fans shall be used for baseline building systems 5-8 that have a return/relief fan. |

Return/Relief Fan kW

| | |
|---------------------------|--|
| <i>Applicability</i> | Any system with a return fan |
| <i>Definition</i> | The supply fan power per unit of flow |
| <i>Units</i> | kW/cfm |
| <i>Input Restrictions</i> | As specified in the manufacturers' literature |
| <i>Baseline Rules</i> | Applicable when the baseline building uses the power-per-unit-flow method. Fan power is determined using Table 6.7.3-1 [6] for ASHRAE Standard 90.1-2007 and Table 6.7.3-1 [7] for ASHRAE Standard 90.1-2001. This power is then multiplied by the return fan ratio. |

Exhaust Fan Systems

Exhaust fans include toilet exhaust, kitchen exhaust, as well as fume hoods in laboratories and other spaces. Some systems typically operate at constant flow, while flow varies for other systems depending on, for instance, the position of the sash for fume hoods. Exhaust fan flow is

specified and scheduled for each thermal block. An exhaust fan system may serve multiple thermal blocks. The baseline building has exhaust fans when the proposed design has exhaust fans. The exhaust air flow is the same for the baseline building and the proposed design.

Exhaust Fan Name

| | |
|---------------------------|--|
| <i>Applicability</i> | All exhaust systems serving multiple thermal blocks |
| <i>Definition</i> | A unique descriptor for each exhaust fan. This should be keyed to the construction documents, if possible, to facilitate plan checking. Exhaust rates and schedules at the thermal block level refer to this name. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | Where applicable, this should match the tags that are used on the plans. |
| <i>Baseline Rules</i> | The baseline building will have an exhaust system that corresponds to the proposed design. The name can be identical to that used for the proposed design or some other appropriate name may be used. |

Exhaust Fan System Modeling Method

| | |
|---------------------------|--|
| <i>Applicability</i> | All exhaust fan systems |
| <i>Definition</i> | Software commonly models fans in three ways. See definition for supply system modeling method. |
| <i>Units</i> | List: power-per-unit-flow, static pressure or brake horsepower |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | If the proposed design uses the power-per-unit-flow method, the baseline building shall also use this method, otherwise the baseline building shall use the brake horsepower method. |

Exhaust Fan Rated Capacity

| | |
|---------------------------|---|
| <i>Applicability</i> | All exhaust systems |
| <i>Definition</i> | The rated design air flow rate of the exhaust fan system. This building descriptor defines the 100% flow case for the part-flow curve. Actual air flow is the sum of the flow specified for each thermal block, as modified by the schedule for each thermal block. |
| <i>Units</i> | cfm |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as proposed design |

Fan Control Method

| | |
|---------------------------|---|
| <i>Applicability</i> | All exhaust fan systems |
| <i>Definition</i> | A description of how the exhaust fan(s) are controlled. The options include: <ul style="list-style-type: none">• Constant volume• Two-speed• Variable-flow, inlet or discharge dampers• Variable-flow, inlet guide vanes• Variable-flow, variable speed drive (VSD)• Variable-flow, variable pitch blades |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed, however, when exhaust fan flow at the thermal block level is varied through a schedule, one of the variable-flow options shall be specified. |
| <i>Baseline Rules</i> | The baseline building exhaust fan control shall generally be the same as the proposed design. For laboratories that have exhaust flow of 5,000 cfm or more, the baseline building exhaust flow shall vary in response to scheduled fume hood exhaust and lab zone airflow schedules. Fume hood exhaust flow control shall be the same as design, and general exhaust (relief) shall be VSD. |

Exhaust Fan Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All exhaust fan systems |
| <i>Definition</i> | A schedule that indicates when the exhaust fan system is available for operation. Exhaust fan flow is specified at the thermal block level. |
| <i>Units</i> | Data structure: schedule, on/off |
| <i>Input Restrictions</i> | The exhaust fan system shall be available during all periods when one or more thermal blocks served by the system are scheduling exhaust. |
| <i>Baseline Rules</i> | Same as the proposed design |

Exhaust Fan Brake Horsepower

| | |
|---------------------------|---|
| <i>Applicability</i> | All exhaust fan systems |
| <i>Definition</i> | The design shaft brake horsepower of the exhaust fan(s). |
| <i>Units</i> | Brake horsepower (bhp) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The bhp for the baseline building is the total system fan horsepower from Table 6.7.3-1 [6] or Table 6.7.3-1 [7] times the exhaust fan ratio. |

Exhaust Fan Design Static Pressure

| | |
|----------------------|--|
| <i>Applicability</i> | Any system with return or relief fans that uses the static pressure method |
| <i>Definition</i> | The design static pressure for exhaust fan system. This is important for both fan electric energy usage and duct heat gain calculations. |

| | |
|---------------------------|---|
| <i>Units</i> | Inches of water column (in. H ₂ O) |
| <i>Input Restrictions</i> | As designed. The design static pressure for the exhaust fan does not need to be specified if the exhaust fan brake horsepower (bhp) is specified. |
| <i>Baseline Rules</i> | Not applicable. When static pressure and fan efficiency are entered for the proposed design, the baseline building shall use brake horsepower. |

Exhaust Fan Efficiency

| | |
|---------------------------|--|
| <i>Applicability</i> | Any exhaust fan system that uses the static pressure method |
| <i>Definition</i> | The efficiency of the exhaust fan at rated capacity |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | As designed. The exhaust fan efficiency does not need to be specified if the return fan brake horsepower (bhp) is specified. |
| <i>Baseline Rules</i> | Not applicable. When static pressure and fan efficiency are entered for the proposed design, the baseline building shall use brake horsepower. |

Exhaust Fan Motor Efficiency

| | |
|---------------------------|---|
| <i>Applicability</i> | All exhaust fan systems |
| <i>Definition</i> | The full-load efficiency of the motor serving the exhaust fan |
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | From Table 10.8 of ASHRAE Standard 90.1-2007 or Table 10.2 of ASHRAE Standard 90.1-2001 |

Fan Part-Flow Power Curve

| | |
|---------------------------|--|
| <i>Applicability</i> | All variable flow exhaust fan systems |
| <i>Definition</i> | A part-load power curve which represents the ratio full-load power draw of the exhaust fan as a function of the ratio full-load air flow. |
| <i>Units</i> | Unitless ratio |
| <i>Input Restrictions</i> | As designed. The default fan curve shall be selected from Equation (6.7.3-1) and Table 6.7.3-4 [8] for the type of fan specified in the proposed design. |
| <i>Baseline Rules</i> | The baseline building fan curve shall be selected from Equation (6.7.3-1) and Table 6.7.3-4 [8] for the type of fan specified in the proposed design. |

Exhaust Fan KW

| | |
|---------------------------|---|
| <i>Applicability</i> | All exhaust systems |
| <i>Definition</i> | The fan power of the exhaust fan per unit of flow. This building descriptor is applicable only with the power-per-unit-flow method. |
| <i>Units</i> | W/cfm |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | The fan system power from Table 6.7.3-1 [6] or Table 6.7.3-1 [7] |

6.7.4 Outdoor Air Controls and Economizers

Outside Air Controls

Maximum Outside Air Ratio

| | |
|---------------------------|---|
| <i>Applicability</i> | All systems with modulating outside air dampers |
| <i>Definition</i> | The descriptor is used to limit the maximum amount of outside air that a system can provide as a percentage of the design supply air. It is used where the installation has a restricted intake capacity. |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | 1.0 |

Design Outside Air Flow

| | |
|---------------------------|--|
| <i>Applicability</i> | All systems with outside air dampers |
| <i>Definition</i> | The rate of outside air that needs to be delivered by the system at design conditions. This input may be derived from the sum of the design outside air flow for each of the zones served by the system. |
| <i>Units</i> | cfm |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as proposed design. This input along with occupant density determines if the zones served by the system shall have demand control ventilation. See <i>ventilation control method</i> at the zone level. |

Outdoor Air Control Method

| | |
|----------------------|--|
| <i>Applicability</i> | All HVAC systems that deliver outside air to zones |
| <i>Definition</i> | The method of determining the amount of outside air that needs to be delivered by the system. Each of the zones served by the system report their outside air requirements on an hourly basis. The options for determining the outside air at the zone level are discussed above. This control method addresses how the system responds to this information on an hourly basis. Options include: |

Options include:

- Average Flow. The outside air delivered by the system is the sum of the outside air requirement for each zone, without taking into account the position of the VAV damper in each zone. The assumption is that there is mixing between zones through the return air fan.
- Critical Zone. The critical zone is the zone with the highest ratio of outside air to supply air. The assumption is that there is no mixing between zones. This method will provide greater outside air than the average flow method because when the critical zone sets the outside air fraction at the system, the other zones are getting greater outside air than required.

The quantity of outside air can be controlled in a number of ways, but a common method is to install a flow station at the outside air supply which modulates the position of the outside air and return dampers to maintain the desired outside air flow. With the average flow, a CO₂ sensor in the return air duct is another way to control the position of the outside air and return dampers.

| | |
|---------------------------|-------------------------|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as proposed design |

Air Side Economizers

Economizer Control Type

| | |
|----------------------|---|
| <i>Applicability</i> | All systems with an air-side economizer |
| <i>Definition</i> | An air-side economizer increases outside air ventilation during periods when refrigeration loads can be reduced from increased outside air flow. The control types include: <ul style="list-style-type: none"> • No economizer • Fixed dry-bulb. The system shifts to 100% outside air and shuts off the cooling when the temperature of the outside air is equal to or lower than the supply air temperature. • Differential dry-bulb. The system shifts to 100% outside air when the temperature of the outside air is lower than the return air temperature but continues to operate the cooling system until the outside air temperature reaches the supply air temperature. • Fixed enthalpy. The system shifts to 100% outside air and shuts off the cooling when the enthalpy of the outside air is equal to or lower than the supply air enthalpy. • Differential enthalpy. The system shifts to 100% outside air when the enthalpy of the outside air is lower than the return air enthalpy but continues to operate the cooling system until the outside air enthalpy reaches the supply air enthalpy. |

| | |
|---------------------------|--|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The control should be <i>no economizer</i> when the baseline building cooling capacity <i>TeX Embedding failed!</i> 50 tons AND the baseline building system total cooling capacity <i>TeX Embedding failed!</i> 95,000 Btu/h. Otherwise, the control should be based on the prescribed system type as shown in Table 6.7.4-1 [9]. |

Table 6.7.4-1: "Baseline Economizer Control Type"

| Baseline building System | Economizer Control |
|--|---|
| System 1 – PTAC | None |
| System 2 – PTHP | None |
| System 3 – PSZ-AC | Differential dry-bulb None in climate zones 1a-4a and 1b |
| System 4 – PSZ-HP | Differential dry-bulb None in climate zones 1a-4a and 1b |
| System 5 – Packaged VAV with Reheat | Differential dry-bulb None in climate zones 1a-4a and 1b |
| System 6 – Packaged VAV with PFP boxes | Differential dry-bulb None in climate zones 1a-4a and 1b |
| System 7 – VAV with Reheat | Differential dry-bulb None in climate zones 1a-4a and 1b |
| System 8 – VAV with PFP boxes | Differential dry-bulb None in climate zones 1a-4a and 1b |

Economizer High Temperature Lockout

| | |
|----------------------|--|
| <i>Applicability</i> | Systems with fixed <i>dry-bulb</i> economizer |
| <i>Definition</i> | The outside air setpoint temperature above which the economizer will return to minimum position. |
| <i>Units</i> | Degrees Fahrenheit (°F) |

| | |
|---|---|
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |
| Economizer Low Temperature Lockout | |
| <i>Applicability</i> | Systems with air-side economizers |
| <i>Definition</i> | A feature that permits the lockout of economizer operation (return to minimum outside air position) when the outside air temperature is below the lockout setpoint. |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not used |
| Economizer High Enthalpy Lockout | |
| <i>Applicability</i> | Systems with fixed enthalpy or differential enthalpy economizers |
| <i>Definition</i> | The outside air enthalpy above which the economizer will return to minimum position |
| <i>Units</i> | Btu/lb |
| <i>Input Restrictions</i> | As designed. The default is 25 Btu/lb. |
| <i>Baseline Rules</i> | No lockout limit |

6.7.5 Cooling Systems

General

This group of building descriptors applies to all cooling systems.

| | |
|---------------------------|--|
| Cooling Source | |
| <i>Applicability</i> | All systems |
| <i>Definition</i> | The source of cooling for the system. The choices are: <ul style="list-style-type: none">• Chilled water• Direct expansion (DX)• Other |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The baseline building cooling source is shown in Table 6.7.5-1 [10]. See Figure 6.1.2-1 [1] for HVAC system mapping. |

Table 6.7.5-1: "Cooling Source for Baseline Building System"

| Baseline building System | Cooling Source |
|--|-----------------------|
| System 1 – PTAC | Direct expansion (DX) |
| System 2 – PTHP | Direct expansion (DX) |
| System 3 – PSZ-AC | Direct expansion (DX) |
| System 4 – PSZ-HP | Direct expansion (DX) |
| System 5 – Packaged VAV with Reheat | Direct expansion (DX) |
| System 6 – Packaged VAV with PFP boxes | Direct expansion (DX) |
| System 7 – VAV with Reheat | Chilled water |
| System 8 – VAV with PFP boxes | Chilled water |

| | |
|-------------------------------|--|
| Total Cooling Capacity | |
| <i>Applicability</i> | All cooling systems |
| <i>Definition</i> | The total cooling capacity (both sensible and latent) of a cooling coil or packaged DX system at ARI conditions. The building descriptors defined in this chapter assume that the fan is modeled separately, including any heat it adds to the air stream. The cooling capacity specified by this building descriptor should not consider the heat of the fan. |
| <i>Units</i> | kBtu/h |
| <i>Input Restrictions</i> | As designed. For packaged equipment that has the fan motor in the air stream such that it adds heat to the cooled air, the software shall adjust the <i>total cooling capacity</i> as follows: |

(6.7.5-1)

TeX Embedding failed!

where

| | |
|-------------|---|
| $Q_{t,adj}$ | The adjusted total cooling capacity of a packaged unit (kBtu/h) |
|-------------|---|

$Q_{t, \text{rated}}$ The ARI rated total cooling capacity of a packaged unit (kBtu/h) from manufactures' literature
 BHP_{supply} The supply fan brake horsepower (bhp).

If the number of unmet load hours in the proposed design exceeds 300, the software shall warn the user to resize the equipment.

Baseline Rules The total cooling capacity of the baseline building is oversized by 15%. However, the cooling equipment may need to be subsequently downsized such that the difference in unmet load hours between the proposed design and the baseline building is less than 50 (see Chapter 2). Sizing calculations shall be based on 1% dry-bulb and 1% wet-bulb design conditions.

Sensible Cooling Capacity

Applicability All cooling systems
Definition The sensible heat cooling capacity of the coil or packaged equipment at ARI conditions. The building descriptors defined in this chapter assume that the fan is modeled separately, including any heat it adds to the air stream. The cooling capacity specified by this building descriptor should not consider the heat of the fan.
Units kBtu/h
Input Restrictions As designed. For packaged equipment that has the fan motor located in the air stream such that it adds heat to the cooled air, the software shall adjust the *sensible cooling capacity* as follows:

(6.7.5-2)

TeX Embedding failed!

where

$Q_{s, \text{adj}}$ The adjusted sensible cooling capacity of a packaged unit (kBtu/h)
 $Q_{s, \text{rated}}$ The ARI rated sensible cooling capacity of a packaged unit (kBtu/h)
 BHP_{supply} The supply fan brake horsepower (bhp).

If the number of unmet load hours in the proposed design exceeds 300, the software shall warn the user to resize the equipment.

Baseline Rules The sensible cooling capacity of the baseline building is oversized by 15%. However, the cooling equipment may need to be subsequently downsized such that the difference in unmet load hours between the proposed design and the baseline building is less than 50 (see Chapter 2). Sizing calculations shall be based on 1% dry-bulb and 1% wet-bulb design conditions.

Cooling Capacity Adjustment Curves

Applicability All cooling systems
Definition A curve that represents the available total cooling capacity as a function of cooling coil and/or condenser conditions. The common form of these curves is given as follows:

(6.7.5-3)

TeX Embedding failed!

For air cooled direct expansion

(6.7.5-4)

TeX Embedding failed!

For water cooled direct expansion

(6.7.5-5)

TeX Embedding failed!

For chilled water coils

(6.7.5-6)

TeX Embedding failed!

where

$Q_{t, \text{available}}$ Available cooling capacity at specified evaporator and/or condenser conditions (MBH)

| | |
|---------------|---|
| $Q_{t,adj}$ | Adjusted capacity at ARI conditions (Btu/h) (see Equation(6.7.5-1)) |
| CAP_FT | A multiplier to adjust $Q_{t,adj}$ |
| t_{wb} | The entering coil wet-bulb temperature (°F) |
| t_{db} | The entering coil dry-bulb temperature (°F) |
| t_{wt} | The water supply temperature (°F) |
| t_{odb} | The outside-air dry-bulb temperature (°F) |

Note: if an air-cooled unit employs an evaporative condenser, t_{odb} is the effective dry-bulb temperature of the air leaving the evaporative cooling unit.

Software may represent the relationship between cooling capacity and temperature in ways other than the equations given above.

Table 6.7.5-2: "Cooling Capacity Curve Coefficients"

| Co-efficient | Air Cooled Direct Expansion | | Water Cooled Direct Expansion | | Chilled Water Coils | |
|--------------|-----------------------------|-----------------------|-------------------------------|-------------------------|---------------------|---------------------|
| | Air-Source (PTAC) | Air-Source (Other DX) | Water-Source (Heat Pump) | Water-Source (Other DX) | Fan-Coil | Other Chilled Water |
| a | 1.1839345 | 0.8740302 | -0.2780377 | 0.9452633 | 0.5038866 | 2.5882585 |
| b | -0.0081087 | -0.0011416 | 0.0248307 | -0.0094199 | -0.0869176 | -0.2305879 |
| c | 0.0002110 | 0.0001711 | -0.0000095 | 0.0002270 | 0.0016847 | 0.0038359 |
| d | -0.0061435 | -0.0029570 | -0.0032731 | 0.0004805 | 0.0336304 | 0.1025812 |
| e | 0.0000016 | 0.0000102 | 0.0000070 | -0.0000045 | 0.0002478 | 0.0005984 |
| f | -0.0000030 | -0.0000592 | -0.0000272 | -0.0000599 | -0.0010297 | -0.0028721 |

Note: These curves are the DOE-2.1E defaults, except for Water-Source (Other DX), which is taken from the "ECB Compliance Supplement, public review draft prepared by the SSPC 90.1 ECB Panel, Version 1.2, March 1996.

| | |
|---------------------------|--|
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | As designed. The equations and coefficients given above are the default. |
| <i>Baseline Rules</i> | Use the default curves or equivalent data for other models. |

Coil Bypass Factor

| | |
|---------------------------|---|
| <i>Applicability</i> | All cooling systems |
| <i>Definition</i> | The ratio of air that bypasses the cooling coil at design conditions to the total system airflow. |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed. Default values are given in Table 6.7.5-3 [11]. |

Table 6.7.5-3: "Default Coil Bypass Factors"

| System Type | Default Bypass Factor |
|---|-----------------------|
| Packaged Terminal Air-conditioners and Heat Pumps | 0.241 |
| Other Packaged Equipment | 0.190 |
| Multi-Zone Systems | 0.078 |
| All Other | 0.037 |

| | |
|-----------------------|----------|
| <i>Baseline Rules</i> | Defaults |
|-----------------------|----------|

Coil Bypass Factor Adjustment Curve

| | |
|---------------------------|--|
| <i>Applicability</i> | All cooling systems |
| <i>Definition</i> | Adjustments for the amount of coil bypass due to the following factors: <ul style="list-style-type: none"> • Coil airflow rate as a percentage of rated system airflow • Entering air wet-bulb temperature • Entering air dry-bulb temperature • Part load ratio |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | Default to the simulation engine defaults based on HVAC system type. The following default values shall be used for the adjustment curves: |

(6.7.5-7)

TeX Embedding failed!

(6.7.5-8)

TeX Embedding failed!

(6.7.5-9)

TeX Embedding failed!

(6.7.5-10)

TeX Embedding failed!

where

| | |
|----------------------------|---|
| CBF_{rated} | The coil bypass factor at ARI rating conditions |
| CBF_{adj} | The coil bypass factor adjusted for airflow and coil conditions |
| CFMR | The ratio of airflow to design airflow |
| COIL-BF-FFLOW | A multiplier on the rated coil bypass factor to account for variation in air flow across the coil (take coefficients from Table 6.7.5-4 [12]) |
| COIL-BF-FT | A multiplier on the rated coil bypass factor to account for a variation in coil entering conditions (take coefficients from Table 6.7.5-5 [13]) |
| COIL-BF-FPLR | A multiplier on the rated coil bypass factor to account for the part load ratio (take coefficients from Table 6.7.5-6 [14]) |
| T_{wb} | The entering coil wet-bulb temperature (°F) |
| T_{db} | The entering coil dry-bulb temperature (°F) |
| PLR | Part load ratio |

And the coefficients are listed in the tables below.

Table 6.7.5-4: "Coil Bypass Factor Airflow Adjustment Factor"

| Co-efficient | COIL-BF-FFLOW (PTAC) | COIL-BF-FFLOW (HP) | COIL-BF-FFLOW (PSZ/other) |
|--------------|----------------------|--------------------|---------------------------|
| a | -2.277 | -0.8281602 | -0.2542341 |
| b | 5.21140 | 14.3179150 | 1.2182558 |
| c | -1.93440 | -21.8894405 | 0.0359784 |
| d | | 9.3996897 | |

Table 6.7.5-5: "Coil Bypass Factor Temperature Adjustment Factor"

| Co-efficient | COIL-BF-FT (PTAC) | COIL-BF-FT (HP) | COIL-BF-FT (PSZ, other) |
|--------------|-------------------|-----------------|-------------------------|
| a | -1.5713691 | -29.9391098 | 1.0660053 |
| b | 0.0469633 | 0.8753455 | -0.0005170 |
| c | 0.0003125 | -0.0057055 | 0.0000567 |
| d | -0.0065347 | 0.1614450 | -0.0129181 |
| e | 0.0001105 | 0.0002907 | -0.0000017 |
| f | -0.0003719 | -0.0031523 | 0.0001503 |

Table 6.7.5-6: "Coil Bypass Factor Part Load Adjustment Factor"

| Co-efficient | COIL-BF-FPLR (All Systems) |
|--------------|----------------------------|
| a | 0.00 |
| b | 1.00 |

Baseline Rules

Use defaults as described above.

Direct Expansion

Direct Expansion Cooling Efficiency

| | |
|---------------|--|
| Applicability | Packaged equipment |
| Definition | <p>The cooling efficiency of a direct expansion (DX) cooling system at ARI rated conditions as a ratio of output over input in Btu/h per W, excluding fan energy. The software must accommodate user input in terms of either the <i>Energy Efficiency Ratio</i> (EER) or the <i>Seasonal Energy Efficiency Ratio</i> (SEER). For equipment with SEER ratings, EER shall be taken from manufacturers' data when it is available. When it is not available it shall be calculated as follows:</p> <p>(6.7.5-11)</p> |

TeX Embedding failed!

For all unitary and applied equipment where the fan energy is part of the equipment efficiency rating, the EER shall be adjusted as follows:

(6.7.5-12)

TeX Embedding failed!

where

| | |
|-----------------------|--|
| EER _{adj} | The adjusted Energy Efficiency Ratio for simulation purposes |
| EER | The rated Energy Efficiency Ratio |
| Q _{t,rated} | The ARI rated total cooling capacity of a packaged unit (kBtu/h) |
| BHP _{supply} | The supply fan brake horsepower (bhp) shall be taken from manufacturers' literature when available, otherwise use Equation(6.7.3-2). |

| | |
|--------------------|---|
| Units | Btu/h-W |
| Input Restrictions | As designed. When possible, specify the SEER and EER for packaged equipment with cooling capacity less than 65,000 Btu/h. For equipment with capacity above 65,000 Btu/h, specify EER. |
| Baseline Rules | For the purpose of green building ratings, look up the requirement from Table 6.8.1A and Table 6.8.1B in ASHRAE Standard 90.1-2007. For the purpose of tax deduction calculations, look up the requirement from Table 6.2.1A and 6.2.1B in ASHRAE Standard 90.1-2001. Use the total cooling capacity of the proposed design to determine the size category. |

Direct Expansion Cooling Efficiency Adjustment Curve

| | |
|---------------|--|
| Applicability | Packaged DX equipment |
| Definition | <p>A curve or group of curves that varies the cooling efficiency of a direct expansion (DX) coil as a function of evaporator conditions, condenser conditions and part-load ratio. The default curves are given as follows as adjustments to the energy input ratio (EIR)¹:</p> <p>(6.7.5-13)</p> |

TeX Embedding failed!

(6.7.5-14)

TeX Embedding failed!

(6.7.5-15)

For air-cooled DX systems:

TeX Embedding failed!

(6.7.5-16)

For water-cooled DX systems:

TeX Embedding failed!

(6.7.5-17)

TeX Embedding failed!

where

| | |
|--------|--|
| PLR | Part load ratio based on available capacity (not rated capacity) |
| EIR- | A multiplier on the EIR to account for the part load ratio |
| FPLR | |
| FIR-ET | A multiplier on the FIR to account for the wet-bulb temperature entering the coil and the outdoor dry-bulb |

| | |
|------------------------------|--|
| EIR-F | A multiplier on the EIR to account for the wet-bulb temperature entering the coil and the outdoor dry-bulb temperature |
| Q_{operating} | Present load on heat pump (Btu/h) |
| Q_{available} | Heat pump available capacity at present evaporator and condenser conditions (in Btu/h). |
| t_{wb} | The entering coil wet-bulb temperature (°F) |
| t_{wt} | The water supply temperature (°F) |
| t_{odb} | The outside-air dry-bulb temperature (°F) |
| P_{rated} | Rated power draw at ARI conditions (kW) |
| P_{operating} | Power draw at specified operating conditions (kW) |

Note: if an air-cooled unit employs an evaporative condenser, t_{odb} is the effective dry-bulb temperature of the air leaving the evaporative cooling unit.

Table 6.7.5-7: "Cooling System Coefficients for EIR-FPLR"

| Co-efficient | Water-Source (Heat Pump) | Water-Source (Other) | Air-Source (PTAC) | Air-Source (Other) |
|--------------|--------------------------|----------------------|-------------------|--------------------|
| a | 0.1250000 | 0.2012301 | 0.1250000 | 0.2012301 |
| b | 0.8750000 | -0.0312175 | 0.8750000 | -0.0312175 |
| c | 0.0000000 | 1.9504979 | 0.0000000 | 1.9504979 |
| d | 0.0000000 | -1.1205105 | 0.0000000 | -1.1205105 |

Table 6.7.5-8: "Cooling System Coefficients for EIR-FT"

| Co-efficient | Water-Source (Heat Pump) | Water-Source (Other) | Air-Source (PTAC) | Air-Source (Other) |
|--------------|--------------------------|----------------------|-------------------|--------------------|
| a | 2.0280385 | -1.8394760 | -0.6550461 | -1.0639310 |
| b | -0.0423091 | 0.0751363 | 0.0388910 | 0.0306584 |
| c | 0.0003054 | -0.0005686 | -0.0001925 | -0.0001269 |
| d | 0.0149672 | 0.0047090 | 0.0013046 | 0.0154213 |
| e | 0.0000244 | 0.0000901 | 0.0001352 | 0.0000497 |
| f | -0.0001640 | -0.0001218 | -0.0002247 | -0.0002096 |

| | |
|---------------------------|--|
| Units | Data structure |
| Input Restrictions | User may input curves or use default curves. If defaults are overridden, the software must indicate that supporting documentation is required on the output forms. |
| Baseline Rules | Use default curves. |

Minimum Unloading Ratio

| | |
|---------------------------|---|
| Applicability | Packaged systems which use hot-gas bypass during low load conditions |
| Definition | The upper end of the hot-gas bypass operating range. This is the percentage of peak cooling capacity below which hot-gas bypass will operate. |
| Units | Ratio |
| Input Restrictions | As designed. The user must enter this descriptor for each DX cooling system. If hot-gas bypass is not employed, a value of 0 may be entered. A maximum of 0.5 is allowed for units with a peak cooling capacity of 240 kBtu/h (20 tons) or less, and a maximum value of 0.25 is allowed for units with a peak cooling capacity greater than 240 kBtu/h. |
| Baseline Rules | Not applicable |

Minimum HGB Ratio

| | |
|---------------------------|--|
| Applicability | Packaged systems which use hot-gas bypass during low load conditions |
| Definition | The lower end of the hot-gas bypass operating range. The percentage of peak cooling capacity below which hot-gas bypass will no longer operate (i.e. the compressor will cycle). |
| Units | Ratio |
| Input Restrictions | As designed. The user must enter this descriptor for each DX cooling system. If hot-gas bypass is not employed, a value of 0 may be entered. |
| Baseline Rules | Not applicable |

Condenser Type

| | |
|----------------------|---|
| Applicability | All direct expansion systems including heat pumps |
| Definition | The type of condenser for a direct expansion (DX) cooling system. The choices are: <ul style="list-style-type: none"> • Air-Cooled • Water-Cooled • Air-Cooled with Evaporative Pre-cooler |

| | |
|--------------|------------------|
| Units | List (see above) |
|--------------|------------------|

| | |
|---------------------------|--|
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Based on the prescribed system type. Refer to the HVAC System Map in Figure 6.1.2-1 [1]. |

Table 6.7.5-9: "Baseline Building Condenser Type"

| Baseline building System | Condenser Type |
|--|----------------|
| System 1 – PTAC | Air-cooled |
| System 2 – PTHP | Air-cooled |
| System 3 – PSZ-AC | Air-cooled |
| System 4 – PSZ-HP | Air-Cooled |
| System 5 – Packaged VAV with Reheat | Air-cooled |
| System 6 – Packaged VAV with PFP boxes | Air-cooled |
| System 7 – VAV with Reheat | N/A |
| System 8 – VAV with PFP boxes | N/A |

Condenser Flow Type

| | |
|---------------------------|---|
| <i>Applicability</i> | All direct expansion systems including heat pumps |
| <i>Definition</i> | Describes water flow control for a water-cooled condenser. The choices are: <ul style="list-style-type: none">• Fixed Flow• Two-position• Variable Flow |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | Default to fixed flow. If the variable-flow is selected, the software must indicate that supporting documentation is required on the output forms. |
| <i>Baseline Rules</i> | Always fixed flow |

Evaporative Cooler

This is equipment that pre-cools the outside air that is brought into the building. It may be used with any type of cooling system that brings in outside air. This equipment is not applicable for the baseline building.

Evaporative Cooling Type

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems with evaporative pre-cooling |
| <i>Definition</i> | The type of evaporative pre-cooler, including: <ul style="list-style-type: none">• None• Non-Integrated Indirect• Non-Integrated Direct/Indirect• Integrated Indirect• Integrated Direct/Indirect <p>An integrated pre-cooler can operate together with the compression or CHW cooling. A non-integrated pre-cooler will shut down the evaporative cooling whenever it is unable to provide 100% of the cooling required.</p> <p>In all cases, the evaporative pre-cooler must be modeled with 100% of the outside air routed through the pre-cooler.</p> |
| <i>Units</i> | None |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Direct Stage Effectiveness

| | |
|----------------------|--|
| <i>Applicability</i> | Systems with evaporative pre-cooling |
| <i>Definition</i> | The effectiveness of the direct stage of an evaporative cooling system. Effectiveness is defined as follows: |

(6.7.5-18)

TeX Embedding failed!

where

DirectEFF The direct stage effectiveness

| | | |
|---------------------------|---------------------------|---|
| | T_{db} | The entering air dry-bulb temperature |
| | T_{wb} | The entering air wet-bulb temperature |
| | T_{direct} | The direct stage leaving dry-bulb temperature |
| Units | Numeric | |
| Input Restrictions | As designed | |
| Baseline Rules | Not applicable | |

Indirect Stage Effectiveness

Applicability Systems with evaporative pre-cooling

Definition The effectiveness of the indirect stage of an evaporative cooling system. Effectiveness is defined as follows:

(6.7.5-19)

TeX Embedding failed!

where

IndEFF The indirect stage effectiveness

T_{db} The entering air dry-bulb temperature of the supply air

T_{wb} The entering air wet-bulb temperature of the “scavenger air”

T_{ind} The supply air leaving dry-bulb temperature

| | |
|---------------------------|----------------|
| Units | Numeric |
| Input Restrictions | As designed |
| Baseline Rules | Not applicable |

Evaporative Cooling Performance Curves

Applicability Systems with evaporative cooling

Definition A curve that varies the evaporative cooling effectiveness as a function of primary air stream airflow. The default curves are given as follows:

(6.7.5-20)

TeX Embedding failed!

TeX Embedding failed!

where

PLR Part load ratio of airflow based on design airflow

EFF-FFLOW A multiplier on the evaporative cooler effectiveness to account for variations in part load

CFM_{operating} Operating primary air stream airflow (cfm)

CFM_{design} Design primary air stream airflow (cfm)

Table 6.7.5-10: "Part Load Curve Coefficients – Evaporative Cooler Effectiveness"

| Co-efficient | Direct | Indirect |
|--------------|------------|------------|
| a | 1.1833000 | 1.0970000 |
| b | -0.2575300 | -0.1650600 |
| c | 0.0742450 | 0.0680690 |

| | |
|---------------------------|--|
| Units | Data structure |
| Input Restrictions | User may input curves or use default curves. If defaults are overridden, the software must indicate that supporting documentation is required on the output forms. |
| Baseline Rules | Not used. |

Auxiliary Evaporative Cooling Power

Applicability Systems with evaporative cooling

Definition The auxiliary energy of the indirect evaporative cooler fan, and the pumps for both direct and indirect stages

| | |
|---------------------------|----------------|
| Units | kW/cfm |
| Input Restrictions | As designed |
| Baseline Rules | Not applicable |

Evaporative Cooling Scavenger Air Source

Applicability Systems with evaporative cooling

Definition The source of scavenger air for an indirect section of an evaporative cooler. Options include:

- Return Air
- Outside Air

| | |
|---------------------------|------------------|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Evaporative Condenser

Evaporative Condenser Power

| | |
|---------------------------|---|
| <i>Applicability</i> | Direct expansion systems with an evaporatively cooled condenser |
| <i>Definition</i> | The power of the evaporative precooling unit. This includes any pump(s) and/or fans that are part of the precooling unit. |
| <i>Units</i> | Kilowatts (kW) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Evaporative Condenser Effectiveness

| | |
|----------------------|--|
| <i>Applicability</i> | Direct expansion systems with an evaporatively cooled condenser |
| <i>Definition</i> | The effectiveness of the evaporative precooling unit for a condenser. Effectiveness is defined as follows: |

(6.7.5-21)

TeX Embedding failed!

where

DirectEFF The direct stage effectiveness

T_{db} The entering air dry-bulb temperature

T_{wb} The entering air wet-bulb temperature

T_{direct} The direct stage leaving dry-bulb temperature

| | |
|---------------------------|----------------|
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Evaporative Condenser Operation Range

| | |
|---------------------------|--|
| <i>Applicability</i> | Direct expansion systems with an evaporatively cooled condenser. |
| <i>Definition</i> | The temperature range within which the evaporative condenser operates. Two values are provided: |
| | $T_{maximum}$ The threshold outside air dry-bulb temperature below which evaporative condenser operates. |
| | $T_{minimum}$ The threshold outside air dry-bulb temperature above which evaporative condenser operates. |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

¹ The EIR is the ratio of energy used by the system to cooling capacity in the same units. It is the reciprocal of the coefficient of performance (COP).

6.7.6 Heating Systems

General

Heating Source

| | |
|----------------------|--|
| <i>Applicability</i> | All systems that provide heating |
| <i>Definition</i> | The source of heating for the heating and preheat coils. The choices are: |
| | <ul style="list-style-type: none"> • Hot water • Steam • Electric resistance • Electric heat pump • Gas furnace |

- Gas heat pump (optional feature)
- Oil furnace
- Heat recovery (for preheat coils in proposed designs)

| | |
|---------------------------|--|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Based on the prescribed system type. Refer to the HVAC System Map in Figure 6.1.2-1 [1]. |

Table 6.7.6-1: "Heating Source for Baseline Building"

| Baseline Building System | Heating Source |
|--|---------------------|
| System 1 – PTAC | Gas Furnace |
| System 2 – PTHP | Heat pump |
| System 3 – PSZ-AC | Gas or Oil Furnace |
| System 4 – PSZ-HP | Heat pump |
| System 5 – Packaged VAV with Reheat | Hot water |
| System 6 – Packaged VAV with PFP boxes | Electric Resistance |
| System 7 – VAV with Reheat | Hot water |
| System 8 – VAV with PFP boxes | Electric Resistance |

Preheat Coil

Preheat Coil Capacity

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems with a preheat coil located in the outside air stream |
| <i>Definition</i> | The heating capacity of a preheating coil at design conditions. |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | If the proposed design has a preheat coil and it can be modeled in the baseline building system, then the baseline building also has a preheat coil sized to meet the preheat coil temperature specified for the proposed design. Autosize to maintain the preheat coil temperature of the proposed design. |

Heating Coils

Systems with boilers have heating coils, including baseline building systems 1, 5 and 7.

Heating Coil Capacity

| | |
|---------------------------|--|
| <i>Applicability</i> | All systems with a heating coil |
| <i>Definition</i> | The heating capacity of a heating coil at ARI conditions |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | As designed. Adjust the capacity if the number of unmet load hours exceeds 300. |
| <i>Baseline Rules</i> | Autosize with a heating oversizing factor of 25%. If the number of unmet load hours for the proposed design exceeds the number of unmet load hours for the baseline building by more than 50, reduce the heating coil capacity as indicated in Figure 2.5.2-1 [3]. |

Furnace

Furnace Capacity

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems with a furnace |
| <i>Definition</i> | The full load heating capacity of the unit |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | As designed. Adjust the capacity if the number of unmet load hours exceeds 300. |
| <i>Baseline Rules</i> | Autosize with an oversizing factor of 25% (let the software determine heating capacity based on the building loads). If the number of unmet load hours for the proposed design exceeds the number of unmet load hours for the baseline building by more than 50, reduce the furnace capacity as indicated in Figure 2.4-1 [2] and Figure 2.5.2-1 [3]. |

Furnace Fuel Heating Efficiency

| | |
|----------------------|--|
| <i>Applicability</i> | Systems with a furnace |
| <i>Definition</i> | The full load thermal efficiency of either a gas or oil furnace at design conditions. The software must accommodate input in either <i>Thermal Efficiency</i> (E_t) or <i>Annual Fuel Utilization Efficiency</i> (AFUE). Where AFUE is provided, E_t shall be calculated as follows: |

TeX Embedding failed!
TeX Embedding failed!
TeX Embedding failed!
TeX Embedding failed!
TeX Embedding failed!
TeX Embedding failed!

where

AFUE The annual fuel utilization efficiency (%)
E_t The thermal efficiency (fraction)

| | |
|--------------------|--|
| Units | Fraction |
| Input Restrictions | As designed |
| Baseline Rules | Look up the requirement from the equipment efficiency tables in Table 6.8.1E of Standard 90.1-2007 Table 6.2.1E of Standard 90.1-2001. Use the heating input of the proposed design system to determine the size category. |

Furnace Fuel Heating Part Load Efficiency Curve

| | |
|---------------|--|
| Applicability | Systems with furnaces |
| Definition | An adjustment factor that represents the percentage of full load fuel consumption as a function of the percentage full load capacity. This curve shall take the form of a quadratic equation as follows: |

(6.7.6-2)

TeX Embedding failed!

(6.7.6-3)

TeX Embedding failed!

where

FHeatPLC The Fuel Heating Part Load Efficiency Curve
Fuel_{partload} The fuel consumption at part load conditions (Btu/h)
Fuel_{rated} The fuel consumption at full load (Btu/h)
Q_{partload} The capacity at part load conditions (Btu/h)
Q_{rated} The capacity at rated conditions (Btu/h)

Table 6.7.6-2: "Furnace Efficiency Curve Coefficients"

| Coefficient | Furnace |
|-------------|------------|
| a | 0.0186100 |
| b | 1.0942090 |
| c | -0.1128190 |

| | |
|--------------------|--|
| Units | Data structure |
| Input Restrictions | As designed when data is available, otherwise use the default values are provided above. |
| Baseline Rules | Use defaults |

Furnace Fuel Heating Pilot

| | |
|--------------------|---|
| Applicability | Systems that use a furnace for heating |
| Definition | The fuel input for a pilot light on a furnace |
| Units | Btu/h |
| Input Restrictions | As designed |
| Baseline Rules | Zero (pilotless ignition) |

Furnace Fuel Heating Fan/Auxiliary

| | |
|--------------------|---|
| Applicability | Systems that use a furnace for heating |
| Definition | The fan energy in forced draft furnaces and the auxiliary (pumps and outdoor fan) energy in fuel-fired heat pumps |
| Units | Kilowatts (kW) |
| Input Restrictions | As designed |
| Baseline Rules | Not applicable |

Electric Heat Pump

Electric Heat Pump Heating Capacity

| | |
|---------------|----------------|
| Applicability | All heat pumps |
|---------------|----------------|

| | |
|---------------------------|---|
| <i>Definition</i> | The full load heating capacity of the unit, excluding supplemental heating capacity at ARI rated conditions |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Autosize and use an oversizing factor of 25% (let the software determine heating capacity based on the building loads). The autosized equipment may need to be downsized to achieve a maximum difference in unmet load hours between the proposed design and the baseline building of 50. |

Electric Heat Pump Supplemental Heating Source

| | |
|---------------------------|--|
| <i>Applicability</i> | All heat pumps |
| <i>Definition</i> | The auxiliary heating source for a heat pump heating system. The common control sequence is to lock out the heat pump compressor when the supplemental heat is activated. Other building descriptors may be needed if this is not the case. Choices for supplemental heat include: <ul style="list-style-type: none">• Electric resistance• Gas furnace• Oil furnace• Hot water• Other |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Electric resistance |

Electric Heat Pump Heating Efficiency

| | |
|----------------------|---|
| <i>Applicability</i> | All heat pumps |
| <i>Definition</i> | The heating efficiency of a heat pump at ARI rated conditions as a dimensionless ratio of output over input. The software must accommodate user input in terms of either the <i>Coefficient of Performance</i> (COP) or the <i>Heating Season Performance Factor</i> (HSPF). Where HSPF is provided, COP shall be calculated as follows: <div>(6.7.6-4)</div> |

TeX Embedding failed!
TeX Embedding failed!
TeX Embedding failed!
TeX Embedding failed!

For all unitary and applied equipment where the fan energy is part of the equipment efficiency rating, the COP shall be adjusted as follows to remove the fan energy:

(6.7.6-5)

TeX Embedding failed!

where

- COP_{adj}** The adjusted coefficient of performance for simulation purposes
- COP** The ARI rated coefficient of performance
- HCAP_{rated}** The ARI rated heating capacity of a packaged unit (kBtu/h)
- BHP_{supply}** The supply fan brake horsepower (bhp).

Refer to building descriptor *Supply Fan BHP*.

| | |
|---------------------------|--|
| <i>Units</i> | Unitless |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | For the purpose of green building ratings, look up the requirement from the equipment efficiency Table 6.8.1B and Table 6.8.1D in ASHRAE Standard 90.1-2007. For the purpose of tax deduction calculations, find the equipment efficiency from Table 6.2.1B and 6.2.1D in ASHRAE Standard 90.1-2001. Use the heating capacity of the proposed design to determine the size category. |

Electric Heat Pump Heating Capacity Adjustment Curve(s)

| | |
|----------------------|--|
| <i>Applicability</i> | All heat pumps |
| <i>Definition</i> | A curve or group of curves that represent the available heat-pump heating capacity as a function of evaporator and condenser conditions. The default curves are given as follows: <div>(6.7.6-6)</div> |

TeX Embedding failed!

For air-cooled heat pumps:

(6.7.6-7)

TeX Embedding failed!

For water-cooled heat pumps:

(6.7.6-8)

TeX Embedding failed!

where

| | |
|------------------------------|--|
| Q_{available} | Available heating capacity at present evaporator and condenser conditions (kBtu/h) |
| t_{db} | The entering coil dry-bulb temperature (°F) |
| t_{wt} | The water supply temperature (°F) |
| t_{odb} | The outside-air dry-bulb temperature (°F) |
| Q_{rated} | Rated capacity at ARI conditions (in kBtu/h) |

Table 6.7.6-3: "Heat Pump Capacity Adjustment Curves (CAP-FT)"

| Coefficient | Water-Source | Air-Source |
|-------------|--------------|------------|
| a | 0.4886534 | 0.2536714 |
| b | -0.0067774 | 0.0104351 |
| c | N/A | 0.0001861 |
| d | 0.0140823 | -0.0000015 |

| | |
|--------------------|--|
| Units | Data structure |
| Input Restrictions | User may input curves or use default curves. If defaults are overridden, supporting documentation shall be provided. |
| Baseline Rules | Use default curves. |

Electric Heat Pump Heating Efficiency Adjustment Curve(s)

| | |
|---------------|--|
| Applicability | All heat pumps |
| Definition | A curve or group of curves that varies the heat-pump heating efficiency as a function of evaporator conditions, condenser conditions and part-load ratio. The default curves are given as follows: |

(6.7.6-9)

TeX Embedding failed!

(6.7.6-10)

TeX Embedding failed!

Air Source Heat Pumps:

(6.7.6-11)

TeX Embedding failed!

Water Source Heat Pumps:

(6.7.6-12)

TeX Embedding failed!

(6.7.6-13)

TeX Embedding failed!

where

| | |
|---------------|---|
| PLR | Part load ratio based on available capacity (not rated capacity) |
| EIR- | A multiplier on the EIR of the heat pump as a function of part load ratio |
| FPLR | |
| EIR-FT | A multiplier on the EIR of the heat pump as a function of the wet-bulb temperature entering the coil and the outdoor dry-bulb temperature |
| Q | Present load on heat pump (Btu/h) |

$\dot{Q}_{\text{operating}}$ Present load on heat pump (Btu/h)

$Q_{\text{available}}$ Heat pump available capacity at present evaporator and condenser conditions (Btu/h).

t_{db} The entering coil dry-bulb temperature (°F)

t_{wt} The water supply temperature (°F)

t_{odb} The outside air dry-bulb temperature (°F)

P_{rated} Rated power draw at ARI conditions (kW)

$P_{\text{operating}}$ Power draw at specified operating conditions (kW)

Table 6.7.6-4: "Heat Pump Heating Efficiency Adjustment (Curves)"

| Coefficient | Air-and Water-Source EIR-FPLR | Water-Source EIR-FT | Air-Source EIR-FT |
|-------------|----------------------------------|------------------------|----------------------|
| a | 0.0856522 | 1.3876102 | 2.4600298 |
| b | 0.9388137 | 0.0060479 | -0.0622539 |
| c | -0.1834361 | N/A | 0.0008800 |
| d | 0.1589702 | -0.0115852 | -0.0000046 |

Units None

Input Restrictions User may input curves or use default curves. If defaults are overridden, documentation shall be provided.

Baseline Rules Use default curves

Electric Heat Pump Supplemental Heating Capacity

Applicability All heat pumps

Definition The design heating capacity of a heat pump supplemental heating coil at ARI conditions

Units Btu/h

Input Restrictions As designed

Baseline Rules Autosize

Electric Supplemental Heating Control Temp

Applicability All heat pumps

Definition The outside dry-bulb temperature below which the heat pump supplemental heating is allowed to operate

Units Degrees Fahrenheit (°F)

Input Restrictions As designed. Default to 40°F

Baseline Rules 40°F

Coil Defrost

Applicability Air-cooled electric heat pump

Definition The defrost control mechanism for an air-cooled heat pump. The choices are:

- Hot-gas defrost, on-demand
- Hot-gas defrost, timed 3.5 minute cycle
- Electric resistance defrost, on-demand
- Electric resistance defrost, timed 3.5 minute cycle

Defrost shall be enabled whenever the outside air dry-bulb temperature drops below 40°F.

Units List (see above)

Input Restrictions Default to use hot-gas defrost, timed 3.5 minute cycle. User may select any of the above.

Baseline Rules The baseline building uses the default.

Coil Defrost kW

Applicability Heat pumps with electric resistance defrost

Definition The capacity of the electric resistance defrost heater

Units Kilowatts (kW)

Input Restrictions As designed. This descriptor defaults to 0 if nothing is entered.

Baseline Rules Not applicable. Baseline building systems 2 and 4 use hot-gas, timed 3.5 minute cycle.

Crank Case Heater kW

Applicability All heat pumps

Definition The capacity of the electric resistance heater in the crank case of a direct expansion (DX) compressor. The crank case heater operates only when the compressor is off.

Units Kilowatts (kW)

Input Restrictions As designed. This descriptor defaults to 0 if nothing is entered.

Baseline Rules Zero (0)

Crank Case Heater Shutoff Temperature

Applicability All heat pumps

Definition The outdoor air dry-bulb temperature above which the crank case heater is not permitted to operate.

| | |
|--------------------|--|
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed. This descriptor defaults to 50°F. |
| Baseline Rules | 50°F |

Heat Recovery

Exhaust to Outside Heat Recovery Effectiveness

Applicability Any system with outside air heat recovery

Definition

The effectiveness of an air-to-air heat exchanger between the building exhaust and entering outside air streams. Effectiveness is defined as follows:

(6.7.6-14)

TeX Embedding failed!

where

HREFF The air-to-air heat exchanger effectiveness

EEA_{db} The exhaust air dry-bulb temperature entering the heat exchanger

ELA_{db} The exhaust air dry-bulb temperature leaving the heat exchanger

OSA_{db} The outside air dry-bulb temperature

Units Ratio

Input Restrictions As designed

Baseline Rules Required for fan systems with a design supply air flow rate of 5,000 cfm or greater if the minimum outside air quantity is 70% of the design air flow rate. If required, the energy recovery system should have at least 50% effectiveness. Energy recovery is not required for heating systems in climate zones 1 through 3 or for cooling systems in climate zones 3c, 4c, 5b, 5c, 6b, 7 and 8.

Condenser Heat Recovery Effectiveness

Applicability Systems that use recover heat from a condenser

Definition The percentage of heat rejection at design conditions from a DX or heat pump unit in cooling mode that is available for space or water heating.

Units Percent (%)

Input Restrictions As designed. The software must indicate that supporting documentation is required on the output forms if heat recovery is specified.

Baseline Rules Not applicable for most conditions. Condenser heat recovery is required for 24-hour facilities when the heat rejection exceeds 6,000,000 Btu/h and the design service water heating load exceeds 1,000,000 Btu/h. When required, the effectiveness will be 60%.

Heat Recovery Use

Applicability Systems that use heat recovery

Definition The end use of the heat recovered from a DX or heat pump unit. The choices are:

- Reheat coils
- Water heating

Units List (see above)

Input Restrictions As designed. The software must indicate that supporting documentation is required on the output forms if heat recovery is specified.

Baseline Rules Not applicable for most conditions. The end use will be water heating if required for 24-hour facility operation.

6.7.7 Humidity Controls and Devices

General

Humidifier Type

Applicability Optional humidifier

Definition The type of humidifier employed. Choices include:

- Hot-Water
- Steam
- Electric
- Evaporative Humidification

| | |
|---------------------------|-----------------------------|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as the proposed design |

Humidistat Maximum Setting

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems with humidity control |
| <i>Definition</i> | The control setpoint for dehumidification |
| <i>Units</i> | Percent (%) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as the proposed design |

Humidistat Minimum Setting

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems with humidity control |
| <i>Definition</i> | The control setpoint for humidification |
| <i>Units</i> | Percent (%) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as proposed design |

Desiccant

Desiccant Type

| | |
|---------------------------|--|
| <i>Applicability</i> | Systems with desiccant dehumidification |
| <i>Definition</i> | Describes the configuration of desiccant cooling equipment The following configurations for desiccant systems are allowed: <ul style="list-style-type: none"> • LIQ-VENT-AIR1 – a liquid desiccant dehumidifying unit • LIQ-VENT-AIR2 – a liquid desiccant dehumidifying unit combined with a gas-fired absorption chiller • SOL-VENT-AIR1 – a solid desiccant dehumidifying unit • NO-DESICCANT – the default, which indicates that no desiccant system is present |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Desiccant Control Mode

| | |
|----------------------|--|
| <i>Applicability</i> | Systems with desiccant dehumidification |
| <i>Definition</i> | The method of controlling the operation of the desiccant unit. For liquid-based systems this can be either: <ul style="list-style-type: none"> • Dry-bulb – the desiccant unit is turned on whenever the outside air dry-bulb exceeds a set limit. • Evaporative cooling– cycles the desiccant unit on when an evaporative cooler is on to maintain a dewpoint setpoint. • Dewpoint – cycles the desiccant unit on and off to maintain the dewpoint temperature of the supply air. <p>For solid-based systems the following configurations are possible:</p> <ul style="list-style-type: none"> • Dehumidification only – the desiccant unit cycles on and off to maintain indoor humidity levels • Sensible heat exchanger plus regeneration – the desiccant unit includes a sensible heat exchanger to precool the hot, dry air leaving the desiccant unit. The air leaving the exhaust side of the heat exchanger is directed to the desiccant unit • Sensible heat exchanger – the desiccant unit includes a heat exchanger, but the air leaving the exhaust side of the heat exchanger is exhausted to the outdoors |

| | |
|---------------------------|------------------|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Desiccant Air Fraction

| | |
|---------------------------|---|
| <i>Applicability</i> | Systems with desiccant dehumidification |
| <i>Definition</i> | The fraction of the supply air that passes through the desiccant unit. Typically either the minimum outside air fraction or all of the air passes through the desiccant system. |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Desiccant Heat Source

| | |
|----------------------|--|
| <i>Applicability</i> | Systems with desiccant dehumidification |
| <i>Definition</i> | The source of heat that is used to dry out the desiccant. This can be either: <ul style="list-style-type: none"> • Gas – Hydronic – the regeneration heat load is met with a gas-fired heater |

- Hot water – the heat load is met with hot water from the plant

| | |
|---------------------------|------------------|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Liquid Desiccant Performance Curves

Applicability Systems with liquid-based desiccant dehumidification

Definition A set of performance curves that apply to liquid desiccant systems.

(6.7.7-1)

TeX Embedding failed!

(6.7.7-2)

TeX Embedding failed!

(6.7.7-3)

TeX Embedding failed!

(6.7.7-4)

TeX Embedding failed!

where

| | |
|---------------------|---------------------------------------|
| DESC-T-FTW | temperature leaving desiccant unit |
| DESC-W-FTW | humidity ratio leaving desiccant unit |
| DESC-Gas-FTW | Gas usage of desiccant unit |
| DESC-kW-FTW | Electric usage of desiccant unit |
| T | entering air temperature |
| w | entering humidity ratio |

Table 6.7.7-1: "Liquid Desiccant Unit Performance Curves"

| Coefficient | DESC-T-FTW | DESC-W-FTW | DESC-Gas-FTW | DESC-kW-FTW |
|-------------|------------|------------|---------------|-------------|
| a | 11.5334997 | 11.8993998 | 58745.8007813 | 3.5179000 |
| b | 0.6586730 | -0.2695580 | -1134.4899902 | -0.0059317 |
| c | -0.0010280 | 0.0044549 | -3.6676099 | 0.0000000 |
| d | 0.2950410 | 0.0830525 | 3874.5900879 | 0.0040401 |
| e | -0.0001700 | 0.0006974 | -1.6962700 | 0.0000000 |
| f | -0.0008724 | 0.0015879 | -13.0732002 | 0.0000000 |

| | |
|---------------------------|--|
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | As designed, default to values in Table 6.7.7-1 [15] |
| <i>Baseline Rules</i> | Not applicable |

Desiccant Dewpoint Temperature Setpoint

Applicability Systems with desiccant dehumidification

Definition The setpoint dewpoint temperature of the air leaving the desiccant system

Units Degrees Fahrenheit (°F)

Input Restrictions As designed. Defaults to 50°F.

Baseline Rules Not applicable

Desiccant Heat Exchanger Effectiveness

Applicability Systems with desiccant dehumidification

Definition The effectiveness of a sensible heat exchanger used with a desiccant system

Units Ratio

Input Restrictions As designed

Baseline Rules Not applicable

Desiccant Heat Exchanger Pressure Drop

Applicability Systems with desiccant dehumidification

Definition The pressure drop across a sensible heat exchanger used with a desiccant system

Units in. H₂O

Input Restrictions As designed. Defaults to 1.0 in. H₂O

Source URL: <http://www.comnet.org/mgp/content/67-hvac-secondary-systems>

Links:

- [1] <http://www.comnet.org/mgp/content/hvac-system-map#hvac-mapping>
- [2] <http://www.comnet.org/mgp/content/24-calculation-procedures#calculation-process-for-tax-deductions-and-green-building-ratings>
- [3] <http://www.comnet.org/mgp/content/252-sizing-equipment-baseline-building#procedure-for-adjusting-equipment-hvac-sizes-in-the-baseline-building>
- [4] <http://www.comnet.org/mgp/content/system-controls#sat-cooling-setpoint-reset-based-on-outdoor-air-temperature-oat-for-dry-b-and-marine-c-climates>
- [5] <http://www.comnet.org/mgp/content/system-controls#example-of-sat-heating-setpoint-reset-based-on-outdoor-air-temperature-oat>
- [6] <http://www.comnet.org/mgp/content/673-fan-systems#baseline-building-fan-system—ASHRAE-standard-90.1-2007>
- [7] <http://www.comnet.org/mgp/content/673-fan-systems#baseline-building-fan-system—ASHRAE-standard-90.1-2001>
- [8] <http://www.comnet.org/mgp/content/673-fan-systems#fan-curve-default-values>
- [9] <http://www.comnet.org/mgp/content/674-outdoor-air-controls-and-economizers#baseline-economizer-control-type>
- [10] <http://www.comnet.org/mgp/content/675-cooling-systems#cooling-source-for-baseline-building-system>
- [11] <http://www.comnet.org/mgp/content/675-cooling-systems#default-coil-bypass-factors>
- [12] <http://www.comnet.org/mgp/content/675-cooling-systems#coil-bypass-factor-airflow-adjustment-factor>
- [13] <http://www.comnet.org/mgp/content/675-cooling-systems#coil-bypass-factor-temperature-adjustment-factor>
- [14] <http://www.comnet.org/mgp/content/675-cooling-systems#coil-bypass-factor-part-load-adjustment-actor>
- [15] <http://www.comnet.org/mgp/content/677-humidity-controls-and-devices#liquid-desiccant-unit-performance-curves>

6.8 HVAC Primary Systems

6.8.1 Boilers

| Boiler Name | |
|----------------------------------|--|
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | A unique descriptor for each boiler, heat pump, central heating heat-exchanger or heat recovery device. |
| <i>Units</i> | None |
| <i>Input Restrictions</i> | User entry. Where applicable, this should match the tags that are used on the plans for the proposed design. |
| <i>Baseline Rules</i> | Boilers are only designated in the baseline model if the Baseline System is of type 1 (PTAC), type 5 (Packages VAV with Reheat) or type 7 (VAV with Reheat). |
| Boiler Fuel | |
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | The fuel source for the central heating equipment. The choices are: <ul style="list-style-type: none"> • Gas • Oil • Electricity |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same fuel as the proposed design |
| Boiler Type | |
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | The boiler type. Choices include: <ul style="list-style-type: none"> • Steam Boiler • Hot Water Boiler • Heat-Pump Water Heater |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The boiler type will be a hot water boiler for baseline systems 1, 5 and 7, according to the baseline system descriptions from Table G3.1.1B. All other system types do not have a boiler. |
| Boiler Draft Type | |
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | How combustion airflow is drawn through the boiler. Choices are: <ul style="list-style-type: none"> • Natural (sometimes called atmospheric) • Mechanical <p>Natural draft boilers use natural convection to draw air for combustion through the boiler. Natural draft boilers are subject to outside air conditions and the temperature of the flue gases.</p> <p>Mechanical draft boilers enhance the air flow in one of three ways: 1) Induced draft, which uses ambient air, a steam jet, or a fan to induce a negative pressure which pulls flow through the exhaust stack; 2) Forced draft, which uses a fan and ductwork to create a positive pressure that forces air into the furnace, and 3) Balanced draft, which uses both induced draft and forced draft methods to bring air through the furnace, usually keeping the pressure slightly below atmospheric.</p> |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed. Default is natural draft. |
| <i>Baseline Rules</i> | The baseline boiler is always assumed to be a natural draft boiler. (G3.1.3.2) |
| Number of Identical Boiler Units | |
| <i>Applicability</i> | All boilers |

| | |
|---------------------------|---|
| <i>Definition</i> | The number of identical units for staging |
| <i>Units</i> | Numeric: integer |
| <i>Input Restrictions</i> | As designed. Default is 1. |
| <i>Baseline Rules</i> | The number of boilers in the baseline case is set as follows (G3.1.3.2). The baseline building has one boiler when it serves an area less than or equal to 15,000 ft ² . For larger service areas, the baseline building shall have two equally sized boilers. |

Boiler Heat Loss

| | |
|---------------------------|---|
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | The boiler or heat-exchanger heat loss expressed as a percentage of full load output capacity. This loss only occurs when the boiler is firing. |
| <i>Units</i> | Percent (%) |
| <i>Input Restrictions</i> | Default is 2% for electric boilers and heat-exchangers and 0% for fuel-fired boilers. If the user overrides the default, supporting documentation is required. |
| <i>Baseline Rules</i> | Prescribed at 2% for electric boilers and heat-exchangers. Prescribed at 0% for fuel-fired boilers, since this loss is already incorporated into the overall thermal efficiency, combustion efficiency or AFUE of the boiler. |

Boiler Design Capacity

| | |
|---------------------------|--|
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | The heating capacity at design conditions |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | Unmet load hours shall not exceed 300. If they do, the proposed boiler capacity shall be increased incrementally until the unmet loads are reduced to 300 or less. |
| <i>Baseline Rules</i> | <p>The boiler is sized to be 25% larger than the peak loads of the baseline building. Baseline boilers shall be sized using weather files containing 99.6% heating design temperatures and 1% dry-bulb and 1% wet-bulb cooling design temperatures.</p> <p>The unmet load hours of the proposed case shall also not exceed the unmet load hours of the baseline design by more than 50 hours. If they do, then the capacity of the baseline boiler shall be decreased incrementally until this difference is less than 50 hours.</p> |

Boiler Efficiency Type

| | |
|---------------------------|---|
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | <p>The full load efficiency of a boiler is expressed as one of the following:</p> <ul style="list-style-type: none"> <i>Annual Fuel Utilization Efficiency</i> (AFUE) is a measure of the boiler’s efficiency over a predefined heating season. <i>Thermal Efficiency</i> (E_t) is the ratio of the heat transferred to the water divided by the heat input of the fuel. <i>Combustion Efficiency</i> (E_c) is the measure of how much energy is extracted from the fuel and is the ratio of heat transferred to the combustion air divided by the heat input of the fuel. |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | <p><i>Annual Fuel Utilization Efficiency</i> (AFUE), for all gas and oil-fired boilers with less than 300,000 Btu/h capacity.</p> <p><i>Thermal Efficiency</i> (E_t), for all gas and oil-fired boilers with capacities between 300,000 and 2,500,000 Btu/h.</p> <p><i>Combustion Efficiency</i> (E_c), for all gas and oil-fired boilers with capacities above 2,500,000 Btu/h.</p> |
| <i>Baseline Rules</i> | Same as proposed design |

Boiler Efficiency

| | |
|----------------------|--|
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | The full load efficiency of a boiler at rated conditions (see efficiency type above) expressed as a dimensionless ratio of output over input. The software must accommodate input in either <i>Thermal Efficiency</i> (E_t) or <i>Annual Fuel Utilization Efficiency</i> (AFUE). Where AFUE is provided, E_t shall be calculated as follows: |

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

TEX EMBEDDING FAILED!

TeX Embedding failed!

All electric boilers will have an efficiency of 100%.

| | |
|--------------------|---|
| Units | Ratio |
| Input Restrictions | As designed |
| Baseline Rules | Boilers for the baseline design are assumed to have the minimum efficiency as listed in Table 6.8.1F from ASHRAE Standard 90.1-2007 or Table 6.2.1F from ASHRAE Standard 90.1-2001. |

Boiler Part-Load Performance Curve

| | |
|---------------|---|
| Applicability | All boilers |
| Definition | An adjustment factor that represents the percentage full load fuel consumption as a function of the percentage full load capacity. This curve shall take the form of a quadratic equation as follows: |

(6.8.1-2)

TeX Embedding failed!

TeX Embedding failed!

where

| | |
|--|--|
| F_{HeatPLC} | The Fuel Heating Part Load Efficiency Curve |
| F_{fuel}_{partload} | The fuel consumption at part load conditions (Btu/h) |
| F_{fuel}_{design} | The fuel consumption at design conditions (Btu/h) |
| Q_{partload} | The boiler capacity at part load conditions (Btu/h) |
| Q_{rated} | The boiler capacity at design conditions (Btu/h) |
| a | Constant, 0.082597 |
| b | Constant, 0.996764 |
| c | Constant, -0.079361 |

| | |
|--------------------|--|
| Units | Ratio |
| Input Restrictions | As designed. If the user does not use the default curve, supporting documentation is required. The software may auto-generate curves for other boiler types from descriptive type information such as boiler type, core, full or partial condensing, combustion air control, minimum unloading or staging, and return water temperature. |
| Baseline Rules | The baseline building uses the default |

Boiler Minimum Unloading Ratio

| | |
|---------------|--|
| Applicability | All boilers |
| Definition | The minimum unloading capacity of a boiler expressed as a percentage of the rated capacity. Below this level the boiler must cycle to meet the load. |

Table 6.8.1-1: "Default Minimum Unloading Ratios"

| Boiler Type | Default Unloading Ratio |
|----------------------|-------------------------|
| Electric Steam | 1% |
| Electric Hot Water | 1% |
| Fuel-Fired Steam | 25% |
| Fuel-Fired Hot Water | 25% |

| | |
|--------------------|---|
| Units | Percent (%) |
| Input Restrictions | As designed. If the user does not use the default curve the software must indicate that supporting documentation is required on the output forms. |
| Baseline Rules | Use defaults. |

Hot Water Supply Temperature

| | |
|--------------------|--|
| Applicability | All boilers |
| Definition | The temperature of the water produced by the boiler and supplied to the hot water loop |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed |
| Baseline Rules | Use 180°F for baseline boiler (G3.1.3.3). |

Hot Water Return Temperature

| | |
|---------------|--|
| Applicability | All boilers |
| Definition | The temperature of the water returning to the boiler from the hot water loop |
| Units | Degrees Fahrenheit (°F) |

| | |
|---|--|
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Use 130°F for baseline boiler design. |
| Hot Water Supply Temperature Reset | |
| <i>Applicability</i> | All boilers |
| <i>Definition</i> | Variation of the hot water supply temperature with outdoor air temperature. |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The hot water supply temperature should vary according to the following: <ul style="list-style-type: none">• 180°F when outside air is < 20°F• ramp linearly between 180°F & 150°F when outdoor air is between 20°F and 50°F• 150°F when outdoor air is > 50°F |

6.8.2 Chillers

| Chiller Name | | | | | | | | | |
|--|--|----------------------------|---------------------------------|-------------------------------|------------------------------|----------------------|---|-------------------------------|---|
| <i>Applicability</i> | All chillers | | | | | | | | |
| <i>Definition</i> | A unique descriptor for each chiller | | | | | | | | |
| <i>Units</i> | Text, unique | | | | | | | | |
| <i>Input Restrictions</i> | User entry. Where applicable, this should match the tags that are used on the plans. | | | | | | | | |
| <i>Baseline Rules</i> | Chillers are only designated when the baseline system is of type 7 (VAV with reheat) or 8 (VAV with PFP Boxes) (see Table G3.1.1B). | | | | | | | | |
| Chiller Type | | | | | | | | | |
| <i>Applicability</i> | All chillers | | | | | | | | |
| <i>Definition</i> | The type of chiller, either a vapor-compression chiller or an absorption chiller. <p>Vapor compression chillers operate on the reverse-Rankine cycle, using mechanical energy to compress the refrigerant, and include:</p> <ul style="list-style-type: none">• Reciprocating – uses pistons for compression• Screw – uses two counter rotating screws for compression• Scroll – uses two interlocking spirals or scrolls to perform the compression• Centrifugal – uses rotating impeller blades to compress the air• Absorption chillers – use heat to vaporize a working fluid (usually either ammonia or lithium bromide)• Single Effect Absorption – use a single generator & condenser• Double Effect Absorption – use two generators/concentrators and condensers, one at a lower temperature and the other at a higher temperature. It is more efficient than the single effect, but it must use a higher temperature heat source. | | | | | | | | |
| <i>Units</i> | List (see above) | | | | | | | | |
| <i>Input Restrictions</i> | As designed | | | | | | | | |
| <i>Baseline Rules</i> | The baseline building chiller is based on the design capacity of the proposed design as follows from ASHRAE 90.1 Appendix G: <p>Table 6.8.2-1: "Type and Number of Chillers"</p> <table><tr><th>Building Peak Cooling Load</th><th>Number and Type of Chillers (s)</th></tr><tr><td>TeX Embedding failed!300 tons</td><td>1 water-cooled screw chiller</td></tr><tr><td>>300 tons, <600 tons</td><td>2 water-cooled screw chillers sized equally</td></tr><tr><td>TeX Embedding failed!600 tons</td><td>2 water-cooled centrifugal chillers minimum with chillers added so that no chiller is larger than 800 tons, all sized equally</td></tr></table> | Building Peak Cooling Load | Number and Type of Chillers (s) | TeX Embedding failed!300 tons | 1 water-cooled screw chiller | >300 tons, <600 tons | 2 water-cooled screw chillers sized equally | TeX Embedding failed!600 tons | 2 water-cooled centrifugal chillers minimum with chillers added so that no chiller is larger than 800 tons, all sized equally |
| Building Peak Cooling Load | Number and Type of Chillers (s) | | | | | | | | |
| TeX Embedding failed!300 tons | 1 water-cooled screw chiller | | | | | | | | |
| >300 tons, <600 tons | 2 water-cooled screw chillers sized equally | | | | | | | | |
| TeX Embedding failed!600 tons | 2 water-cooled centrifugal chillers minimum with chillers added so that no chiller is larger than 800 tons, all sized equally | | | | | | | | |
| Number of Identical Chiller Units | | | | | | | | | |
| <i>Applicability</i> | All chillers | | | | | | | | |
| <i>Definition</i> | The number of identical units for staging. | | | | | | | | |
| <i>Units</i> | None | | | | | | | | |
| <i>Input Restrictions</i> | As designed. Default is 1. | | | | | | | | |
| <i>Baseline Rules</i> | From Table 6.8.2-1 [1] above, there is one chiller if the cooling load is 300 tons or less and two equally sized chillers for loads between 300 and 600 tons. For loads above 600 tons, two or more chillers of equal size are used, with no chiller larger than 800 tons. | | | | | | | | |

Chiller Fuel

| | |
|--------------------|--|
| Applicability | All chillers |
| Definition | The fuel source for the chiller. The choices are: <ul style="list-style-type: none">Electricity (for all vapor-compression chillers)Gas (Absorption units only, designated as direct-fired units)Oil (Absorption units only, designated as direct-fired units)Hot Water (Absorption units only, designated as indirect-fired units)Steam (Absorption units only, designated as indirect-fired units) |
| Units | List (see above) |
| Input Restrictions | As designed. |
| Baseline Rules | Electricity |

Chiller Rated Capacity

| | |
|--------------------|--|
| Applicability | All chillers |
| Definition | The cooling capacity of a piece of heating equipment at rated conditions. |
| Units | Btu/h or tons |
| Input Restrictions | As designed. If unmet load hours are greater than 300, the chiller may have to be made larger. |
| Baseline Rules | Determine loads for baseline building and oversize by 15%. |

Chiller Rated Efficiency

| | |
|--------------------|--|
| Applicability | All chillers |
| Definition | The Coefficient of Performance (COP) at ARI rated conditions. |
| Units | Ratio |
| Input Restrictions | As designed |
| Baseline Rules | With the ASHRAE Standard 90.1-2007 baseline, use the minimum values of efficiency from either Table 6.8.1C for various types of chillers or the values from Tables 6.8.1H, 6.8.1I or 6.8.1J for centrifugal chillers. With the ASHRAE Standard 90.1-2001 baseline, use the minimum values of efficiency from either Table 6.2.1C for various types of chillers, or the values from Tables 6.2.1H, 6. 2.1I or 6. 2.1J for centrifugal chillers. |

Chiller Minimum Unloading Ratio

| | |
|---------------|--|
| Applicability | All chillers |
| Definition | The minimum unloading capacity of a chiller expressed as a fraction of the rated capacity. Below this level the chiller must cycle to meet the load. |

Table 6.8.2-2: "Default Minimum Unloading Ratios"

| Chiller Type | Default Unloading Ratio |
|--------------------------|-------------------------|
| Reciprocating | 25% |
| Screw | 15% |
| Centrifugal | 10% |
| Scroll | 25% |
| Single Effect Absorption | 10% |
| Double Effect Absorption | 10% |

| | |
|--------------------|--|
| Units | Percent (%) |
| Input Restrictions | As designed. If the user does not employ the default values, supporting documentation is required. |
| Baseline Rules | Use defaults listed above. |

Chiller Cooling Capacity Adjustment Curve

| | |
|---------------|---|
| Applicability | All chillers |
| Definition | A curve or group of curves or other functions that represent the available total cooling capacity as a function of evaporator and condenser conditions and perhaps other operating conditions. The default curves are given as follows: |

(6.8.2-1)

TeX Embedding failed!

For air-cooled chillers:

(6.8.2-2)

TeX Embedding failed!

For water-cooled chillers:

TeX Embedding failed!

where

| | |
|------------------------|---|
| $Q_{\text{available}}$ | Available cooling capacity at present evaporator and condenser conditions (MBH) |
| t_{chws} | The chilled water supply temperature (°F) |
| t_{cws} | The condenser water supply temperature (°F) |
| t_{odb} | The outside air dry-bulb temperature (°F) |
| Q_{rated} | Rated capacity at ARI conditions (MBH) |

Note: If an air-cooled unit employs an evaporative condenser, t_{odb} is the effective dry-bulb temperature of the air leaving the evaporative cooling unit.

Table 6.8.2-3: "Default Capacity Coefficients – Electric Air-Cooled Chillers"

| Coefficient | Scroll | Recip | Screw | Centrifugal |
|-------------|-------------|-------------|-------------|-------------|
| a | 0.40070684 | 0.57617295 | -0.09464899 | N/A |
| b | 0.01861548 | 0.02063133 | 0.03834070 | N/A |
| c | 0.00007199 | 0.00007769 | -0.00009205 | N/A |
| d | 0.00177296 | -0.00351183 | 0.00378007 | N/A |
| e | -0.00002014 | 0.00000312 | -0.00001375 | N/A |
| f | -0.00008273 | -0.00007865 | -0.00015464 | N/A |

Table 6.8.2-4: "Default Capacity Coefficients – Electric Water-Cooled Chillers"

| Coefficient | Scroll | Recip | Screw | Centrifugal |
|-------------|-------------|-------------|-------------|-------------|
| a | 0.36131454 | 0.58531422 | 0.33269598 | -0.29861976 |
| b | 0.01855477 | 0.01539593 | 0.00729116 | 0.02996076 |
| c | 0.00003011 | 0.00007296 | -0.00049938 | -0.00080125 |
| d | 0.00093592 | -0.00212462 | 0.01598983 | 0.01736268 |
| e | -0.00001518 | -0.00000715 | -0.00028254 | -0.00032606 |
| f | -0.00005481 | -0.00004597 | 0.00052346 | 0.00063139 |

Table 6.8.2-5: "Default Capacity Coefficients – Fuel- & Steam-Source Water-Cooled Chillers"

| Coefficient | Single Stage Absorption | Double Stage Absorption | Direct-Fired Absorption | Engine Driven Chiller |
|-------------|-------------------------|-------------------------|-------------------------|-----------------------|
| a | 0.723412 | -0.816039 | 1.000000 | 0.573597 |
| b | 0.079006 | -0.038707 | 0.000000 | 0.0186802 |
| c | -0.000897 | 0.000450 | 0.000000 | 0.000000 |
| d | -0.025285 | 0.071491 | 0.000000 | -0.00465325 |
| e | -0.000048 | -0.000636 | 0.000000 | 0.000000 |
| f | 0.000276 | 0.000312 | 0.000000 | 0.000000 |

| | |
|--------------------|--|
| Units | Data structure |
| Input Restrictions | User may input curves, other appropriate functions, or use default curves. If the default curves are overridden, supporting documentation is required. |
| Baseline Rules | Use default curves. |

Electric Chiller Cooling Efficiency Adjustment Curves

| | |
|---------------|---|
| Applicability | All chillers |
| Definition | A curve or group of curves that varies the cooling efficiency of an electric chiller as a function of evaporator conditions, condenser conditions and part-load ratio. The default curves are given as follows: |

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

where

| | |
|------------------------|---|
| PLR | Part load ratio based on available capacity (not rated capacity) |
| $Q_{\text{operating}}$ | Present load on chiller (Btu/h) |
| $Q_{\text{available}}$ | Chiller available capacity at present evaporator and condenser conditions (Btu/h) |
| t_{chws} | The chilled water supply temperature (°F) |
| t_{cws} | The condenser water supply temperature (°F) |
| t_{odb} | The outside air dry-bulb temperature (°F) |
| P_{rated} | Rated power draw at ARI conditions (kW) |
| $P_{\text{operating}}$ | Power draw at specified operating conditions (kW) |

Note: If an air-cooled chiller employs an evaporative condenser, t_{odb} is the effective dry-bulb temperature of the air leaving the evaporative cooling unit.

Table 6.8.2-6: "Default Efficiency EIR-FT Coefficients – Air-Cooled Chillers"

| Coefficient | Scroll | Reciprocating | Screw | Centrifugal |
|-------------|-------------|---------------|-------------|-------------|
| a | 0.99006553 | 0.66534403 | 0.13545636 | N/A |
| b | -0.00584144 | -0.01383821 | 0.02292946 | N/A |
| c | 0.00016454 | 0.00014736 | -0.00016107 | N/A |
| d | -0.00661136 | 0.00712808 | -0.00235396 | N/A |
| e | 0.00016808 | 0.00004571 | 0.00012991 | N/A |
| f | -0.00022501 | -0.00010326 | -0.00018685 | N/A |

Table 6.8.2-7: "Default Efficiency EIR-FT Coefficients – Water-Cooled Chiller"

| Coefficient | Scroll | Reciprocating | Screw | Centrifugal |
|-------------|-------------|---------------|-------------|-------------|
| a | 1.00121431 | 0.46140041 | 0.66625403 | 0.51777196 |
| b | -0.01026981 | -0.00882156 | 0.00068584 | -0.00400363 |
| c | 0.00016703 | 0.00008223 | 0.00028498 | 0.00002028 |
| d | -0.00128136 | 0.00926607 | -0.00341677 | 0.00698793 |
| e | 0.00014613 | 0.00005722 | 0.00025484 | 0.00008290 |
| f | -0.00021959 | -0.00011594 | -0.00048195 | -0.00015467 |

Table 6.8.2-8: "Default Efficiency EIR-FPLR Coefficients – Air-Cooled Chillers"

| Coefficient | Scroll | Reciprocating | Screw | Centrifugal |
|-------------|------------|---------------|------------|-------------|
| a | 0.06369119 | 0.11443742 | 0.03648722 | N/A |
| b | 0.58488832 | 0.54593340 | 0.73474298 | N/A |
| c | 0.35280274 | 0.34229861 | 0.21994748 | N/A |

Table 6.8.2-9: "Default Efficiency EIR-FPLR Coefficients – Water-Cooled Chillers"

| Coefficient | Scroll | Reciprocating | Screw | Centrifugal |
|-------------|------------|---------------|------------|-------------|
| a | 0.04411957 | 0.08144133 | 0.33018833 | 0.17149273 |
| b | 0.64036703 | 0.41927141 | 0.23554291 | 0.58820208 |
| c | 0.31955532 | 0.49939604 | 0.46070828 | 0.23737257 |

| | |
|--------------------|--|
| Units | Data structure |
| Input Restrictions | User may input curves or use default curves. If defaults are overridden, supporting documentation is required. |
| Baseline Rules | Use default curves. |

Fuel and Steam Chiller Cooling Efficiency Adjustment Curves

| | |
|---------------|--|
| Applicability | All chillers |
| Definition | A curve or group of curves that varies the cooling efficiency of a fuel-fired or steam chiller as a function of evaporator conditions, condenser conditions, and part-load ratio. The default curves are given as follows: Default Curves for Steam-Driven Single and Double Effect Absorption Chillers |

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

Default Curves for Direct-Fired Double Effect Absorption Chillers

(6.8.2-6)

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

TeX Embedding failed!

The default curves for engine driven chillers are the same format as those for the Steam-Driven Single and Double Effect Absorption Chillers but there are three sets of curves for different ranges of operation based on the engine speed.

where

| | |
|--------------------------------|--|
| PLR | Part load ratio based on available capacity (not rated capacity) |
| FIR-FPLR | A multiplier on the fuel input ratio (FIR) to account for part load conditions |
| FIR-FT | A multiplier on the fuel input ratio (FIR) to account for the chiller water supply temperature and the condenser water temperature |
| FIR-FT1 | A multiplier on the fuel input ratio (FIR) to account for chilled water supply temperature |
| FIR-FT2 | A multiplier on the fuel input ratio (FIR) to account for condenser water supply temperature |
| CAP-FT | A multiplier on the capacity of the chiller (see Equation (6.8.2-2)) |
| Q_{operating} | Present load on chiller (in Btu/h) |
| Q_{available} | Chiller available capacity at present evaporator and condenser conditions (in Btu/h) |
| t_{chws} | The chilled water supply temperature (in °F) |
| t_{cws} | The condenser water supply temperature (in °F) |
| t_{odb} | The outside air dry-bulb temperature (°F) |
| Fuel_{rated} | Rated fuel consumption at ARI conditions (in Btu/h) |
| Fuel_{partload} | Fuel consumption at specified operating conditions (in Btu/h) |

Table 6.8.2-10: "Default FIR-FPLR coefficients – Fuel- & Steam-Source Water-Cooled Absorption Chillers"

| Coefficient | Single Stage Absorption | Double Stage Absorption | Direct-Fired Absorption |
|-------------|-------------------------|-------------------------|-------------------------|
| a | 0.098585 | 0.013994 | 0.13551150 |
| b | 0.583850 | 1.240449 | 0.61798084 |
| c | 0.560658 | -0.914883 | 0.24651277 |
| d | -0.243093 | 0.660441 | 0.00000000 |

Table 6.8.2-11: "Default FIR-FPLR coefficients – Engine Driven Chillers"

| Coefficient | %Speed TeX Embedding failed!Min. | %Speed>Min. %Speed<60% | %Speed>60% |
|-------------|--|---------------------------|------------|
| a | 0.3802 | 1.14336 | 1.38861 |
| b | 2.3609 | 0.022889 | -0.388614 |
| c | 0.0000 | 0.0000 | 0.0000 |
| d | 0.0000 | 0.0000 | 0.000 |

Table 6.8.2-12: "Default FIR-FT coefficients – Fuel- & Steam-Source Water-Cooled Absorption Chillers"

| Coefficient | Single Stage Absorption | Double Stage Absorption | Direct-Fired Absorption |
|-------------|-------------------------|-------------------------|-------------------------|
| a | 0.652273 | 1.658750 | 4.42871284 |
| b | 0.000000 | 0.000000 | -0.13298607 |
| c | 0.000000 | 0.000000 | 0.00125331 |
| d | -0.000545 | -0.290000 | 0.86173749 |
| e | 0.000055 | 0.000250 | -0.00708917 |
| f | 0.000000 | 0.000000 | 0.0010251 |

Table 6.8.2-13: "Default FIR-FT coefficients – Engine Driven Chillers"

| Coefficient | %SpeedTeX Embedding failed!Min. | %Speed>Min. %Speed<60% | %Speed>60% |
|-------------|---------------------------------|---------------------------|------------|
| a | 1.0881500 | 1.2362400 | 1.2362400 |
| b | 0.0141064 | 0.0168923 | 0.0168923 |
| c | 0.0000000 | 0.0000000 | 0.0000000 |
| d | -0.00833912 | -0.0115235 | -0.0115235 |
| e | 0.0000000 | 0.0000000 | 0.0000000 |
| f | 0.0000000 | 0.0000000 | 0.0000000 |

| | |
|--------------------|--|
| Units | Data structure |
| Input Restrictions | User may input curves or use default curves. If defaults are overridden, supporting documentation is required. |
| Baseline Rules | Use default curves. |

Chilled Water Supply Temperature

| | |
|--------------------|--|
| Applicability | All chillers |
| Definition | The chilled water supply temperature of the chiller at design conditions |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed |
| Baseline Rules | The baseline chilled water supply temperature is set to 44°F. |

Chilled Water Return Temperature

| | |
|--------------------|---|
| Applicability | All chillers |
| Definition | The chilled water return temperature setpoint |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed |
| Baseline Rules | The baseline chilled water return temperature is set to 56°F. |

Chilled Water Supply Temperature Reset

| | |
|--------------------|--|
| Applicability | All chillers |
| Definition | The reset schedule for the chilled water supply temperature. The chilled water setpoint may be reset based on demand or outdoor air temperature. |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed. The default is Figure 6.8.2-1 [2]. |
| Baseline Rules | The baseline chilled water supply temperature is reset from 44°F to 54°F based on outdoor air temperature as shown in the figure below. |




Figure 6.8.2-1: "Chilled Water Supply Temperature Reset Schedule"

Condenser Type

| | |
|---------------|--|
| Applicability | All chillers |
| Definition | The type of condenser for a chiller. The choices are: <ul style="list-style-type: none"> • Air-Cooled • Water-Cooled • Evaporatively-Cooled |

Air-cooled chillers use air to cool the condenser coils. Water-cooled chillers use cold water to cool the condenser and additionally need either a cooling tower or a local source of cold water. Evaporatively-cooled chillers are similar to air-cooled chillers, except they use a water mist to cool the condenser coil which makes them more efficient.

| | |
|-------|------------------|
| Units | List (see above) |
|-------|------------------|

| | |
|---------------------------|---|
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The baseline chiller is always assumed to have a water-cooled condenser, although the chiller type will change depending on the design capacity. If the chiller size is less than 600 tons, the baseline chiller is a water-cooled screw; if the capacity is greater than or equal to 600 tons, the baseline chiller is a water-cooled centrifugal chiller. |

Air-Cooled Condenser Power

| | |
|---------------------------|--|
| <i>Applicability</i> | All chillers |
| <i>Definition</i> | The energy usage of the condenser fan(s) at design conditions on an air-cooled chiller. This unit should only be used for chillers composed of separate evaporator and condenser sections where the fan energy is not part of the chiller COP. |
| <i>Units</i> | Kilowatts (kW) |
| <i>Input Restrictions</i> | As designed. The user must enter data for remote air-cooled condensing units. |
| <i>Baseline Rules</i> | Not applicable, since all baseline chillers have water-cooled condensers. |

6.8.3 Cooling Towers

Baseline Building Summary. Baseline building systems 7 and 8 have one or more cooling towers. One tower is assumed to be matched to each baseline building chiller. The number of baseline building chillers is determined in 6.8.2. Each baseline building chiller has its own condenser water pump that operates when the chiller is brought into service. The range between the condenser water return (CWR) and condenser water supply (CWS) is 10 F so the condenser water flow is a constant 2.5 gpm per cooling ton¹ when the chiller is in service. The baseline building pumping energy is assumed to be 19 W/gpm. The baseline building cooling tower is assumed to have a two-speed fan that is controlled to provide a CWS of 70 F when weather permits. The tower fan cycles to one-speed or off to maintain a CWS of 70 F at low wetbulb conditions. Under cooling conditions closer to design conditions, the CWS floats up to a maximum of 85 F (the design condition).

Cooling Tower Name

| | |
|---------------------------|--|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | A unique descriptor for each cooling tower |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | User entry. Where applicable, this should match the tags that are used on the plans. |
| <i>Baseline Rules</i> | Descriptive name that keys the baseline building plant |

Cooling Tower Type

| | |
|---------------------------|--|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | <p>The type of cooling tower employed. The choices are:</p> <ul style="list-style-type: none"> • Open tower, centrifugal fan • Open tower, axial fan • Closed tower, centrifugal fan • Closed tower, axial fan <p>Open cooling towers collect the cooled water from the tower and pump it directly back to the cooling system. Closed towers circulate the evaporated water over a heat exchanger to indirectly cool the system fluid.</p> |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The baseline cooling tower is an open tower axial fan device with a two-speed fan (See PRM G3.1.3.11) |

Cooling Tower Capacity

| | |
|---------------------------|---|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | The tower thermal capacity per cell adjusted to CTI (Cooling Technology Institute) rated conditions of 95 F condenser water return, 85 F condenser water supply, and 78 F wetbulb with a 3 gpm/nominal ton water flow. The default cooling tower curves below are at unity at these conditions. |
| <i>Units</i> | Btu/h |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The baseline building chiller is autosized and increased by 15%. The tower is sized to deliver 85 F condenser water supply at design conditions for the oversized chiller. |

Cooling Tower Number of Cells

| | |
|---------------------------|---|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | The number of cells in the cooling tower. Each cell will be modeled as equal size. Cells are subdivisions in cooling towers into individual cells, each with their own fan and water flow, and allow the cooling system to respond more efficiently to lower load conditions. |
| <i>Units</i> | Numeric: integer |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | One cell per tower and one tower per chiller. |

Cooling Tower Total Fan Horse Power

| | |
|----------------------|--------------------|
| <i>Applicability</i> | All cooling towers |
|----------------------|--------------------|

| | |
|---------------------------|--|
| <i>Definition</i> | The sum of the nameplate rated horsepower (hp) of all fan motors on the cooling tower. Pony motors should not be included. |
| <i>Units</i> | Horsepower (hp) |
| <i>Input Restrictions</i> | As designed. For minimum compliance with ASHRAE Standard 90.1-2007, must be at least 38.2 gpm/hp for an axial fan cooling tower and at least 20.0 gpm/hp for a centrifugal fan cooling tower. (Table 6.8.1G) |
| <i>Baseline Rules</i> | Not applicable since pump power is specified as 19 watts/gpm. |

Cooling Tower Design Wet-Bulb

| | |
|---------------------------|--|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | The design wet-bulb temperature that was used for selection and sizing of the cooling tower. |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | Same as proposed design |

Cooling Tower Design Entering Water Temperature

| | |
|---------------------------|--|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | The design condenser water supply temperature (leaving tower) that was used for selection and sizing of the cooling tower. |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | As designed. Default to 85°F. |
| <i>Baseline Rules</i> | 85°F or 10°F above the design wet-bulb temperature, whichever is lower (Table 6.8.1G) |

Cooling Tower Design Return Water Temperature

| | |
|---------------------------|---|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | The design condenser water return temperature (entering tower) that was used for selection and sizing of the cooling tower. |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | As designed. Default to 95°F. |
| <i>Baseline Rules</i> | Set to 95°F for a range of 10 F. (Table 6.8.1G) |

Cooling Tower Capacity Adjustment Curve(s)

| | |
|----------------------|--|
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | A curve or group of curves that represent the available total cooling capacity as a function of outdoor air wet-bulb, condenser water supply and condenser water return temperatures. The default curves are given as follows: |

(6.8.3-1)

$$Q_{available} = Q_{rated} \left[\frac{t_{cws} - t_{cwr}}{t_{owb} - t_R} \right]^a \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^b \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^c \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^d \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^e \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^f$$

$$FRA = \left[\frac{t_{cws} - t_{cwr}}{t_{owb} - t_R} \right]^a \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^b$$

$$FWB = \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^c \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^d \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^e \left[\frac{t_{owb} - t_A}{t_{owb} - t_R} \right]^f$$

where

| | |
|------------------------------|--|
| Q_{available} | Available cooling capacity at present outside air and condenser water conditions (MBH) |
| Q_{rated} | Rated cooling capacity at CTI test conditions (MBH) |
| t_{cws} | The condenser water supply temperature (in °F) |
| t_{cwr} | The condenser water return temperature (in °F) |
| t_{owb} | The outside air wet-bulb temperature (°F) |
| t_R | The tower range (in °F) |
| t_A | The tower approach (in °F) |
| FRA | An intermediate capacity curve based on range and approach |
| FWB | The ratio of available capacity to rated capacity (gpm/gpm). |

Table 6.8.3-1: "Default Capacity Coefficients – Cooling Towers"

| Coefficient | FRA | FWB |
|-------------|-------------|-------------|
| a | -2.22888899 | 0.60531402 |
| b | 0.16679543 | -0.03554536 |
| c | -0.01410247 | 0.00804083 |
| d | 0.03222333 | -0.02860259 |
| e | 0.18560214 | 0.00024972 |
| f | 0.24251871 | 0.00490857 |

| | |
|--------------|----------------|
| <i>Units</i> | Data structure |
|--------------|----------------|

| | |
|--|--|
| <i>Input Restrictions</i> | User may input curves or use default curves. If defaults are overridden, the rating software must indicate that supporting documentation is required on the output forms. |
| <i>Baseline Rules</i> | Use default curves. |
| Cooling Tower Set Point Control | |
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | The type of control for the condenser water supply. The choices are: <ul style="list-style-type: none"> • Fixed • Wet-bulb reset <p>A fixed control will modulate the tower to provide the design supply water temperature at all times. A wet-bulb reset control will reset according to the following control scheme:</p> <div style="text-align: right;">(6.8.3-2)</div> <div style="text-align: center;"><i>TeX Embedding failed!</i></div> <p>where</p> <div> t_{cws} The condenser water supply setpoint (in °F) t_{owb} The outside air wet-bulb temperature (°F) t_{dwb} The design outside air wet-bulb temperature (°F). t_A The tower design approach (in °F). RR The reset ratio (default is 0.29) </div> <p>A reset ratio (RR) of 0 will force the tower to always attempt a fixed approach to the outdoor wet-bulb temperature. A reset ratio (RR) of 1 will cause the system to perform as if it had fixed condenser water controls.</p> |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed. If the user does not use the default curve, supporting documentation is required. |
| <i>Baseline Rules</i> | Fixed at 70°F |
| Cooling Tower Capacity Control | |
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | Describes the modulation control employed in the cooling tower. Choices include: <ul style="list-style-type: none"> • Fluid Bypass provides a parallel path to divert some of the condenser water around the cooling tower at part-load conditions • Fan Cycling is a simple method of capacity control where the tower fan is cycled on and off. This is and is often used on multiple-cell installations. • Two-Speed Fan/Pony Motor. From an energy perspective, these are the same. A lower horsepower pony motor is an alternative to a two-speed motor; the pony motor runs at part-load conditions (instead of the full sized motor) and saves fan energy when the tower load is reduced. Additional building descriptors are triggered when this method of capacity control is selected. • Variable Speed Fan. A variable frequency drive is installed for the tower fan so that the speed can be modulated. |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | Two-speed fan |
| Cooling Tower Low-Speed Airflow Ratio | |
| <i>Applicability</i> | All cooling towers with two-speed or pony motors |
| <i>Definition</i> | The percentage full load airflow that the tower has at low speed or with the pony motor operating. This is equivalent to the percentage full load capacity when operating at low speed. |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | 0.50 |
| Cooling Tower Low-Speed kW Ratio | |
| <i>Applicability</i> | All cooling towers |
| <i>Definition</i> | The percentage full load power that the tower fans draw at low speed or with the pony motor operating |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | 0.30 |
| Cooling Tower Power Adjustment Curve | |
| <i>Applicability</i> | All cooling towers with VSD control |
| <i>Input Restrictions</i> | As designed. |
| <i>Baseline Rules</i> | As designed. |

A curve that varies the cooling tower fan energy usage as a function of part-load ratio for cooling towers with variable speed fan control. The default curve is given as follows:

(6.8.3-3)

$$\frac{P_{\text{operating}}}{P_{\text{rated}}} = \frac{Q_{\text{operating}}}{Q_{\text{available}}} \left(\frac{t_{\text{owb}} - t_{\text{R}}}{t_{\text{A}} - t_{\text{R}}} \right)^a \left(\frac{t_{\text{owb}} - t_{\text{R}}}{t_{\text{A}} - t_{\text{R}}} \right)^b \left(\frac{t_{\text{owb}} - t_{\text{R}}}{t_{\text{A}} - t_{\text{R}}} \right)^c$$

$$P_{\text{operating}} = P_{\text{rated}} \left(\frac{Q_{\text{operating}}}{Q_{\text{available}}} \right)^a \left(\frac{t_{\text{owb}} - t_{\text{R}}}{t_{\text{A}} - t_{\text{R}}} \right)^b \left(\frac{t_{\text{owb}} - t_{\text{R}}}{t_{\text{A}} - t_{\text{R}}} \right)^c$$

where

| | |
|------------------------|--|
| PLR | Part load ratio based on available capacity (not rated capacity) |
| $Q_{\text{operating}}$ | Present load on tower (in Btu/h) |
| $Q_{\text{available}}$ | Tower available capacity at present range, approach, and outside wet-bulb conditions (in Btu/h). |
| t_{owb} | The outside air wet-bulb temperature (°F) |
| t_{R} | The tower range (°F) |
| t_{A} | The tower approach (°F) |
| P_{rated} | Rated power draw at CTI conditions (kW) |
| $P_{\text{operating}}$ | Power draw at specified operating conditions (kW) |

Table 6.8.3-2: "Default Efficiency TWR-FAN-FPLR Coefficients – VSD on Cooling Tower Fan"

| Coefficient | TWR-FAN-FPLR |
|-------------|--------------|
| a | 0.33162901 |
| b | -0.88567609 |
| c | 0.60556507 |

| | |
|--------------------|--|
| Units | Data structure |
| Input Restrictions | User may input curves or use default curves. If defaults are overridden, supporting documentation is required. |
| Baseline Rules | Use default curves from DOE 2, given above. |

Cooling Tower Minimum Speed

| | |
|--------------------|---|
| Applicability | All cooling towers with a VSD control |
| Definition | The minimum fan speed setting of a VSD controlling a cooling tower fan expressed as a ratio of full load speed. |
| Units | Ratio |
| Input Restrictions | As designed. The default is 0.40. |
| Baseline Rules | Not applicable |

1. Cooling capacity is related to flow and delta-T through the equation $Q = 500 \times \text{GPM} \times \Delta T$. When Q is one ton (12,000 Btu/h), $\text{GPM} = 24 / \Delta T$ and $\Delta T = 24 / \text{GPM}$

6.8.4 Water-side Economizers

Baseline Building Summary. None of the baseline building systems use a water-side economizer.

Water-Side Economizer Name

| | |
|--------------------|---|
| Applicability | All water-side economizers |
| Definition | The name of a water-side economizer for a cooling system |
| Units | Text, unique |
| Input Restrictions | Descriptive reference to the construction documents. The default is no water-side economizer. |
| Baseline Rules | No water economizer |

Water Economizer Type

| | |
|---------------|---|
| Applicability | All water-side economizers |
| Definition | The type of water-side economizer. Choices include: <ul style="list-style-type: none">• None• Heat exchanger in parallel with chillers. This would be used with an open cooling tower is often referred to as a non-integrated economizer, because the chillers are locked out when the plant is in economizer mode.• Heat exchanger in series with chillers. This would be used with an open cooling tower and is often referred to as an integrated, because the chillers can operate simultaneously with water economizer operation.• Direct water economizer. This would be used with a closed cooling tower. In this case, a heat exchanger is not needed. This type works only as a non-integrated economizer. |

needed. This type works only as a non-integrated economizer.

- Thermo-cycle (also known as refrigerant migration). With thermo-cycle, bypass valves allow for the flow to vapor refrigerant to the condenser and allow gravity flow of liquid refrigerant to the evaporator without use of the compressor. Only some chillers have this capability and capacity may be limited under this mode. There is no additional piping; the cooler water from the tower is brought directly to the chiller(s) and the chiller(s) respond by shutting down the compressor and relying on thermal forces to drive the refrigerant. This method is also known as “thermosiphon” since thermal gradients passively move refrigerant between the evaporator and condenser.

| | |
|--------------------|---------------------|
| Units | List (see above) |
| Input Restrictions | As designed |
| Baseline Rules | No water economizer |

Water-Side Economizer HX Effectiveness

| | |
|---------------|--|
| Applicability | Water-side economizers with an open cooling tower |
| Definition | The effectiveness of a water-side heat exchanger at design conditions. This is defined as: |

(6.8.4-1)

TeX Embedding failed!

where

WSE_{eff} The effectiveness of the water-side economizer coil

t_{ea} The entering coil air dry-bulb temperature (°F)

t_{la} The leaving coil air dry-bulb temperature (°F)

t_{ea} The entering coil water temperature (°F)

| | |
|--------------------|-----------------------------------|
| Units | Ratio |
| Input Restrictions | As designed. The default is 60 %. |
| Baseline Rules | No water economizer |

Water-Side Economizer Maximum T_{db}

| | |
|--------------------|---|
| Applicability | All water-side economizers |
| Definition | The control temperature (outside air dry-bulb temperature) above which the water-side economizer is disabled. |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed. Defaults to 65°F. |
| Baseline Rules | No water economizer |

Water-Side Economizer Maximum CWS

| | |
|--------------------|---|
| Applicability | All water-side economizers |
| Definition | The control temperature (condenser water supply temperature) above which the water-side economizer is disabled. |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed. Defaults to 50°F. |
| Baseline Rules | No water economizer |

Water-Side Economizer CWS Setpoint

| | |
|--------------------|---|
| Applicability | All water-side economizers |
| Definition | The design condenser water supply temperature for the cooling tower in economizer mode. |
| Units | Degrees Fahrenheit (°F) |
| Input Restrictions | As designed. Defaults to 45°F or 40°F for “Thermo Cycle.” |
| Baseline Rules | No water economizer |

Water-Side Economizer Availability Schedule

| | |
|--------------------|---|
| Applicability | All water-side economizers |
| Definition | A schedule which represents the availability of the water-side economizer |
| Units | Data structure: schedule, on/off |
| Input Restrictions | As designed |
| Baseline Rules | No water economizer |

Water-Side Economizer Auxiliary kW

| | |
|--------------------|--|
| Applicability | Water-side economizers with an open tower |
| Definition | The electrical input (pumps and auxiliaries) for a dedicated pump for the chilled water side of the heat exchanger. This power is in excess of the condenser water pumps and cooling tower fans for the system during water-side economizer operation. |
| Units | KW or kW/ton |
| Input Restrictions | As designed |
| Baseline Rules | No water economizer |

6.8.5 Pumps

Baseline Building Summary. Hot water pumping in the baseline building (systems 1, 5, and 7) shall be modeled as a variable flow primary only system. When the spaces served by the hot water system are greater than or equal to 120,000 ft², the pump shall have a variable speed drive, otherwise, the pump “rides the curve”. Pumping energy shall be assumed to be 19 W/gpm. Two-way valves are assumed at the heating coils with a modulating bypass valve at the end of the loop. The bypass valve shall open as necessary to maintain minimum flow through the boiler when the system is activated. This will establish the minimum flow through the system.

Chilled water pumping in the baseline building (systems 7 and 8) is a primary/secondary system. Each chiller has its own primary and condenser water pumps that operate when the chiller is activated. All primary and secondary pumps shall be assumed to be 22 W/gpm and the condenser water pump is assumed to be 19 W/gpm. For plants less than or equal to 300 tons, the secondary pump “rides the curve” for larger plants, the pump has a variable speed drive.

General Notes. The building descriptors in this section are repeated for each pumping system. See the Pump Service building descriptor for a list of common pump services.

| Pump Name | |
|---------------------------|---|
| <i>Applicability</i> | All pumps |
| <i>Definition</i> | A unique descriptor for each pump |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | User entry. Where applicable, this should match the tags that are used on the plans. |
| <i>Baseline Rules</i> | Same as the proposed design. If there is no equivalent in the proposed design, assign a sequential tag to each piece of equipment. The sequential tags should indicate the pump service as part of the descriptor (e.g. CW for condenser water, CHW for chilled water, or HHW for heating hot water). |

| Pump Service | |
|---------------------------|--|
| <i>Applicability</i> | All pumps |
| <i>Definition</i> | The service for each pump. Choices include: <ul style="list-style-type: none">• Chilled water• Chilled water (primary)• Chilled water (secondary)• Heating water• Heating water (primary)• Heating water (secondary)• Service hot water• Condenser water• Loop water (for hydronic heat pumps) |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | As needed by the baseline building system |

| Number of Pumps | |
|---------------------------|---|
| <i>Applicability</i> | All pumps |
| <i>Definition</i> | The number of identical pumps in service in a particular loop, e.g. the heating hot water loop, chilled water loop, or condenser water loop |
| <i>Units</i> | Numeric: integer |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | There will be one heating hot water pump for each boiler, one chilled water pump, and one condenser water pump for each chiller. |

| Water Loop Design | |
|---------------------------|--|
| <i>Applicability</i> | All pumps |
| <i>Definition</i> | The heating and cooling delivery systems can consist of a simple primary loop system, or more complicated primary/secondary loops or primary/secondary/tertiary loops. |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Assume primary loops only for heating hot water. For chilled water loops, a primary-secondary loop design is assumed. |

| Pump Motor Modeling Method | |
|----------------------------|---|
| <i>Applicability</i> | All pumps |
| <i>Definition</i> | Software commonly models fans in one of two ways: The simple method is for the user to enter the electric power per unit of flow (W/gpm). This method is commonly used for smaller systems. A more detailed method requires a specification of the pumping head, impeller efficiency, motor efficiency, and other inputs. |
| <i>Units</i> | List: Power-Per-Unit-Flow or Detailed |
| <i>Input Restrictions</i> | Either method may be used, as appropriate. |
| <i>Baseline Rules</i> | Power-Per-Unit-Flow |

Pump Motor Power-Per-Unit-Flow

| | |
|---------------------------|---|
| <i>Applicability</i> | All baseline building pumps and proposed design pumps that use the Power-Per-Unit-Flow method. |
| <i>Definition</i> | The electric power of the pump divided by the flow at design conditions. |
| <i>Units</i> | W/gpm |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Prescribed to be 19 W/gpm for condenser and heating hot water pumps and 22 W/gpm for primary and secondary chilled water pumps. |

Impeller Efficiency

| | |
|---------------------------|--|
| <i>Applicability</i> | All pumps in proposed design that use the detailed modeling method |
| <i>Definition</i> | The full load efficiency of the impeller |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Motor Efficiency

| | |
|---------------------------|--|
| <i>Applicability</i> | All pumps in proposed design that use the detailed modeling method |
| <i>Definition</i> | The full load efficiency of the pump motor |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Pump Design Head

| | |
|---------------------------|--|
| <i>Applicability</i> | All pumps in proposed design that use the detailed modeling method |
| <i>Definition</i> | The design pressure for the pump |
| <i>Units</i> | Feet of water (or feet of head) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not applicable |

Pump Minimum Speed

| | |
|---------------------------|---|
| <i>Applicability</i> | All two-speed or variable-speed pumps |
| <i>Definition</i> | The minimum pump speed for a two-speed or variable-speed pump. For two-speed pumps this is typically 0.67 or 0.5. Note that the pump minimum speed is not necessarily the same as the minimum flow ratio, since the system head may change. |
| <i>Units</i> | Ratio |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | The secondary chilled water pumps for baseline building systems 7 and 8 have variable speed drives when the size of the cooling plant is greater than 300 tons. In these cases the Pump Minimum Speed shall be 0.10. |

Pump Design Flow (GPM)

| | |
|---------------------------|---|
| <i>Applicability</i> | All pumps |
| <i>Definition</i> | The flow rate of the pump at design conditions. This is derived from the load, and the design supply and return temperatures. |
| <i>Units</i> | gpm or gpm/ton for condenser and primary chilled water pumps |
| <i>Input Restrictions</i> | Not a user input |
| <i>Baseline Rules</i> | The temperature change on the evaporator side of the chillers is 12 F (56 F less 44 F) and this equates to a flow of 2 gpm/ton. The temperature change on the condenser side of the chillers is 10 F, which equates to a flow of 2.5 gpm/ton. The flow for secondary chilled water pumps varies with cooling demand, since there are two-way valves at the coils. The flow for primary only heating varies with demand down to the minimum required for flow through the boiler. A VSD is required for heating pumps when the service area is greater than or equal to 120,000 ft². |

Pump Control Type

| | |
|---------------------------|---|
| <i>Applicability</i> | All pumps |
| <i>Definition</i> | The type of control for the pump. Choices are: <ul style="list-style-type: none"> • Fixed speed, fixed flow • Fixed speed, variable flow (the default, with flow control via a valve) • Two-speed • Variable speed, variable flow |
| <i>Units</i> | None |
| <i>Input Restrictions</i> | As designed. The default is “Fixed Speed, Variable Flow” which models the action of a constant speed pump riding the curve against 2-way control valves. |
| <i>Baseline Rules</i> | The hot water and condenser water loops shall be primary loops only. When the hot water system serves less than 120,000 ft², the hot water pump shall be modeled as a fixed speed, variable flow pump (riding the pump curve). When the hot water system serves more than 120,000 ft², the hot water pump shall be modeled as a variable speed pump on a primary loop. The chilled water pumping for systems 7 and 8 is primary/secondary with variable flow. When the chilled water system has a capacity of less than 300 tons, the secondary system pumps shall ride the pump curve. When the chilled water system has a |

capacity of more than 300 tons, the secondary chilled water pumps shall be variable speed. Chilled water pumps used in the primary loop shall be fixed speed, fixed flow. Condenser water pumps shall be modeled as fixed speed, fixed flow.

| Pump Operation | |
|--------------------|--|
| Applicability | All pumps |
| Definition | The type of pump operation can be either On-Demand, Standby or Scheduled. On-Demand operation means the pumps are only pumping when their associated equipment is cycling, so chiller and condenser pumps are on when the chiller is on and the heating hot water pump operates when its associated boiler is cycling. Standby operation allows hot or chilled water to circulate through the primary loop of a primary/secondary loop system or through a reduced portion of a primary-only system, assuming the system has appropriate 3-way valves. Scheduled operation means that the pumps and their associated equipment are turned completely off according to occupancy schedules, time of year, or outside conditions. Under scheduled operation, when the systems are on they are assumed to be in On-Demand mode. |
| Units | List (see above) |
| Input Restrictions | As designed |
| Baseline Rules | The baseline system pumps are assumed to operate in On-Demand mode. The chilled water and condenser pumps are tied to the chiller operation, cycling on and off with the chiller, and the heating hot water pumps are tied to the boiler operation. |

| Pump Part Load Curve | |
|----------------------|--------------------------------------|
| Applicability | All pumps |
| Definition | A part-load power curve for the pump |

(6.8.5-1)

TeX Embedding failed!

(6.8.5-2)

TeX Embedding failed!

where

- PLR Part load ratio (the ratio of operating flow rate in gpm to design flow rate in gpm)
 P_{pump} Pump power draw at part-load conditions (W)
 P_{design} Pump power draw at design conditions (W)

Table 6.8.5-1: "Default Part-Load CIRC-PUMP-FPLR Coefficients – VSD on Circulation Pump"

| Coefficient | CIRC-PUMP-FPLR |
|-------------|----------------|
| a | 0.0015303 |
| b | 0.0052081 |
| c | 1.1086242 |
| d | -0.1163556 |

| | |
|--------------------|--------------------------------------|
| Units | Data structure |
| Input Restrictions | As designed. Default is curve above. |
| Baseline Rules | Use the defaults described above. |

6.8.6 Thermal Storage

There are multiple ways to model thermal storage in the proposed design. The baseline building does not have thermal storage.

6.8.7 Heat Recovery Equipment

| Heat Recovery Name | |
|---------------------------|---|
| Applicability | All heat recovery systems |
| Definition | A name assigned to a heat recovery system. This would provide a link to the construction documents. |
| Units | Text, unique |
| Input Restrictions | As designed |
| Baseline Rules | No heat recovery systems |
| Heat Recovery Device Type | |
| Applicability | All heat recovery systems |
| Definition | The type of heat recovery equipment. Choices include: |

- Double-Bundled Chiller

- Generator
- Engine-Driven Chiller
- Air Conditioning Unit
- Refrigerated Casework

| | |
|---------------------------|--|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Heat recovery systems are not included in the baseline system. |

Heat Recovery Loads

| | |
|----------------------|--|
| <i>Applicability</i> | All heat recovery systems |
| <i>Definition</i> | The loads met by the heat recovery system. Choices include: <ul style="list-style-type: none"> • Service water heating • Space heating • Process heating <p>More than one load may be selected.</p> |

| | |
|---------------------------|--------------------------------------|
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Not required in the baseline system. |

6.8.8 Plant Management

Plant management is a method of sequencing equipment. Separate plant management schemes may be entered for chilled water systems, hot water systems, etc.

Equipment Type Managed

| | |
|----------------------|--|
| <i>Applicability</i> | All plant systems |
| <i>Definition</i> | The type of equipment under a plant management control scheme. Choices include: <ul style="list-style-type: none"> • Chilled water cooling • Hot water space heating • Condenser water heat rejection • Service water heating • Electrical generation |

| | |
|---------------------------|-----------------------------|
| <i>Units</i> | None |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as the proposed design |

Equipment Schedule

| | |
|---------------------------|--|
| <i>Applicability</i> | All plant equipment |
| <i>Definition</i> | A schedule which identifies when the equipment is in service. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Where multiple equipment is used, they shall be staged in operation. |

Equipment Operation

| | |
|---------------------------|---|
| <i>Applicability</i> | All plant equipment |
| <i>Definition</i> | Equipment operation can be either On-Demand or Always-On. On-Demand operation means the equipment cycles on when it is scheduled to be in service and when it is needed to meet building loads, otherwise it is off. Always-On means that equipment runs continuously when it scheduled to be in service. |
| <i>Units</i> | None |
| <i>Input Restrictions</i> | As designed; the default is On-Demand. |
| <i>Baseline Rules</i> | Assume On-Demand operation |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/68-hvac-primary-systems>

Links:

- [1] <http://www.comnet.org/mgp/content/chillers#type-and-number-of-chillers>
[2] <http://www.comnet.org/mgp/content/chillers#chilled-water-supply-temperature-reset-schedule>

6.9 Miscellaneous Energy Uses

Miscellaneous energy uses are defined as those that may be treated separately since they have little or no interaction with the conditioned thermal blocks or the HVAC systems that serve them.

6.9.1 Water Heating

Water heating systems shall always be modeled for both the proposed design and baseline building when the proposed building is expected to have a water heating load, even if no water heating is shown on the plans or specifications for the proposed design. In such instances, an electric resistance system shall be modeled for both the proposed design and baseline building, meeting the efficiency requirements of the baseline standard.

When the construction documents show a water heating system, the layout and configuration of the baseline building system shall be the same as the proposed design, e.g. the baseline building shall have the same number of water heaters and the same distribution system.

System Loads and Configuration

Water Heating System Name

| | |
|---------------------------|---|
| <i>Applicability</i> | All water heating systems |
| <i>Definition</i> | A unique descriptor for each water heating system. A system consists of one or more water heaters, a distribution system, an estimate of hot water use, and a schedule for that use. Nonresidential buildings will typically have multiple systems, perhaps a separate electric water heater for each office break room, etc. Other building types such as hotels and hospitals may have a single system serving the entire building. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | Where applicable, this should match the tags that are used on the plans such that a plan reviewer can make a connection. |
| <i>Baseline Rules</i> | The naming convention for the baseline building system shall be similar to the proposed design. |

Water Heating Peak Use

| | |
|---------------------------|---|
| <i>Applicability</i> | All water heating systems, required |
| <i>Definition</i> | <p>An indication of the peak hot water usage (e.g. service to sinks, showers, and kitchen appliances, etc.). When specified per occupant, this value is multiplied by design occupancy density values and modified by service water heating schedules to obtain hourly load values which are used in the simulation.</p> <p>Peak consumption is commonly specified as gallons per hour per occupant, dwelling unit, hotel room, patient room, or floor area. If consumption is specified in gallons per hour, then additional inputs would be needed such as supply temperature, cold water inlet temperature, etc.</p> <p>It is also common to specify peak use as a thermal load in Btu/h. In the latter case, there is an implied assumption for the cold water inlet temperature, supply temperature, distribution losses, and other factors. The thermal load does not include conversion efficiencies of water heating equipment.</p> |
| <i>Units</i> | Btu/h or gallons/h |
| <i>Input Restrictions</i> | For the purpose of federal tax deductions, peak use shall be specified as a thermal load using the California 2005 ACM values from Appendix B, Table 5. For the purpose of green building ratings and Design to Earn ENERGY STAR, the inputs from Appendix B are default values, but other values may be used with justification. |
| <i>Baseline Rules</i> | Hot water consumption or load in the baseline building shall be the same as the proposed design, except in cases where a specific measure is specified for the proposed design that will reduce water consumption. Examples of such measures include: low-flow terminal devices or controls, alternative sanitizing technologies, or heat recovery laundry or showers drains. |

Water Heating Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All water heating systems, required |
| <i>Definition</i> | A fractional schedule reflecting the time pattern of water heating use. This input modifies the water heating peak use, described above. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | For the purpose of federal tax deductions, the schedules for the California 2005 ACM from Appendix B, Table 7 shall be used. For the purpose of green building ratings and Design to Earn ENERGY STAR, the inputs from Appendix B, Table 7 are default values, but other values may be used with justification. |

are default values, but other values may be used with justification.

| | |
|-----------------------|---|
| <i>Baseline Rules</i> | Hot water schedules for the baseline building shall be the same as the proposed design, except in cases where a specific measure is specified for the proposed design that will reduce water consumption and the impact of the measure can be best approximated through an adjustment to the schedule. In general, such measures would be addressed through an adjustment to the water heating, peak use (see above). |
|-----------------------|---|

Water Heating System Configuration

| | |
|---------------------------|---|
| <i>Applicability</i> | All water heating systems, required |
| <i>Definition</i> | The configuration and layout of the water heating system, including the number of water heaters; the size, location, length and insulation of distribution pipes; recirculation systems and pumps; and any other details about the system that would affect the energy model. |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | The baseline building shall have the same configuration and layout as the proposed design. |

Water Heaters

This section describes the building descriptors for water heaters. Typically, a building will have multiple water heating systems and each system can have multiple water heaters, so these building descriptors may need to be specified more than once.

Water Heater Name

| | |
|---------------------------|--|
| <i>Applicability</i> | All water heaters |
| <i>Definition</i> | A unique descriptor for each water heater in the system. Some systems will have multiple pieces of equipment, for instance a series of water heaters plumbed in parallel or a boiler with a separate storage tank. |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | Where applicable, this should match the tags that are used on the plans such that a plan reviewer can make a connection. |
| <i>Baseline Rules</i> | The naming convention for the baseline building system shall be similar to the proposed design. |

Water Heater Type and Size

| | |
|---------------------------|---|
| <i>Applicability</i> | All water heaters |
| <i>Definition</i> | <p>This building descriptor includes information needed to determine the criteria from baseline standards. The choices are listed below. See Table 7.2.2 of ASHRAE Standard 90.1-2001 or Table 7.8 of ASHRAE Standard 90.1-2007 for more detail.</p> <ul style="list-style-type: none">• Electric water heaters (storage and instantaneous)<ul style="list-style-type: none">◦ Small (≤ 12 kW)◦ Large (> 12 kW)• Heat pump• Gas storage water heaters<ul style="list-style-type: none">◦ Small ($\leq 75,000$ Btu/h)◦ Medium ($> 75,000$ and $\leq 155,000$ Btu/h)◦ Large ($> 155,000$ Btu/h)• Gas instantaneous water heaters<ul style="list-style-type: none">◦ Small ($> 50,000$ and $< 200,000$ Btu/h)◦ Large ($\geq 200,000$ Btu/h)• Oil storage water heaters<ul style="list-style-type: none">◦ Small ($\leq 105,000$ Btu/h)◦ Medium ($> 105,000$ and $\leq 155,000$ Btu/h)◦ Large ($> 155,000$ Btu/h)• Oil instantaneous water heaters<ul style="list-style-type: none">◦ Small ($\leq 210,000$ Btu/h)◦ Large ($> 210,000$ Btu/h)• Gas hot water supply boiler• Oil hot water supply boiler |
| <i>Units</i> | List (see above) |
| <i>Input Restrictions</i> | The water heater type shall agree with equipment specified in the construction documents. |
| <i>Baseline Rules</i> | Water heaters in the baseline system shall be the same as those in the proposed design, except when the proposed design has a heat pump water heater, in which case the baseline building system shall have an electric storage water heater. |

Rated Capacity

| | |
|----------------------|---|
| <i>Applicability</i> | All water heaters |
| <i>Definition</i> | The heating capacity of a water heater at the rated conditions specified in Table 7.8 of ASHRAE Standard 90.1-2007 or |

| | |
|--------------------|---|
| | Table 7.2.2 of ASHRAE Standard 90.1-2001 |
| Units | Thousands of British Thermal Units per hour (MBH) |
| Input Restrictions | As designed. If the loads are not met, autosize. |
| Baseline Rules | Autosize |

Energy Factor

| | |
|--------------------|--|
| Applicability | Equipment covered by NAECA, which includes small storage and instantaneous water heaters |
| Definition | The energy factor (EF) is the ratio of the energy delivered by the water heater divided by the energy used, in the same units. EF is calculated according to the DOE 10 CFR Part 430 test procedure, which specifies a 24-hour pattern of draws, a storage temperature, inlet water temperature, and other test conditions. These conditions result in the energy delivered for the test period. Energy inputs are measured for the same test period and the EF ratio is calculated. |
| Units | Unitless ratio |
| Input Restrictions | Building descriptors for the proposed design should be consistent with equipment specified on the construction documents or observed in the candidate building. |
| Baseline Rules | The EF for the baseline building system shall be determined from Table 7.2.2 of ASHRAE Standard 90.1-2001 or Table 7.8 of ASHRAE Standard 90.1-2007, depending on the purpose of the simulations. |

Thermal Efficiency

| | |
|--------------------|---|
| Applicability | Oil and gas fired water heaters not covered by NAECA |
| Definition | The full load efficiency of a water heater at rated conditions expressed as a dimensionless ratio of output over input |
| Units | Unitless ratio |
| Input Restrictions | Building descriptors for the proposed design should be consistent with equipment specified on the construction documents or observed in the candidate building. |
| Baseline Rules | The thermal efficiency for the baseline building system shall be determined from Table 7.2.2 of ASHRAE Standard 90.1-2001 or Table 7.8 of ASHRAE Standard 90.1-2007, depending on the purpose of the simulations. |

Tank Standby Loss

| | |
|--------------------|---|
| Applicability | Water heaters not covered by NAECA |
| Definition | The tank standby loss for storage tanks, which includes the effect of recovery efficiency. |
| Units | Btu/h for the entire tank |
| Input Restrictions | As specified in manufacturer data and documented on the construction documents |
| Baseline Rules | The tank standby loss for the baseline building system shall be determined from Table 7.2.2 of ASHRAE Standard 90.1-2001 or Table 7.8 of ASHRAE Standard 90.1-2007. |

Fuel Water Heater Part Load Efficiency Curve

| | |
|--------------------|--|
| Applicability | Equipment not covered by NAECA for which a thermal efficiency, as opposed to an EF is specified |
| Definition | A set of factors that adjust the full-load thermal efficiency for part load conditions. Typically, the factor is set as a curve. |
| Units | Percent (%) |
| Input Restrictions | The following default curve shall be used unless detailed information is provided to justify alternative values. The default curve shall take the form of a quadratic equation as follows: |

(6.9.1-1)

TeX Embedding failed!

TeX Embedding failed!

where

| | |
|---------------------------------|---|
| FHeatPLC | The fuel heating part load efficiency curve |
| Fuel _{partload} | The fuel consumption at part load conditions (Btu/h) |
| Fuel _{design} | The fuel consumption at design conditions (Btu/h) |
| Q _{partload} | The water heater capacity at part load conditions (Btu/h) |
| Q _{rated} | The water heater capacity at design conditions (Btu/h) |
| a | Constant, 0.021826 |
| b | Constant, 0.977630 |
| c | Constant, 0.000543 |

| | |
|----------------|---|
| Baseline Rules | The baseline building equipment shall use the default curve |
|----------------|---|

Recirculation Systems

This section describes the building descriptors for hot water recirculation systems. The baseline building has a recirculation system when the proposed design does. This is one aspect of the water heating system configuration (see above).

Recirculation System Name

| | |
|---------------|---------------------------|
| Applicability | All recirculation systems |
|---------------|---------------------------|

| | |
|---------------------------|--|
| <i>Definition</i> | A unique descriptor for each water heating recirculation system |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | Where applicable, this should match the tags or descriptions that are used on the plans such that a plan reviewer can make a connection. |
| <i>Baseline Rules</i> | The naming convention for the baseline building system shall be similar to the proposed design. |

Pumping Power

| | |
|---------------------------|--|
| <i>Applicability</i> | All recirculation systems |
| <i>Definition</i> | The electric demand of the pumps when the recirculation system is operating. This input is a function of the flow rate, the pumping head, the motor efficiency, and the pump efficiency. Some software may allow each of these factors to be separately entered. |
| <i>Units</i> | Watts (W) |
| <i>Input Restrictions</i> | Pumping power shall be consistent with the piping configuration, flow rate, and equipment specified on the construction documents. |
| <i>Baseline Rules</i> | Pumping power in the baseline building shall be the same as the proposed design unless specific measures are included in the proposed design to reduce the pumping power. Example measures could include reducing pumping head by oversizing distribution piping or specifying premium efficiency motors or pumps. |

Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All recirculation systems |
| <i>Definition</i> | An on/off or fraction schedule that indicates when the recirculation system is expected to be operated |
| <i>Units</i> | Data structure: schedule, on/off or fraction |
| <i>Input Restrictions</i> | The schedule for operation of the recirculation system shall be consistent with the design intent of the system. Hotels, hospitals, and other 24x7 institutional buildings will typically have a system that runs continuously. The schedule should be consistent with the controls called for on the construction documents: no control (runs constantly), timer control, temperature control, timer/temperature control, or demand control. |
| <i>Baseline Rules</i> | Recirculation schedules for the baseline building shall be the same as the proposed design. |

Piping

| | |
|---------------------------|--|
| <i>Applicability</i> | All recirculation systems |
| <i>Definition</i> | The heat loss rate of piping for recirculating systems. This may be defined separately for pipe that is exposed to outdoor conditions, indoor or semi-heated conditions, or buried underground conditions. These losses may be modeled as additional loads on the water heater(s). |
| <i>Units</i> | Btu/h-°F specified separately for outdoor, indoor, or buried locations |
| <i>Input Restrictions</i> | All piping in the recirculation system should be included. Heat loss for each of the three conditions should be consistent with piping runs, sizes, and insulation as shown on the construction documents. |
| <i>Baseline Rules</i> | The length and size of piping in the baseline building shall be the same as the proposed design. Insulation in the baseline building shall be as prescribed in Table 6.8.3 for ASHRAE Standard 90.1-2007 and Table 6.2.4.1.3 of ASHRAE Standard 90.1-2001. |

Water Heating Auxiliaries

External Storage Tanks

| | |
|---------------------------|--|
| <i>Applicability</i> | All water heating systems that have an external storage tank |
| <i>Definition</i> | Some water heating systems have a storage tank that is separate from the water heater(s) that provides additional storage capacity. This building descriptor addresses the heat loss related to the external tank, which is an additional load that must be satisfied by the water heater(s). The heat loss shall account for the surface area and U-factor tank, as well as the average temperature conditions where the tank is located. Some software may allow these factors to be separately specified. |
| <i>Units</i> | Btu/h for the entire tank |
| <i>Input Restrictions</i> | As specified in manufacturer data and documented on the construction documents |
| <i>Baseline Rules</i> | Heat loss associated with the storage tank in the baseline building shall meet the requirements for an unfired storage tank in the baseline standards which is an insulation R-value of 12.5. The surface area and location of the storage tank shall be the same as the proposed design. |

Heat Recovery

| | |
|---------------------------|--|
| <i>Applicability</i> | Water heating systems that are coupled to heat recovery equipment |
| <i>Definition</i> | Building equipment such as air conditioners, chillers, gas fired generators, etc. produce thermal energy that may be recovered and used to heat water. The heat producing characteristics are generally defined for the equipment that is producing the heat, not the equipment that is receiving the heat (water heaters in this case). The building descriptors will vary depending on the equipment. The models for heat producing equipment need to produce output on an hourly basis so that the schedule of heat production and heating needs can be aligned and evaluated in the water heating model. |
| <i>Units</i> | Data structure: depends on the equipment producing the heat |
| <i>Input Restrictions</i> | There are no restrictions, other than agreement with the construction documents. |
| <i>Baseline Rules</i> | The baseline building has heat recovery when the baseline standard is ASHRAE Standard 90.1-2007 and the conditions of Section 6.5.6.2 of that standard are satisfied. The baseline building is modeled with heat recovery when all of the following conditions are true: |

The building operates 24 hours per day.

The building has water cooled chillers with a heat rejection capacity greater than 6 million Btu/h. This equates to about 400 tons of electric chiller capacity.

The water heating peak use is greater than 1,000,000 Btu/h.

See the User's Manual for ASHRAE Standard 90.1-2007, page 6-82 for details on the requirements for the heat recovery system and exceptions to the requirement.

Solar Thermal

| | |
|---------------------------|--|
| <i>Applicability</i> | Water heating systems with a solar thermal system |
| <i>Definition</i> | <p>A solar thermal water heating system consists of one or more collectors. Water is passed through these collectors and is heated under the right conditions. There are two general types of solar water heaters: integrated collector storage (ICS) systems and active systems. Active systems include pumps to circulate the water, storage tanks, piping, and controls. ICS systems generally have no pumps and piping is minimal.</p> <p>Solar systems may be tested and rated as a complete system or the collectors may be separately tested and rated. SRCC OG-300 is the test procedure for whole systems and SRCC OG-100 is the test procedure for collectors. The building descriptors used to define the solar thermal system may vary with each software application and with the details of system design.</p> <p>Heat produced by solar thermal systems will generally not align perfectly with the need for heating, so the model needs to account for the temporal mismatch in some manner.</p> |
| <i>Units</i> | Data structure: will vary with the software and system details |
| <i>Input Restrictions</i> | There are no restrictions, other than agreement with the construction documents. |
| <i>Baseline Rules</i> | The baseline building has no solar auxiliary system. |

Combined Space Heating and Water Heating

| | |
|---------------------------|---|
| <i>Applicability</i> | Projects that use a boiler to provide both space heat and water heating |
| <i>Definition</i> | <p>A system that provides both space heating and water heating from the same equipment, generally the space heating boiler. Such systems are restricted by the baseline standards, but may be modeled in the candidate building. The restrictions are due to the misalignment of the space heating load and the water heating load. The first is highly intermittent and weather dependent, while the latter is more constant and not generally related to the weather.</p> |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | The proposed design may have a combined space and water heating system. |
| <i>Baseline Rules</i> | The baseline building shall be modeled with separate space heating and water heating systems, meeting the prescriptive requirements for each. The water heating system shall use the same fuel as the combined boiler. |

6.9.2 Exterior Lighting

All exterior lighting applications shall be included in the model when the purpose is for green building ratings or Design to Earn ENERGY STAR. Exterior lighting is an optional input for the purpose of tax deductions. If an exterior lighting application is not connected to the building electricity meter, then it should not be included, e.g. street lighting or common area lighting.

The building descriptors that are described in this section apply separately to each lighting application; input for each building descriptor is provided for parking lot lighting, façade lighting, entry lighting, etc. Each lighting application is modeled as a separate system. Exterior lighting applications affect the electric load of the building but do not produce heat that would need to be removed by the building's cooling system.

With ASHRAE Standard 90.1-2007, exterior lighting applications are grouped as tradable or non-tradable. Non-tradable lighting applications are use-it-or-lose-it categories such that the allowed power is the lesser of the power used for the proposed design or the allowed power.

- Tradable applications include uncovered parking areas, building grounds, building entrances and exits, canopies and overhangs, and outdoor sales areas. Thus, the allowed lighting power density of these applications is multiplied by the associated area or length to yield the baseline power.
- Non-tradable applications can only be used for the specific application and cannot be traded between applications or with other non-tradable applications such as building façades, automated teller machines, guardhouses, loading for law enforcement, drive through windows, or parking near retail. The allotment is in a use-it-or-lose-it format. Thus, the baseline power for these applications is the lesser of the wattage input for these applications or the product of the lighting power density for these applications and the area/length of these applications.

Exterior Lighting Name

| | |
|---------------------------|--|
| <i>Applicability</i> | All exterior lighting systems |
| <i>Definition</i> | A name for the lighting system |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | The name should be descriptive and provide a link to the construction documents. |

| | |
|-----------------------|---|
| <i>Baseline Rules</i> | The baseline building should have a corresponding exterior lighting system that maps to the one in the proposed design. The name should be similar. |
|-----------------------|---|

Exterior Lighting Category

| | |
|---------------------------|--|
| <i>Applicability</i> | All exterior lighting systems |
| <i>Definition</i> | <p>A classification of each exterior lighting system from Table 9.4.5 in ASHRAE Standard 90.1-2007 or Table 9.3.2 in ASHRAE Standard 90.1-2001. This classification will determine the lighting power for the baseline building (see below). The lighting category establishes if the exterior lighting application is tradable or non-tradable under ASHRAE Standard 90.1-2007. Credit is offered for power reductions for tradable lighting applications, but not for non-tradable lighting applications.</p> <p>The baseline standard and the associated User's Manual should be consulted for how to classify exterior lighting applications, however main entries shall provide access to the general public and shall not be used exclusively for staff or service personnel."¹ A couple of other clarifications are as follows:</p> <p>Bikeways – treated as walkways</p> <p>Outdoor dining – treated as plaza areas</p> <p>One of the categories offered by the software should be “Lighting that is specifically designated as required by a health or life safety statute, ordinance, or regulation.” This lighting is specifically excluded by the baseline standards such that the baseline building lighting power is the same as the proposed design.</p> |
| <i>Units</i> | List (from Table 9.4.5 of ASHRAE Standard 90.1-2007) (from Table 9.3.2 of ASHRAE Standard 90.1-2001) |
| <i>Input Restrictions</i> | The classification should accurately match the exterior lighting application in the rated building. |
| <i>Baseline Rules</i> | Same as the proposed design |

Exterior Lighting Area or Length

| | |
|---------------------------|--|
| <i>Applicability</i> | All exterior lighting systems |
| <i>Definition</i> | <p>Each exterior lighting system application (see above) has an area or length associated with it. This area or length is a factor in determining the baseline building lighting power (see below). The following rules should be taken into account when calculating length or area:</p> <ul style="list-style-type: none"> • Façade Illuminated area. Only areas of façade that are illuminated without obstruction are included in the illuminated area. • If the lighted façade area exceeds exterior wall area or if door linear footage exceeds 25% of building perimeter, the software shall produce a warning. • Uncovered parking shall be calculated according to the rules for the parking portion of “Illuminated hardscape” from Title 24-2005. This definition accounts for the paved area that is within 3 times the luminaire mounting height of parking luminaires: “Illuminated area is defined as any area within a square pattern around each luminaire or pole that is six times the mounting height with the luminaire in the middle of the pattern less any area that is within a building, under a canopy, beyond property lines or obstructed by a sign or structure.”² |
| <i>Units</i> | ft ² or ft |
| <i>Input Restrictions</i> | The area of the exterior lighting application should be determined using the rules in the baseline standard and the associated User's Manual. |
| <i>Baseline Rules</i> | Same as the proposed design |

Exterior Lighting Power

| | |
|---------------------------|--|
| <i>Applicability</i> | All exterior lighting systems |
| <i>Definition</i> | The power used for the exterior lighting application. This power should include the lamp as well as the ballast. |
| <i>Units</i> | W or W/ft ² |
| <i>Input Restrictions</i> | The lighting power should match the construction documents or the existing building being rated. |
| <i>Baseline Rules</i> | <p>The exterior lighting power for the baseline building is determined from the product of the <i>exterior lighting area or length</i> and the allowed power for the exterior <i>lighting category</i>. The allowed power is determined from Table 9.4.5 in ASHRAE Standard 90.1-2007 or Table 9.3.2 in ASHRAE Standard 90.1-2001.</p> <p>For non-tradable exterior lighting applications, the baseline building lighting power is the lesser of the lighting power for the proposed design application or the allowed power determined above.</p> |

Exterior Lighting Control

| | |
|----------------------|---|
| <i>Applicability</i> | All exterior lighting systems |
| <i>Definition</i> | <p>The means of controlling exterior lighting systems. The baseline standards required both daylight control and scheduling (e.g. a photocell and a standard time clock or an astronomical time clock). Additional controls could include:</p> <ul style="list-style-type: none"> • Standard (as required by baseline standards) |

- Bi-level motion sensing controls²
- On/off motion sensing control
- Bi-level scheduling controls⁴

| | |
|---------------------------|---|
| <i>Units</i> | List (see above) along with an associated power adjustment factor (PAF) or schedule adjustment |
| <i>Input Restrictions</i> | As designed. Documentation should be provided for lighting controls other than standard and evidence should be provided to support the reduction in lighting power (PAF) or the modification to the schedule. |
| <i>Baseline Rules</i> | The baseline building shall have standard lighting controls, e.g. a photocell and standard time clock. No adjustment is made to either the baseline building exterior lighting power or the schedule |

Exterior Lighting Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All exterior lighting systems |
| <i>Definition</i> | The exterior lighting schedule describes the fraction of installed connected lighting power that is operating for any given hour. The lighting schedule is a matrix of fractional values for each hour of the day and by day of week. |
| <i>Units</i> | Data structure: schedule, fractional. |
| <i>Input Restrictions</i> | <p>The default exterior lighting schedule shall be from dusk until 1 hour after the indoor lighting schedule drops below emergency lighting level (i.e. below 15%). Custom schedules may be created for atypical operating hours for exterior lighting systems. Each lighting system may operate on its own schedule. The default schedule shall be used when detailed information is unavailable.</p> <p>The schedule may be modified when qualifying lighting controls are installed (see above).</p> |
| <i>Baseline Rules</i> | The schedule for the baseline building shall be the same as the proposed design unless the proposed design schedule is adjusted for qualifying lighting controls, in which case the unadjusted schedule is used for the baseline building. |

1. From CA T-24-2008 Table 147B
2. 2005 T-24 T-24-2005 §147(c)1A
3. A PG&E study of bi-level motion sensing lighting controls for an outdoor parking lot found that the lights operated at low output for 45% of the evening hours. Pacific Gas and Electric Company Bi-Level LED Parking Lot Lighting: Raley's Supermarket West Sacramento, CA: February 2009 Emerging Technologies Program Application Assessment Report #0815 <http://www.etc-ca.com/images/stories/final20emerging20technology20repor...> [1]
4. For bi-level scheduling controls, one could turn off a fraction of the lights after interior lighting schedule dropped below 50% to indicate reduced lighting for after normal business hours or if parking lot lighting is within scope, reduced parking area that is illuminated during stocking, and other reduced activity periods.

6.9.3 Swimming Pools

Configuration and Design Requirements

| Pool Name | |
|---------------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | A unique identifier that keys the pool to the construction documents |
| <i>Units</i> | Text, unique |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | The name for the baseline building pool should be similar to the proposed design. |
| Volume | |
| <i>Applicability</i> | All pools |
| <i>Definition</i> | The volume of the pool |
| <i>Units</i> | Cubic feet (ft ³) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |
| Surface Area | |
| <i>Applicability</i> | All pools |
| <i>Definition</i> | The surface area of the pool affects heat loss and evaporation. |
| <i>Units</i> | Square feet (ft ²) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |
| Cover | |
| <i>Applicability</i> | All pools |
| <i>Definition</i> | An indication |

| | |
|---------------------------|---|
| <i>Definition</i> | An indication |
| <i>Units</i> | Boolean (Yes/No) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | The baseline building shall have a pool cover per Section 7.4.5.2 of ASHRAE Standard 90.1-2007. |

Cover Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | A schedule indicating when the pool cover is in place |
| <i>Units</i> | Data structure: schedule, on/off or fractional |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |

Filtration Rate

| | |
|---------------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | The rate at which the pool water is passed through the filtering system when the filtration system is operating |
| <i>Units</i> | Hours per pool change |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |

Filtration Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | A schedule indicating when the pool filtration system is in operation |
| <i>Units</i> | Data structure: schedule, on/off or fractional |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |

Temperature

| | |
|---------------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | The temperature at which the pool is maintained |
| <i>Units</i> | Degrees Fahrenheit (°F) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |

Temperature Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | A schedule indicating variation in the pool temperature, either seasonally or monthly |
| <i>Units</i> | Data structure: schedule, temperature |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design |

Pumping and Filtration

Pumping Power

| | |
|---------------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | The power used by the pumping system. This is a function of the pumping head (which depends on pipe lengths, sizes, and filtration type), the pump efficiency, the motor efficiency, and the flow rate. Some software may allow these to be entered as separate building descriptors. This value should be consistent with the filtration rate noted above. |
| <i>Units</i> | Watts (W) |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Same as the proposed design unless the proposed design uses special low head filters and premium efficiency motors |

Heating Equipment

Heater Type

| | |
|----------------------|---|
| <i>Applicability</i> | All pools |
| <i>Definition</i> | The type of equipment that is used to maintain the pool temperature |
| <i>Units</i> | List: solar, heat pump, gas, oil, or electric resistance |

| | |
|---------------------------|---|
| <i>Units</i> | List: solar, heat pump, gas, oil, or electric resistance |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | If there is gas or oil on the site, the baseline building shall be modeled with a natural gas or oil pool heater meeting the requirements of Table 7.8 for ASHRAE Standard 90.1-2007. If there is no gas or oil on the site, the baseline building shall be modeled with a heat pump pool heater meeting the requirements of Table 7.8 for ASHRAE Standard 90.1-2007. |

Heater Efficiency

| | |
|---------------------------|---|
| <i>Applicability</i> | All pools with heaters |
| <i>Definition</i> | The thermal efficiency of the pool heater |
| <i>Units</i> | Unitless, thermal efficiency |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | See the baseline building rules for heater type |

Solar System Features

| | |
|---------------------------|--|
| <i>Applicability</i> | All pools with solar pool heaters |
| <i>Definition</i> | The collector area, size, efficiency, and pumping characteristics of the solar pool system |
| <i>Units</i> | Data structure |
| <i>Input Restrictions</i> | None |
| <i>Baseline Rules</i> | Not applicable. The baseline building has a pool cover, not solar |

6.9.4 Other Electricity Use

This set of building descriptors should be used to include any miscellaneous electricity use that would add to the electric load of the building and would be on the building meter. These energy uses are assumed to be outside the building envelope and do not contribute heat gain to any thermal block.

Miscellaneous Electric Power

| | |
|---------------------------|---|
| <i>Applicability</i> | All buildings with miscellaneous electric equipment located on the building site |
| <i>Definition</i> | The power for miscellaneous equipment. |
| <i>Units</i> | Watts (W) |
| <i>Input Restrictions</i> | As designed. All miscellaneous power shall be accounted for when the purpose is a green building rating or an energy label. |
| <i>Baseline Rules</i> | Same as the proposed design |

Miscellaneous Electric Schedule

| | |
|---------------------------|---|
| <i>Applicability</i> | All buildings with miscellaneous electric equipment located on the building site |
| <i>Definition</i> | The schedule of operation for miscellaneous electric equipment. This is used to convert electric power to energy use. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | The schedule specified for the building should match the operation patterns of the system. |
| <i>Baseline Rules</i> | Same as the proposed design |

6.9.5 Other Gas Use

This set of building descriptors should be used to include any miscellaneous gas use that would add to the load of the building and would be on the building meter. These energy uses are assumed to be outside the building envelope and do not contribute heat gain to any thermal block.

Other Gas Power

| | |
|---------------------------|--|
| <i>Applicability</i> | All buildings that have commercial gas equipment |
| <i>Definition</i> | Gas power is the peak power which is modified by the schedule (see below). |
| <i>Units</i> | Btu/h-ft ² |
| <i>Input Restrictions</i> | As designed |
| <i>Baseline Rules</i> | Same as the proposed design |

Other Gas Schedule

| | |
|---------------------------|--|
| <i>Applicability</i> | All buildings that have commercial gas equipment |
| <i>Definition</i> | The schedule of operation for commercial gas equipment. This is used to convert gas power to energy use. |
| <i>Units</i> | Data structure: schedule, fractional |
| <i>Input Restrictions</i> | Continuous operation is prescribed. |
| <i>Baseline Rules</i> | Same as the proposed design |

Source URL: <http://www.comnet.org/mgp/content/69-miscellaneous-energy-uses>

Links:

[1] <http://www.etcc-ca.com/images/stories/final20emerging20technology20report20for20led20parking20lot20lighting1.pdf>

7 Advanced Modeling Tips

7.1 Challenging Building Types

Modeling tips and advice is offered in this section for laboratories, healthcare and data centers. Each of these building types presents unique challenges to energy modelers. The guidance here supplements the information in Chapter 6. Information provided in this chapter supersedes information in Chapter 6 when there is a conflict.

7.1.1 Laboratories

Many aspects of laboratory energy usage are not directly regulated by the baseline standards. However, these energy uses must be accounted for in order to obtain an accurate simulation of the building energy usage and properly calculate percent savings for green building ratings (tax deduction calculations only require consideration of regulated energy use, e.g. heating, cooling, fans, hot water and interior lighting). In addition, it is also important to note that the non-regulated energy components of the laboratory will impose loads on the regulated portions, such as chillers and boilers, increasing the importance of capturing this energy usage.

Laboratory HVAC Systems

Laboratories tend to be large buildings so the basic HVAC mapping rules presented in Chapter 6 will typically map to baseline building systems 5 through 8, which are variable air volume systems with one air handler per floor. There are three exceptions to this rule, however, that could affect the baseline building systems for laboratories:

- The first exception is specific for laboratories. This exception applies when a laboratory or group of laboratories have an exhaust system designed for 5,000 cfm or more of air movement. The baseline building system serving the laboratory spaces shall be either system 5 (PVAV with hot water reheat) or system 6 (PVAV with parallel fan-powered boxes and electric reheat), depending on the heating source in the building. The PVAV system must be capable of reducing the exhaust and makeup air volume to 50% of design values during unoccupied periods. This exception essentially requires VAV for both the supply fan and the exhaust system. (See the PRM, G3.1.1, Exception c.)
- When the above exception for laboratories does not apply, a separate laboratory system may still be required to be modeled in the baseline building. Either system 3 (PSZ-AC) or system 4 (PSZ-HP) shall serve laboratories in the baseline building (depending on the heating source for the building) when one of the following conditions apply:
 - Spaces on a floor have significantly different schedules or internal heat loads: heat gain differences of more than 10 Btu/h or operation schedule differences of more than 40 hours/week. (See the PRM, G3.1.1, Exception b.)
 - Spaces on a floor have "special pressurization relationships, cross-contamination requirements, or code-required minimum circulation rates." Many laboratory spaces with fume hoods would likely trigger this exception. (See the PRM, G3.1.1, Exception c.)

These special systems apply to the spaces that trigger one or more of the exceptions. The rest of the building/floor would be served by the baseline building HVAC system and air handlers.

Equipment Loads

The amount of internal load in a laboratory from equipment will vary greatly based upon function, and also will vary based upon time, with night-time loads typically much lower. The topic of diversity is addressed under the topic of schedules; however the peak load should be input based upon the actual equipment selection. In most cases, the equipment power will be the same for both the baseline and proposed design, except when the proposed design employs explicit strategies to reduce energy use and reduce internal loads, in which case, more efficient equipment or lower internal loads may be assumed in the proposed design. As an example, localized refrigeration equipment in the lab space might be replaced by a central chilled water system, thus reducing the heat rejection load that occurs in the space and increasing the efficiency of cooling the equipment. In this case, it would be acceptable to have different internal loads in the baseline and proposed buildings. When equipment power or internal loads are different between the proposed design and the baseline building, special documentation shall be provided. Some common laboratory equipment is discussed in greater detail in subsequent sections.

Redundancy

In some cases it is standard practice to provide redundant equipment in laboratories because of the risk involved in equipment failure. If additional equipment is installed for pure redundancy, then this equipment shall be ignored in the modeling of the proposed design and the baseline building.

equipment is included for pure redundancy, then this equipment shall be ignored in the modeling of the proposed design and the baseline building. For a more complex situation, a laboratory with a 100 ton load might be designed with two 75 ton chillers with the idea that should one chiller fail, the remaining chiller will be able to satisfy the critical load. If this design intent can be documented, then it is acceptable to model the proposed design in this fashion. The baseline building equipment will be autosized according to the rules in Chapter 2 and Chapter 6 and the number of chillers or boilers will be determined based on the rules in Chapter 6.

Design Conditions

Space dry-bulb temperature setpoints should generally be based upon actual design requirements, but for laboratories will generally be around 70°F for heating, 72°F for cooling. Humidification to at least 30% RH is common in most areas of the country. Dehumidification, when required, is accomplished by keeping coil leaving air temperatures around 53 F during humid ambient conditions.

Air Delivery

For systems serving laboratory spaces, use a supply-air-to-room-air temperature difference of 17°F for the baseline building and the proposed design (Chapter 6 specifies 20°F for other building types). If return or relief fans are specified in the proposed design, the baseline building design shall also be modeled with fans serving the same functions (this is the general Chapter 6 modeling rule). The baseline building return/relief fans shall be sized for the baseline system supply fan air quantity less the minimum outdoor air, or 90% of the supply fan air quantity, whichever is larger. See the discussion above on laboratory HVAC systems for more detail on exhaust systems serving fume hoods.

Outside Air

Due to the presence of hazardous materials in laboratory environments, it is common practice to use 100% outside air. The codes do not explicitly forbid lab air recirculation within individual lab zones, but code requirements are most easily met by a 100% outside air system. The Chapter 6 modeling rules apply in this case, as the outside air for the baseline building is the same as the outside air for the proposed design.

In some cases, labs are part of a mixed-use building that includes both office spaces as well as laboratories served by the same air handling system. In most cases, the baseline building system serving laboratories will be separate from the main building system (see laboratory HVAC systems above).

Outside air delivered by these dedicated systems would be the same as the air delivered by the proposed design systems, unless the assignment of thermal blocks to systems is modified.

Schedules

Appendix C has schedules for laboratories that shall be used as a default. The schedules assume heavier loads during more typical working hours. Fans are assumed to be on 24 hours throughout the day. If the laboratory operates on a seasonal schedule, such as a school schedule, and has lower usage during one season, adjust the schedules as needed.

Animal Cages

Open animal cages that do not include their own dedicated ventilation system are commonly used in laboratories. These shall be the same in the proposed design and the baseline building.

Autoclaves

These systems use high pressure steam for sterilization. Typically efficiency measures accounted for here would be on the steam side.

Compressed Dry Air

Some laboratories require a supply of compressed dry air for drying and other purposes. When these systems exist in the proposed design, they shall also exist in the baseline building. In the baseline building, the supply air pressure setpoint is constant and the systems do not employ heat recovery. The air dryers are regenerated with compressed air, on a regular time-based interval. Energy efficiency measures may be documented for the proposed design with proper documentation.

De-Ionized Water

These systems remove minerals and ions from the water to reduce the electrical conductivity of the water and would typically be the same in the baseline and proposed buildings.

Environmental Chambers

Heat pumps typically heat or cool the interior of the chamber to provide a controlled test environment. For the baseline building, heat rejection (or absorption) from the heat pumps is assumed to occur directly into the space in which the heat pump is installed. The proposed design may employ

energy efficiency measures, including high efficiency heat pump units, as well as remote heat rejection through a condenser water system.

Fume Hoods

Fume hoods generally do not contain local fans, but rather have an exhaust system serving multiple hoods. The energy use of a fume hood is reflected in the amount of air moving through the hood and the efficiency of the exhaust system that serves it. Fume hood exhaust systems in the proposed design can be operated as constant air volume (CAV) or variable air volume (VAV). The baseline building exhaust system shall be VAV for laboratory exhaust systems that are designed for 5,000 cfm or more. See laboratory HVAC systems above. Otherwise, the baseline building exhaust fan system and operation shall be the same as the proposed design. The modeling assumption for the sash opening face velocity is a constant 100 ft/min for both the proposed design and the baseline building, regardless of space occupancy and regardless of whether an occupant is standing in front of the hood. However the baseline hood exhaust schedule assumes the hoods are closed and airflow reduced during unoccupied periods.

Biosafety cabinets can also be operated as CAV or VAV. However, biosafety cabinets have a more demanding tolerance (+/-5%) on variations in air flow than fume hoods. The air flow variation in a typical VAV system is on the order of +/-1 for biosafety cabinets is CAV.

Glass Washers

These machines will wash and sterilize lab glassware. The equipment will typically be the same in the baseline and proposed buildings. This equipment has high but intermittent heat and moisture gains to the containing spaces.

Vacuum Systems

Process vacuum pumps create a negative-pressure distribution system needed for certain types of lab equipment. Not to be confused with the "house" vacuum system, used for janitorial purposes. In most cases, the baseline and proposed vacuum pumps will be the same, although more efficient vacuum pumps could be substituted in the proposed design with suitable documentation of what is considered a typical base case condition.

Reverse Osmosis Water

These systems are similar to the de-ionized water systems except that the process involves pumping the water through a semi-permeable membrane. These systems would typically be the same in the baseline and proposed buildings. Average loads should be far below design electrical capacities.

7.1.2 Health Care

Many health care projects are designated as occupancy group "I", which subjects them to specialized code requirements necessary based upon health and safety requirements. Typically, the envelope components of health care projects are not that different from conventional occupancies. However, lighting, HVAC and domestic hot water systems can be significantly different and will present some challenges in the modeling process. In addition, these facilities can have many other energy consuming systems that will require attention.

Lighting

Health care projects typically have a wide range of space uses. A typical hospital could have 50 or 60 different space functions occurring in the facility. In modeling the facility, there are two possible choices for lighting. The easiest choice is to use the *building classification* method for all spaces that occur in the building. The second choice is to break the building out into each space function and use the *space-by-space* method, which will entail a significantly larger amount of work. Choosing the approach can be difficult, as a facility with a large amount of space functions requiring large amounts of light would benefit from the more granular approach of using the space functions. Given the fact that a hospital might require HVAC zoning of several hundred zones, the additional work of layering in space function lighting can result in models with zones numbering 600 to 1000. In either case, the baseline and proposed buildings will have the same thermal blocks, zoning and space functions.

An additional consideration is that many spaces in the proposed design may use task/ambient lighting systems. For example, patient rooms will typically have an ambient lighting system that provides minimal illumination, and a second lighting system that will only be activated by staff during brief examination periods. Other areas, such as surgery rooms, will have surgical lights that are only used during active surgery, so it is important that the lighting systems include appropriate schedules for the task lighting that accounts for the intermittent use. Note that in modeling the baseline building, the baseline lighting power density allowance will be modeled, using the ambient lighting schedule from the proposed design. An alternative schedule may be used for task lighting in the proposed design. For exempt lighting uses, this alternative schedule shall be used for both the baseline building and the proposed design.

HVAC

The basic HVAC system mapping rules described in Chapter 6 apply to health care facilities. Most are large buildings so the baseline building systems will tend to be system 7 (VAV with hydronic reheat) or system 8 (VAV with parallel fan-powered boxes and electric reheat). However,

many spaces in healthcare facilities trigger the exceptions to the HVAC mapping rules:

- The laboratory exception applies when a laboratory or group of laboratories have an exhaust system designed for 5,000 cfm or more of air movement. The baseline building system serving the laboratory spaces shall be either system 5 (PVA V with hot water reheat) or system 6 (PVA V with parallel fan- powered boxes and electric reheat), depending on the heating source in the building. The PVA V system must be capable of reducing the exhaust and makeup air volume to 50% of design values during unoccupied periods. This exception essentially requires VAV for both the supply fan and the exhaust system. (See the PRM, G3.1.1, Exception c.)baseline?
- When the above exception for laboratories does not apply, a separate system may still be required to be modeled in the baseline building. Either system 3 (PSZ-AC) or system 4 (PSZ-HP) shall serve healthcare spaces in the baseline building (depending on the heating source for the building) when one of the following conditions apply:
 - Spaces have significantly different schedules or internal heat loads. Heat gain differences or more than 10 Btu/h or operation schedule differences of more than 40 hours/week trigger this exception. (See the PRM, G3.1.1, Exception b.)
 - Spaces on a floor have "special pressurization relationships, cross-contamination requirements, or code-required minimum circulation rates". Surgical suites and other healthcare spaces would likely trigger this exception. (See the PRM, G3.1.1, Exception c.)

The HVAC systems in many healthcare facilities are in operation 24 hours per day and consume very large amounts of energy. In many cases, the decision of a certain type of mechanical system in these facilities is made for health and safety code compliance, and in many cases they will be 100% outside air systems. It is not unusual to see very large static pressure requirements due to HEPA filtration and sound attenuators. In the case of 100% outside air systems, exhaust fans are also an important aspect of the design. Given the large diversity of space uses, and the fact that each may have specialized ventilation requirements, it is important to model the building with a sufficient number of zones to account for these uses. In modeling the baseline building, the same zones are used with the same ventilation rates used in the proposed building. These conditions will likely trigger one of the exceptions to the HVAC mapping rules and require that the spaces be served by a separate system.

Some healthcare facilities will have areas that are used continuously, such as patient rooms, mixed in with areas that are only in use during normal daytime hours, such as medical offices. In some cases an entire wing or floor of a facility will be on a normal 8-5 operation and will have a dedicated HVAC system to allow night-time shutdown. In this case, the proposed building modeling should include appropriate HVAC operating schedules to account for the night-time operation. The baseline building will typically have separate systems for spaces with a different schedule (see discussion above).

Most areas of hospitals have relatively high airflow minimums and require continuous operation even when unoccupied. Some areas do not allow VAV operation or require return air VAV valves to assure pressurization. Some areas of the building will have very large air change rates, such as surgical suites. However, in many applications, these suites are only used during daytime hours. One strategy is to have a night setback in these spaces, reducing the air change rate from 20 in the daytime, for example, down to 6 at night. This will require the proposed building to include schedules to account for this, but in the case of the baseline building, operation would be assumed to be at the 20 air change rate for all hours.

Surgical suites may also require low SATs and special dehumidification. Most hospitals require winter humidification, varying among systems and zones.

Domestic Hot Water

Domestic hot water usage will vary greatly depending upon the type of facility, as well as functions that occur in the facility. Some hospitals have on-site laundry facilities, while many others out-source this activity to offsite providers. Facilities such as medical office buildings will have dramatically lower hot water usage than a multi-bed facility with many patient rooms. Once again, accurate schedules that reflect this usage will need to be developed. In most cases, the baseline and proposed buildings will include the same hot water usage and schedules, unless a reduction in hot water usage can be demonstrated due to a proposed design feature that is not required by or typical of the baseline building. An example might be a laundry facility that uses water saving equipment. Other energy savings in the proposed building could come from the boiler efficiency and possibly the recirculation pumping system.

Internal Loads

A wide range of internal loads exist in healthcare facilities, ranging from television sets in patient rooms to radiology equipment in labs, all running during different hours of the day. Most internal loads are reduced to a minimum at night while a facility is fully staffed in the daytime. There will be a need to develop equipment operation schedules to reflect this operation. In addition, given the fact that some equipment will only run a few minutes out of the hour, such as an MRI machine, it is important not to overestimate the loads attributed to the equipment. In most cases, the baseline and proposed building models will include the same equipment loads and operating schedules, unless the modeler can clearly demonstrate a more efficient piece of equipment is being used compared to standard practice or code minimum.

7.1.3 Data Centers

Data centers are spaces specifically designed to accommodate dense arrangements of computer equipment. This currently includes telephone company "central offices" ("telcos") and computer labs. Any space where dedicated HVAC is installed to handle computing equipment load is likely to be considered a data center.

Data Center HVAC Systems

Data centers in the baseline building will typically be served by a separate system because they trigger the exception to the HVAC mapping

requirements having to do with abnormal internal heat gain and schedules of operation. When heat gain differences of more than 10 Btu/h or operation schedule differences of more than 40 hours/week trigger this exception, a separate system is required to serve the data center. Either system 3 (PSZ-AC) or system 4 (PSZ-HP) shall serve the data center (depending on the heating source for the building). See the PRM, G3.1.1, Exception b.

Loads

Loads in a data center could range from anywhere as low as 20 W/ ft² up to 400 W/ ft². Load densities above 400 W/ ft² would not typically be handled by an air based cooling system. As a rule of thumb: the initial actual energy use of a new data center is 50% of the design capacity of the cooling system serving the data center, so the equipment is initially oversized by a significant margin. In many cases, the data center load will increase each year, as additional equipment is added, reaching full load after a five year period. However, if there is more precise information on the expected load, this should be used. In most cases, the load for the baseline and proposed buildings should be the same, unless documentation of equipment that is more efficient than standard practice can be provided.

Redundancy

Given the uptime requirements of data center equipment, redundant equipment is a necessity. Purely redundant equipment is ignored in the modeling of the proposed building and the baseline building. This might simply be additional CRAC (computer room air conditioning) units, or might be more complicated to include additional chillers and supporting pumps.

Ventilation

In mixed-use facilities, ventilation for the data center is often provided by the “house air” system, i.e. the system that serves the office or other commercial space, with a separate system providing cooling. In dedicated data center systems, the ventilation air is typically provided by a dedicated outside air system and should be modeled accordingly. Outside air in the proposed and baseline system will be the same, but the baseline building system will typically be modeled with its own supply of outside air.

Humidity Control Systems

The ASHRAE document “Thermal Guidelines for Data Processing Environments” describes the “Recommended” relative humidity (RH) range for Class 1 and Class 2 computing environments as 40% to 55%, and the “Allowable” range for these same environments as 20% to 80%. These RH values apply to the air entering the computer equipment.

CRAC units with on-board humidity control systems typically have the temperature and humidity sensors factory-mounted in the return air opening of the CRAC. For open aisle data centers, the sensors are typically left in this position, and the humidity of the return air is controlled to the ASHRAE recommended range of 40% to 55%.

For ducted return and fully enclosed data center aisles, the practice is to relocate the CRAC temperature and humidity sensors to a cold aisle, or to install additional temperature and humidity sensors in the cold aisles and disable the original CRAC sensors. The aisle-mounted sensors will control the CRAC humidity system to provide the ASHRAE recommended range of 40% to 55% in the cold aisles.

The baseline building system shall be modeled with the same temperature and humidity conditions as the proposed design.

Uninterruptible Power Supply (UPS)

Data centers typically include some type of battery-based system to address power failures. Depending upon the size, configuration and amount of load, the efficiency of these systems will range from 86% to 93%. In determining the data center power usage, this must be accounted for in the building modeling. In addition, there will be additional cooling requirements for the UPS systems that will need to be modeled. Both the baseline and proposed buildings should be modeled with the same UPS configuration and power, unless supporting documentation of a more efficient technology or arrangement can be documented.

7.2 Design Features

7.2.1 Automatically Controlled Window Shades

Some advanced buildings include either interior or exterior shading systems that include automatic controls to optimize the shade position for energy savings. In some cases, this may be as simple as a time based control system that operates the shades based upon time of day. More sophisticated systems may include sensors designed to detect solar gains on the fenestration, and determine the optimum shade position.

Most simulation programs include a variety of commands to facilitate modeling the various scenarios that will be found in buildings. In the case of the simple time of day based control system, a straightforward hourly/daily/monthly schedule command can be utilized that will adjust the solar gain through the fenestration using a multiplier that is applied to the hourly solar gain.

For the more sophisticated case, a solar gain or glare threshold should be input that will result in the shades being closed. In some software, this

For the more sophisticated case, a solar gain or glare threshold should be input that will result in the shades being closed. In some software, this may include hourly pairs of values that describe the solar gain threshold and corresponding solar gain multiplier resulting from the shade.

7.2.2 Active Chilled Beams

An active chilled beam is a device that is located in or above the conditioned space to provide heating, cooling and ventilation. The system consists of a coil box that is recessed in or hung from the ceiling with chilled water flowing through the coil. Ventilation air is introduced by a remote air handler into the diffuser box through small air jets, which induces room air to flow through the coils. Because the active introduction of ventilation air magnifies the natural induction effect, active chilled beams are commonly referred to as induction diffusers.

Depending upon the modeling software, active chilled beams may be modeled directly in the software or by using the more commonly available induction unit selection. Since each zone in a building will typically have its own chilled beam system (multiple units) with thermostatic control, a decision will need to be made as to how to properly zone the building to account for the individual chilled beam units. In most cases, conventional zoning of the building will be sufficient, such that thermally similar zones would be combined together. In combining zones, however, the source of ventilation air will need to be taken into account. Thus, two thermally similar chilled beam zones that are supplied by different ventilation air handlers would need to be separated out for modeling purposes.

Once the thermal zoning has been determined, each zone will then be modeled with a chilled beam induction system; inputs would include the system cooling capacity and the induction ratio. In addition, the source of heat, whether electric or hot water, would need to be specified. Since one or more dedicated ventilation fan systems will provide the outside air to the chilled beams, this would be modeled in the same fashion as the dedicated outside air system described below, with each chilled beam system coupled to this dedicated outdoor air system.

7.2.3 Dedicated Outside Air Systems (DOAS)

Dedicated outdoor air systems are provided to pre-condition the outside air which is then supplied to the main HVAC systems in the building. In most cases, the purpose of a DOAS is to address the large loads associated with the introduction of outside air, whether due to low ambient conditions, high ambient conditions or high humidity of the outside air. Depending upon the configuration, the DOAS may include heating coils, cooling coils and possibly a heat recovery component, in addition to the supply and optional exhaust fans associated with the unit. The main HVAC system fed by the DOAS could be any number of HVAC system types but typically will be smaller zonal systems such as water source heat pumps, VRF systems or fan coil units. By shifting the outdoor air load over to the DOAS, these systems may be smaller.

The DOAS system is modeled as a conventional HVAC system if that is how it is configured, with inputs for heating and cooling coils as well as fans. The choice of system type will depend upon the type of system being modeled. The DOAS system could be a simple rooftop DX system, or possibly a chilled water air handler with hot water coils fed from a central plant. It is important that the system be specified with 100% outside air, unless a more sophisticated outside air control scheme has been utilized. Optional parameters that could be specified include an exhaust fan and/or a heat recovery component. Heat recovery would require the specification of the heat recovery effectiveness as well as any pumps or fans associated with the heat recovery component. Often DOAS AHUs include precool-reheat loops (wraparound heat pipes or sensible loops) or mixed dual heat recovery systems. If proposed buildings include these systems, software should be chosen that models these systems explicitly. DOAS equipment often delivers warmer air to zones with chilled beams, panels or other local cooling. Where minimum airflows are high, this can lead to significant savings in reheat.

Each HVAC system that receives outside air from the DOAS will be specified as a conventional HVAC system, except that the source of outdoor air will be coupled to the DOAS system associated with this unit. When specifying the ventilation rates for the zones served by the HVAC system, they will be specified as normal. By coupling the HVAC system to the DOAS system, the energy model will utilize that stream of air as the basis of the outdoor air.

If the DOAS only provides outdoor air tempering for other mechanical systems, the baseline building is not modeled with a corresponding DOAS system. However, in the case where the DOAS also provides general space conditioning to a space (such as conditioned air into a hallway, that is then pulled out by other HVAC systems) then that space will be modeled with the HVAC systems defined in Chapter 6.

7.2.4 Displacement ventilation

Displacement Ventilation (DV), a space conditioning technology in use in Europe since the 1970's, has the ability to reduce energy usage in buildings due to a number of energy saving strategies not found in conventional overhead mixing systems. The fundamental principle involved in a DV system is to supply significantly warmer supply air temperatures during cooling mode, typically 63°F to 68°F. With the use of higher supply air temperatures comes the ability to operate in economizer mode many more hours each year. When producing the higher supply air temperatures, chilled water systems have the ability to operate at much higher chilled water temperatures, thus resulting in a significant increase in the chiller efficiency when producing chilled water. In addition, for systems that will be requiring reheat, additional heating and cooling energy is saved since they will be reheating air that is cooled to only 65°F versus a conventional system that has cooled the air to 55°F.

By not mixing the air in the room, the DV system results in more of a stratification effect. Thus, much of the heat in the space will rise towards the ceiling, where it will be exhausted by the high return air register. A portion of the cooling load in the space, including occupant heat gain, lighting and equipment, never appears as a cooling load.

Some software tools have built-in system types that allow for the direct modeling of DV systems while others will require the user to make

approximations of some of the effects associated with DV, in particular, the stratification of room loads. In all cases, the supply air temperature of the system will need to be set to the higher design value of the system, and in most cases the control strategy for the cooling coil will be to reset the leaving temperature based upon the warmest zone requiring cooling.

For modeling the actual zone, the idea is to account for the stratification of air in the zone. One technique is to model the lower 6 feet of the zone as a conventionally conditioned zone and to model the upper portion of the zone as a return air plenum. Loads associated with the wall, roof, lighting and some of the equipment will then be modeled as being part of the return air plenum, rather than part of the space. This has the effect of modeling the stratified, non-mixed air in the zone, placing much of the heat gains into the return air. When the system is operating in economizer mode, these loads will simply be exhausted out of the building, rather than appearing as a cooling load in the space.

Assuming the system is VAV with reheat, each zone will be modeled with a conventional VAV terminal box to account for heating. Note that once modeling has been completed, it is important to verify that the higher supply air temperatures associated with the DV system will in fact meet the loads. Output reports from the software should be checked for unmet load hours. In addition, if working in a humid climate, it is unlikely that the higher temperatures will satisfy the latent loads. One solution is to design the system with a bypass on the cooling coil so that a certain portion of air will be cooled to 55 degrees and dehumidified, with the rest bypassing the coil, resulting in a mixed air temperature of 63°F to 68°F.

Depending upon the strategy used for the coil temperature, the chilled water temperature may also be modeled at a higher temperature. Assuming the bypass strategy is not used, the chilled water temperature should be set based upon the higher design, resulting in additional savings at the chiller.

The baseline building is not modeled with displacement ventilation.

7.2.5 Gas Engine Driven Heat Pumps

These systems typically are conventional DX packaged systems that utilize a natural gas or propane engine in place of an electric motor. During cooling operation, the gas engine will operate the cooling compressor to provide cooling to the DX coil. During heating operation, the same effect will be utilized. In both cases, the manufacturer may include the option for heat recovery from the gas engine for use in building hot water loads, such as domestic hot water or heating coils.

Given the unique nature of these systems, the energy modeling will need to utilize a system selection in the modeling software specific to gas engine driven heat pumps. In addition, user defined operating curves will need to be input to reflect the manufacturer specific operation during heating and cooling modes. Should the system utilize heat recovery, the heat recovery efficiency will need to be determined and assigned to the system. Two possible types of heat recovery include jacket based heat recovery, where heat is extracted from the engine jacket used to cool the engine, and exhaust based heat recovery, where heat is recovered from the engine exhaust. In some cases, heat recovery may come from both sources. The heat recovery energy will then need to be assigned to a hot water or other demand in the building. This might include supplying domestic hot water needs for the occupants or perhaps reheat coils used downstream in the HVAC system.

The baseline building is not modeled with gas engine driven heat pumps.

7.2.6 Ground Source Heat Pumps

Sometimes referred to as geothermal systems, ground source heat pumps (GSHP) couple the condenser water side of the heat pump to a ground source. Possible couplings include vertical wells, horizontal wells or a body of water such as a pond or lake. In closed loop systems, water or an antifreeze solution is circulated through a series of pipes, while in open loop systems, water is pumped through the system and discharged openly.

The temperature of the heat sink available to the GSHP is going to be highly site dependent, and should be based upon the anticipated temperatures that will result after the system has been operational for a reasonable period of time. In some cases, a large lake may have fairly stable temperatures that can be anticipated on a monthly basis based upon historical trends. In other cases, a smaller heat sink such as drilled wells may be subject to localized temperature increases in the areas surrounding the wells, and this will need to be factored in. In addition, sites that have underground aquifers will see different resulting ground temperatures than sites without. As a result, local conditions will need to be factored into the ground temperature assumptions which are key to GSHP modeling.

Modeling of the GSHP systems will begin with the basic zoning of the building. It is common to use fairly small (5 ton and under) systems, so each will typically require a separate zone in the model. In cases where zones have the same GSHP installed and are thermally similar, combining of zones is acceptable. Some large applications of this technology will utilize multiple zone air handlers, in which case conventional zoning procedures will apply. Input descriptions for the GSHP will include heating and cooling capacities, the heating COP and cooling EER, as well as the supply fan and possibly return fan information. On some larger systems, economizers may be included.

The coupling of the GSHP system will occur through the condenser water loop, so the next step is to define this loop. Included in this definition will be information such as the pumping flow rate of the system, type of pumping (variable speed, constant speed), pump motor size as well as whether the GSHP condenser coils include three-way or two-way valves to control flow.

In cold climates, a backup boiler may be included as part of the condenser water system to prevent low water temperatures in the loop. The basic boiler information will need to be specified, as well as a minimum loop temperature which will dictate when the boiler is activated.

The final step is to define the actual ground or pond heat sink. This may include defining a schedule of monthly temperatures to represent a large

body of water, although on smaller bodies of water changes in

temperature from the GSHP system will need to be accounted for. In the case of a vertical or horizontal well system, information including the type of well, well spacing and well depth will need to be included.

The baseline building will not have a GSHP.

7.2.7 Ice Storage Air Conditioners

Ice Storage Air Conditioner (ISAC) systems contain ice storage tanks distributed throughout the building, with each tank associated with the air-side component of a single HVAC system. In contrast, traditional thermal energy storage systems centralize the storage, which then serves the load of the entire building. The ISAC system will typically rely on cooling fed from the storage tank to an air handler containing either a chilled water or DX coil. The tank will be charged by a condenser during night-time hours, and discharge will occur during the daytime hours. In modeling the ISAC system, the modeler will typically utilize the Split DX system type available in most analysis software. This system type will most closely approximate the performance of the condensing unit that will be used to charge the ice storage tank. In addition, custom cooling curves will need to be input to account for the system performance during the charging mode, since much lower temperatures will need to be produced by the condensing unit.

Operating schedules for the charging and melting model will depend upon the controls configuration of the ISAC system. Some systems are designed and configured to run in a simple charge/melt mode, where the entire daytime load will be handled by the ISAC system, and then the system will be recharged at night. Others are designed to only address peak period loads, and thus will run only during the peak utility period, with the condenser operating in the mornings during the shoulder peak periods. Another variation is an ISAC system that is designed for peak load shaving, with the ice melt supplementing the condenser cooling. These different strategies will require the use of appropriate operating schedules to control the condenser operating strategy as well as the ice tank charge/melt occurrences.

The baseline building does not have ISAC.

7.2.8 Radiant Heating and/or Cooling

Radiant heating systems rely on the delivery of heat via a system located in the floor, or in some cases, ceiling or wall mounted panels. The delivery can be either via a hydronic system coupled to a boiler (or other source of hot water) or using electric radiant panels. In the case of radiant cooling systems, delivery is typically via a hydronic system that is supplied with chilled water from a chiller or other cooling source. One of the most important factors of a radiant cooling system design is the control of the chilled water temperature that is supplied to the system. If the chilled water temperature supplied results in the radiant delivery system surface temperature falling below the dewpoint in the space, condensation will occur on the surface. The result of this would be moisture on the floor or ceiling, depending upon the location of the delivery system. As such, the chilled water supplied to the radiant system will be maintained at a higher temperature than a conventional chilled water system. This higher chilled water temperature will need to be accounted for in the energy modeling as it will impact both the pumping energy use as well as the chiller energy use. "Radiant" heating or cooling systems that utilize concrete slabs may be very slow to react to load changes. Simulation programs should be chosen that account for this or these systems should only be modeled in spaces that will have very slow load changes.

Since these systems rely upon the radiant delivery of heating and cooling, no fans are associated with the radiant component of the system. However, it is common that a fan is associated with the ventilation system. Modeling of the fan associated with the ventilation will depend upon how the ventilation system is configured. One approach is to utilize a Dedicated Outside Air System (DOAS). The modeling procedures for this type of system are described elsewhere in this chapter. Another approach used with radiant systems is to use a displacement ventilation system, in which case modeling of this component will follow procedures dictated elsewhere in this chapter. In some cases, radiant systems utilize natural ventilation as the source of outside air. These procedures are also addressed in this chapter.

The baseline building does not have radiant heating or cooling.

7.2.9 Switchable glazing

Switchable glazing can change the light transmittance, transparency, or shading of windows in response to an environmental signal such as sunlight, temperature or an electrical control. Technologies such as electrochromic and liquid crystal windows change from transparent to darkened by applying an electrical current to the window. Once the change in tint has been initiated, the glazing does not need constant voltage to maintain the tinting, so electrical usage is negligible for energy modeling. In addition, the film can be tuned to block certain wavelengths of light, such as infrared energy.

In modeling switchable glazing that includes an automatic control such as a heat sensor, a control set-point, usually in Btu/h, will be used in the model. The basic window will be modeled with the U-Factor, SHGC and VT (visible transmittance) of the glazing with no tinting applied. The energy model will then include modifiers to each of these values when the control set-point has been reached. Thus, the energy model will reduce the energy gain through the windows in response to solar gains on the particular window.

Another approach is to apply the same modifiers on an hourly basis using a series of schedules. This approach might be used in a circumstance where the glazing is being controlled with a building energy management system and would be applied at a consistent time of day, or seasonally.

In this case, the hourly schedule would dictate the multiplier to be applied to the U-Factor, SHGC and/or visible transmittance.

This is but one way to model switchable glazing; other engines such as EnergyPlus have more advanced features and the use of alternative approaches is acceptable.

The baseline building does not have switchable glazing.

7.2.10 UFAD

Underfloor Air Distribution (UFAD) systems provide cooling supply air streams at significantly warmer temperatures than conventional systems, typically 60°F to 68°F. With the use of higher supply air temperatures comes the ability to operate in economizer mode many more hours each year. When producing the higher supply air temperatures, chilled water systems have the ability to operate at much higher chilled water temperatures, thus resulting in a significant increase in the chiller efficiency when producing chilled water. In addition, for systems that will be requiring reheat, additional heating and cooling energy is saved since they will be reheating air that is cooled to only 65°F versus a conventional system that has cooled the air to 55°F.

Since UFAD systems deliver air at lower velocities than conventional system, there is more potential for stratification since room air is mixed less. Thus, a certain portion of the heat in the space will rise towards the ceiling, where it will be exhausted by the return air register. The overall result is that (like with Displacement Ventilation) a portion of the cooling load in the space, including occupant heat gain, lighting and equipment, never appears as a cooling load. Given the fact that at any given point in time, at least some portion of the return air will be exhausted due to outside air requirements, this heat gain will also be exhausted.

Modeling of the UFAD system will follow the same general approach as the Displacement Ventilation systems described earlier. In some instances, fan powered terminal units are used in this application, so a fan powered box may need to be included in the zone inputs. The baseline building does not have an UFAD system.

7.2.11 Variable Refrigerant Flow

Commonly referred to as VRF systems, Variable Refrigerant Flow systems are produced by a number of manufacturers and consist of both heat pump and heat recovery units. Similar in nature to a Water Source Heat Pump system, the VRF system consists of an outdoor condenser unit tied to a group of indoor heating and cooling units using a piping loop. Unlike a water source heat pump system, however, the VRF system uses a refrigerant loop connection between the indoor and outdoor units. In the case of the heat recovery version of the VRF system, indoor units are able to exchange heating and cooling energy via the refrigerant loop.

Given the nature of partial loading on the outdoor unit from the various indoor units, using a simple full load EER to approximate unit performance will result in a gross underestimation of system performance. Accurate hourly loading of each indoor unit is necessary to derive the maximum accuracy. Each indoor unit must be modeled as a zone or thermostatic control element in the software. In situations where a single zone contains a number of indoor units, it is acceptable to group those units as a single zone, provided each area served by the indoor units is thermally similar. Once the thermal zones have been determined, each indoor unit will be modeled based upon actual heating and cooling capacity and fan characteristics. Some VRF systems include optional components that provide outdoor air heat recovery and/or economizer capability, so these features will need to be specified at the zone level inputs of the software.

Once all the indoor units have been defined, each indoor unit will need to be associated with a loop that connects it to an outdoor unit. As part of the specification of the loop, heat recovery may also be included if the unit has this capability. Each outdoor unit will be specified with inputs for capacity and full load efficiency. In addition, operating curves will be input to adjust the full load efficiency for part load conditions and varying outdoor conditions.

Additionally, some VRF systems include the ability to connect all of the outdoor condensing units to a water or glycol based condenser water loop that includes a cooling tower and possibly a boiler. If this is the case, additional parameters will need to be input to define this water loop including the description of the pumps, cooling tower and boiler. This description will be similar to the parameters that are described for a conventional water source heat pump condenser water loop.

A final variation on the water cooled condensers is the inclusion of a ground coupled system. In this case, the condenser water will be pumped through a series of wells that couple the condenser water to the ground temperature. This portion of the modeling should generally follow the procedures specified in the section on ground source heat pumps elsewhere in this chapter.

The baseline building does not have a VRF system.

Appendices

| | |
|---|--|
| Appendix A – Building Descriptors Table [1] | Tabular summary and classification of building descriptors |
| Appendix B – Modeling Data [2] | Modeling data and assumptions by building type and space use. For technical documentation on plug loads, click here [3]. |
| Appendix C – Schedules [4] | Default and prescribed schedules of operation. |
| Appendix D – Construction Materials [5] | Default construction materials library. |
| Appendix E – Software Tests [6] | Spreadsheets and specifications for software tests. |
| Appendix F – Energy Costs [7] | Documentation of the methodology used to develop the Chapter 5 energy costs. |
| Appendix G – XML Schema | The COMNET compliant XML schema specified in Chapter 4 and supported by the COMNET Portal. |
| Appendix H – Equipment Curves [8] | Spreadsheet that summarizes and graphs the default equipment performance curves referenced in the Modeling Guidelines and Procedures. |

© 2010-2014 New Buildings Institute

Source URL: <http://www.comnet.org/mgp/content/appendices>

Links:

- [1] http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix%20A%20-%20Building%20Descriptors%20Table%20%28Rev%204%29.xlsx
- [2] [http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix B - Modeling Data \(Rev 7\).xlsx](http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix B - Modeling Data (Rev 7).xlsx)
- [3] http://www.comnet.org/mgp/sites/default/files/mgp_appendices/130221 Plug Loads TSD.pdf
- [4] [http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix C - Schedules \(Rev 1\).xlsx](http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix C - Schedules (Rev 1).xlsx)
- [5] [http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix D - Construction Materials \(Rev 1\).pdf](http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix D - Construction Materials (Rev 1).pdf)
- [6] [http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix E - Portfolio \(Rev 1\).pdf](http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix E - Portfolio (Rev 1).pdf)
- [7] [http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix F - TOU Costs Methodology \(Rev 1\).pdf](http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix F - TOU Costs Methodology (Rev 1).pdf)
- [8] [http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix H - Equipment Curves \(Rev 1\).xlsx](http://www.comnet.org/mgp/sites/default/files/mgp_appendices/Appendix H - Equipment Curves (Rev 1).xlsx)