

|            |            |
|------------|------------|
| DIST.      | EP - 8 - 2 |
| CC - H - W | PT & T - 2 |
| C - V - CP |            |
| TOTAL      | 18         |
| UGD        | 6          |
| UGC        | 8          |
| OHD        |            |
| ET         |            |
| VUD        |            |
| D30S       |            |
| COORD 1    |            |
| CES 2      |            |
| T. DELL-I  |            |

DC 044  
32-3153

- NOTES:
- CONTACT M. CADIZ (x4852) PRIOR TO CONSTRUCTION
  - ALL PLASTIC CONDUIT IS TO BE PVC ENCASED BURIED, EB, UNLESS OTHERWISE NOTED.
  - SEE DRAWING FOR CABLE WORK.
  - COVER OVER ALL CONDUIT IS TO BE 30" BELOW GG
  - REFERENCES:

| ①          | ②      |
|------------|--------|
| R = 12.5'  | 65'    |
| L = 19.63' | 13.04' |
| T = 12.5'  | 6.4'   |
| Δ = 90°    | 11.25° |

BURBANK

(A.C. PVMT.)

AVE.

EXIST. M.H. 5547  
G-328; G-3

ACTIVE 4.8 KV RISER  
D-21-N  
ACTIVE 4.8 KV  
D-22-N

NEW PP  
(TO BE INSTALLED)

PT & T (24' W / Q)  
7-5" & 2-4" P DWPPS  
(16.5' (W / Q)  
12-5" & 4-4" P DWPPS  
(14' W / Q)

INTERCEPT 2-5" P  
2-4" P

FULTON  
(A.C. PVMT.)


ENGINEERS  
COPY

BLVD.

D.E.

H-10796  
H-10463

INTERCEPT 2-5" P TO PP  
TO D.E. INTERCEPT 2-4" P



N. WALL  
EXIST. M.H. 5547

RECEIVED  
JUN 10 1987

Valley Dist. Hq.

KBX13/REN28  
O.H. - HCZ73  
51- QDC68

PERMIT 4-8701-0607  
ISSUED 4-14-87

|                                                                                  |                                                       |
|----------------------------------------------------------------------------------|-------------------------------------------------------|
| CITY OF LOS ANGELES<br>DEPARTMENT OF WATER & POWER<br>UNDERGROUND DESIGN SECTION |                                                       |
| 4.8 KV CONDUIT<br>BURBANK BLVD. (W / FULTON AVE.)                                |                                                       |
| DESIGN M CADIZ                                                                   | DATE 3-20-87                                          |
| O.K. <i>John Malon</i>                                                           | APPROVED <i>Bm Boychuk/John</i><br>SR. ELEC. ENGINEER |
| A.J. No 25341<br>SEP 23 1987                                                     |                                                       |

FOREMAN'S PRINT

SCALE: 1" = 30'

THOMAS GUIDE: P23-1A  
SYSTEM MAP 360-20  
PRIMARY CIRCUIT 71-32 & 34

COMMERCIAL

| DATE    | INIT'L  | REVISION   | APP'V'D. |
|---------|---------|------------|----------|
| CONDUIT | 8-11-87 | COMP. DATE | BY       |
| CABLE   |         | COMP. DATE | BY       |