

Statutory Factory Safety Layout & Hazard Mitigation Scheme

1. Occupational Health & Factory Structural Safety Audit

Maximum Daily Workers:	220 Persons (180 Male, 40 Female across 3 shifts)
Total Connected Power:	650 kVA (HT Substation 11 kV / 415 V)
Ventilation & Airflow:	Mechanical Exhaust 12 Air Changes/Hr with natural ridge monitors
Working Space / Worker:	18.5 cubic meters per worker (Exceeds Sec 16 statutory 14.2 m3)

2. Machinery Guarding & Hazardous Area Zoning

- Interlocking safety guards & light curtains on all CNC power presses and automated stamping lines
- Flameproof Electrical Fixtures (Ex-d rated) installed in solvent storage and chemical mixing bays
- Emergency Stop Wire Pull Switched spanning entire conveyor belt perimeter with audible warning sirens
- Dual Pressure Relief Valves on steam boilers tested as per Indian Boiler Regulations (IBR 1950)

3. Chemical Spill Containment & Occupational Welfare Facilities

- Bundy Wall Capacity: 110% of largest liquid bulk chemical storage tank
- Emergency Eye Wash & Drench Showers situated within 10 meters of chemical handling workstations
- Occupational Health Centre (OHC) equipped with 2 stretchers, oxygen cylinder & full-time certified nurse
- Personal Protective Equipment (PPE) Matrix: Mandatory helmet, safety shoes, nitrile gloves & respirator

4. Statutory Safety Committee & Certified Inspection Seal

- Constituted Joint Safety Committee as per Section 41-G of The Factories Act 1948
- Approved by Qualified Safety Officer (Govt. of Maharashtra Post-Graduate Safety Diploma)

[VERIFIED STATUTORY BLUEPRINT TEMPLATE - MAHARASHTRA RIGHT TO SERVICES ACT]

Applicants may use this statutory layout template as a standardized reference when preparing department submissions.
All specifications comply with Maharashtra Industrial Development & Single-Window Clearance Regulations 2026.